

NPDES authorization to discharge to waters of the United States, Permit No. NM0029891

The applicant's mailing address is:

City of Raton
P.O. Box 99
Raton, NM 87740

The facility is located at 1350 North First Street, Raton, New Mexico. Under Standard Industrial Classification (SIC) Code 4941, the applicant currently operates a surface water treatment plant. This plant intakes and treats about 4 MGD of Lake Maloya surface water using coagulation, flocculation, sedimentation, filtration, and disinfection processes. It has a design flow of 0.08 MGD. The facility is designed for total reuse of wastewater and has not been discharged since 2001. However, this permit is maintained in case an event occurs when the facility cannot reclaim all the backwash water. If discharging, the effluent from the facility is discharged into an ephemeral Arroyo, thence to Raton Creek, thence to Chicorica Creek, thence to the Canadian River in Segment 20.6.4.305. Designated uses of the receiving water are stated in the Fact Sheet.

This is a renewal of a permit previously issued on July 19, 2021, with an effective date of August 1, 2021, and an expiration date of July 31, 2026.

A fact sheet is available.

State Certification

This Notice also serves as Public Notice of the intent of the New Mexico Environment Department, Surface Water Quality Bureau to consider issuing Clean Water Act (CWA) Section 401 Certification. The purpose of such certification is to reasonably ensure that the permitted activities will be conducted in a manner that will comply with applicable New Mexico water quality standards, including the anti-degradation policy, and the statewide water quality management plan. The NPDES permit will not be issued until the certification requirements of Section 401 have been met.

If you want to comment on State Certification submit written comments within the 30 day period to:

Susan A. Lucas Kamat
Program Manager, Point Source Regulation Section
New Mexico Environment Department
Surface Water Quality Bureau
1190 Saint Francis Drive
P.O. Box 5469
Santa Fe, NM 87502-5469
Phone: 505-946-8924
Susan.LucasKamat@state.nm.us