

**TEST REPORT FOR
2023 STATIONARY COMBUSTION TURBINES
EMISSIONS INFORMATION COLLECTION
REPORT ON CT-4 AND CT-5 AT
SUNSHINE GAS PRODUCERS, LLC**

Prepared For:

Sunshine Gas Producers, LLC
14747 San Fernando Road
Sylmar, California 91342

For Submittal To:

U.S Environmental Protection Agency
Office of Air Quality Planning and Standards
Melanie King
(919) 541-2469
King.Melaine@epa.gov

Prepared By:

Montrose Air Quality Services, LLC
1631 E. St. Andrew Pl.
Santa Ana, California 92705
(714) 279-6777

Pete San Juan

Test Dates: **February 7 – 17, 2023**
Production Date: **April 14, 2023**
Report Number: **W002AS-023392-RT-4542**




CONFIDENTIALITY STATEMENT

Except as otherwise required by law or regulation, this information contained in this communication is intended exclusively for the individual or entity to which it is addressed. This communication may contain information that is proprietary, privileged or confidential or otherwise legally exempt from disclosure. If you are not the named addressee, you are not authorized to read, print, retain, copy, or disseminate this message or any part of it.


REVIEW AND CERTIFICATION

I certify that, to the best of my knowledge, the information contained in this document is complete and accurate and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature:  Date: 4/14/2023

Name: Pete San Juan Title: Field Project Manager

I have reviewed, technically and editorially, details and other appropriate written materials contained herein. I hereby certify that to the best of my knowledge the presented material is authentic and accurate and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature:  Date: 4/14/2023

Name: Surya Adhikari Title: Senior Reporting QC Specialist

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION AND SUMMARY	6
1.1 RESULTS SUMMARY.....	6
1.2 PROGRAM CONTACTS	11
2.0 UNIT DESCRIPTION	12
2.2 OPERATION DURING TESTS.....	12
2.3 SAMPLE LOCATIONS	12
3.0 TEST METHODOLOGY	14
3.1 O ₂ , CO ₂ , and CO BY CONTINUOUS ANALYZERS.....	14
3.2 VELOCITY	16
3.3 MOISTURE.....	16
3.4 PARTICULATE MATTER (FILTERABLE) BY EPA METHOD 5	16
3.5 TRACE METALS BY EPA METHOD 29 (MULTI-METALS)	17
3.6 FORMALDEHYDE AND ACID GASES BY EPA METHOD 320	18
4.0 TEST RESULTS AND OVERVIEW	19
4.1 CT-4 TEST RESULTS.....	19
4.2 CT-5 TEST RESULTS.....	25
4.3 FIELD TEST DEVIATIONS AND EXCEPTIONS	31

LIST OF APPENDICES

A TEST DATA	32
A.1 Sample Location Data	33
A.2 Gaseous DAS Data	37
A.2.1 CT-4 Data	38
A.2.2 CT-5 Data	82
A.3 Particulate Field and Laboratory Data.....	122
A.3.1 CT-4 Field Data.....	123
A.3.2 CT-5 Field Data.....	131
A.3.3 CT4 and CT-5 Laboratory Data	139
A.4 Metals Field and Laboratory Data	174
A.4.1 CT-4 Field Data.....	175
A.4.2 CT-5 Field Data.....	190
A.4.3 CT-4 and CT-5 Laboratory Data	205
A.5 EPA Method 320 Data	392
A.6 Fuel Analysis Report	436
A.7 Quality Assurance Data	445
B PLANT DATA.....	494
B.1 CT-4 Data	495
B.2 CT-5 Data	560

TABLE OF CONTENTS (CONTINUED)

<u>SECTION</u>		<u>PAGE</u>
C	CALCULATIONS	629
C.1	General Emissions Calculations.....	630
C.2	Data Summaries.....	634
C.2.1	CT-4 Data	635
C.2.2	CT-5 Data	646
D	QUALITY ASSURANCE INFORMATION.....	657
D.1	Quality Assurance Program Summary.....	658
D.2	CARB and STAC Certifications	664
D.3	Individual QI Certificates.....	667
E	STATIONARY COMBUSTION TURBINES EMISSIONS INFORMATION COLLECTION DOCUMENT	673

LIST OF TABLES

1-1	CO EMISSIONS RESULTS SUMMARY	7
1-2	PARTICULATE MATTER RESULTS SUMMARY.....	7
1-3	TOTAL METALS RESULTS SUMMARY	8
1-4	FRONT HALF METALS RESULTS SUMMARY	9
1-5	BACK HALF METALS RESULTS SUMMARY	10
1-6	EPA 320 EMISSIONS RESULTS SUMMARY.....	11
2-1	OPERATING PARAMETERS CT-4	12
2-2	OPERATING PARAMETERS CT-5	12
2-3	SAMPLING LOCATION	13
3-1	TEST SUMMARY	14
4-1	CO RESULTS CT-4	19
4-2	PARTICULATE MATTER RESULTS CT-4	20
4-3	TOTAL TRACE METALS RESULTS SUMMARY CT-4.....	21
4-4	FRONT HALF TRACE METALS RESULTS SUMMARY CT-4.....	22
4-5	BACK HALF TRACE METALS RESULTS SUMMARY CT-4	23
4-6	ACID GASES AND FORMALDEHYDE RESULTS SUMMARY CT-4	24
4-7	CO RESULTS CT-5	25
4-8	PARTICULATE MATTER RESULTS CT-5.....	26
4-9	TOTAL TRACE METALS RESULTS SUMMARY CT-5.....	27
4-10	FRONT HALF TRACE METALS RESULTS SUMMARY CT-5.....	28
4-11	BACK HALF TRACE METALS RESULTS SUMMARY CT-5	29
4-12	ACID GASES AND FORMALDEHYDE RESULTS SUMMARY CT-5	30

LIST OF FIGURES

2-1	SIMPLIFIED PROCESS BLOCK DIAGRAM.....	13
-----	---------------------------------------	----

1.0 INTRODUCTION AND SUMMARY

Montrose Air Quality Services, LLC (MAQS) has been contracted by Sunshine Gas Producers, LLC (Sunshine) to conduct source testing at their facility in Sylmar, California. Testing was conducted according to the document submitted to Sunshine by the Environmental Protection Agency (EPA), titled "Stationary Combustion Turbines Emissions Information Collection." The testing was conducted from February 7 through February 17, 2023 at the exhaust stacks of Landfill gas -fired Stationary Combustion Turbine 4 (CT-4) and Combustion Turbine 5 (CT-5) to meet the following objectives:

- Provide emissions test data to the EPA under Clean Air Act Section 114 Information Collection Request (ICR) for Stationary Combustion Turbines. The following tests listed below were conducted during this test program:

Emissions Tests: Seven test runs were performed on each CT to measure the following emissions parameters:

- Carbon Monoxide (CO): ppmvd, ppmvd @ 15% O₂, and lb/hr
- Particulate: gr/dscf, gr/dscf @ 15% O₂, and lb/hr
- Acid Gases and Formaldehyde: ppmvd, ppmvd @ 15% O₂, and lb/hr
- Multiple Metals (listed below): mg/dscm, mg/dscm @ 15% O₂, and lb/hr

Additional compounds that were determined during this test program are:

- metals from the multi-metals train: antimony (Sb), arsenic (As), beryllium (Be), cadmium (Cd), chromium (Cr), cobalt (Co), lead (Pb), manganese (Mn), mercury (Hg), nickel (Ni), selenium (Se);

Exhaust gas flow rate, moisture content, O₂ and CO₂ were determined in conjunction with the isokinetic tests. Sampling was coordinated with plant personnel throughout the program. The testing was performed by Pete San Juan, Dominic Heredero, James Navarrete, and Allen Dusky of MAQS. James Navarrete was the on-site Qualified Individual for MAQS. Nick Diedrich of Sunshine Gas Producers, LLC coordinated testing.

This test report contains unit description, operating conditions, and sample locations in Section 2. Section 3 contains a test program overview including the test procedures and the test schedule. The Appendices contain additional information including original data, calculations, and quality assurance information.

1.1 RESULTS SUMMARY

Tables 1-1 through 1-6 summarize the results of the tests.

TABLE 1-1
CO EMISSIONS RESULTS SUMMARY
SUNSHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5

Parameter/Units	CT-4 Averages	CT-5 Averages
Diluent Emissions and Stack Flow Rate		
O ₂ , % Volume Dry	16.03	16.15
CO ₂ , % Volume Dry	4.44	4.22
Stack Flow Rate, dscfm	34,630	33,960
Pollutant Emissions		
Carbon Monoxide (CO)		
ppm Volume Dry	0.82	0.18
ppmc Volume Dry @ 15% O ₂	1.00	0.22
lb/hr	0.12	0.03

TABLE 1-2
PARTICULATE MATTER RESULTS SUMMARY
SUNSHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5

Parameter/Units	CT-4 Averages	CT-5 Averages
Diluent Emissions and Stack Flow Rate		
Moisture Fraction, %	5.1	5.3
O ₂ , % Volume Dry	16.03	16.15
CO ₂ , % Volume Dry	4.44	4.22
Stack Flow Rate, wacfm	85,252	84,194
Stack Flow Rate, dscfm	34,630	33,960
Total Particulate Matter (PM)		
Grain Loading, gr/dscf	0.00009	0.00007
Grain Loading @ 15% O ₂	0.00011	0.00009
lb/hr	0.026	0.020

Note: Results of individual test runs are presented in the tables in Section 4.0.

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 1-3
TOTAL METALS RESULTS SUMMARY
SUNSHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5

Parameter/Units	CT-4 Averages	CT-5 Averages
Diluent Emissions and Stack Flow Rate		
Flow Rate, dscfm	34,688	33,777
Sample Volume, dscf	177.29	175.38
O ₂ , % Volume Dry	16.03	16.15
CO ₂ , % Volume Dry	4.44	4.22
Moisture, % by Volume	5.03	4.90
Antimony		
mg/m ³	<	0.00007
mg/m ³ @ 15% O ₂	<	0.00008
lb/hr	<	8.49 x 10 ⁻⁶
Arsenic		
mg/m ³	<	0.00015
mg/m ³ @ 15% O ₂	<	0.00018
lb/hr	<	1.91 x 10 ⁻⁵
Beryllium		
mg/m ³	<	0.00002
mg/m ³ @ 15% O ₂	<	0.00002
lb/hr	<	2.54 x 10 ⁻⁶
Cadmium		
mg/m ³	<	0.00005
mg/m ³ @ 15% O ₂	<	0.00006
lb/hr	<	6.43 x 10 ⁻⁶
Chromium		
mg/m ³		0.00119
mg/m ³ @ 15% O ₂		0.00144
lb/hr		1.55 x 10 ⁻⁴
Cobalt		
mg/m ³	<	0.00006
mg/m ³ @ 15% O ₂	<	0.00007
lb/hr	<	7.54 x 10 ⁻⁶
Lead		
mg/m ³		0.00015
mg/m ³ @ 15% O ₂		0.00018
lb/hr		1.92 x 10 ⁻⁵
Manganese		
mg/m ³		0.00038
mg/m ³ @ 15% O ₂		0.00047
lb/hr		4.98 x 10 ⁻⁶
Mercury		
mg/m ³	<	0.00012
mg/m ³ @ 15% O ₂	<	0.00014
lb/hr	<	1.55 x 10 ⁻⁵
Nickel		
mg/m ³		0.00046
mg/m ³ @ 15% O ₂		0.00056
lb/hr		6.02 x 10 ⁻⁵
Selenium		
mg/m ³	<	0.00055
mg/m ³ @ 15% O ₂	<	0.00066
lb/hr	<	7.08 x 10 ⁻⁵

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

TABLE 1-4
FRONT HALF METALS RESULTS SUMMARY
SUNSHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5

Parameter/Units	CT-4 Averages		CT-5 Averages	
Diluent Emissions and Stack Flow Rate				
Flow Rate, dscfm		34,688		33,777
Sample Volume, dscf		177.29		175.38
O ₂ , % Volume Dry		16.03		16.15
CO ₂ , % Volume Dry		4.44		4.22
Moisture, % by Volume		5.03		4.90
Antimony F_{1/2}				
mg/m ³	<	0.00005	ND<	0.00005
mg/m ³ @ 15% O ₂	<	0.00006	ND<	0.00006
lb/hr	<	6.81 x 10 ⁻⁶	ND<	6.36 x 10 ⁻⁶
Arsenic F_{1/2}				
mg/m ³	ND<	0.00013	ND<	0.00014
mg/m ³ @ 15% O ₂	ND<	0.00016	ND<	0.00017
lb/hr	ND<	1.74 x 10 ⁻⁵	ND<	1.71 x 10 ⁻⁵
Beryllium F_{1/2}				
mg/m ³	<	0.00002	<	0.00001
mg/m ³ @ 15% O ₂	<	0.00002	<	0.00001
lb/hr	<	2.01 x 10 ⁻⁶	<	1.41 x 10 ⁻⁶
Cadmium F_{1/2}				
mg/m ³	<	0.00002	<	0.00001
mg/m ³ @ 15% O ₂	<	0.00002	<	0.00001
lb/hr	<	2.45 x 10 ⁻⁶	<	1.32 x 10 ⁻⁶
Chromium F_{1/2}				
mg/m ³		0.00108		0.00093
mg/m ³ @ 15% O ₂		0.00131		0.00115
lb/hr		1.41 x 10 ⁻⁴		1.18 x 10 ⁻⁴
Cobalt F_{1/2}				
mg/m ³	<	0.00005	ND<	0.00001
mg/m ³ @ 15% O ₂	<	0.00006	ND<	0.00001
lb/hr	<	6.34 x 10 ⁻⁶	ND<	1.43 x 10 ⁻⁶
Lead F_{1/2}				
mg/m ³		0.00008		0.00006
mg/m ³ @ 15% O ₂		0.00010		0.00008
lb/hr		1.09 x 10 ⁻⁵		8.12 x 10 ⁻⁶
Manganese F_{1/2}				
mg/m ³		0.00021		0.00026
mg/m ³ @ 15% O ₂		0.00025		0.00032
lb/hr		2.71 x 10 ⁻⁵		3.23 x 10 ⁻⁵
Mercury F_{1/2}				
mg/m ³	ND<	0.000005	ND<	0.00001
mg/m ³ @ 15% O ₂	ND<	0.000006	ND<	0.00001
lb/hr	ND<	6.47 x 10 ⁻⁷	ND<	6.36 x 10 ⁻⁷
Nickel F_{1/2}				
mg/m ³		0.00033		0.00030
mg/m ³ @ 15% O ₂		0.00040		0.00037
lb/hr		4.26 x 10 ⁻⁵		3.80 x 10 ⁻⁵
Selenium F_{1/2}				
mg/m ³	ND<	0.00006	ND<	0.00006
mg/m ³ @ 15% O ₂	ND<	0.00007	ND<	0.00008
lb/hr	ND<	7.86 x 10 ⁻⁶	ND<	7.74 x 10 ⁻⁶

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 1-5
BACK HALF METALS RESULTS SUMMARY
SUNSHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5

Parameter/Units	CT-4 Averages	CT-5 Averages
Diluent Emissions and Stack Flow Rate		
Flow Rate, dscfm	34,688	33,777
Sample Volume, dscf	177.29	175.38
O ₂ , % Volume Dry	16.03	16.15
CO ₂ , % Volume Dry	4.44	4.22
Moisture, % by Volume	5.03	4.90
Antimony B½		
mg/m ³	<	0.00001
mg/m ³ @ 15% O ₂	<	0.00002
lb/hr	<	1.68 x 10 ⁻⁶
Arsenic B½		
mg/m ³	<	0.00001
mg/m ³ @ 15% O ₂	<	0.00002
lb/hr	<	1.71 x 10 ⁻⁶
Beryllium B½		
mg/m ³	<	0.000004
mg/m ³ @ 15% O ₂	<	0.000005
lb/hr	<	5.29 x 10 ⁻⁷
Cadmium B½		
mg/m ³	<	0.00003
mg/m ³ @ 15% O ₂	<	0.00004
lb/hr	<	3.98 x 10 ⁻⁶
Chromium B½		
mg/m ³		0.00011
mg/m ³ @ 15% O ₂		0.00013
lb/hr		1.42 x 10 ⁻⁵
Cobalt B½		
mg/m ³		0.00001
mg/m ³ @ 15% O ₂		0.00001
lb/hr		1.19 x 10 ⁻⁶
Lead B½		
mg/m ³		0.00006
mg/m ³ @ 15% O ₂		0.00008
lb/hr		8.38 x 10 ⁻⁶
Manganese B½		
mg/m ³		0.00018
mg/m ³ @ 15% O ₂		0.00021
lb/hr		2.27 x 10 ⁻⁵
Mercury B½		
mg/m ³	<	0.00011
mg/m ³ @ 15% O ₂	<	0.00014
lb/hr	<	1.49 x 10 ⁻⁵
Nickel B½		
mg/m ³		0.00014
mg/m ³ @ 15% O ₂		0.00016
lb/hr		1.77 x 10 ⁻⁵
Selenium B½		
mg/m ³		0.00049
mg/m ³ @ 15% O ₂		0.00059
lb/hr		6.29 x 10 ⁻⁵

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

TABLE 1-6
EPA 320 EMISSIONS RESULTS SUMMARY
SUNHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5

Parameter/Units	CT-4 Averages	CT-5 Averages
Diluent Emissions and Stack Flow Rate		
O ₂ , % Volume Dry	16.0	16.1
CO ₂ , % Volume Dry	4.5	4.3
Stack Flow Rate, dscfm	34,630	33,962
Pollutant Emissions		
Hydrochloric Acid (HCl)		
ppm Volume Dry	0.52	0.34
ppmc Volume Dry @ 15% O ₂	0.63	0.41
lb/hr	0.10	0.06
Hydrogen Fluoride (HF)		
ppm Volume Dry	1.79	1.40
ppmc Volume Dry @ 15% O ₂	2.16	1.72
lb/hr	0.19	0.15
Formaldehyde (CH₂O)⁽¹⁾		
ppm Volume Dry	0.027	0.070
ppmc Volume Dry @ 15% O ₂	0.033	0.086
lb/hr	0.004	0.011

(1) As measured values are reported from FTIR. These values are below the instrument detection limit (BDL).

1.2 PROGRAM CONTACTS

The following list contains information on personnel to be contacted regarding any aspect of the test program. Pete San Juan was the on-site Project Manager and James Navarrete was the on-site Qualified Individual for MAQS.

Nick Diedrich
Sunshine Gas Producers, LLC
14747 San Fernando Road
Sylmar, California 91342
Phone: (559) 665-0807 x107
Fax: (559) 665-0817

Pete San Juan
Montrose Air Quality Services, LLC
1631 E. St. Andrew Pl.
Santa Ana, California 92705
Phone: (714) 279-6777
Email: PSanjuan@montrose-env.com

2.0 UNIT DESCRIPTION

Sunshine Gas Producers owns and operates five (5) stationary combustion turbines located at 14747 San Fernando Rd, Sylmar, California facility. The five (5) turbines are identical Solar, Mercury 50, landfill gas fired, rated at 61 MMBtu/hr, driving a nominal 4.9 megawatt (MW) electrical generator. The units are equipped with flow rate recording devices and a continuous emission monitoring system (CEMS) for NO_x and O₂ concentrations.

2.2 OPERATION DURING TESTS

The turbines operated at the highest normal load conditions achievable during the source tests. The operating parameters for each turbine during the tests are shown below in Tables 2-1 and 2-2:

**TABLE 2-1
OPERATING PARAMETERS CT-4
SUNSHINE GAS PRODUCERS**

Parameter/Units	2/7/2023	2/8/2023	2/9/2023	2/10/2023
Gas Flow, scfh	101929.4	101866.7	101031.4	100468.1
Heat Input, MMBtu/hr	46.99	46.94	46.80	46.93
Electrical Production, MW	4.2	4.1	4.1	4.1
Exhaust Temperature, °F	1200.0	1200.0	1200.0	1200.0

**TABLE 2-2
OPERATING PARAMETERS CT-5
SUNSHINE GAS PRODUCERS**

Parameter/Units	2/14/2023	2/15/2023	2/16/2023	2/17/2023
Gas Flow, scfh	94486.8	98249.4	96888.0	96781.7
Heat Input, MMBtu/hr	44.15	44.90	45.15	45.25
Electrical Production, MW	3.7	3.8	3.8	3.8
Exhaust Temperature, °F	1200.0	1199.7	1200.0	1200.0

2.3 SAMPLE LOCATIONS


Reference method measurements were performed from sample ports located on the exhaust stacks. The sample locations meet the dimensional requirements of EPA Method 1. A diagram of the sample location is presented as Figure 2-1. Isokinetic testing was performed using a matrix of 24 points located according to EPA Method 1 procedures.

Table 2-3 presents stack measurements and traverse points for the sampling location listed.

TABLE 2-3
SAMPLING LOCATION
SUNHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5

Sampling Location	Duct Inside Diameter (in.)	Distance from Nearest Disturbance Downstream EPA "B" (ft./dia.)	Distance from Nearest Disturbance Upstream EPA "A" (ft./dia.)	Number of Traverse Points
CT-4	55	14.8/3.22	2.9/0.6	Isokinetic: 24 (2/port) Gaseous: 24 (2/port)
CT-5	55	14.8/3.22	2.9/0.6	Isokinetic: 24 (2/port) Gaseous: 24 (2/port)

FIGURE 2-1
SIMPLIFIED PROCESS BLOCK DIAGRAM
SUNHINE GAS PRODUCERS
COMBUSTION TURBINES 4 & 5



3.0 TEST METHODOLOGY

Table 3-1 summarizes the test methods and techniques used for the tests. The following sections describe each method in further detail.

**TABLE 3-1
TEST SUMMARY**

Parameter	Measurement Principle	Reference Method	Replicates-Duration	Comments
Flue Gas Velocity, Stack Flow Rate	S-type Pitot traverse	EPA 1 and 2	--	With all tests
H ₂ O	Condensation Gravimetric	EPA 4	--	With all tests
O ₂	Continuous Analyzer (Electrochemical Cell)	EPA 3A	--	With all tests
CO ₂	Continuous Analyzer (Non-dispersive infrared)	EPA 3A	--	With all tests
CO	Continuous Analyzer (Non-dispersive infrared)	EPA 10	7 – 240 minutes	N/A
Trace Metals	ICP-MS/OES and CVAAS	EPA 29	7 – 240 minutes	N/A
Particulate Matter (PM)	Gravimetric	EPA 5	7 – 240 minutes	N/A
Formaldehyde (CH ₂ O)	FTIR	EPA 320	7 – 60 minutes	N/A
Hydrochloric Acid (HCl)	FTIR	EPA 320	7 – 60 minutes	N/A
Hydrogen Fluoride (HF)	FTIR	EPA 320	7 – 60 minutes	N/A

3.1 O₂, CO₂, and CO BY CONTINUOUS ANALYZERS

O₂, CO₂, and CO concentrations were measured using EPA Methods 3A and 10. These measurements were made on-site with MAQS' mobile emission measurement laboratory. The system used for this project consisted of a probe, heated Teflon line, moisture removal system, unheated Teflon line, sample pump, sample filter, and individual component analyzers.

O₂ was measured using an approved electro-chemical cell analyzer. The cell contains an electrolytic fluid that reacts with oxygen to generate an electrical signal proportional to the concentration. The analyzer was operated on a 0-20% range.

CO₂ was measured using an approved non-dispersive infrared analyzer. The analyzer employs gas filter correlation to minimize or eliminate the interferences of other species such as H₂O or CO₂. The analyzer was operated on a 0-10 ppm range.

CO was measured using an approved non-dispersive infrared analyzer. The analyzer employs gas filter correlation to minimize or eliminate the interferences of other species such as H₂O or CO₂. The analyzer was operated on a 0-10 ppm range.

The analyzers and sampling system were subjected to calibration and quality assurance procedures including leak checks and calibration error determinations before sampling, and system bias and drift determinations as part of each test run as detailed below. Data were corrected for any observed bias or drift.

An Analyzer Calibration was performed as necessary by adjusting the zero and span settings of the analyzer. Calibration Error was then determined at three levels for each range of each analyzer. This check was performed at the beginning of each test day. The calibration error must not exceed $\pm 2\%$ of the calibration span of the analyzer as determined by the following equation:

$$\text{Calibration Error} = \frac{\text{Analyzer Response} - \text{Cal. Gas Value}}{\text{Calibration Span}} * 100\%$$

The Sample System Bias test was performed before and after each test run and must not exceed $\pm 5\%$ of the calibration span for both the zero and upscale span gas. The system bias is calculated using the following equation:

$$\text{Sample System Bias} = \frac{\text{Response to System Bias} - \text{Response to Analyzer Cal}}{\text{Calibration Span}} * 100\%$$

Where:

Response to Analyzer Cal = the analyzer response to the last time the same calibration gas was introduced directly to the analyzer (this may be the pre-test calibration error value or a more recent analyzer calibration adjustment)

Zero and Calibration Drift were calculated for each test run based on the analyzer response during the pre- and post-test sample system bias test. Zero and upscale drift must not exceed $\pm 3\%$ of the calibration span.

$$\text{Analyzer Drift} = \frac{\text{Post-Test System Bias Response} - \text{Pre-Test System Bias Response}}{\text{Calibration Span}} * 100\%$$

The pre- and post-test analyzer responses during the sample system bias test were used to correct the raw test average for any sample system bias and analyzer drift. The drift/bias corrected data are the actual reported concentrations and are used for subsequent calculations (mass emission rates, lb/MMBtu, corrections to 3% or 15% O₂, etc.). The drift/bias corrections are performed using the following equation:

$$C_c = \frac{\bar{C} - C_o}{C_m - C_o} * C_{ma}$$

Where:

C_c = Drift/bias corrected concentration

\bar{C} = Raw Test Average

C_m = Average of pre- and post-test response to sample system bias span

C_o = Average of pre- and post-test to sample system bias zero

C_{ma} = Span gas value

3.2 VELOCITY

The stack gas velocity was measured using EPA Method 2 which utilizes an S-type pitot tube and type-K thermocouple.

3.3 MOISTURE

Stack gas moisture content was measured in conjunction with all isokinetic tests.

3.4 PARTICULATE MATTER (FILTERABLE) BY EPA METHOD 5

Replicates of 7, 240-minute samples using EPA Method 5 were conducted to measure emissions of Particulate Matter (PM):

The sampling train included:

- Nozzle (part a);
- Heated glass-lined probe (part b);
- Filter heated to $248 \pm 25^{\circ}\text{F}$ (part c);
- Flexible Teflon connecting tube or “sample line” (part d);
- An impinger train consisting of 2 impingers containing 100ml of deionized water, an empty impinger, and an impinger containing silica gel (part e).

Sampling was conducted as described in EPA Method 5. After sampling, the apparatus was leak-checked as described in that Method, then the sampling train was disassembled for sample recovery.

Recovery and Analysis of “Front Half” or filterable PM: Sample was recovered from the nozzle, probe liner and filter holder as described in EPA Method 5 with acetone washes and brushing into an amber glass bottle. The filter was returned to its pre-numbered Petri dish. The filterable PM emissions was determined from gravimetric analysis of the samples as described in EPA Method 5.

3.5 TRACE METALS BY EPA METHOD 29 (MULTI-METALS)

Replicates of 7, 240-minute samples were collected for metals using the procedure in EPA Method 29. These samples were analyzed for antimony, arsenic, beryllium, cadmium, chromium, cobalt, lead, manganese, mercury, nickel, and selenium.

This procedure isokinetically withdraws flue gas through the sample train described below:

1. The probe and nozzle are glass to prevent metal contamination of the sample.
2. The filter is Quartz fiber to minimize interferences.
3. The first impinger is empty, the second and third impingers contain 5% nitric acid and 10% hydrogen peroxide to collect any volatile metals which pass through the filter.
4. The fourth impinger is empty to prevent carry over of the $\text{HNO}_3/\text{H}_2\text{O}_2$ solution into the permanganate solution.
5. The fifth and sixth impingers contain acidified potassium permanganate solution to collect any mercury that is not collected in the $\text{HNO}_3/\text{H}_2\text{O}_2$ impingers.
6. The last impinger contains silica gel.

Sampling reagents and media are all trace metals quality with lot analyses of specific heavy metals available. The sampling train is pre-cleaned with DI water and nitric acid before testing and sealed with parafilm.

A field blank and reagent blank was collected and analyzed for this sampling program.

Sample recovery consists of recovering the following sample fractions:

- Probe, nozzle and front filter holder rinse – 100 ml of 0.1N HNO_3 and brushing.
- Filter - returned to pre-numbered petri dish and sealed.
- First three impingers, back half of filter holder and sample line - 100 ml of 0.1N HNO_3 acid rinse.
- Empty impinger 100 ml of 0.1N HNO_3 rinse.
- Permanganate impingers - 4% $\text{KMnO}_4/10\%$ H_2SO_4 rinse followed by DI water rinse.
- 8N hydrochloric acid rinse of permanganate impingers to remove residual manganese dioxide adhering to the impinger walls.

All sample fractions are stored in acid washed sample bottles.

Analysis for these metals except mercury was performed by ICP-MS and ICP-OES. Mercury was analyzed by cold vapor atomic absorption spectroscopy (CVAAS). Sample analyses were performed by Enthalpy Analytical, LLC in Durham, North Carolina. In the laboratory, decomposition of each sample fraction was performed per the method, and front half and back half fractions were analyzed and reported separately as requested by the EPA guidance document for this testing program. Five mercury analyses were performed per sample train: the combined filter/probe wash, nitric acid impinger catch, the empty impinger rinse, the potassium permanganate impinger catch, and the hydrochloric acid rinse of the permanganate impingers.

The reagent blank, the field blank and a laboratory preparation blank were analyzed for all trace metals. Spike recoveries and duplicate analyses are reported with the sample results in the laboratory report. No blank corrections were applied to the reported results since majority of the blank values were non-detect.

3.6 FORMALDEHYDE AND ACID GASES BY EPA METHOD 320

Replicates of 7 - 60 minute samples were collected for formaldehyde, hydrochloric acid (HCl), and hydrogen fluoride (HF) by EPA Method 320.

EPA Method 320 is an instrumental test method used to measure specific analyte concentrations for which EPA reference spectra have been developed or prepared. Extractive emission measurements are performed using FTIR spectroscopy. The FTIR analyzer is composed of a spectrometer and detector, a high optical throughput sampling cell, analysis software, and a quantitative spectral library. The analyzer collects high resolution spectra in the mid infrared spectral region (600 to 4,500 cm⁻¹), which are analyzed using the quantitative spectral library. This provides an accurate, highly sensitive measurement of gases and vapors.

Pertinent information regarding the performance of the method is presented below:

- Method Options:
 - The specific analyte concentrations include H₂O, formaldehyde, HCl and HF
 - Continuous static sampling is performed at a flow rate of approximately 10 liters per minute
 - A dynamic matrix spike is performed using formaldehyde, HCl and HF. Each spiking cylinder contained SF₆ as a tracer gas
- Method Exceptions:
 - The minimum detectable concentration values are determined using the MDC2 calculation specified in ASTM Method D6348-12
- Target and/or Minimum Required Sample Duration: 60 minutes

4.0 TEST RESULTS AND OVERVIEW

4.1 CT-4 TEST RESULTS

The results of the CT-4 tests are presented in Tables 4-1 through 4-6.

**TABLE 4-1
CO RESULTS CT-4
SUNSHINE GAS PRODUCERS**

Parameter/Units	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Average
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	--
Start Time	10:53	08:11	13:06	08:06	12:41	07:51	12:16	--
Stop Time	15:03	12:18	17:12	12:21	16:55	12:00	16:25	--
Pre-Test Information								
Reference Temperature, °F	68	68	68	68	68	68	68	--
Diluent Emissions and Stack Flow Rate								
O ₂ , % Volume Dry	16.02	16.01	16.07	16.04	15.98	16.01	16.05	16.03
CO ₂ , % Volume Dry	4.40	4.52	4.47	4.37	4.30	4.49	4.54	4.44
Stack Flow Rate, dscfm	34,673	34,670	34,381	34,767	34,864	34,564	34,491	34,630
Pollutant Emissions								
Carbon Monoxide (CO)								
ppm Volume Dry	1.22	1.27	0.96	0.63	1.04	0.43	0.22	0.82
ppmc Volume Dry @ 15% O ₂	1.48	1.53	1.18	0.77	1.25	0.52	0.26	1.00
lb/hr	0.18	0.19	0.14	0.10	0.16	0.06	0.03	0.12

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-2
PARTICULATE MATTER RESULTS CT-4
SUNSHINE GAS PRODUCERS

Parameter/Units	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Average
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	--
Start Time	10:50	08:10	13:05	08:05	12:40	07:50	12:15	--
Stop Time	15:00	12:20	17:15	12:15	16:50	12:00	16:25	--
Test Information								
Reference Temperature, °F	68	68	68	68	68	68	68	--
Diluent Emissions and Stack Flow Rate								
Moisture Fraction, %	5.3	5.2	5.2	4.7	4.8	5.0	5.2	5.1
O ₂ , % Volume Dry	16.02	16.01	16.07	16.04	15.98	16.01	16.05	16.03
CO ₂ , % Volume Dry	4.40	4.52	4.47	4.37	4.30	4.49	4.54	4.44
Stack Flow Rate, wacfm	85,268	85,063	84,263	85,048	85,359	85,851	85,914	85,252
Stack Flow Rate, dscfm	34,673	34,670	34,381	34,767	34,864	34,564	34,491	34,630
Particulate Emissions								
Grain Loading, gr/dscf	0.00006	0.00013	0.00010	0.00006	0.00011	0.00004	0.00012	0.00009
Grain Loading @ 15% O ₂ lb/hr	0.00007	0.00015	0.00013	0.00007	0.00013	0.00005	0.00015	0.00011
	0.018	0.037	0.031	0.017	0.033	0.013	0.036	0.026

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-3
TOTAL TRACE METALS RESULTS SUMMARY CT-4
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 29	2-EPA 29	3-EPA 29	4-EPA 29	5-EPA 29	6-EPA 29	7-EPA 29	Averages
Diluent Emissions and Stack Flow Rate								
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	--
Start Time	10:50	08:10	13:05	08:05	12:40	07:50	12:15	--
Stop Time	15:00	12:20	17:15	12:15	16:50	12:00	16:25	--
Flow Rate, dscfm	34,801	34,847	34,702	34,614	34,850	34,552	34,453	34,688
Sample Volume, dscf	178.48	179.87	178.95	181.31	177.55	173.28	171.62	177.29
O ₂ , % Volume Dry	16.02	16.01	16.07	16.04	15.98	16.01	16.05	16.03
CO ₂ , % Volume Dry	4.40	4.52	4.47	4.37	4.30	4.49	4.54	4.44
Moisture, % by Volume	5.03	5.07	5.13	5.04	4.90	4.94	5.09	5.03
Antimony								
mg/m ³	0.00009	0.00006	<	0.00006	ND<	0.00006	ND<	0.00006
mg/m ³ @ 15% O ₂	0.00011	0.00008	<	0.00008	ND<	0.00007	ND<	0.00008
lb/hr	1.14 x 10 ⁻⁵	8.22 x 10 ⁻⁶	<	8.14 x 10 ⁻⁶	ND<	7.73 x 10 ⁻⁶	ND<	7.98 x 10 ⁻⁶
Arsenic								
mg/m ³	<	0.00014	<	0.00016	<	0.00015	ND<	0.00015
mg/m ³ @ 15% O ₂	<	0.00017	<	0.00019	<	0.00018	ND<	0.00018
lb/hr	<	1.88 x 10 ⁻⁵	<	2.03 x 10 ⁻⁶	<	1.90 x 10 ⁻⁵	ND<	1.92 x 10 ⁻⁵
Beryllium								
mg/m ³	0.00003	0.00004	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/m ³ @ 15% O ₂	0.00004	0.00004	ND<	0.00002	ND<	0.00002	ND<	0.00002
lb/hr	3.81 x 10 ⁻⁶	4.72 x 10 ⁻⁶	ND<	1.80 x 10 ⁻⁶	ND<	1.83 x 10 ⁻⁶	ND<	1.97 x 10 ⁻⁶
Cadmium								
mg/m ³	0.00017	0.00006	<	0.00003	<	0.00004	<	0.00002
mg/m ³ @ 15% O ₂	0.00021	0.00008	<	0.00004	<	0.00004	<	0.00002
lb/hr	2.24 x 10 ⁻⁵	8.27 x 10 ⁻⁶	<	3.78 x 10 ⁻⁶	<	4.67 x 10 ⁻⁶	<	2.08 x 10 ⁻⁶
Chromium								
mg/m ³	0.00103	0.00136	0.00099	0.00130	0.00136	0.00097	0.00135	0.00119
mg/m ³ @ 15% O ₂	0.00124	0.00164	0.00121	0.00158	0.00163	0.00117	0.00164	0.00144
lb/hr	1.34 x 10 ⁻⁴	1.77 x 10 ⁻⁴	1.29 x 10 ⁻⁴	1.69 x 10 ⁻⁴	1.77 x 10 ⁻⁴	1.25 x 10 ⁻⁴	1.74 x 10 ⁻⁴	1.55 x 10 ⁻⁴
Cobalt								
mg/m ³	0.00004	0.00005	0.00023	0.00002	<	0.00002	<	0.00002
mg/m ³ @ 15% O ₂	0.00005	0.00006	0.00028	0.00003	<	0.00002	<	0.00002
lb/hr	5.82 x 10 ⁻⁶	7.01 x 10 ⁻⁶	2.98 x 10 ⁻⁵	3.06 x 10 ⁻⁵	<	2.42 x 10 ⁻⁶	<	2.19 x 10 ⁻⁶
Lead								
mg/m ³	0.00027	0.00020	0.00011	0.00014	0.00012	0.00010	0.00010	0.00015
mg/m ³ @ 15% O ₂	0.00033	0.00024	0.00013	0.00016	0.00015	0.00012	0.00012	0.00018
lb/hr	3.53 x 10 ⁻⁵	2.62 x 10 ⁻⁵	1.41 x 10 ⁻⁵	1.75 x 10 ⁻⁵	1.59 x 10 ⁻⁵	1.33 x 10 ⁻⁵	1.24 x 10 ⁻⁵	1.92 x 10 ⁻⁵
Manganese								
mg/m ³	0.00044	0.00036	0.00023	0.00026	0.00027	0.00050	0.00062	0.00038
mg/m ³ @ 15% O ₂	0.00054	0.00044	0.00028	0.00032	0.00033	0.00061	0.00075	0.00047
lb/hr	5.77 x 10 ⁻⁵	4.73 x 10 ⁻⁵	2.97 x 10 ⁻⁵	3.40 x 10 ⁻⁵	3.58 x 10 ⁻⁵	6.51 x 10 ⁻⁵	7.93 x 10 ⁻⁵	4.98 x 10 ⁻⁵
Mercury								
mg/m ³	<	0.00015	<	0.00011	<	0.00010	<	0.00009
mg/m ³ @ 15% O ₂	<	0.00018	<	0.00013	<	0.00013	<	0.00012
lb/hr	<	1.95 x 10 ⁻⁵	<	1.44 x 10 ⁻⁵	<	2.57 x 10 ⁻⁵	<	1.33 x 10 ⁻⁵
Nickel								
mg/m ³	0.00071	0.00048	0.00042	0.00053	0.00041	0.00033	0.00037	0.00046
mg/m ³ @ 15% O ₂	0.00086	0.00058	0.00052	0.00064	0.00049	0.00040	0.00045	0.00056
lb/hr	9.28 x 10 ⁻⁵	6.25 x 10 ⁻⁵	5.48 x 10 ⁻⁵	6.80 x 10 ⁻⁵	5.29 x 10 ⁻⁵	4.26 x 10 ⁻⁵	4.80 x 10 ⁻⁵	6.02 x 10 ⁻⁵
Selenium								
mg/m ³	<	0.00028	<	0.00012	<	0.00029	<	0.00018
mg/m ³ @ 15% O ₂	<	0.00034	<	0.00015	<	0.00035	<	0.00022
lb/hr	<	3.70 x 10 ⁻⁵	<	1.60 x 10 ⁻⁵	<	3.75 x 10 ⁻⁵	<	2.18 x 10 ⁻⁴
ND< - species not detected in sample. ND< = BDL < - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL Data reported without ND< or < = ADL								

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-4
FRONT HALF TRACE METALS RESULTS SUMMARY CT-4
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 29	2-EPA 29	3-EPA 29	4-EPA 29	5-EPA 29	6-EPA 29	7-EPA 29	Averages
Diluent Emissions and Stack Flow Rate								
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	--
Start Time	10:50	08:10	13:05	08:05	12:40	07:50	12:15	--
Stop Time	15:00	12:20	17:15	12:15	16:50	12:00	16:25	--
Flow Rate, dscfm	34,801	34,847	34,702	34,614	34,850	34,552	34,453	34,688
Sample Volume, dscf	178.48	179.87	178.95	181.31	177.55	173.28	171.62	177.29
O ₂ , % Volume Dry	16.02	16.01	16.07	16.04	15.98	16.01	16.05	16.03
CO ₂ , % Volume Dry	4.40	4.52	4.47	4.37	4.30	4.49	4.54	4.44
Moisture, % by Volume	5.03	5.07	5.13	5.04	4.90	4.94	5.09	5.03
Antimony F%								
mg/dscm	0.00007	0.00005	ND<	0.00005	ND<	0.00005	ND<	0.00005
mg/dscm @ 15% O ₂	0.00008	0.00006	ND<	0.00006	ND<	0.00006	ND<	0.00006
lb/hr	8.84 x 10 ⁻⁶	6.43 x 10 ⁻⁶	ND<	6.41 x 10 ⁻⁶	ND<	6.31 x 10 ⁻⁶	ND<	6.3 x 10 ⁻⁶
Arsenic F%								
mg/dscm	ND<	0.00013	ND<	0.00013	ND<	0.00013	ND<	0.00014
mg/dscm @ 15% O ₂	ND<	0.00016	ND<	0.00016	ND<	0.00016	ND<	0.00017
lb/hr	ND<	1.73 x 10 ⁻⁵	ND<	1.72 x 10 ⁻⁵	ND<	1.69 x 10 ⁻⁵	ND<	1.78 x 10 ⁻⁵
Beryllium F%								
mg/dscm	0.00002	0.00003	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	0.00003	0.00004	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	2.99 x 10 ⁻⁶	4.20 x 10 ⁻⁶	ND<	1.36 x 10 ⁻⁶	ND<	1.34 x 10 ⁻⁶	ND<	1.41 x 10 ⁻⁶
Cadmium F%								
mg/dscm	0.00005	0.00003	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	0.00006	0.00004	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	5.98 x 10 ⁻⁶	4.43 x 10 ⁻⁶	ND<	1.33 x 10 ⁻⁶	ND<	1.31 x 10 ⁻⁶	ND<	1.39 x 10 ⁻⁶
Chromium F%								
mg/dscm	0.00090	0.00124	0.00089	0.00119	0.00125	0.00087	0.00126	0.00108
mg/dscm @ 15% O ₂	0.00108	0.00149	0.00109	0.00144	0.00150	0.00105	0.00153	0.00131
lb/hr	1.17 x 10 ⁻⁴	1.61 x 10 ⁻⁴	1.16 x 10 ⁻⁴	1.54 x 10 ⁻⁴	1.63 x 10 ⁻⁴	1.12 x 10 ⁻⁴	1.62 x 10 ⁻⁴	1.41 x 10 ⁻⁴
Cobalt F%								
mg/dscm	0.00003	0.00004	0.00022	0.00002	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	0.00003	0.00005	0.00027	0.00002	ND<	0.00001	ND<	0.00001
lb/hr	3.66 x 10 ⁻⁶	5.15 x 10 ⁻⁶	2.92 x 10 ⁻⁵	1.96 x 10 ⁻⁶	ND<	1.46 x 10 ⁻⁶	ND<	1.49 x 10 ⁻⁶
Lead F%								
mg/dscm	0.00013	0.00011	0.00007	0.00007	0.00008	0.00006	0.00007	0.00008
mg/dscm @ 15% O ₂	0.00015	0.00013	0.00008	0.00008	0.00010	0.00008	0.00009	0.00010
lb/hr	1.63 x 10 ⁻⁵	1.40 x 10 ⁻⁵	8.84 x 10 ⁻⁶	8.98 x 10 ⁻⁶	1.05 x 10 ⁻⁵	8.20 x 10 ⁻⁵	9.13 x 10 ⁻⁶	1.09 x 10 ⁻⁵
Manganese F%								
mg/dscm	0.00020	0.00019	0.00015	0.00015	0.00014	0.00030	0.00033	0.00021
mg/dscm @ 15% O ₂	0.00025	0.00023	0.00018	0.00018	0.00017	0.00036	0.00040	0.00025
lb/hr	2.65 x 10 ⁻⁵	2.49 x 10 ⁻⁵	1.90 x 10 ⁻⁵	1.95 x 10 ⁻⁵	1.88 x 10 ⁻⁵	3.82 x 10 ⁻⁵	4.27 x 10 ⁻⁵	2.71 x 10 ⁻⁵
Mercury F%								
mg/dscm	ND<	0.00000	ND<	0.00000	ND<	0.00000	ND<	0.00000
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	ND<	6.44 x 10 ⁻⁷	ND<	6.40 x 10 ⁻⁷	ND<	6.41 x 10 ⁻⁷	ND<	6.63 x 10 ⁻⁷
Nickel F%								
mg/dscm	0.00043	0.00036	0.00027	0.00038	0.00030	0.00025	0.00030	0.00033
mg/dscm @ 15% O ₂	0.00052	0.00044	0.00033	0.00046	0.00036	0.00031	0.00037	0.00040
lb/hr	5.57 x 10 ⁻⁵	4.74 x 10 ⁻⁵	3.51 x 10 ⁻⁵	4.92 x 10 ⁻⁵	3.87 x 10 ⁻⁵	3.29 x 10 ⁻⁵	3.90 x 10 ⁻⁵	4.26 x 10 ⁻⁵
Selenium F%								
mg/dscm	ND<	0.00006	ND<	0.00006	ND<	0.00006	ND<	0.00006
mg/dscm @ 15% O ₂	ND<	0.00007	ND<	0.00007	ND<	0.00007	ND<	0.00007
lb/hr	ND<	7.83 x 10 ⁻⁶	ND<	7.78 x 10 ⁻⁶	ND<	7.79 x 10 ⁻⁶	ND<	7.86 x 10 ⁻⁶

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-5
BACK HALF TRACE METALS RESULTS SUMMARY CT-4
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 29	2-EPA 29	3-EPA 29	4-EPA 29	5-EPA 29	6-EPA 29	7-EPA 29	Averages
Diluent Emissions and Stack Flow Rate								
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	--
Start Time	10:50	08:10	13:05	08:05	12:40	07:50	12:15	--
Stop Time	15:00	12:20	17:15	12:15	16:50	12:00	16:25	--
Flow Rate, dscfm	34,801	34,847	34,702	34,614	34,850	34,552	34,453	34,688
Sample Volume, dscf	178.48	179.87	178.95	181.31	177.55	173.28	171.62	177.29
O ₂ , % Volume Dry	16.02	16.01	16.07	16.04	15.98	16.01	16.05	16.03
CO ₂ , % Volume Dry	4.40	4.52	4.47	4.37	4.30	4.49	4.54	4.44
Moisture, % by Volume	5.03	5.07	5.13	5.04	4.90	4.94	5.09	5.03
Antimony B½								
mg/dscm	0.00002	0.00001	0.00001	ND<	0.00001	ND<	0.00001	< 0.00001
mg/dscm @ 15% O ₂	0.00002	0.00002	0.00002	ND<	0.00001	ND<	0.00001	< 0.00002
lb/hr	2.60 x 10 ⁻⁶	1.80 x 10 ⁻⁶	1.73 x 10 ⁻⁶	ND<	1.42 x 10 ⁻⁶	ND<	1.37 x 10 ⁻⁶	ND< 1.41 x 10 ⁻⁶ < 1.68 x 10 ⁻⁶
Arsenic B½								
mg/dscm	0.00001	0.00002	0.00001	ND<	0.00001	ND<	0.00001	< 0.00001
mg/dscm @ 15% O ₂	0.00001	0.00003	0.00002	ND<	0.00001	ND<	0.00001	< 0.00002
lb/hr	1.53 x 10 ⁻⁶	3.07 x 10 ⁻⁶	1.79 x 10 ⁻⁶	ND<	1.42 x 10 ⁻⁶	ND<	1.37 x 10 ⁻⁶	ND< 1.40 x 10 ⁻⁶ < 1.41 x 10 ⁻⁶ < 1.71 x 10 ⁻⁶
Beryllium B½								
mg/dscm	0.000006	0.000004	ND<	0.000003	ND<	0.000004	ND<	0.000004 < 0.000004
mg/dscm @ 15% O ₂	0.000008	0.000005	ND<	0.000004	ND<	0.000004	ND<	0.000005 < 0.000005
lb/hr	8.22 x 10 ⁻⁷	5.25 x 10 ⁻⁷	4.41 x 10 ⁻⁷	ND<	4.59 x 10 ⁻⁷	ND<	4.46 x 10 ⁻⁷	ND< 4.53 x 10 ⁻⁷ < 5.60 x 10 ⁻⁷ < 5.29 x 10 ⁻⁷
Cadmium B½								
mg/dscm	0.00013	0.00003	0.00002	0.00003	0.00001	ND<	0.00000	ND< 0.00000 < 0.00003
mg/dscm @ 15% O ₂	0.00015	0.00004	0.00002	0.00003	0.00001	ND<	0.00001	ND< 0.00001 < 0.00004
lb/hr	1.64 x 10 ⁻⁵	3.84 x 10 ⁻⁶	2.44 x 10 ⁻⁶	ND<	3.36 x 10 ⁻⁶	ND<	7.29 x 10 ⁻⁷	ND< 5.40 x 10 ⁻⁷ ND< 5.44 x 10 ⁻⁷ < 3.98 x 10 ⁻⁶
Chromium B½								
mg/dscm	0.00013	0.00012	0.00010	0.00011	0.00011	0.00010	0.00009	0.00011
mg/dscm @ 15% O ₂	0.00016	0.00014	0.00012	0.00014	0.00013	0.00013	0.00011	0.00013
lb/hr	1.70 x 10 ⁻⁵	1.55 x 10 ⁻⁵	1.26 x 10 ⁻⁵	1.47 x 10 ⁻⁶	1.45 x 10 ⁻⁵	1.35 x 10 ⁻⁵	1.19 x 10 ⁻⁵	1.42 x 10 ⁻⁵
Cobalt B½								
mg/dscm	0.00002	0.00001	0.00000	0.00001	0.00001	0.00001	0.00001	0.000001
mg/dscm @ 15% O ₂	0.00002	0.00002	0.00001	0.00001	0.00001	0.00001	0.00001	0.000001
lb/hr	2.16 x 10 ⁻⁶	1.87 x 10 ⁻⁶	6.18 x 10 ⁻⁷	1.10 x 10 ⁻⁶	9.60 x 10 ⁻⁷	7.11 x 10 ⁻⁷	9.23 x 10 ⁻⁷	1.19 x 10 ⁻⁶
Lead B½								
mg/dscm	0.00015	0.00009	0.00004	0.00007	0.00004	0.00004	0.00003	0.00006
mg/dscm @ 15% O ₂	0.00018	0.00011	0.00005	0.00008	0.00005	0.00005	0.00003	0.00008
lb/hr	1.90 x 10 ⁻⁵	1.22 x 10 ⁻⁵	5.25 x 10 ⁻⁶	8.53 x 10 ⁻⁶	5.40 x 10 ⁻⁶	5.06 x 10 ⁻⁶	3.24 x 10 ⁻⁶	8.38 x 10 ⁻⁶
Manganese B½								
mg/dscm	0.00024	0.00017	0.00008	0.00011	0.00013	0.00021	0.00028	0.00018
mg/dscm @ 15% O ₂	0.00029	0.00021	0.00010	0.00014	0.00016	0.00025	0.00035	0.00021
lb/hr	3.12 x 10 ⁻⁵	2.23 x 10 ⁻⁵	1.07 x 10 ⁻⁵	1.45 x 10 ⁻⁵	1.70 x 10 ⁻⁵	2.69 x 10 ⁻⁵	3.66 x 10 ⁻⁵	2.27 x 10 ⁻⁵
Mercury B½								
mg/dscm	< 0.00014	< 0.00011	< 0.00019	< 0.00010	< 0.00008	< 0.00010	< 0.00008	< 0.00011
mg/dscm @ 15% O ₂	< 0.00017	< 0.00013	< 0.00024	< 0.00012	< 0.00010	< 0.00012	< 0.00010	< 0.00014
lb/hr	< 1.88 x 10 ⁻⁵	< 1.37 x 10 ⁻⁵	< 2.51 x 10 ⁻⁵	< 1.27 x 10 ⁻⁵	< 1.07 x 10 ⁻⁵	< 1.28 x 10 ⁻⁵	< 1.04 x 10 ⁻⁵	< 1.49 x 10 ⁻⁵
Nickel B½								
mg/dscm	0.00028	0.00012	0.00015	0.00015	0.00011	0.00007	0.00007	0.00014
mg/dscm @ 15% O ₂	0.00034	0.00014	0.00019	0.00018	0.00013	0.00009	0.00009	0.00016
lb/hr	3.71 x 10 ⁻⁵	1.51 x 10 ⁻⁵	1.97 x 10 ⁻⁵	1.88 x 10 ⁻⁵	1.43 x 10 ⁻⁵	9.62 x 10 ⁻⁶	9.02 x 10 ⁻⁶	1.77 x 10 ⁻⁵
Selenium B½								
mg/dscm	0.00022	0.00006	0.00023	0.00091	0.00023	0.00163	0.00011	0.00049
mg/dscm @ 15% O ₂	0.00027	0.00008	0.00028	0.00111	0.00028	0.00196	0.00014	0.00059
lb/hr	2.91 x 10 ⁻⁵	8.24 x 10 ⁻⁶	2.97 x 10 ⁻⁵	1.18 x 10 ⁻⁴	3.01 x 10 ⁻⁵	2.10 x 10 ⁻⁴	1.48 x 10 ⁻⁵	6.29 x 10 ⁻⁵

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-6
ACID GASES AND FORMALDEHYDE RESULTS SUMMARY CT-4
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 320	2-EPA 320	3-EPA 320	4-EPA 320	5-EPA 320	6-EPA 320	7-EPA 320	Averages
Date	2/7/2023	2/7/2023	2/7/2023	2/8/2023	2/8/2023	2/8/2023	2/8/2023	--
Start Time	10:50	12:00	13:15	09:06	10:19	11:23	13:05	--
Stop Time	11:50	13:08	14:15	10:06	11:19	12:32	14:05	--
Pre-Test Information								
Reference Temperature, °F	68	68	68	68	68	68	68	--
Diluent Emissions and Stack Flow Rate								
O ₂ , % Volume Dry	16.02	16.02	16.02	16.01	16.01	16.01	16.07	16.03
CO ₂ , % Volume Dry	4.40	4.40	4.40	4.52	4.52	4.52	4.47	4.46
Stack Flow Rate, dscfm	34,673	34,673	34,673	34,670	34,670	34,670	34,381	34,630
Pollutant Emissions								
Hydrochloric Acid (HCl)								
ppm Volume Dry	0.54	0.49	0.50	0.45	0.51	0.56	0.60	0.52
ppmc Volume Dry @ 15% O ₂	0.65	0.59	0.61	0.54	0.61	0.68	0.73	0.63
lb/hr	0.11	0.10	0.10	0.09	0.10	0.11	0.12	0.10
Hydrogen Fluoride (HF)								
ppm Volume Dry	1.72	1.67	1.79	1.62	1.81	1.90	2.00	1.79
ppmc Volume Dry @ 15% O ₂	2.08	2.02	2.16	1.95	2.19	2.30	2.44	2.16
lb/hr	0.19	0.18	0.19	0.17	0.20	0.21	0.21	0.19
Formaldehyde (CH₂O)⁽¹⁾								
ppm Volume Dry	0.021	0.021	0.028	0.035	0.026	0.028	0.030	0.027
ppmc Volume Dry @ 15% O ₂	0.026	0.025	0.034	0.042	0.032	0.034	0.037	0.033
lb/hr	0.003	0.003	0.005	0.006	0.004	0.005	0.005	0.004

(1) As measured values are reported from FTIR. These values are below the instrument detection limit (BDL).

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

4.2 CT-5 TEST RESULTS

The results of the CT-5 tests are presented in Tables 4-7 through 4-12.

**TABLE 4-7
CO RESULTS CT-5
SUNSHINE GAS PRODUCERS**

Parameter/Units	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Average
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023	--
Start Time	08:01	12:21	07:36	12:01	07:36	12:01	07:31	--
Stop Time	12:10	16:30	11:46	16:11	11:45	16:10	11:40	--
Pre-Test Information								
Reference Temperature, °F	68	68	68	68	68	68	68	--
Diluent Emissions and Stack Flow Rate								
O ₂ , % Volume Dry	16.08	16.08	16.11	16.15	16.20	16.22	16.17	16.15
CO ₂ , % Volume Dry	4.29	4.25	4.23	4.18	4.19	4.14	4.27	4.22
Stack Flow Rate, dscfm	33,956	33,815	34,017	33,819	34,037	34,235	33,840	33,960
Pollutant Emissions								
Carbon Monoxide (CO)								
ppm Volume Dry	0.39	0.08	0.14	0.12	0.15	0.08	0.26	0.18
ppmc Volume Dry @ 15% O ₂	0.48	0.09	0.17	0.15	0.19	0.10	0.33	0.22
lb/hr	0.06	0.01	0.02	0.02	0.02	0.01	0.04	0.03

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-8
PARTICULATE MATTER RESULTS CT-5
SUNSHINE GAS PRODUCERS

Parameter/Units	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Average
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023	--
Start Time	08:00	12:20	07:35	12:00	07:35	12:00	07:30	--
Stop Time	12:10	16:30	11:45	16:10	11:45	16:10	11:40	--
Test Information								
Reference Temperature, °F	68	68	68	68	68	68	68	--
Diluent Emissions and Stack Flow Rate								
Moisture Fraction, %	5.7	5.5	5.5	5.5	5.3	4.4	5.3	5.3
O ₂ , % Volume Dry	16.08	16.08	16.11	16.15	16.20	16.22	16.17	16.15
CO ₂ , % Volume Dry	4.29	4.25	4.23	4.18	4.19	4.14	4.27	4.22
Stack Flow Rate, wacfm	84,863	84,333	84,176	84,188	84,147	83,710	83,942	84,194
Stack Flow Rate, dscfm	33,956	33,815	34,017	33,819	34,037	34,235	33,840	33,960
Particulate Emissions								
Grain Loading, gr/dscf	0.00005	0.00010	0.00007	0.00006	0.00000	0.00015	0.00006	0.00007
Grain Loading @ 15% O ₂ lb/hr	0.00006	0.00012	0.00008	0.00008	0.00000	0.00019	0.00008	0.00009
	0.015	0.028	0.020	0.018	0.000	0.043	0.017	0.020

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-9
TOTAL TRACE METALS RESULTS SUMMARY CT-5
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 29	2-EPA 29	3-EPA 29	4-EPA 29	5-EPA 29	6-EPA 29	7-EPA 29	Averages
Diluent Emissions and Stack Flow Rate								
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023	--
Start Time	08:00	12:20	07:35	12:00	07:35	12:00	7:30	--
Stop Time	12:10	16:30	12:45	16:10	11:45	16:10	11:40	--
Flow Rate, dscfm	33,749	33,854	33,920	33,742	33,727	33,795	33,652	33,777
Sample Volume, dscf	175.69	171.57	178.69	174.82	179.16	173.04	174.67	175.38
O ₂ , % Volume Dry	16.08	16.08	16.11	16.15	16.20	16.22	16.17	16.15
CO ₂ , % Volume Dry	4.29	4.25	4.23	4.18	4.19	4.14	4.27	4.22
Moisture, % by Volume	5.09	4.79	4.95	4.97	4.76	4.81	4.91	4.90
Antimony								
mg/m ³	ND<	0.00006	ND<	0.00006	ND<	0.00006	ND<	0.00006
mg/m ³ @ 15% O ₂	ND<	0.00007	ND<	0.00008	ND<	0.00007	ND<	0.00008
lb/hr	ND<	7.69 × 10 ⁻⁵	ND<	7.90 × 10 ⁻⁶	ND<	7.68 × 10 ⁻⁶	ND<	7.54 × 10 ⁻⁶
Arsenic								
mg/m ³	ND<	0.00015	ND<	0.00015	ND<	0.00015	ND<	0.00015
mg/m ³ @ 15% O ₂	ND<	0.00018	ND<	0.00018	ND<	0.00018	ND<	0.00018
lb/hr	ND<	1.84 × 10 ⁻⁵	ND<	1.89 × 10 ⁻⁵	ND<	1.82 × 10 ⁻⁵	ND<	1.80 × 10 ⁻⁵
Beryllium								
mg/m ³	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/m ³ @ 15% O ₂	ND<	0.00002	ND<	0.00002	ND<	0.00002	ND<	0.00002
lb/hr	ND<	1.79 × 10 ⁻⁶	ND<	1.84 × 10 ⁻⁶	ND<	1.79 × 10 ⁻⁶	ND<	1.75 × 10 ⁻⁶
Cadmium								
mg/m ³	ND<	0.00001	<	0.00003	<	0.00002	ND<	0.00001
mg/m ³ @ 15% O ₂	ND<	0.00002	<	0.00003	<	0.00002	ND<	0.00002
lb/hr	ND<	1.84 × 10 ⁻⁶	<	3.17 × 10 ⁻⁶	<	2.20 × 10 ⁻⁶	ND<	1.85 × 10 ⁻⁶
Chromium								
mg/m ³		0.00102		0.00136		0.00104	0.00101	0.00082
mg/m ³ @ 15% O ₂		0.00125		0.00166		0.00128	0.00126	0.00103
lb/hr		1.29 × 10 ⁻⁴		1.72 × 10 ⁻⁴		1.32 × 10 ⁻⁴	1.28 × 10 ⁻⁴	1.03 × 10 ⁻⁴
Cobalt								
mg/m ³	ND<	0.00001	ND<	0.00001	<	0.00002	ND<	0.00001
mg/m ³ @ 15% O ₂	ND<	0.00002	ND<	0.00002	<	0.00002	ND<	0.00002
lb/hr	ND<	1.84 × 10 ⁻⁶	ND<	1.89 × 10 ⁻⁵	<	1.96 × 10 ⁻⁶	<	1.87 × 10 ⁻⁶
Lead								
mg/m ³		0.00008		0.00009		0.00009	0.00008	0.00009
mg/m ³ @ 15% O ₂		0.00010		0.00011		0.00011	0.00010	0.00011
lb/hr		1.07 × 10 ⁻⁵		1.11 × 10 ⁻⁵		1.11 × 10 ⁻⁵	9.85 × 10 ⁻⁶	1.10 × 10 ⁻⁵
Manganese								
mg/m ³		0.00323		0.00057		0.00049	0.00023	0.00031
mg/m ³ @ 15% O ₂		0.00395		0.00070		0.00060	0.00028	0.00039
lb/hr		4.07 × 10 ⁻⁴		7.27 × 10 ⁻⁵		6.19 × 10 ⁻⁵	2.86 × 10 ⁻⁵	3.94 × 10 ⁻⁵
Mercury								
mg/m ³	<	0.00009	<	0.00009	<	0.00009	<	0.00009
mg/m ³ @ 15% O ₂	<	0.00010	<	0.00011	<	0.00011	<	0.00010
lb/hr	<	1.08 × 10 ⁻⁵	<	1.16 × 10 ⁻⁵	<	1.10 × 10 ⁻⁵	<	1.10 × 10 ⁻⁵
Nickel								
mg/m ³		0.00036		0.00043		0.00037	0.00039	0.00051
mg/m ³ @ 15% O ₂		0.00044		0.00052		0.00045	0.00049	0.00064
lb/hr		4.56 × 10 ⁻⁵		5.39 × 10 ⁻⁵		4.68 × 10 ⁻⁵	4.95 × 10 ⁻⁵	6.42 × 10 ⁻⁵
Selenium								
mg/m ³	<	0.00175	<	0.00053	<	0.00405	<	0.00022
mg/m ³ @ 15% O ₂	<	0.00214	<	0.00065	<	0.00499	<	0.00016
lb/hr	<	2.20 × 10 ⁻⁴	<	6.76 × 10 ⁻⁵	<	5.1 × 10 ⁻⁴	<	2.79 × 10 ⁻⁵

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-10
FRONT HALF TRACE METALS RESULTS SUMMARY CT-5
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 29	2-EPA 29	3-EPA 29	4-EPA 29	5-EPA 29	6-EPA 29	7-EPA 29	Averages
Diluent Emissions and Stack Flow Rate								
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023	--
Start Time	08:00	12:20	07:35	12:00	07:35	12:00	07:30	--
Stop Time	12:10	16:30	12:45	16:10	11:45	16:10	11:40	--
Flow Rate, dscfm	33,749	33,854	33,920	33,742	33,727	33,795	33,652	33,777
Sample Volume, dscf	175.69	171.57	178.69	174.82	179.16	173.04	174.67	175.38
O ₂ , % Volume Dry	16.08	16.08	16.11	16.15	16.20	16.22	16.17	16.15
CO ₂ , % Volume Dry	4.29	4.25	4.23	4.18	4.19	4.14	4.27	4.22
Moisture, % by Volume	5.09	4.79	4.95	4.97	4.76	4.81	4.91	4.90
Antimony F%								
mg/dscm	ND<	0.00005	ND<	0.00005	ND<	0.00005	ND<	0.00005
mg/dscm @ 15% O ₂	ND<	0.00006	ND<	0.00006	ND<	0.00006	ND<	0.00006
lb/hr	ND<	6.35 x 10 ⁻⁶	ND<	6.52 x 10 ⁻⁶	ND<	6.27 x 10 ⁻⁶	ND<	6.37 x 10 ⁻⁶
Arsenic F%								
mg/dscm	ND<	0.00013	ND<	0.00014	ND<	0.00013	ND<	0.00014
mg/dscm @ 15% O ₂	ND<	0.00017	ND<	0.00017	ND<	0.00017	ND<	0.00017
lb/hr	ND<	1.70 x 10 ⁻⁵	ND<	1.75 x 10 ⁻⁵	ND<	1.68 x 10 ⁻⁵	ND<	1.71 x 10 ⁻⁵
Beryllium F%								
mg/dscm	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00002
lb/hr	ND<	1.35 x 10 ⁻⁶	ND<	1.39 x 10 ⁻⁶	ND<	1.33 x 10 ⁻⁶	ND<	1.37 x 10 ⁻⁶
Cadmium F%								
mg/dscm	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	ND<	1.32 x 10 ⁻⁶	ND<	1.35 x 10 ⁻⁶	ND<	1.30 x 10 ⁻⁶	ND<	1.33 x 10 ⁻⁶
Chromium F%								
mg/dscm		0.00092		0.00126		0.00091		0.00089
mg/dscm @ 15% O ₂		0.00112		0.00154		0.00112		0.00112
lb/hr		1.16 x 10 ⁻⁴		1.60 x 10 ⁻⁴		1.15 x 10 ⁻⁴		1.13 x 10 ⁻⁴
Cobalt F%								
mg/dscm	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	ND<	1.43 x 10 ⁻⁶	ND<	1.47 x 10 ⁻⁶	ND<	1.41 x 10 ⁻⁶	ND<	1.43 x 10 ⁻⁶
Lead F%								
mg/dscm		0.00006		0.00006		0.00006		0.00007
mg/dscm @ 15% O ₂		0.00008		0.00008		0.00007		0.00009
lb/hr		8.15 x 10 ⁻⁶		8.19 x 10 ⁻⁶		7.40 x 10 ⁻⁶		8.60 x 10 ⁻⁶
Manganese F%								
mg/dscm		0.00013		0.00047		0.00014		0.00013
mg/dscm @ 15% O ₂		0.00016		0.00057		0.00017		0.00017
lb/hr		1.65 x 10 ⁻⁵		5.95 x 10 ⁻⁵		1.72 x 10 ⁻⁵		1.67 x 10 ⁻⁵
Mercury F%								
mg/dscm	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	ND<	6.35 x 10 ⁻⁷	ND<	6.52 x 10 ⁻⁷	ND<	6.27 x 10 ⁻⁷	ND<	6.37 x 10 ⁻⁷
Nickel F%								
mg/dscm		0.00028		0.00034		0.00028		0.00028
mg/dscm @ 15% O ₂		0.00035		0.00042		0.00035		0.00035
lb/hr		3.58 x 10 ⁻⁵		4.33 x 10 ⁻⁵		3.59 x 10 ⁻⁵		3.54 x 10 ⁻⁵
Selenium F%								
mg/dscm	ND<	0.00006	ND<	0.00006	ND<	0.00006	ND<	0.00006
mg/dscm @ 15% O ₂	ND<	0.00007	ND<	0.00008	ND<	0.00008	ND<	0.00008
lb/hr	ND<	7.72 x 10 ⁻⁶	ND<	7.93 x 10 ⁻⁶	ND<	7.63 x 10 ⁻⁶	ND<	7.74 x 10 ⁻⁶

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-11
BACK HALF TRACE METALS RESULTS SUMMARY CT-5
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 29	2-EPA 29	3-EPA 29	4-EPA 29	5-EPA 29	6-EPA 29	7-EPA 29	Averages
Diluent Emissions and Stack Flow Rate								
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023	--
Start Time	08:00	12:20	07:35	12:00	07:35	12:00	07:30	--
Stop Time	12:10	16:30	12:45	16:10	11:45	16:10	11:40	--
Flow Rate, dscfm	33,749	33,854	33,920	33,742	33,727	33,795	33,652	33,777
Sample Volume, dscf	175.69	171.57	178.69	174.82	179.16	173.04	174.67	175.38
O ₂ , % Volume Dry	16.08	16.08	16.11	16.15	16.20	16.22	16.17	16.15
CO ₂ , % Volume Dry	4.29	4.25	4.23	4.18	4.19	4.14	4.27	4.22
Moisture, % by Volume	5.09	4.79	4.95	4.97	4.76	4.81	4.91	4.90
Antimony B½								
mg/dscm	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	ND<	1.35 x 10 ⁻⁶	ND<	1.38 x 10 ⁻⁶	ND<	1.41 x 10 ⁻⁶	ND<	1.35 x 10 ⁻⁶
Arsenic B½								
mg/dscm	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00001	ND<	0.00001	ND<	0.00001
lb/hr	ND<	1.35 x 10 ⁻⁶	ND<	1.38 x 10 ⁻⁶	ND<	1.41 x 10 ⁻⁶	ND<	1.35 x 10 ⁻⁶
Beryllium B½								
mg/dscm	ND<	0.000003	ND<	0.000004	ND<	0.000004	ND<	0.000003
mg/dscm @ 15% O ₂	ND<	0.000004	ND<	0.000004	ND<	0.000004	ND<	0.000004
lb/hr	ND<	4.37 x 10 ⁻⁷	ND<	4.49 x 10 ⁻⁶	ND<	4.57 x 10 ⁻⁷	ND<	4.38 x 10 ⁻⁷
Cadmium B½								
mg/dscm	ND<	0.00000	ND<	0.00001	ND<	0.00000	ND<	0.00000
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00002	ND<	0.00001	ND<	0.00001
lb/hr	ND<	5.20 x 10 ⁻⁷	ND<	1.82 x 10 ⁻⁶	ND<	8.96 x 10 ⁻⁷	ND<	5.10 x 10 ⁻⁷
Chromium B½								
mg/dscm	ND<	0.00011	ND<	0.00010	ND<	0.00013	ND<	0.00010
mg/dscm @ 15% O ₂	ND<	0.00013	ND<	0.00012	ND<	0.00016	ND<	0.00013
lb/hr	ND<	1.35 x 10 ⁻⁵	ND<	1.25 x 10 ⁻⁵	ND<	1.67 x 10 ⁻⁵	ND<	1.53 x 10 ⁻⁵
Cobalt B½								
mg/dscm	ND<	0.00000	ND<	0.00000	ND<	0.00000	ND<	0.00000
mg/dscm @ 15% O ₂	ND<	0.00001	ND<	0.00002	ND<	0.00001	ND<	0.00001
lb/hr	ND<	5.20 x 10 ⁻⁷	ND<	1.82 x 10 ⁻⁶	ND<	8.96 x 10 ⁻⁷	ND<	5.10 x 10 ⁻⁷
Lead B½								
mg/dscm	ND<	0.00002	ND<	0.00002	ND<	0.00003	ND<	0.00002
mg/dscm @ 15% O ₂	ND<	0.00002	ND<	0.00003	ND<	0.00004	ND<	0.00003
lb/hr	ND<	4.16 x 10 ⁻⁷	ND<	4.28 x 10 ⁻⁷	ND<	5.52 x 10 ⁻⁷	ND<	4.34 x 10 ⁻⁷
Manganese B½								
mg/dscm	ND<	0.00310	ND<	0.00010	ND<	0.00035	ND<	0.00009
mg/dscm @ 15% O ₂	ND<	0.00379	ND<	0.00013	ND<	0.00043	ND<	0.00011
lb/hr	ND<	3.91 x 10 ⁻⁴	ND<	1.33 x 10 ⁻⁵	ND<	4.47 x 10 ⁻⁵	ND<	1.08 x 10 ⁻⁵
Mercury B½								
mg/dscm	<	0.00008	<	0.00009	<	0.00008	<	0.00008
mg/dscm @ 15% O ₂	<	0.00010	<	0.00011	<	0.00010	<	0.00010
lb/hr	<	1.02 x 10 ⁻⁵	<	1.10 x 10 ⁻⁵	<	1.04 x 10 ⁻⁵	<	1.05 x 10 ⁻⁵
Nickel B½								
mg/dscm	ND<	0.00008	ND<	0.00008	ND<	0.00009	ND<	0.00008
mg/dscm @ 15% O ₂	ND<	0.00010	ND<	0.00010	ND<	0.00014	ND<	0.00013
lb/hr	ND<	9.85 x 10 ⁻⁶	ND<	1.06 x 10 ⁻⁵	ND<	1.09 x 10 ⁻⁵	ND<	1.37 x 10 ⁻⁵
Selenium B½								
mg/dscm	ND<	0.00168	ND<	0.00047	ND<	0.00399	ND<	0.00007
mg/dscm @ 15% O ₂	ND<	0.00206	ND<	0.00058	ND<	0.00492	ND<	0.00008
lb/hr	ND<	2.13 x 10 ⁻⁴	ND<	5.97 x 10 ⁻⁵	ND<	5.07 x 10 ⁻⁴	ND<	8.32 x 10 ⁻⁶

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

TABLE 4-12
ACID GASES AND FORMALDEHYDE RESULTS SUMMARY CT-5
SUNSHINE GAS PRODUCERS

Parameter/Units	1-EPA 320	2-EPA 320	3-EPA 320	4-EPA 320	5-EPA 320	6-EPA 320	7-EPA 320	Averages
Date	2/14/2023	2/14/2023	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/15/2023	--
Start Time	09:15	10:20	11:25	12:40	09:05	10:10	11:15	--
Stop Time	10:15	11:20	12:34	13:40	10:05	11:10	12:30	--
Pre-Test Information								
Reference Temperature, °F	68	68	68	68	68	68	68	--
Diluent Emissions and Stack Flow Rate								
O ₂ , % Volume Dry	16.08	16.08	16.08	16.08	16.11	16.11	16.11	16.09
CO ₂ , % Volume Dry	4.29	4.29	4.29	4.25	4.23	4.23	4.23	4.26
Stack Flow Rate, dscfm	33,956	33,956	33,956	33,815	34,017	34,017	34,017	33,962
Pollutant Emissions								
Hydrochloric Acid (HCl)								
ppm Volume Dry	0.29	0.31	0.35	0.38	0.29	0.33	0.39	0.34
ppmc Volume Dry @ 15% O ₂	0.35	0.38	0.43	0.47	0.35	0.41	0.49	0.41
lb/hr	0.06	0.06	0.07	0.07	0.06	0.06	0.08	0.06
Hydrogen Fluoride (HF)								
ppm Volume Dry	1.26	1.34	1.40	1.45	1.21	1.52	1.64	1.40
ppmc Volume Dry @ 15% O ₂	1.54	1.64	1.72	1.77	1.49	1.87	2.02	1.72
lb/hr	0.13	0.14	0.15	0.15	0.13	0.16	0.17	0.15
Formaldehyde (CH₂O)⁽¹⁾								
ppm Volume Dry	0.096	0.081	0.092	0.077	0.051	0.054	0.040	0.070
ppmc Volume Dry @ 15% O ₂	0.118	0.100	0.112	0.094	0.063	0.066	0.049	0.086
lb/hr	0.015	0.013	0.015	0.012	0.008	0.009	0.006	0.011

(1) As measured values are reported from FTIR. These values are below the instrument detection limit (BDL).

4.3 FIELD TEST DEVIATIONS AND EXCEPTIONS

No filed deviations or exceptions from the test plan or test methods occurred during this test program. Per the EPA guidance document, front and back half fractions were analyzed separately for EPA Method 29. The results of front half and back half analyses for individual metals were reported separately along with a total emission. The reported results are not blank corrected since majority of the blank values were non-detect. Sampling duration was designed such that a minimum volume of 141 dscf (4 dscm) was collected per run for each metal and particulate sampling train. Isokinetic sampling rate was maintained for each metal and particulate sampling train within the specification of $100 \pm 10\%$. The reported results are considered representative.

APPENDIX A TEST DATA

Appendix A.1 Sample Location Data




1631 E St. Andrew Place
Santa Ana, California 92705
Phone: 714-279- 6777
Fax: 714-279-6781

TRAVERSE POINT LOCATION FOR CIRCULAR STACKS

Checked by: PSJ

Plant:	Sunshine Gas
Source:	Turbine 4 and 5
Date:	2/7-2/17, 2023
Inside of far wall to outside of nipple (a):	60"
Inside of near wall to outside of nipple (b):	5"
Stack I.D. (a-b):	55"
Nearest upstream disturbance:	177.6"
Nearest downstream disturbance:	34.8"
Calculator:	SJ




Schematic of duct

MONTROSE AQS
 1631 E. ST ANDREW PLACE
 SANTA ANA, CA 92705

CYCLONIC FLOW VERIFICATION DATA SHEET

FACILITY	Sunshine
SOURCE	COG 4
DATE	2/7/23
PROJECT NUMBER	023392
STACK DIAMETER/DIMENSION	55"
BAROMETRIC PRESSURE	28.36
STATIC PRESSURE	-0.55
RUN NUMBER	1-7
TOTAL TRAVERSE POINTS	24
OPERATOR	OH, AD DSJ




SAMPLE POINT	DISTANCE FROM SAMPLE PORT (INCHES)	NULL POINT ROTATION ANGLE	
		A NORTH/SOUTH	B EAST/WEST
1	1.2	0	1
2	3.7	1	0
3	6.5	2	0
4	9.2	1	1
5	13.8	3	2
6	19.6	1	1
7	35.4	0	0
8	41.3	2	0
9	45.3	0	3
10	48.5	0	1
11	51.3	1	0
12	53.8	0	1
AVERAGE			1

MONTROSE AQS
 1631 E. ST ANDREW PLACE
 SANTA ANA, CA 92705

CYCLONIC FLOW VERIFICATION DATA SHEET

FACILITY	Sunshine
SOURCE	COL 5
DATE	2/14/23
PROJECT NUMBER	023392
STACK DIAMETER/DIMENSION	55"
BAROMETRIC PRESSURE	22.98
STATIC PRESSURE	-6.5
RUN NUMBER	1-7
TOTAL TRAVERSE POINTS	24
OPERATOR	OH, AD, PBT



SAMPLE POINT	DISTANCE FROM SAMPLE PORT (INCHES)	NULL POINT ROTATION ANGLE	
		NORTH/SOUTH	EAST/WEST
1	1.2	0	1
2	3.7	0	0
3	6.5	1	0
4	9.3	0	1
5	13.8	1	2
6	19.4	0	1
7	35.4	2	0
8	41.3	1	1
9	45.3	0	0
10	48.5	1	0
11	51.3	2	0
12	53.8	0	1
		AVERAGE	1

Appendix A.2 Gaseous DAS Data

Appendix A.2.1 CT-4 Data

Date	Time	O2%	CO2%	CO ppm	
2/7/2023	8:49:00	0.071	-0.255		
2/7/2023	8:50:00	0.072	-0.092	-0.088	
2/7/2023	8:51:00	-0.019	-0.029	-0.04	< Zero Direct
2/7/2023	8:52:00	-0.027	-0.032	-0.024	
2/7/2023	8:53:00	-0.027	-0.038	-0.042	
2/7/2023	8:54:00	1.583	0.25	-0.014	
2/7/2023	8:55:00	9.504	4.541	5.999	
2/7/2023	8:56:00	10.193	4.71	9.661	
2/7/2023	8:57:00	18.098	8.918	9.673	
2/7/2023	8:58:00	19.116	9.364	9.649	< Direct High
2/7/2023	8:59:00	19.286	9.623	9.619	< Direct High
2/7/2023	9:00:00	12.646	6.299	8.922	
2/7/2023	9:01:00	10.098	4.944	4.706	< Direct Mid
2/7/2023	9:02:00	10.959	4.815	4.711	
2/7/2023	9:03:00	15.996	4.468	2.504	
2/7/2023	9:04:00	15.979	4.475	1.446	
2/7/2023	9:05:00	15.975	4.468	1.43	
2/7/2023	9:06:00	15.977	4.475	1.19	
2/7/2023	9:07:00	15.974	4.468	1.256	
2/7/2023	9:08:00	15.979	4.461	1.219	
2/7/2023	9:09:00	15.966	4.465	1.272	
2/7/2023	9:10:00	15.964	4.467	1.26	
2/7/2023	9:11:00	15.943	4.484	1.205	
2/7/2023	9:12:00	15.963	4.459	1.224	
2/7/2023	9:13:00	15.957	4.455	1.159	
2/7/2023	9:14:00	15.97	4.454	1.049	
2/7/2023	9:15:00	15.929	4.465	1.123	
2/7/2023	9:16:00	15.906	4.449	1.185	
2/7/2023	9:17:00	15.902	4.452	1.21	
2/7/2023	9:18:00	15.91	4.432	1.34	
2/7/2023	9:19:00	14.581	3.685	1.275	
2/7/2023	9:20:00	-0.009	0.101	0.728	
2/7/2023	9:21:00	-0.031	0.088	-0.048	
2/7/2023	9:22:00	-0.035	0.091	-0.044	
2/7/2023	9:23:00	-0.037	0.083	-0.028	
2/7/2023	9:24:00	-0.037	0.076	-0.042	
2/7/2023	9:25:00	-0.041	0.081	-0.031	
2/7/2023	9:26:00	-0.042	0.087	-0.036	
2/7/2023	9:27:00	-0.042	0.082	-0.045	
2/7/2023	9:28:00	-0.04	0.073	-0.042	
2/7/2023	9:29:00	-0.038	0.078	-0.052	
2/7/2023	9:30:00	-0.039	0.08	-0.045	
2/7/2023	9:31:00	-0.037	0.082	-0.042	
2/7/2023	9:32:00	-0.041	0.072	-0.05	
2/7/2023	9:33:00	-0.041	0.071	-0.049	
2/7/2023	9:34:00	-0.04	0.073	-0.055	
2/7/2023	9:35:00	-0.042	0.068	-0.046	
2/7/2023	9:36:00	-0.042	0.069	-0.045	

2/7/2023	9:37:00	-0.041	0.067	-0.058
2/7/2023	9:38:00	-0.039	0.065	-0.055
2/7/2023	9:39:00	-0.039	0.077	-0.061
2/7/2023	9:40:00	-0.04	0.085	-0.062
2/7/2023	9:41:00	-0.041	0.093	-0.071
2/7/2023	9:42:00	-0.04	0.102	-0.065
2/7/2023	9:43:00	-0.039	0.104	-0.067
2/7/2023	9:44:00	-0.041	0.093	-0.063
2/7/2023	9:45:00	-0.043	0.097	-0.065
2/7/2023	9:46:00	-0.042	0.095	-0.069
2/7/2023	9:47:00	-0.042	0.093	-0.074
2/7/2023	9:48:00	-0.042	0.101	-0.073
2/7/2023	9:49:00	12.777	3.663	0.536
2/7/2023	9:50:00	15.891	4.429	1.486
2/7/2023	9:51:00	15.913	4.41	1.21
2/7/2023	9:52:00	15.918	4.423	1.031
2/7/2023	9:53:00	15.898	4.472	1.481
2/7/2023	9:54:00	15.907	4.461	1.611
2/7/2023	9:55:00	15.891	4.468	1.015
2/7/2023	9:56:00	15.905	4.459	1.288
2/7/2023	9:57:00	15.923	4.45	1.623
2/7/2023	9:58:00	15.921	4.431	1.965
2/7/2023	9:59:00	15.904	4.449	1.347
2/7/2023	10:00:00	15.92	4.428	1.404
2/7/2023	10:01:00	15.901	4.439	1.103
2/7/2023	10:02:00	15.904	4.436	1.366
2/7/2023	10:03:00	15.899	4.441	1.122
2/7/2023	10:04:00	15.911	4.433	1.183
2/7/2023	10:05:00	15.899	4.459	1.159
2/7/2023	10:06:00	15.923	4.456	1.327
2/7/2023	10:07:00	15.927	4.456	1.069
2/7/2023	10:08:00	15.913	4.473	1.226
2/7/2023	10:09:00	15.92	4.456	1.238
2/7/2023	10:10:00	15.916	4.448	1.139
2/7/2023	10:11:00	15.922	4.451	1.169
2/7/2023	10:12:00	15.88	4.475	1.051
2/7/2023	10:13:00	15.896	4.481	1.205
2/7/2023	10:14:00	15.891	4.462	1.632
2/7/2023	10:15:00	15.923	4.428	1.288
2/7/2023	10:16:00	15.912	4.443	1.388
2/7/2023	10:17:00	15.917	4.45	1.514
2/7/2023	10:18:00	15.915	4.461	1.445
2/7/2023	10:19:00	15.908	4.47	1.914
2/7/2023	10:20:00	15.86	4.503	1.521
2/7/2023	10:21:00	15.899	4.455	1.272
2/7/2023	10:22:00	15.896	4.462	1.158
2/7/2023	10:23:00	15.899	4.458	1.131
2/7/2023	10:24:00	15.871	4.479	1.365
2/7/2023	10:25:00	15.915	4.442	1.765

2/7/2023	10:26:00	15.91	4.433	1.388	
2/7/2023	10:27:00	15.917	4.441	1.418	
2/7/2023	10:28:00	15.934	4.436	1.222	
2/7/2023	10:29:00	15.924	4.457	1.063	
2/7/2023	10:30:00	15.905	4.492	1.076	
2/7/2023	10:31:00	16.431	5.553	1.144	
2/7/2023	10:32:00	11.153	5.506	-0.059	
2/7/2023	10:33:00	-0.071	0.058	-0.163	< Direct Zero
2/7/2023	10:34:00	-0.028	-0.023	-0.096	< Direct Zero
2/7/2023	10:35:00	13.002	5.903	3.208	
2/7/2023	10:36:00	19.118	9.58	9.524	< Direct High
2/7/2023	10:37:00	19.287	9.635	9.636	< Direct High
2/7/2023	10:38:00	19.292	9.619	9.631	
2/7/2023	10:39:00	11.608	5.675	7.961	
2/7/2023	10:40:00	10.129	4.897	4.687	
2/7/2023	10:41:00	10.128	4.903	4.653	
2/7/2023	10:42:00	10.124	4.899	4.664	< Direct Mid
2/7/2023	10:43:00	12.856	4.681	4.516	
2/7/2023	10:44:00	12.473	4.582	1.454	
2/7/2023	10:45:00	10.059	4.954	-0.093	< System O2, CO2
2/7/2023	10:46:00	3.221	1.401	0.813	
2/7/2023	10:47:00	-0.026	0.006	4.594	< System CO
2/7/2023	10:48:00	-0.031	0.153	4.644	
2/7/2023	10:49:00	5.322	1.56	4.592	
2/7/2023	10:50:00	15.899	4.451	2.037	
2/7/2023	10:51:00	15.903	4.457	1.327	
2/7/2023	10:52:00	15.884	4.464	1.446	< Start run 1
2/7/2023	10:53:00	15.897	4.447	1.237	12
2/7/2023	10:54:00	15.904	4.429	1.022	
2/7/2023	10:55:00	15.924	4.412	1.095	
2/7/2023	10:56:00	15.924	4.42	1.471	
2/7/2023	10:57:00	15.925	4.412	1.107	
2/7/2023	10:58:00	15.921	4.416	0.98	
2/7/2023	10:59:00	15.926	4.419	1.439	
2/7/2023	11:00:00	15.922	4.432	1.177	
2/7/2023	11:01:00	15.902	4.46	1.376	
2/7/2023	11:02:00	15.94	4.438	0.993	
2/7/2023	11:03:00	15.927	4.46	1.063	11
2/7/2023	11:04:00	15.933	4.449	1.189	
2/7/2023	11:05:00	15.94	4.447	0.935	
2/7/2023	11:06:00	15.931	4.451	1.015	
2/7/2023	11:07:00	15.935	4.458	1.005	
2/7/2023	11:08:00	15.928	4.479	1.092	
2/7/2023	11:09:00	15.931	4.475	0.948	
2/7/2023	11:10:00	15.925	4.489	1.192	
2/7/2023	11:11:00	15.937	4.489	1.004	
2/7/2023	11:12:00	15.932	4.479	0.949	
2/7/2023	11:13:00	15.928	4.48	1.341	10
2/7/2023	11:14:00	15.934	4.489	1.427	

2/7/2023	11:15:00	15.931	4.492	1.413	
2/7/2023	11:16:00	15.95	4.48	1.172	
2/7/2023	11:17:00	15.934	4.483	1.173	
2/7/2023	11:18:00	15.923	4.475	1.262	
2/7/2023	11:19:00	15.933	4.472	1.443	
2/7/2023	11:20:00	15.939	4.458	1.241	
2/7/2023	11:21:00	15.942	4.468	1.322	
2/7/2023	11:22:00	15.936	4.463	1.536	
2/7/2023	11:23:00	15.905	4.501	1.137	9
2/7/2023	11:24:00	15.929	4.464	1.122	
2/7/2023	11:25:00	15.948	4.458	0.953	
2/7/2023	11:26:00	15.928	4.484	0.949	
2/7/2023	11:27:00	15.925	4.486	1.091	
2/7/2023	11:28:00	15.952	4.477	1.391	
2/7/2023	11:29:00	15.929	4.503	1.402	
2/7/2023	11:30:00	15.916	4.512	1.338	
2/7/2023	11:31:00	15.928	4.501	1.035	
2/7/2023	11:32:00	15.911	4.491	1.017	
2/7/2023	11:33:00	15.935	4.457	1.37	8
2/7/2023	11:34:00	15.96	4.44	1.068	
2/7/2023	11:35:00	15.926	4.493	1.339	
2/7/2023	11:36:00	15.924	4.49	1.146	
2/7/2023	11:37:00	15.944	4.463	1.053	
2/7/2023	11:38:00	15.947	4.441	1.119	
2/7/2023	11:39:00	15.944	4.461	1.071	
2/7/2023	11:40:00	15.947	4.466	1.301	
2/7/2023	11:41:00	15.949	4.465	0.977	
2/7/2023	11:42:00	15.941	4.473	1.054	
2/7/2023	11:43:00	15.952	4.45	1.072	7
2/7/2023	11:44:00	15.944	4.453	1.567	
2/7/2023	11:45:00	15.956	4.44	1.168	
2/7/2023	11:46:00	15.927	4.48	0.961	
2/7/2023	11:47:00	15.947	4.473	1.011	
2/7/2023	11:48:00	15.949	4.499	1.267	
2/7/2023	11:49:00	15.935	4.509	1.154	
2/7/2023	11:50:00	15.912	4.538	1.027	
2/7/2023	11:51:00	15.931	4.506	1.333	
2/7/2023	11:52:00	15.95	4.486	1.767	
2/7/2023	11:53:00	15.948	4.486	1.586	6
2/7/2023	11:54:00	15.964	4.466	1.878	
2/7/2023	11:55:00	15.952	4.471	1.162	
2/7/2023	11:56:00	15.946	4.477	1.441	
2/7/2023	11:57:00	15.922	4.489	1.719	
2/7/2023	11:58:00	15.953	4.457	1.095	
2/7/2023	11:59:00	15.921	4.49	1.201	
2/7/2023	12:00:00	15.949	4.467	1.036	
2/7/2023	12:01:00	15.96	4.451	0.984	
2/7/2023	12:02:00	15.95	4.463	1.535	
2/7/2023	12:03:00	15.957	4.474	1.047	5

2/7/2023	12:04:00	15.963	4.48	0.923
2/7/2023	12:05:00	15.934	4.524	1.236
2/7/2023	12:06:00	15.919	4.551	1.312
2/7/2023	12:07:00	15.952	4.496	0.931
2/7/2023	12:08:00	15.947	4.489	1.213
2/7/2023	12:09:00	15.947	4.488	1.462
2/7/2023	12:10:00	15.948	4.479	1.254
2/7/2023	12:11:00	15.97	4.468	1.081
2/7/2023	12:12:00	15.926	4.504	0.994
2/7/2023	12:13:00	15.918	4.505	1.232
2/7/2023	12:14:00	15.957	4.467	1.596
2/7/2023	12:15:00	15.958	4.467	1.781
2/7/2023	12:16:00	15.929	4.48	1.151
2/7/2023	12:17:00	15.946	4.452	2.113
2/7/2023	12:18:00	15.939	4.483	1.701
2/7/2023	12:19:00	15.95	4.486	1.342
2/7/2023	12:20:00	15.97	4.482	0.977
2/7/2023	12:21:00	15.951	4.502	1.123
2/7/2023	12:22:00	15.963	4.481	1.278
2/7/2023	12:23:00	15.958	4.474	0.984
2/7/2023	12:24:00	15.957	4.46	1.089
2/7/2023	12:25:00	15.96	4.47	1.148
2/7/2023	12:26:00	15.952	4.475	1.161
2/7/2023	12:27:00	15.955	4.487	1.271
2/7/2023	12:28:00	15.94	4.487	1.057
2/7/2023	12:29:00	15.948	4.455	1.403
2/7/2023	12:30:00	15.937	4.46	0.953
2/7/2023	12:31:00	15.95	4.442	1.341
2/7/2023	12:32:00	15.937	4.455	1.162
2/7/2023	12:33:00	15.957	4.446	1.204
2/7/2023	12:34:00	15.969	4.422	1.045
2/7/2023	12:35:00	15.963	4.419	1.143
2/7/2023	12:36:00	15.972	4.408	1.237
2/7/2023	12:37:00	15.962	4.421	1.223
2/7/2023	12:38:00	15.973	4.418	1.468
2/7/2023	12:39:00	15.962	4.434	1.065
2/7/2023	12:40:00	15.966	4.451	1.24
2/7/2023	12:41:00	15.965	4.448	1.282
2/7/2023	12:42:00	15.973	4.432	1.23
2/7/2023	12:43:00	15.958	4.44	1.192
2/7/2023	12:44:00	15.953	4.439	1.497
2/7/2023	12:45:00	15.893	4.495	1.086
2/7/2023	12:46:00	15.914	4.488	1.279
2/7/2023	12:47:00	15.951	4.468	1.33
2/7/2023	12:48:00	15.963	4.441	1.186
2/7/2023	12:49:00	15.96	4.446	0.977
2/7/2023	12:50:00	15.928	4.46	1.387
2/7/2023	12:51:00	15.94	4.452	1.691
2/7/2023	12:52:00	15.954	4.44	1.671

2/7/2023	12:53:00	15.956	4.436	1.214	
2/7/2023	12:54:00	15.918	4.46	1.118	
2/7/2023	12:55:00	15.911	4.473	1.129	
2/7/2023	12:56:00	14.707	4.442	1.263	
2/7/2023	12:57:00	10.085	4.958	0.286	
2/7/2023	12:58:00	10.079	4.968	-0.012	< System O2, CO2
2/7/2023	12:59:00	5.342	2.426	0.114	
2/7/2023	13:00:00	-0.012	-0.005	4.151	
2/7/2023	13:01:00	-0.018	-0.02	4.626	< System CO
2/7/2023	13:02:00	-0.021	-0.033	4.619	
2/7/2023	13:03:00	9.14	2.574	4.173	< Resume
2/7/2023	13:04:00	15.905	4.446	1.237	12
2/7/2023	13:05:00	15.924	4.441	1.393	
2/7/2023	13:06:00	15.927	4.466	1.056	
2/7/2023	13:07:00	15.956	4.451	1.346	
2/7/2023	13:08:00	15.954	4.466	1.084	
2/7/2023	13:09:00	15.959	4.481	1.063	
2/7/2023	13:10:00	15.944	4.476	1.177	
2/7/2023	13:11:00	15.954	4.445	1.873	
2/7/2023	13:12:00	15.933	4.463	1.217	
2/7/2023	13:13:00	15.942	4.442	1.402	
2/7/2023	13:14:00	15.959	4.431	1.198	11
2/7/2023	13:15:00	15.957	4.442	1.307	
2/7/2023	13:16:00	15.95	4.45	2.071	
2/7/2023	13:17:00	15.946	4.439	1.392	
2/7/2023	13:18:00	15.942	4.442	1.404	
2/7/2023	13:19:00	15.966	4.404	2.075	
2/7/2023	13:20:00	15.951	4.424	1.351	
2/7/2023	13:21:00	15.957	4.437	1.116	
2/7/2023	13:22:00	15.959	4.437	1.251	
2/7/2023	13:23:00	15.956	4.427	1.19	
2/7/2023	13:24:00	15.951	4.422	1.356	10
2/7/2023	13:25:00	15.952	4.415	1.759	
2/7/2023	13:26:00	15.955	4.424	1.139	
2/7/2023	13:27:00	15.963	4.44	0.946	
2/7/2023	13:28:00	15.956	4.444	1.013	
2/7/2023	13:29:00	15.918	4.485	1.007	
2/7/2023	13:30:00	15.954	4.468	1.043	
2/7/2023	13:31:00	15.949	4.472	0.993	
2/7/2023	13:32:00	15.964	4.466	0.932	
2/7/2023	13:33:00	15.966	4.478	0.9	
2/7/2023	13:34:00	15.957	4.476	0.907	9
2/7/2023	13:35:00	15.962	4.461	0.93	
2/7/2023	13:36:00	15.956	4.459	0.903	
2/7/2023	13:37:00	15.96	4.458	0.924	
2/7/2023	13:38:00	15.938	4.493	1.726	
2/7/2023	13:39:00	15.951	4.483	1.55	
2/7/2023	13:40:00	15.959	4.485	1.602	
2/7/2023	13:41:00	15.964	4.498	1.277	

2/7/2023	13:42:00	15.962	4.487	0.931	
2/7/2023	13:43:00	15.968	4.478	0.912	
2/7/2023	13:44:00	15.967	4.475	0.903	8
2/7/2023	13:45:00	15.961	4.484	0.874	
2/7/2023	13:46:00	15.952	4.508	0.893	
2/7/2023	13:47:00	15.96	4.504	0.989	
2/7/2023	13:48:00	15.949	4.507	1.234	
2/7/2023	13:49:00	15.956	4.493	1.074	
2/7/2023	13:50:00	15.962	4.474	1.145	
2/7/2023	13:51:00	15.972	4.462	1.13	
2/7/2023	13:52:00	15.972	4.462	1.164	
2/7/2023	13:53:00	15.967	4.455	0.966	
2/7/2023	13:54:00	15.976	4.457	1.07	7
2/7/2023	13:55:00	15.951	4.484	1.049	
2/7/2023	13:56:00	15.97	4.472	1.196	
2/7/2023	13:57:00	15.965	4.474	1.071	
2/7/2023	13:58:00	15.962	4.492	0.926	
2/7/2023	13:59:00	15.968	4.496	0.907	
2/7/2023	14:00:00	15.97	4.5	0.954	
2/7/2023	14:01:00	15.97	4.504	0.931	
2/7/2023	14:02:00	15.965	4.518	1.049	
2/7/2023	14:03:00	15.97	4.515	0.98	
2/7/2023	14:04:00	15.962	4.519	1.005	6
2/7/2023	14:05:00	15.971	4.511	0.966	
2/7/2023	14:06:00	15.98	4.51	0.907	
2/7/2023	14:07:00	15.945	4.54	0.936	
2/7/2023	14:08:00	15.964	4.534	1	
2/7/2023	14:09:00	15.973	4.533	0.975	
2/7/2023	14:10:00	15.969	4.536	1.098	
2/7/2023	14:11:00	15.978	4.52	1.179	
2/7/2023	14:12:00	15.978	4.501	1.311	
2/7/2023	14:13:00	15.981	4.48	1.026	
2/7/2023	14:14:00	15.974	4.491	0.989	5
2/7/2023	14:15:00	15.974	4.481	0.985	
2/7/2023	14:16:00	15.986	4.466	0.953	
2/7/2023	14:17:00	15.975	4.482	0.937	
2/7/2023	14:18:00	15.972	4.483	0.918	
2/7/2023	14:19:00	15.964	4.499	0.923	
2/7/2023	14:20:00	15.972	4.492	1.035	
2/7/2023	14:21:00	15.975	4.5	0.908	
2/7/2023	14:22:00	15.981	4.513	0.956	
2/7/2023	14:23:00	15.986	4.536	0.99	
2/7/2023	14:24:00	15.937	4.566	1.006	4
2/7/2023	14:25:00	15.972	4.516	1.027	
2/7/2023	14:26:00	15.989	4.51	0.925	
2/7/2023	14:27:00	15.993	4.507	0.891	
2/7/2023	14:28:00	15.971	4.543	0.956	
2/7/2023	14:29:00	15.968	4.543	1.023	
2/7/2023	14:30:00	15.975	4.525	0.932	

2/7/2023	14:31:00	15.972	4.523	0.952	
2/7/2023	14:32:00	15.968	4.518	1.05	
2/7/2023	14:33:00	15.974	4.526	1.233	
2/7/2023	14:34:00	15.979	4.538	1.082	3
2/7/2023	14:35:00	15.974	4.516	1.023	
2/7/2023	14:36:00	15.978	4.516	0.933	
2/7/2023	14:37:00	15.985	4.512	0.948	
2/7/2023	14:38:00	15.975	4.52	0.89	
2/7/2023	14:39:00	15.948	4.54	0.97	
2/7/2023	14:40:00	15.969	4.539	1.152	
2/7/2023	14:41:00	15.98	4.531	1.122	
2/7/2023	14:42:00	15.943	4.553	1.17	
2/7/2023	14:43:00	15.989	4.498	0.938	
2/7/2023	14:44:00	15.993	4.492	0.886	2
2/7/2023	14:45:00	15.992	4.524	0.895	
2/7/2023	14:46:00	15.976	4.557	0.986	
2/7/2023	14:47:00	15.99	4.533	0.998	
2/7/2023	14:48:00	15.988	4.529	0.961	
2/7/2023	14:49:00	15.981	4.545	0.915	
2/7/2023	14:50:00	15.986	4.539	1.137	
2/7/2023	14:51:00	15.99	4.535	1.085	
2/7/2023	14:52:00	15.983	4.529	0.98	
2/7/2023	14:53:00	15.997	4.494	0.923	
2/7/2023	14:54:00	15.988	4.487	0.902	1
2/7/2023	14:55:00	15.987	4.489	0.916	
2/7/2023	14:56:00	15.997	4.496	0.886	
2/7/2023	14:57:00	15.975	4.512	0.901	
2/7/2023	14:58:00	15.968	4.509	0.925	
2/7/2023	14:59:00	15.982	4.496	0.92	
2/7/2023	15:00:00	15.985	4.518	0.939	
2/7/2023	15:01:00	15.981	4.513	0.915	
2/7/2023	15:02:00	15.964	4.527	0.956	
2/7/2023	15:03:00	15.971	4.525	1.039	
2/7/2023	15:04:00	15.977	4.522	0.942	
2/7/2023	15:05:00	15.983	4.511	0.96	
2/7/2023	15:06:00	11.956	4.767	0.778	
2/7/2023	15:07:00	10.095	5.061	-0.048	< System O2, CO2
2/7/2023	15:08:00	3.832	1.812	0.532	
2/7/2023	15:09:00	-0.014	-0.011	4.413	
2/7/2023	15:10:00	-0.019	-0.017	4.649	< System CO
2/7/2023	15:11:00	1.813	0.314	4.648	
2/7/2023	15:12:00	19.308	9.794	6.302	
2/7/2023	15:13:00	19.329	9.707	9.565	< Direct High
2/7/2023	15:14:00	13.594	6.9	9.203	
2/7/2023	15:15:00	10.14	4.985	5.063	
2/7/2023	15:16:00	10.144	4.983	4.639	< Direct Mid
2/7/2023	15:17:00	10.143	4.991	4.634	
2/7/2023	15:18:00	10.14	4.987	4.624	
2/7/2023	15:19:00	10.142	4.985	4.643	

2/7/2023	15:20:00	10.145	4.99	4.658
2/7/2023	15:21:00	10.142	5.003	4.661
2/7/2023	15:22:00	10.143	4.989	4.645
2/7/2023	15:23:00	10.145	4.964	4.657
2/7/2023	15:24:00	10.142	4.959	4.65
2/7/2023	15:25:00	10.143	4.953	4.656
2/7/2023	15:26:00	10.144	4.95	4.63
2/7/2023	15:27:00	10.144	4.956	4.641
2/7/2023	15:28:00	10.141	4.978	4.632
2/7/2023	15:29:00	10.142	4.974	4.63
2/7/2023	15:30:00	10.141	4.966	4.643
2/7/2023	15:31:00	10.141	4.954	4.641
2/7/2023	15:32:00	10.139	4.941	4.654
2/7/2023	15:33:00	10.139	4.937	4.649
2/7/2023	15:34:00	10.142	4.948	4.637
2/7/2023	15:35:00	10.142	4.961	4.64
2/7/2023	15:36:00	10.139	4.968	4.645
2/7/2023	15:37:00	10.14	4.95	4.651
2/7/2023	15:38:00	10.14	4.926	4.643
2/7/2023	15:39:00	10.143	4.922	4.637
2/7/2023	15:40:00	10.139	4.923	4.627
2/7/2023	15:41:00	10.139	4.929	4.639
2/7/2023	15:42:00	10.142	4.941	4.634
2/7/2023	15:43:00	10.141	4.96	4.634
2/7/2023	15:44:00	10.14	4.966	4.645
2/7/2023	15:45:00	10.139	4.962	4.643
2/7/2023	15:46:00	10.14	4.954	4.618
2/7/2023	15:47:00	10.141	4.935	4.633
2/7/2023	15:48:00	10.142	4.925	4.646
2/7/2023	15:49:00	10.142	4.915	4.643
2/7/2023	15:50:00	10.142	4.914	4.639
2/7/2023	15:51:00	10.142	4.929	4.662
2/7/2023	15:52:00	10.142	4.94	4.65
2/7/2023	15:53:00	10.143	4.947	4.639
2/7/2023	15:54:00	10.142	4.956	4.641
2/7/2023	15:55:00	10.142	4.959	4.642
2/7/2023	15:56:00	10.141	4.972	4.629
2/7/2023	15:57:00	10.141	4.972	4.635
2/7/2023	15:58:00	10.142	4.96	4.643
2/7/2023	15:59:00	10.142	4.948	4.654
2/7/2023	16:00:00	10.142	4.936	4.633
2/7/2023	16:01:00	10.144	4.943	4.633
2/7/2023	16:02:00	10.143	4.949	4.634
2/7/2023	16:03:00	1.737	0.898	4.08
2/7/2023	16:04:00	-0.052	-0.096	1.27
2/7/2023	16:05:00	-0.053	-0.109	0.224
2/7/2023	16:06:00	-0.012	-0.021	-0.04
2/7/2023	16:07:00	-0.051	-0.114	-0.098
2/7/2023	16:08:00	-0.05	-0.115	-0.122

< Direct Zero

2/7/2023	16:09:00	-0.051	-0.112	-0.135
2/7/2023	16:10:00	-0.053	-0.107	-0.133
2/7/2023	16:11:00	-0.052	-0.106	-0.135
2/7/2023	16:12:00	-0.054	-0.113	-0.123
2/7/2023	16:13:00	-0.053	-0.122	-0.128
2/7/2023	16:14:00	-0.053	-0.126	-0.126
2/7/2023	16:15:00	-0.053	-0.118	-0.132
2/7/2023	16:16:00	-0.054	-0.111	-0.125
2/7/2023	16:17:00	-0.054	-0.103	-0.127
2/7/2023	16:18:00	-0.055	-0.114	-0.139
2/7/2023	16:19:00	-0.055	-0.128	-0.135
2/7/2023	16:20:00	-0.055	-0.127	-0.124
2/7/2023	16:21:00	-0.056	-0.118	-0.129
2/7/2023	16:22:00	-0.055	-0.113	-0.125
2/7/2023	16:23:00	-0.057	-0.108	-0.134
2/7/2023	16:24:00	-0.055	-0.116	-0.117
2/7/2023	16:25:00	-0.053	-0.122	-0.129

Date	Time	O2%	CO2%	CO ppm	
2/8/2023	7:45:00	-0.012	-0.024	-0.018	
2/8/2023	7:46:00	-0.013	-0.015	-0.024	< Direct Zero
2/8/2023	7:47:00	-0.014	-0.012	-0.015	
2/8/2023	7:48:00	1.233	0.243	-0.029	
2/8/2023	7:49:00	19.244	9.625	4.671	
2/8/2023	7:50:00	19.282	9.629	9.662	< Direct High
2/8/2023	7:51:00	13.852	6.765	8.936	
2/8/2023	7:52:00	10.119	4.901	4.932	
2/8/2023	7:53:00	10.219	4.896	4.715	< Direct Mid
2/8/2023	7:54:00	15.935	4.429	3.826	
2/8/2023	7:55:00	15.788	4.322	1.459	
2/8/2023	7:56:00	10.127	4.921	0.612	
2/8/2023	7:57:00	10.092	4.942	-0.079	< System O2, CO2
2/8/2023	7:58:00	3.697	1.7	0.645	
2/8/2023	7:59:00	0.006	0.007	4.438	
2/8/2023	8:00:00	0.001	0.005	4.707	< System CO
2/8/2023	8:01:00	12.61	3.57	3.668	
2/8/2023	8:02:00	15.94	4.433	1.467	
2/8/2023	8:03:00	15.937	4.45	1.431	
2/8/2023	8:04:00	15.944	4.437	1.376	
2/8/2023	8:05:00	15.941	4.427	1.319	
2/8/2023	8:06:00	15.943	4.432	1.285	
2/8/2023	8:07:00	15.949	4.428	1.265	
2/8/2023	8:08:00	15.944	4.431	1.314	
2/8/2023	8:09:00	15.946	4.427	1.327	
2/8/2023	8:10:00	15.943	4.435	1.345	< Start Run 2A 0810
2/8/2023	8:11:00	15.949	4.427	1.375	12
2/8/2023	8:12:00	15.947	4.438	1.358	
2/8/2023	8:13:00	15.944	4.437	1.29	
2/8/2023	8:14:00	15.944	4.431	1.446	
2/8/2023	8:15:00	15.947	4.431	1.304	
2/8/2023	8:16:00	15.953	4.427	1.163	
2/8/2023	8:17:00	15.954	4.426	1.245	
2/8/2023	8:18:00	15.949	4.434	1.294	
2/8/2023	8:19:00	15.951	4.436	1.331	
2/8/2023	8:20:00	15.95	4.434	1.363	
2/8/2023	8:21:00	15.952	4.437	1.279	11
2/8/2023	8:22:00	15.955	4.425	1.268	
2/8/2023	8:23:00	15.953	4.428	1.144	
2/8/2023	8:24:00	15.942	4.435	1.257	
2/8/2023	8:25:00	15.954	4.429	1.397	
2/8/2023	8:26:00	15.93	4.444	1.302	
2/8/2023	8:27:00	15.927	4.441	1.27	
2/8/2023	8:28:00	15.946	4.432	1.282	
2/8/2023	8:29:00	15.962	4.43	1.203	
2/8/2023	8:30:00	15.947	4.447	1.351	
2/8/2023	8:31:00	15.957	4.433	1.271	10
2/8/2023	8:32:00	15.957	4.428	1.3	
2/8/2023	8:33:00	15.95	4.435	1.26	
2/8/2023	8:34:00	15.953	4.426	1.35	
2/8/2023	8:35:00	15.932	4.44	1.284	
2/8/2023	8:36:00	15.946	4.424	1.238	
2/8/2023	8:37:00	15.961	4.418	1.369	
2/8/2023	8:38:00	15.933	4.441	1.322	

2/8/2023	8:39:00	15.94	4.436	1.262	
2/8/2023	8:40:00	15.948	4.437	1.309	
2/8/2023	8:41:00	15.954	4.431	1.285	9
2/8/2023	8:42:00	15.951	4.424	1.307	
2/8/2023	8:43:00	15.93	4.445	1.208	
2/8/2023	8:44:00	15.947	4.428	1.226	
2/8/2023	8:45:00	15.96	4.424	1.226	
2/8/2023	8:46:00	15.95	4.427	1.173	
2/8/2023	8:47:00	15.959	4.422	1.262	
2/8/2023	8:48:00	15.957	4.408	1.257	
2/8/2023	8:49:00	15.952	4.424	1.42	
2/8/2023	8:50:00	15.948	4.437	1.429	
2/8/2023	8:51:00	15.947	4.428	1.279	8
2/8/2023	8:52:00	15.946	4.424	1.273	
2/8/2023	8:53:00	15.946	4.427	1.224	
2/8/2023	8:54:00	15.96	4.414	1.261	
2/8/2023	8:55:00	15.966	4.425	1.059	
2/8/2023	8:56:00	15.961	4.436	1.024	
2/8/2023	8:57:00	15.959	4.43	1.029	
2/8/2023	8:58:00	15.946	4.449	1.374	
2/8/2023	8:59:00	15.939	4.454	1.264	
2/8/2023	9:00:00	15.941	4.466	1.221	
2/8/2023	9:01:00	15.953	4.46	1.325	7
2/8/2023	9:02:00	15.946	4.465	1.365	
2/8/2023	9:03:00	15.952	4.475	1.271	
2/8/2023	9:04:00	15.957	4.469	1.315	
2/8/2023	9:05:00	15.938	4.484	1.424	
2/8/2023	9:06:00	15.931	4.496	1.209	
2/8/2023	9:07:00	15.939	4.493	1.18	
2/8/2023	9:08:00	15.963	4.48	1.182	
2/8/2023	9:09:00	15.958	4.49	1.072	
2/8/2023	9:10:00	15.936	4.522	1.185	
2/8/2023	9:11:00	15.912	4.556	1.154	6
2/8/2023	9:12:00	15.905	4.551	1.134	
2/8/2023	9:13:00	15.947	4.509	1.172	
2/8/2023	9:14:00	15.958	4.494	1.088	
2/8/2023	9:15:00	15.971	4.491	1.055	
2/8/2023	9:16:00	15.953	4.509	1.481	
2/8/2023	9:17:00	15.952	4.513	1.76	
2/8/2023	9:18:00	15.961	4.52	1.416	
2/8/2023	9:19:00	15.955	4.53	1.381	
2/8/2023	9:20:00	15.957	4.529	1.18	
2/8/2023	9:21:00	15.953	4.543	2.052	5
2/8/2023	9:22:00	15.957	4.526	1.92	
2/8/2023	9:23:00	15.959	4.525	1.548	
2/8/2023	9:24:00	15.962	4.534	1.551	
2/8/2023	9:25:00	15.96	4.551	1.557	
2/8/2023	9:26:00	15.961	4.55	1.592	
2/8/2023	9:27:00	15.955	4.556	1.325	
2/8/2023	9:28:00	15.96	4.546	1.63	
2/8/2023	9:29:00	15.957	4.551	1.47	
2/8/2023	9:30:00	15.967	4.542	1.453	
2/8/2023	9:31:00	15.966	4.534	1.496	4
2/8/2023	9:32:00	15.958	4.55	1.181	
2/8/2023	9:33:00	15.962	4.556	1.216	

2/8/2023	9:34:00	15.958	4.564	1.345	
2/8/2023	9:35:00	15.95	4.581	1.355	
2/8/2023	9:36:00	15.961	4.579	1.293	
2/8/2023	9:37:00	15.96	4.57	1.791	
2/8/2023	9:38:00	15.969	4.57	1.398	
2/8/2023	9:39:00	15.962	4.574	1.293	
2/8/2023	9:40:00	15.976	4.559	1.409	
2/8/2023	9:41:00	15.965	4.573	1.209	3
2/8/2023	9:42:00	15.95	4.586	1.589	
2/8/2023	9:43:00	15.943	4.6	1.64	
2/8/2023	9:44:00	15.965	4.576	1.291	
2/8/2023	9:45:00	15.97	4.574	1.11	
2/8/2023	9:46:00	15.975	4.568	1.121	
2/8/2023	9:47:00	15.97	4.587	1.271	
2/8/2023	9:48:00	15.974	4.579	1.195	
2/8/2023	9:49:00	15.974	4.568	1.105	
2/8/2023	9:50:00	15.974	4.576	1.023	
2/8/2023	9:51:00	15.969	4.582	1.126	2
2/8/2023	9:52:00	15.965	4.599	1.968	
2/8/2023	9:53:00	15.971	4.577	1.512	
2/8/2023	9:54:00	15.972	4.594	1.66	
2/8/2023	9:55:00	15.973	4.594	1.714	
2/8/2023	9:56:00	15.966	4.598	1.7	
2/8/2023	9:57:00	15.969	4.597	1.21	
2/8/2023	9:58:00	15.969	4.585	1.162	
2/8/2023	9:59:00	15.968	4.592	1.023	
2/8/2023	10:00:00	15.966	4.605	1.296	
2/8/2023	10:01:00	15.966	4.607	1.247	1
2/8/2023	10:02:00	15.96	4.607	1.179	
2/8/2023	10:03:00	15.966	4.601	1.243	
2/8/2023	10:04:00	15.972	4.602	1.69	
2/8/2023	10:05:00	15.958	4.615	1.636	
2/8/2023	10:06:00	15.97	4.599	1.583	
2/8/2023	10:07:00	15.977	4.582	1.61	
2/8/2023	10:08:00	15.972	4.605	1.642	
2/8/2023	10:09:00	15.959	4.614	1.732	
2/8/2023	10:10:00	15.952	4.611	1.621	
2/8/2023	10:11:00	11.602	4.839	1.225	
2/8/2023	10:12:00	10.093	5.022	-0.058	< System O2, CO2
2/8/2023	10:13:00	8.147	4.087	-0.191	
2/8/2023	10:14:00	-0.002	0.16	3.037	
2/8/2023	10:15:00	-0.013	0.047	4.675	< System CO
2/8/2023	10:16:00	1.933	0.739	4.67	
2/8/2023	10:17:00	15.927	4.579	2.748	
2/8/2023	10:18:00	15.947	4.588	1.605	< Resume Run 2B
2/8/2023	10:19:00	15.945	4.589	2.114	12
2/8/2023	10:20:00	15.953	4.586	1.896	
2/8/2023	10:21:00	15.951	4.583	1.276	
2/8/2023	10:22:00	15.951	4.592	1.515	
2/8/2023	10:23:00	15.947	4.586	1.421	
2/8/2023	10:24:00	15.954	4.576	1.27	
2/8/2023	10:25:00	15.955	4.571	1.053	
2/8/2023	10:26:00	15.95	4.586	1.1	
2/8/2023	10:27:00	15.952	4.586	1.115	
2/8/2023	10:28:00	15.946	4.59	1.598	

2/8/2023	10:29:00	15.956	4.577	1.328	11
2/8/2023	10:30:00	15.956	4.577	1.052	
2/8/2023	10:31:00	15.953	4.583	1.439	
2/8/2023	10:32:00	15.957	4.584	1.15	
2/8/2023	10:33:00	15.952	4.588	1.152	
2/8/2023	10:34:00	15.951	4.592	1.299	
2/8/2023	10:35:00	15.961	4.583	1.092	
2/8/2023	10:36:00	15.962	4.576	0.957	
2/8/2023	10:37:00	15.957	4.593	0.969	
2/8/2023	10:38:00	15.95	4.604	1.123	
2/8/2023	10:39:00	15.951	4.624	1.417	10
2/8/2023	10:40:00	15.955	4.614	1.483	
2/8/2023	10:41:00	15.965	4.594	1.155	
2/8/2023	10:42:00	15.967	4.585	0.964	
2/8/2023	10:43:00	15.968	4.58	0.956	
2/8/2023	10:44:00	15.961	4.597	0.964	
2/8/2023	10:45:00	15.953	4.621	0.989	
2/8/2023	10:46:00	15.956	4.63	1.006	
2/8/2023	10:47:00	15.951	4.635	1.047	
2/8/2023	10:48:00	15.961	4.617	0.98	
2/8/2023	10:49:00	15.955	4.639	1.173	9
2/8/2023	10:50:00	15.958	4.643	1.396	
2/8/2023	10:51:00	15.956	4.63	1.372	
2/8/2023	10:52:00	15.955	4.625	1.28	
2/8/2023	10:53:00	15.966	4.622	1.388	
2/8/2023	10:54:00	15.965	4.639	1.029	
2/8/2023	10:55:00	15.964	4.655	1.263	
2/8/2023	10:56:00	15.946	4.675	1.439	
2/8/2023	10:57:00	15.961	4.65	1.318	
2/8/2023	10:58:00	15.947	4.653	1.342	
2/8/2023	10:59:00	15.961	4.629	1.157	8
2/8/2023	11:00:00	15.968	4.619	1.122	
2/8/2023	11:01:00	15.966	4.626	0.967	
2/8/2023	11:02:00	15.97	4.64	0.976	
2/8/2023	11:03:00	15.953	4.658	1.032	
2/8/2023	11:04:00	15.965	4.657	1.016	
2/8/2023	11:05:00	15.969	4.652	1.26	
2/8/2023	11:06:00	15.979	4.641	1.07	
2/8/2023	11:07:00	15.977	4.64	0.963	
2/8/2023	11:08:00	15.968	4.647	1.02	
2/8/2023	11:09:00	15.946	4.671	1.268	7
2/8/2023	11:10:00	15.957	4.652	1.313	
2/8/2023	11:11:00	15.961	4.649	1.187	
2/8/2023	11:12:00	15.971	4.634	1.264	
2/8/2023	11:13:00	15.974	4.623	1.705	
2/8/2023	11:14:00	15.965	4.648	1.319	
2/8/2023	11:15:00	15.97	4.651	1.409	
2/8/2023	11:16:00	15.972	4.645	1.068	
2/8/2023	11:17:00	15.973	4.632	1.113	
2/8/2023	11:18:00	15.978	4.624	1.003	
2/8/2023	11:19:00	15.966	4.643	0.997	6
2/8/2023	11:20:00	15.97	4.661	1.062	
2/8/2023	11:21:00	15.975	4.653	0.956	
2/8/2023	11:22:00	15.962	4.659	1.012	
2/8/2023	11:23:00	15.975	4.657	1.098	

2/8/2023	11:24:00	15.973	4.657	0.985	
2/8/2023	11:25:00	15.97	4.661	0.944	
2/8/2023	11:26:00	15.965	4.677	1.143	
2/8/2023	11:27:00	15.973	4.684	1.384	
2/8/2023	11:28:00	15.961	4.697	1.205	
2/8/2023	11:29:00	15.972	4.688	1.087	5
2/8/2023	11:30:00	15.981	4.688	0.947	
2/8/2023	11:31:00	15.98	4.689	0.928	
2/8/2023	11:32:00	15.977	4.702	1.077	
2/8/2023	11:33:00	15.974	4.706	1.677	
2/8/2023	11:34:00	15.979	4.699	1.088	
2/8/2023	11:35:00	15.978	4.691	1.178	
2/8/2023	11:36:00	15.985	4.684	1.719	
2/8/2023	11:37:00	15.986	4.687	0.971	
2/8/2023	11:38:00	15.978	4.695	1.03	
2/8/2023	11:39:00	15.978	4.687	0.992	4
2/8/2023	11:40:00	15.975	4.695	0.964	
2/8/2023	11:41:00	15.979	4.689	0.96	
2/8/2023	11:42:00	15.976	4.699	0.994	
2/8/2023	11:43:00	15.985	4.682	0.945	
2/8/2023	11:44:00	15.983	4.683	0.934	
2/8/2023	11:45:00	15.983	4.706	0.935	
2/8/2023	11:46:00	15.977	4.707	1.063	
2/8/2023	11:47:00	15.977	4.696	0.985	
2/8/2023	11:48:00	15.977	4.693	1.073	
2/8/2023	11:49:00	15.978	4.693	1.457	3
2/8/2023	11:50:00	15.994	4.68	0.969	
2/8/2023	11:51:00	15.986	4.687	0.952	
2/8/2023	11:52:00	15.986	4.707	0.993	
2/8/2023	11:53:00	15.992	4.708	1.059	
2/8/2023	11:54:00	15.988	4.701	0.94	
2/8/2023	11:55:00	15.99	4.709	0.947	
2/8/2023	11:56:00	15.983	4.71	0.986	
2/8/2023	11:57:00	15.986	4.696	1.113	
2/8/2023	11:58:00	15.985	4.682	0.988	
2/8/2023	11:59:00	15.988	4.692	0.957	2
2/8/2023	12:00:00	15.989	4.691	1.086	
2/8/2023	12:01:00	15.987	4.687	0.978	
2/8/2023	12:02:00	15.987	4.692	0.951	
2/8/2023	12:03:00	15.985	4.708	0.98	
2/8/2023	12:04:00	15.979	4.709	0.952	
2/8/2023	12:05:00	15.967	4.71	1.016	
2/8/2023	12:06:00	15.974	4.687	1.033	
2/8/2023	12:07:00	15.987	4.665	0.958	
2/8/2023	12:08:00	15.993	4.65	0.961	
2/8/2023	12:09:00	15.986	4.655	0.956	1
2/8/2023	12:10:00	15.995	4.637	0.925	
2/8/2023	12:11:00	15.989	4.643	0.915	
2/8/2023	12:12:00	15.986	4.642	0.942	
2/8/2023	12:13:00	15.976	4.65	0.998	
2/8/2023	12:14:00	15.981	4.632	0.971	
2/8/2023	12:15:00	15.989	4.626	0.94	
2/8/2023	12:16:00	15.993	4.619	0.926	
2/8/2023	12:17:00	16	4.626	0.92	
2/8/2023	12:18:00	15.992	4.646	0.932	< End Run 2

2/8/2023	12:19:00	15.993	4.643	0.967	
2/8/2023	12:20:00	12.286	4.819	0.92	
2/8/2023	12:21:00	10.103	5.027	-0.025	< System O2, CO2
2/8/2023	12:22:00	4.435	2.298	0.365	
2/8/2023	12:23:00	0	0.179	4.319	
2/8/2023	12:24:00	-0.007	0.027	4.664	< System CO
2/8/2023	12:25:00	6.239	1.924	4.515	
2/8/2023	12:26:00	15.992	4.615	1.499	
2/8/2023	12:27:00	16.005	4.614	0.942	
2/8/2023	12:28:00	16	4.626	0.914	
2/8/2023	12:29:00	15.999	4.642	0.95	
2/8/2023	12:30:00	16.001	4.633	0.99	
2/8/2023	12:31:00	15.991	4.648	0.951	
2/8/2023	12:32:00	15.996	4.656	0.936	
2/8/2023	12:33:00	15.996	4.65	0.941	
2/8/2023	12:34:00	15.998	4.653	0.927	
2/8/2023	12:35:00	16.003	4.642	0.919	
2/8/2023	12:36:00	16.002	4.636	0.919	
2/8/2023	12:37:00	15.988	4.658	0.969	
2/8/2023	12:38:00	15.995	4.658	0.966	
2/8/2023	12:39:00	15.994	4.656	1.226	
2/8/2023	12:40:00	16.003	4.638	1.111	
2/8/2023	12:41:00	16.01	4.636	1.017	
2/8/2023	12:42:00	15.997	4.628	1.076	
2/8/2023	12:43:00	16	4.609	1.067	
2/8/2023	12:44:00	16.016	4.583	0.988	
2/8/2023	12:45:00	16	4.578	0.975	
2/8/2023	12:46:00	15.986	4.591	0.976	
2/8/2023	12:47:00	15.999	4.57	0.946	
2/8/2023	12:48:00	15.998	4.578	1.016	
2/8/2023	12:49:00	16.003	4.567	0.963	
2/8/2023	12:50:00	16.006	4.558	0.934	
2/8/2023	12:51:00	15.999	4.56	0.911	
2/8/2023	12:52:00	16.001	4.551	0.931	
2/8/2023	12:53:00	16.018	4.544	0.909	
2/8/2023	12:54:00	15.961	4.589	0.959	
2/8/2023	12:55:00	15.993	4.552	0.936	
2/8/2023	12:56:00	16.009	4.537	0.932	
2/8/2023	12:57:00	16.012	4.544	0.934	
2/8/2023	12:58:00	15.999	4.571	0.986	
2/8/2023	12:59:00	13.218	4.649	0.926	
2/8/2023	13:00:00	10.095	5.011	-0.001	< System O2, CO2
2/8/2023	13:01:00	4.571	2.268	0.349	
2/8/2023	13:02:00	-0.003	0.099	4.321	
2/8/2023	13:03:00	-0.007	0.027	4.647	< System CO
2/8/2023	13:04:00	13.161	3.783	3.432	
2/8/2023	13:05:00	16.007	4.551	0.992	< Start Run 3 13:05
2/8/2023	13:06:00	16.015	4.551	0.906	12
2/8/2023	13:07:00	16.016	4.555	0.91	
2/8/2023	13:08:00	16.019	4.546	0.924	
2/8/2023	13:09:00	16.02	4.546	0.904	
2/8/2023	13:10:00	16.023	4.543	0.9	
2/8/2023	13:11:00	16.012	4.559	0.92	
2/8/2023	13:12:00	16.011	4.552	0.916	
2/8/2023	13:13:00	16.012	4.551	0.899	

2/8/2023	13:14:00	16.019	4.537	0.914	
2/8/2023	13:15:00	16.026	4.533	0.897	
2/8/2023	13:16:00	16.023	4.553	0.963	11
2/8/2023	13:17:00	15.968	4.594	0.992	
2/8/2023	13:18:00	16.011	4.562	0.95	
2/8/2023	13:19:00	16.004	4.557	0.921	
2/8/2023	13:20:00	16.004	4.56	0.922	
2/8/2023	13:21:00	15.999	4.57	0.922	
2/8/2023	13:22:00	15.991	4.584	0.942	
2/8/2023	13:23:00	15.987	4.584	0.949	
2/8/2023	13:24:00	16.004	4.566	0.963	
2/8/2023	13:25:00	16.001	4.571	1.029	
2/8/2023	13:26:00	16.008	4.577	1.036	10
2/8/2023	13:27:00	16.006	4.573	0.954	
2/8/2023	13:28:00	15.993	4.584	1.005	
2/8/2023	13:29:00	15.989	4.587	0.971	
2/8/2023	13:30:00	16.014	4.574	0.94	
2/8/2023	13:31:00	16.019	4.568	0.923	
2/8/2023	13:32:00	16.013	4.583	0.958	
2/8/2023	13:33:00	15.995	4.602	1.011	
2/8/2023	13:34:00	16.002	4.596	0.986	
2/8/2023	13:35:00	16.011	4.581	0.985	
2/8/2023	13:36:00	16.02	4.585	0.935	9
2/8/2023	13:37:00	16.017	4.574	0.914	
2/8/2023	13:38:00	16.009	4.589	0.947	
2/8/2023	13:39:00	16.009	4.597	1.049	
2/8/2023	13:40:00	16.013	4.599	0.915	
2/8/2023	13:41:00	16.013	4.604	0.904	
2/8/2023	13:42:00	16.006	4.607	1.011	
2/8/2023	13:43:00	15.998	4.616	1.003	
2/8/2023	13:44:00	15.997	4.614	0.985	
2/8/2023	13:45:00	16.015	4.602	0.985	
2/8/2023	13:46:00	16.011	4.613	0.904	8
2/8/2023	13:47:00	16.014	4.612	0.918	
2/8/2023	13:48:00	16.017	4.608	0.9	
2/8/2023	13:49:00	16.015	4.605	0.939	
2/8/2023	13:50:00	16.015	4.606	0.975	
2/8/2023	13:51:00	16.003	4.617	0.959	
2/8/2023	13:52:00	16	4.621	0.941	
2/8/2023	13:53:00	16.005	4.615	0.923	
2/8/2023	13:54:00	15.999	4.626	1.235	
2/8/2023	13:55:00	16.012	4.622	0.963	
2/8/2023	13:56:00	16.011	4.622	0.969	7
2/8/2023	13:57:00	16	4.628	0.921	
2/8/2023	13:58:00	16.011	4.623	0.913	
2/8/2023	13:59:00	16.005	4.622	0.931	
2/8/2023	14:00:00	16	4.629	0.93	
2/8/2023	14:01:00	16.001	4.635	0.943	
2/8/2023	14:02:00	16.011	4.623	0.943	
2/8/2023	14:03:00	16.008	4.61	0.926	
2/8/2023	14:04:00	16	4.622	0.904	
2/8/2023	14:05:00	15.998	4.636	0.915	
2/8/2023	14:06:00	16.009	4.628	0.903	6
2/8/2023	14:07:00	16.006	4.626	0.888	
2/8/2023	14:08:00	16.006	4.625	0.925	

2/8/2023	14:09:00	16.01	4.618	0.911	
2/8/2023	14:10:00	16.016	4.622	0.938	
2/8/2023	14:11:00	16.015	4.63	0.916	
2/8/2023	14:12:00	16.011	4.633	0.912	
2/8/2023	14:13:00	16.01	4.64	0.916	
2/8/2023	14:14:00	16.005	4.65	0.943	
2/8/2023	14:15:00	16.005	4.64	0.917	
2/8/2023	14:16:00	16.012	4.623	0.941	5
2/8/2023	14:17:00	16.007	4.619	1.001	
2/8/2023	14:18:00	16.005	4.62	0.985	
2/8/2023	14:19:00	16.012	4.621	1.001	
2/8/2023	14:20:00	16.01	4.617	1.03	
2/8/2023	14:21:00	16.009	4.604	1.048	
2/8/2023	14:22:00	16.01	4.613	1.024	
2/8/2023	14:23:00	16.001	4.618	0.983	
2/8/2023	14:24:00	16.005	4.621	0.984	
2/8/2023	14:25:00	16.004	4.62	0.969	
2/8/2023	14:26:00	16.004	4.617	0.917	4
2/8/2023	14:27:00	15.986	4.635	0.909	
2/8/2023	14:28:00	15.999	4.613	0.938	
2/8/2023	14:29:00	16.002	4.616	0.918	
2/8/2023	14:30:00	16.004	4.619	0.887	
2/8/2023	14:31:00	15.992	4.627	0.91	
2/8/2023	14:32:00	16.001	4.615	0.954	
2/8/2023	14:33:00	16.001	4.622	0.956	
2/8/2023	14:34:00	16.007	4.622	0.912	
2/8/2023	14:35:00	16.003	4.648	0.928	
2/8/2023	14:36:00	16.002	4.649	0.981	3
2/8/2023	14:37:00	15.996	4.641	0.972	
2/8/2023	14:38:00	16.009	4.624	0.923	
2/8/2023	14:39:00	16.004	4.636	0.956	
2/8/2023	14:40:00	16.011	4.625	0.913	
2/8/2023	14:41:00	16.009	4.63	0.921	
2/8/2023	14:42:00	16.006	4.636	0.922	
2/8/2023	14:43:00	16.011	4.617	0.914	
2/8/2023	14:44:00	16.011	4.6	0.943	
2/8/2023	14:45:00	16.007	4.588	0.918	
2/8/2023	14:46:00	16.009	4.587	0.898	2
2/8/2023	14:47:00	16.009	4.575	0.916	
2/8/2023	14:48:00	15.993	4.592	0.922	
2/8/2023	14:49:00	15.993	4.576	0.932	
2/8/2023	14:50:00	16.001	4.577	0.926	
2/8/2023	14:51:00	16.004	4.557	0.932	
2/8/2023	14:52:00	16.002	4.556	0.925	
2/8/2023	14:53:00	16.005	4.557	0.922	
2/8/2023	14:54:00	16.006	4.567	0.959	
2/8/2023	14:55:00	16.015	4.562	0.979	
2/8/2023	14:56:00	16.001	4.565	0.984	1
2/8/2023	14:57:00	15.999	4.56	0.983	
2/8/2023	14:58:00	16.003	4.551	0.98	
2/8/2023	14:59:00	16	4.549	0.93	
2/8/2023	15:00:00	15.996	4.552	0.914	
2/8/2023	15:01:00	16.003	4.55	0.944	
2/8/2023	15:02:00	16.006	4.547	0.947	
2/8/2023	15:03:00	16.011	4.553	0.923	

2/8/2023	15:04:00	16.01	4.556	0.913	
2/8/2023	15:05:00	16.012	4.549	0.919	
2/8/2023	15:06:00	11.139	4.828	0.681	
2/8/2023	15:07:00	10.099	5.012	-0.027	< System O2, CO2
2/8/2023	15:08:00	5.754	2.739	0.099	
2/8/2023	15:09:00	0	0.096	4.067	
2/8/2023	15:10:00	-0.006	0.035	4.641	< System CO
2/8/2023	15:11:00	-0.007	0.083	4.639	
2/8/2023	15:12:00	9.528	3.083	4.003	< Resume Run 3B
2/8/2023	15:13:00	16.05	4.533	0.938	12
2/8/2023	15:14:00	16.057	4.539	0.929	
2/8/2023	15:15:00	16.058	4.539	0.916	
2/8/2023	15:16:00	16.056	4.549	0.933	
2/8/2023	15:17:00	16.052	4.541	0.952	
2/8/2023	15:18:00	16.054	4.539	0.944	
2/8/2023	15:19:00	16.052	4.539	0.922	
2/8/2023	15:20:00	16.044	4.543	0.942	
2/8/2023	15:21:00	16.058	4.541	0.917	
2/8/2023	15:22:00	16.054	4.542	0.925	
2/8/2023	15:23:00	16.057	4.541	0.929	11
2/8/2023	15:24:00	16.052	4.549	0.931	
2/8/2023	15:25:00	16.08	4.531	0.906	
2/8/2023	15:26:00	16.036	4.574	0.907	
2/8/2023	15:27:00	16.044	4.552	0.956	
2/8/2023	15:28:00	16.06	4.537	0.915	
2/8/2023	15:29:00	16.059	4.543	0.912	
2/8/2023	15:30:00	16.068	4.544	0.904	
2/8/2023	15:31:00	16.065	4.556	0.918	
2/8/2023	15:32:00	16.061	4.557	0.91	
2/8/2023	15:33:00	16.06	4.55	0.927	10
2/8/2023	15:34:00	16.061	4.538	0.935	
2/8/2023	15:35:00	16.058	4.527	0.927	
2/8/2023	15:36:00	16.052	4.537	0.929	
2/8/2023	15:37:00	16.06	4.528	0.931	
2/8/2023	15:38:00	16.053	4.538	0.921	
2/8/2023	15:39:00	16.059	4.527	0.957	
2/8/2023	15:40:00	16.052	4.545	0.932	
2/8/2023	15:41:00	16.052	4.544	0.938	
2/8/2023	15:42:00	16.049	4.551	0.921	
2/8/2023	15:43:00	16.046	4.542	0.978	9
2/8/2023	15:44:00	16.037	4.537	0.989	
2/8/2023	15:45:00	16.05	4.53	0.967	
2/8/2023	15:46:00	16.053	4.527	0.917	
2/8/2023	15:47:00	16.052	4.528	0.921	
2/8/2023	15:48:00	16.052	4.526	0.924	
2/8/2023	15:49:00	16.051	4.534	0.913	
2/8/2023	15:50:00	16.042	4.54	0.938	
2/8/2023	15:51:00	16.043	4.525	0.932	
2/8/2023	15:52:00	16.047	4.525	0.933	
2/8/2023	15:53:00	16.063	4.533	0.913	8
2/8/2023	15:54:00	16.018	4.566	0.942	
2/8/2023	15:55:00	16.042	4.535	0.963	
2/8/2023	15:56:00	16.055	4.516	0.95	
2/8/2023	15:57:00	16.056	4.526	1.004	
2/8/2023	15:58:00	16.049	4.527	0.994	

2/8/2023	15:59:00	16.044	4.533	0.951	
2/8/2023	16:00:00	16.038	4.533	0.964	
2/8/2023	16:01:00	16.049	4.519	0.944	
2/8/2023	16:02:00	16.037	4.537	0.959	
2/8/2023	16:03:00	16.051	4.522	0.958	7
2/8/2023	16:04:00	16.047	4.529	0.965	
2/8/2023	16:05:00	16.048	4.529	0.932	
2/8/2023	16:06:00	16.045	4.529	0.924	
2/8/2023	16:07:00	16.038	4.544	0.952	
2/8/2023	16:08:00	16.054	4.525	0.928	
2/8/2023	16:09:00	16.055	4.527	0.929	
2/8/2023	16:10:00	16.028	4.553	0.945	
2/8/2023	16:11:00	16.041	4.547	0.961	
2/8/2023	16:12:00	16.057	4.52	0.951	
2/8/2023	16:13:00	16.078	4.52	0.917	6
2/8/2023	16:14:00	16.007	4.567	0.971	
2/8/2023	16:15:00	16.044	4.534	0.967	
2/8/2023	16:16:00	16.054	4.51	0.957	
2/8/2023	16:17:00	16.055	4.513	0.961	
2/8/2023	16:18:00	16.055	4.528	0.942	
2/8/2023	16:19:00	16.044	4.535	0.938	
2/8/2023	16:20:00	16.047	4.531	0.95	
2/8/2023	16:21:00	16.052	4.512	0.945	
2/8/2023	16:22:00	16.06	4.509	0.937	
2/8/2023	16:23:00	16.055	4.511	0.936	5
2/8/2023	16:24:00	16.047	4.52	0.946	
2/8/2023	16:25:00	16.076	4.526	0.891	
2/8/2023	16:26:00	16.021	4.569	0.946	
2/8/2023	16:27:00	15.996	4.579	0.944	
2/8/2023	16:28:00	15.984	4.556	0.986	
2/8/2023	16:29:00	16.063	4.49	0.92	
2/8/2023	16:30:00	16.009	4.532	0.939	
2/8/2023	16:31:00	15.999	4.567	0.957	
2/8/2023	16:32:00	15.992	4.585	0.964	
2/8/2023	16:33:00	16.004	4.574	1.004	4
2/8/2023	16:34:00	16.014	4.546	0.951	
2/8/2023	16:35:00	16.025	4.54	0.923	
2/8/2023	16:36:00	16.009	4.545	0.958	
2/8/2023	16:37:00	16.008	4.552	0.956	
2/8/2023	16:38:00	16.004	4.559	1.005	
2/8/2023	16:39:00	16.012	4.554	1.007	
2/8/2023	16:40:00	16.021	4.545	0.96	
2/8/2023	16:41:00	16.024	4.531	0.926	
2/8/2023	16:42:00	16.018	4.54	0.968	
2/8/2023	16:43:00	16.01	4.528	1.068	3
2/8/2023	16:44:00	16.053	4.501	1.051	
2/8/2023	16:45:00	16.061	4.505	1.029	
2/8/2023	16:46:00	16.045	4.516	1.015	
2/8/2023	16:47:00	16.043	4.508	0.96	
2/8/2023	16:48:00	16.043	4.499	0.973	
2/8/2023	16:49:00	16.048	4.478	1.064	
2/8/2023	16:50:00	16.051	4.461	1.026	
2/8/2023	16:51:00	16.047	4.458	1.08	
2/8/2023	16:52:00	16.047	4.457	1.047	
2/8/2023	16:53:00	16.049	4.444	1.003	2

2/8/2023	16:54:00	16.049	4.446	0.967	
2/8/2023	16:55:00	16.049	4.441	0.992	
2/8/2023	16:56:00	16.054	4.438	0.958	
2/8/2023	16:57:00	16.051	4.452	0.944	
2/8/2023	16:58:00	16.045	4.467	0.939	
2/8/2023	16:59:00	16.098	4.402	0.923	
2/8/2023	17:00:00	16.073	4.449	0.877	
2/8/2023	17:01:00	16.028	4.534	0.952	
2/8/2023	17:02:00	16.042	4.542	0.963	
2/8/2023	17:03:00	16.04	4.494	0.952	1
2/8/2023	17:04:00	16.042	4.49	0.953	
2/8/2023	17:05:00	16.048	4.473	0.966	
2/8/2023	17:06:00	16.052	4.481	0.955	
2/8/2023	17:07:00	16.048	4.493	0.95	
2/8/2023	17:08:00	16.03	4.51	0.957	
2/8/2023	17:09:00	15.975	4.496	0.954	
2/8/2023	17:10:00	15.993	4.483	0.949	
2/8/2023	17:11:00	15.937	4.756	0.972	
2/8/2023	17:12:00	15.979	4.428	0.952	
2/8/2023	17:13:00	11.264	4.931	1.667	
2/8/2023	17:14:00	10.097	5.015	-0.024	< System O2, CO2
2/8/2023	17:15:00	4.772	2.136	0.315	
2/8/2023	17:16:00	-0.017	0.042	4.138	
2/8/2023	17:17:00	-0.022	0.041	4.668	< System CO
2/8/2023	17:18:00	5.34	1.562	4.588	
2/8/2023	17:19:00	15.978	4.486	1.856	
2/8/2023	17:20:00	13.225	3.948	0.962	
2/8/2023	17:21:00	-0.006	-0.017	0.349	
2/8/2023	17:22:00	-0.006	-0.02	-0.08	< Direct Zero
2/8/2023	17:23:00	-0.004	-0.028	-0.075	
2/8/2023	17:24:00	-0.002	-0.028	-0.065	
2/8/2023	17:25:00	12.266	5.707	0.81	
2/8/2023	17:26:00	19.296	9.082	8.848	
2/8/2023	17:27:00	19.286	9.553	9.59	
2/8/2023	17:28:00	19.282	9.623	9.582	< Direct High
2/8/2023	17:29:00	11.445	5.444	8.262	
2/8/2023	17:30:00	10.124	4.571	4.728	
2/8/2023	17:31:00	10.123	4.567	4.652	
2/8/2023	17:32:00	10.125	4.603	4.644	
2/8/2023	17:33:00	10.126	4.89	4.651	< Direct Mid
2/8/2023	17:34:00	7.997	3.893	4.66	
2/8/2023	17:35:00	-0.023	-0.073	3.374	

Date	Time	O2%	CO2%	CO ppm	
2/9/2023	7:46:00	13.682	7.117	9.549	
2/9/2023	7:47:00	0.001	-0.07	2.764	
2/9/2023	7:48:00	-0.001	-0.07	-0.084	< Direct Zero
2/9/2023	7:49:00	7.637	3.441	0.065	
2/9/2023	7:50:00	19.309	9.665	7.583	
2/9/2023	7:51:00	19.314	9.685	9.617	<, Direct High
2/9/2023	7:52:00	11.047	5.453	7.607	
2/9/2023	7:53:00	10.129	4.926	4.625	< Direct Mid
2/9/2023	7:54:00	10.148	4.931	4.58	
2/9/2023	7:55:00	10.166	4.945	4.556	
2/9/2023	7:56:00	10.172	4.941	4.554	
2/9/2023	7:57:00	14.057	3.811	4.336	
2/9/2023	7:58:00	12.069	4.704	1.227	
2/9/2023	7:59:00	10.098	5.022	-0.032	< System O2, CO2
2/9/2023	8:00:00	1.6	0.759	1.21	
2/9/2023	8:01:00	0.009	0.043	4.397	
2/9/2023	8:02:00	0.007	0.042	4.48	
2/9/2023	8:03:00	0.011	0.039	4.662	< System CO
2/9/2023	8:04:00	11.583	3.291	3.605	
2/9/2023	8:05:00	15.973	4.457	0.958	< Start Run 4 08:05
2/9/2023	8:06:00	15.979	4.465	0.709	12
2/9/2023	8:07:00	15.976	4.476	0.698	
2/9/2023	8:08:00	15.977	4.474	0.753	
2/9/2023	8:09:00	15.982	4.465	0.665	
2/9/2023	8:10:00	15.977	4.469	0.71	
2/9/2023	8:11:00	15.975	4.466	0.633	
2/9/2023	8:12:00	15.979	4.465	0.649	
2/9/2023	8:13:00	15.974	4.474	0.746	
2/9/2023	8:14:00	15.974	4.484	0.891	
2/9/2023	8:15:00	15.975	4.478	0.81	
2/9/2023	8:16:00	15.984	4.462	0.842	11
2/9/2023	8:17:00	15.984	4.457	0.718	
2/9/2023	8:18:00	15.981	4.461	0.716	
2/9/2023	8:19:00	15.978	4.473	0.781	
2/9/2023	8:20:00	15.985	4.46	0.828	
2/9/2023	8:21:00	15.984	4.442	0.735	
2/9/2023	8:22:00	15.976	4.454	0.754	
2/9/2023	8:23:00	15.986	4.432	0.79	
2/9/2023	8:24:00	15.987	4.431	0.735	
2/9/2023	8:25:00	15.983	4.442	0.732	
2/9/2023	8:26:00	15.988	4.433	0.781	10
2/9/2023	8:27:00	15.986	4.422	0.715	
2/9/2023	8:28:00	15.985	4.412	0.796	
2/9/2023	8:29:00	15.979	4.408	0.686	
2/9/2023	8:30:00	15.983	4.407	0.663	
2/9/2023	8:31:00	15.987	4.404	0.641	
2/9/2023	8:32:00	15.977	4.401	0.696	
2/9/2023	8:33:00	15.963	4.423	0.707	
2/9/2023	8:34:00	15.971	4.415	0.68	
2/9/2023	8:35:00	15.972	4.414	0.652	
2/9/2023	8:36:00	15.98	4.403	0.614	9
2/9/2023	8:37:00	15.981	4.407	0.839	
2/9/2023	8:38:00	15.981	4.414	0.81	
2/9/2023	8:39:00	15.986	4.404	0.795	

2/9/2023	8:40:00	15.988	4.388	0.708	
2/9/2023	8:41:00	15.984	4.391	0.725	
2/9/2023	8:42:00	15.98	4.392	0.71	
2/9/2023	8:43:00	15.984	4.391	0.572	
2/9/2023	8:44:00	15.978	4.394	0.664	
2/9/2023	8:45:00	15.987	4.386	0.729	
2/9/2023	8:46:00	15.985	4.384	0.578	8
2/9/2023	8:47:00	15.987	4.382	0.506	
2/9/2023	8:48:00	15.979	4.385	0.638	
2/9/2023	8:49:00	15.975	4.391	0.668	
2/9/2023	8:50:00	15.977	4.401	0.699	
2/9/2023	8:51:00	15.977	4.407	0.691	
2/9/2023	8:52:00	15.969	4.412	0.642	
2/9/2023	8:53:00	15.973	4.411	0.597	
2/9/2023	8:54:00	15.986	4.404	0.575	
2/9/2023	8:55:00	15.958	4.434	0.617	
2/9/2023	8:56:00	15.961	4.423	0.622	7
2/9/2023	8:57:00	15.971	4.415	0.549	
2/9/2023	8:58:00	15.979	4.417	0.703	
2/9/2023	8:59:00	15.984	4.423	0.639	
2/9/2023	9:00:00	15.975	4.415	0.565	
2/9/2023	9:01:00	15.98	4.406	0.569	
2/9/2023	9:02:00	15.972	4.419	0.588	
2/9/2023	9:03:00	15.977	4.423	0.541	
2/9/2023	9:04:00	15.987	4.417	0.481	
2/9/2023	9:05:00	15.979	4.428	0.519	
2/9/2023	9:06:00	15.977	4.422	0.569	6
2/9/2023	9:07:00	15.991	4.409	0.529	
2/9/2023	9:08:00	15.998	4.397	0.396	
2/9/2023	9:09:00	15.992	4.406	0.406	
2/9/2023	9:10:00	15.963	4.439	0.486	
2/9/2023	9:11:00	15.987	4.414	0.507	
2/9/2023	9:12:00	15.989	4.417	0.463	
2/9/2023	9:13:00	15.991	4.419	0.413	
2/9/2023	9:14:00	15.993	4.436	0.492	
2/9/2023	9:15:00	15.993	4.441	0.481	
2/9/2023	9:16:00	15.986	4.443	0.439	5
2/9/2023	9:17:00	15.986	4.44	0.548	
2/9/2023	9:18:00	15.995	4.419	0.424	
2/9/2023	9:19:00	15.988	4.435	0.47	
2/9/2023	9:20:00	15.982	4.437	0.417	
2/9/2023	9:21:00	15.979	4.441	0.569	
2/9/2023	9:22:00	15.973	4.441	0.627	
2/9/2023	9:23:00	15.961	4.449	0.613	
2/9/2023	9:24:00	15.985	4.44	1.353	
2/9/2023	9:25:00	15.932	4.501	1.043	
2/9/2023	9:26:00	15.959	4.488	0.919	4
2/9/2023	9:27:00	15.958	4.473	1.018	
2/9/2023	9:28:00	15.953	4.488	1.865	
2/9/2023	9:29:00	15.978	4.461	1.418	
2/9/2023	9:30:00	15.982	4.462	0.786	
2/9/2023	9:31:00	15.966	4.466	0.846	
2/9/2023	9:32:00	15.981	4.455	1.203	
2/9/2023	9:33:00	15.976	4.438	1.293	
2/9/2023	9:34:00	15.98	4.436	1.223	

2/9/2023	9:35:00	15.976	4.434	2.039	
2/9/2023	9:36:00	15.976	4.416	1.085	3
2/9/2023	9:37:00	15.969	4.406	1.206	
2/9/2023	9:38:00	15.973	4.401	1.369	
2/9/2023	9:39:00	15.983	4.39	0.621	
2/9/2023	9:40:00	15.98	4.397	0.38	
2/9/2023	9:41:00	15.965	4.413	0.41	
2/9/2023	9:42:00	15.979	4.422	0.448	
2/9/2023	9:43:00	15.981	4.427	0.377	
2/9/2023	9:44:00	15.981	4.414	0.34	
2/9/2023	9:45:00	15.982	4.409	0.332	
2/9/2023	9:46:00	15.982	4.406	0.431	2
2/9/2023	9:47:00	15.976	4.415	0.535	
2/9/2023	9:48:00	15.972	4.417	0.681	
2/9/2023	9:49:00	15.979	4.416	0.359	
2/9/2023	9:50:00	15.972	4.432	0.642	
2/9/2023	9:51:00	15.985	4.425	0.61	
2/9/2023	9:52:00	15.985	4.427	0.567	
2/9/2023	9:53:00	15.988	4.434	0.603	
2/9/2023	9:54:00	15.982	4.432	0.771	
2/9/2023	9:55:00	15.973	4.438	0.988	
2/9/2023	9:56:00	15.964	4.44	1.109	1
2/9/2023	9:57:00	15.965	4.432	0.809	
2/9/2023	9:58:00	15.975	4.422	0.635	
2/9/2023	9:59:00	15.978	4.419	0.698	
2/9/2023	10:00:00	15.983	4.422	0.792	
2/9/2023	10:01:00	15.985	4.429	0.647	
2/9/2023	10:02:00	15.984	4.427	0.619	
2/9/2023	10:03:00	15.982	4.424	1.245	
2/9/2023	10:04:00	15.984	4.419	0.708	
2/9/2023	10:05:00	15.98	4.426	0.517	
2/9/2023	10:06:00	15.983	4.423	0.462	
2/9/2023	10:07:00	11.226	4.659	0.2	
2/9/2023	10:08:00	10.107	4.948	-0.088	< System O2, CO2
2/9/2023	10:09:00	5.006	2.329	-0.266	
2/9/2023	10:10:00	0.012	-0.041	3.426	
2/9/2023	10:11:00	1.456	0.376	3.948	
2/9/2023	10:12:00	0.613	0.359	3.983	
2/9/2023	10:13:00	0.001	-0.145	7.494	
2/9/2023	10:14:00	4.37	1.02	9.302	
2/9/2023	10:15:00	16.056	4.401	6.475	
2/9/2023	10:16:00	16.046	4.421	3.435	
2/9/2023	10:17:00	8.679	2.552	1.766	
2/9/2023	10:18:00	-0.011	-0.097	4.037	
2/9/2023	10:19:00	-0.01	-0.01	4.652	< System CO
2/9/2023	10:20:00	12.438	3.409	3.791	
2/9/2023	10:21:00	16.003	4.434	0.665	< Resume
2/9/2023	10:22:00	16	4.44	0.678	12
2/9/2023	10:23:00	16.007	4.431	0.375	
2/9/2023	10:24:00	16.002	4.446	0.442	
2/9/2023	10:25:00	15.98	4.449	0.387	
2/9/2023	10:26:00	15.912	4.504	0.511	
2/9/2023	10:27:00	15.992	4.42	0.366	
2/9/2023	10:28:00	16.001	4.405	0.416	
2/9/2023	10:29:00	16.002	4.381	0.447	

2/9/2023	10:30:00	16	4.386	0.706	
2/9/2023	10:31:00	16.004	4.381	0.387	
2/9/2023	10:32:00	16.003	4.382	0.331	11
2/9/2023	10:33:00	16.002	4.383	0.306	
2/9/2023	10:34:00	16.009	4.383	0.309	
2/9/2023	10:35:00	15.997	4.404	0.302	
2/9/2023	10:36:00	15.989	4.408	0.95	
2/9/2023	10:37:00	16.001	4.409	0.754	
2/9/2023	10:38:00	16.003	4.409	0.505	
2/9/2023	10:39:00	15.994	4.424	0.502	
2/9/2023	10:40:00	16.007	4.423	0.552	
2/9/2023	10:41:00	16.008	4.414	0.372	
2/9/2023	10:42:00	15.997	4.417	0.417	10
2/9/2023	10:43:00	16.006	4.397	0.678	
2/9/2023	10:44:00	16.006	4.415	0.698	
2/9/2023	10:45:00	16.004	4.432	0.503	
2/9/2023	10:46:00	15.991	4.459	0.539	
2/9/2023	10:47:00	16.009	4.443	0.872	
2/9/2023	10:48:00	16.01	4.441	0.497	
2/9/2023	10:49:00	16.009	4.438	0.372	
2/9/2023	10:50:00	16.008	4.44	0.417	
2/9/2023	10:51:00	16.014	4.461	0.377	
2/9/2023	10:52:00	16.009	4.486	0.441	9
2/9/2023	10:53:00	16.014	4.487	0.434	
2/9/2023	10:54:00	16.019	4.48	0.387	
2/9/2023	10:55:00	16.016	4.491	0.431	
2/9/2023	10:56:00	16.018	4.48	0.343	
2/9/2023	10:57:00	16.012	4.486	0.44	
2/9/2023	10:58:00	16.004	4.516	0.454	
2/9/2023	10:59:00	16.005	4.518	0.539	
2/9/2023	11:00:00	16.021	4.498	0.62	
2/9/2023	11:01:00	16.022	4.499	0.363	
2/9/2023	11:02:00	16.02	4.51	0.588	8
2/9/2023	11:03:00	16.025	4.507	0.338	
2/9/2023	11:04:00	16.022	4.509	0.998	
2/9/2023	11:05:00	16.017	4.512	0.443	
2/9/2023	11:06:00	16.011	4.515	0.464	
2/9/2023	11:07:00	16.019	4.514	0.507	
2/9/2023	11:08:00	16.026	4.529	0.329	
2/9/2023	11:09:00	16.016	4.53	0.862	
2/9/2023	11:10:00	16.028	4.52	0.44	
2/9/2023	11:11:00	16.021	4.518	0.395	
2/9/2023	11:12:00	16.023	4.504	0.579	7
2/9/2023	11:13:00	16.024	4.519	0.371	
2/9/2023	11:14:00	16.023	4.529	0.744	
2/9/2023	11:15:00	16.021	4.522	0.628	
2/9/2023	11:16:00	16.034	4.511	0.557	
2/9/2023	11:17:00	16.019	4.521	0.331	
2/9/2023	11:18:00	16.016	4.527	0.32	
2/9/2023	11:19:00	16.023	4.532	0.553	
2/9/2023	11:20:00	16.01	4.541	0.328	
2/9/2023	11:21:00	16.027	4.539	0.316	
2/9/2023	11:22:00	16.022	4.542	0.33	6
2/9/2023	11:23:00	16.021	4.552	0.341	
2/9/2023	11:24:00	16.03	4.533	0.424	

2/9/2023	11:25:00	15.998	4.552	0.399	
2/9/2023	11:26:00	16.004	4.537	0.67	
2/9/2023	11:27:00	16.021	4.519	0.636	
2/9/2023	11:28:00	16.033	4.51	0.365	
2/9/2023	11:29:00	16.023	4.509	0.441	
2/9/2023	11:30:00	16.002	4.52	0.518	
2/9/2023	11:31:00	16.025	4.521	0.928	
2/9/2023	11:32:00	16.011	4.524	0.533	5
2/9/2023	11:33:00	15.995	4.535	0.448	
2/9/2023	11:34:00	16.029	4.499	0.552	
2/9/2023	11:35:00	16.022	4.506	0.738	
2/9/2023	11:36:00	16.003	4.528	0.465	
2/9/2023	11:37:00	16.019	4.499	0.766	
2/9/2023	11:38:00	16.027	4.498	0.501	
2/9/2023	11:39:00	16.014	4.491	0.362	
2/9/2023	11:40:00	15.999	4.479	0.29	
2/9/2023	11:41:00	16.038	4.473	0.395	
2/9/2023	11:42:00	16.018	4.48	0.366	4
2/9/2023	11:43:00	16.034	4.48	0.438	
2/9/2023	11:44:00	16.035	4.493	0.405	
2/9/2023	11:45:00	16.033	4.493	0.528	
2/9/2023	11:46:00	16.028	4.493	0.764	
2/9/2023	11:47:00	16.042	4.494	0.422	
2/9/2023	11:48:00	16.022	4.499	0.413	
2/9/2023	11:49:00	16.031	4.485	0.347	
2/9/2023	11:50:00	16.022	4.491	0.285	
2/9/2023	11:51:00	16.019	4.489	0.298	
2/9/2023	11:52:00	16.017	4.5	0.451	3
2/9/2023	11:53:00	16.015	4.501	0.598	
2/9/2023	11:54:00	16.011	4.489	0.715	
2/9/2023	11:55:00	16.036	4.487	0.82	
2/9/2023	11:56:00	16.038	4.496	0.464	
2/9/2023	11:57:00	16.008	4.523	0.604	
2/9/2023	11:58:00	16.041	4.492	0.363	
2/9/2023	11:59:00	16.019	4.483	0.327	
2/9/2023	12:00:00	16.045	4.49	0.403	
2/9/2023	12:01:00	16.042	4.486	0.566	
2/9/2023	12:02:00	16.023	4.498	0.855	2
2/9/2023	12:03:00	16	4.495	0.618	
2/9/2023	12:04:00	16.037	4.497	0.323	
2/9/2023	12:05:00	16.029	4.494	0.749	
2/9/2023	12:06:00	16.019	4.484	0.639	
2/9/2023	12:07:00	16.012	4.484	0.62	
2/9/2023	12:08:00	16.018	4.483	0.41	
2/9/2023	12:09:00	16.034	4.456	0.416	
2/9/2023	12:10:00	16.039	4.46	0.496	
2/9/2023	12:11:00	16.037	4.473	0.361	
2/9/2023	12:12:00	16.031	4.477	0.563	1
2/9/2023	12:13:00	16.005	4.465	0.502	
2/9/2023	12:14:00	16.039	4.473	0.295	
2/9/2023	12:15:00	16.041	4.476	0.295	
2/9/2023	12:16:00	16.031	4.487	0.406	
2/9/2023	12:17:00	16.042	4.482	0.319	
2/9/2023	12:18:00	16.036	4.478	0.39	
2/9/2023	12:19:00	16.033	4.472	0.274	

2/9/2023	12:20:00	16.038	4.481	0.317	
2/9/2023	12:21:00	16.055	4.472	0.291	
2/9/2023	12:22:00	10.117	5.022	-0.439	
2/9/2023	12:23:00	10.108	5.017	-0.033	< System O2, CO2
2/9/2023	12:24:00	5.616	3.224	1.212	
2/9/2023	12:25:00	-2.003	-0.082	5.754	
2/9/2023	12:26:00	-1.467	-0.092	4.979	
2/9/2023	12:27:00	-0.012	-0.029	4.653	< System CO
2/9/2023	12:28:00	2.199	-0.106	4.672	
2/9/2023	12:29:00	2.743	4.156	4.354	
2/9/2023	12:30:00	15.052	4.417	3.439	
2/9/2023	12:31:00	16.034	4.426	2.761	
2/9/2023	12:32:00	16.034	4.432	2.037	
2/9/2023	12:33:00	15.94	4.445	1.154	
2/9/2023	12:34:00	15.97	4.439	1.147	
2/9/2023	12:35:00	15.926	4.441	1.113	
2/9/2023	12:36:00	15.929	4.44	1.105	
2/9/2023	12:37:00	15.928	4.445	1.152	
2/9/2023	12:38:00	15.951	4.441	1.129	
2/9/2023	12:39:00	15.936	4.438	1.145	
2/9/2023	12:40:00	15.916	4.431	0.871	< Start run 5 1240
2/9/2023	12:41:00	15.887	4.418	0.1	12
2/9/2023	12:42:00	15.917	4.429	0.459	
2/9/2023	12:43:00	15.94	4.424	1.064	
2/9/2023	12:44:00	15.939	4.439	0.936	
2/9/2023	12:45:00	15.969	4.429	0.93	
2/9/2023	12:46:00	15.963	4.434	0.962	
2/9/2023	12:47:00	15.945	4.443	1.007	
2/9/2023	12:48:00	15.955	4.429	1.036	
2/9/2023	12:49:00	15.965	4.422	1	
2/9/2023	12:50:00	15.966	4.416	0.964	
2/9/2023	12:51:00	15.955	4.421	0.953	11
2/9/2023	12:52:00	15.965	4.409	1.285	
2/9/2023	12:53:00	15.965	4.417	1.054	
2/9/2023	12:54:00	15.953	4.42	0.995	
2/9/2023	12:55:00	15.966	4.405	0.957	
2/9/2023	12:56:00	15.958	4.409	1.048	
2/9/2023	12:57:00	15.96	4.417	1.056	
2/9/2023	12:58:00	15.952	4.419	0.951	
2/9/2023	12:59:00	15.962	4.405	0.946	
2/9/2023	13:00:00	15.958	4.402	0.962	
2/9/2023	13:01:00	15.96	4.4	0.956	10
2/9/2023	13:02:00	15.956	4.39	0.966	
2/9/2023	13:03:00	15.954	4.399	0.964	
2/9/2023	13:04:00	15.955	4.393	1.1	
2/9/2023	13:05:00	15.955	4.384	1.004	
2/9/2023	13:06:00	15.954	4.383	1.035	
2/9/2023	13:07:00	15.961	4.375	0.984	
2/9/2023	13:08:00	15.949	4.377	0.971	
2/9/2023	13:09:00	15.954	4.375	1.064	
2/9/2023	13:10:00	15.955	4.374	0.96	
2/9/2023	13:11:00	15.946	4.38	0.923	9
2/9/2023	13:12:00	15.946	4.372	0.93	
2/9/2023	13:13:00	15.948	4.378	0.974	
2/9/2023	13:14:00	15.948	4.369	0.996	

2/9/2023	13:15:00	15.949	4.376	0.976	
2/9/2023	13:16:00	15.949	4.384	0.958	
2/9/2023	13:17:00	15.942	4.379	0.94	
2/9/2023	13:18:00	15.933	4.386	0.97	
2/9/2023	13:19:00	15.936	4.376	0.962	
2/9/2023	13:20:00	15.942	4.355	0.95	
2/9/2023	13:21:00	15.946	4.367	0.948	8
2/9/2023	13:22:00	15.943	4.366	0.959	
2/9/2023	13:23:00	15.936	4.362	0.941	
2/9/2023	13:24:00	15.93	4.372	0.928	
2/9/2023	13:25:00	15.944	4.37	0.931	
2/9/2023	13:26:00	15.94	4.361	0.98	
2/9/2023	13:27:00	15.944	4.359	1.038	
2/9/2023	13:28:00	15.943	4.367	1.009	
2/9/2023	13:29:00	15.954	4.352	0.979	
2/9/2023	13:30:00	15.948	4.351	0.958	
2/9/2023	13:31:00	15.95	4.347	1.093	7
2/9/2023	13:32:00	15.95	4.349	0.979	
2/9/2023	13:33:00	15.942	4.351	1.061	
2/9/2023	13:34:00	15.944	4.348	1.021	
2/9/2023	13:35:00	15.941	4.346	0.931	
2/9/2023	13:36:00	15.938	4.35	1.025	
2/9/2023	13:37:00	15.939	4.349	1.061	
2/9/2023	13:38:00	15.94	4.343	0.951	
2/9/2023	13:39:00	15.92	4.369	0.917	
2/9/2023	13:40:00	15.938	4.353	1	
2/9/2023	13:41:00	15.941	4.348	0.955	6
2/9/2023	13:42:00	15.949	4.341	0.929	
2/9/2023	13:43:00	15.937	4.35	0.933	
2/9/2023	13:44:00	15.939	4.352	0.956	
2/9/2023	13:45:00	15.937	4.355	0.918	
2/9/2023	13:46:00	15.936	4.346	1	
2/9/2023	13:47:00	15.942	4.347	0.919	
2/9/2023	13:48:00	15.948	4.347	0.967	
2/9/2023	13:49:00	15.95	4.35	0.919	
2/9/2023	13:50:00	15.951	4.345	0.909	
2/9/2023	13:51:00	15.944	4.353	0.908	5
2/9/2023	13:52:00	15.929	4.362	0.926	
2/9/2023	13:53:00	15.933	4.356	0.949	
2/9/2023	13:54:00	15.939	4.345	0.93	
2/9/2023	13:55:00	15.945	4.337	0.915	
2/9/2023	13:56:00	15.953	4.332	1.006	
2/9/2023	13:57:00	15.952	4.33	1.043	
2/9/2023	13:58:00	15.961	4.323	0.929	
2/9/2023	13:59:00	15.957	4.333	0.9	
2/9/2023	14:00:00	15.953	4.343	0.913	
2/9/2023	14:01:00	15.946	4.345	0.98	4
2/9/2023	14:02:00	15.941	4.359	1.012	
2/9/2023	14:03:00	15.951	4.347	1.015	
2/9/2023	14:04:00	15.954	4.336	1.014	
2/9/2023	14:05:00	15.959	4.327	0.957	
2/9/2023	14:06:00	15.953	4.327	0.89	
2/9/2023	14:07:00	15.951	4.336	0.999	
2/9/2023	14:08:00	15.959	4.336	0.906	
2/9/2023	14:09:00	15.947	4.341	0.889	

2/9/2023	14:10:00	15.932	4.351	0.949	
2/9/2023	14:11:00	15.941	4.347	0.96	3
2/9/2023	14:12:00	15.944	4.34	0.972	
2/9/2023	14:13:00	15.939	4.344	0.957	
2/9/2023	14:14:00	15.936	4.35	0.929	
2/9/2023	14:15:00	15.939	4.336	1.041	
2/9/2023	14:16:00	15.939	4.338	0.951	
2/9/2023	14:17:00	15.936	4.337	0.915	
2/9/2023	14:18:00	15.938	4.339	0.925	
2/9/2023	14:19:00	15.944	4.337	0.888	
2/9/2023	14:20:00	15.936	4.342	0.971	
2/9/2023	14:21:00	15.949	4.324	0.9	2
2/9/2023	14:22:00	15.942	4.334	0.95	
2/9/2023	14:23:00	15.947	4.336	0.985	
2/9/2023	14:24:00	15.946	4.326	0.913	
2/9/2023	14:25:00	15.944	4.326	0.914	
2/9/2023	14:26:00	15.949	4.329	0.881	
2/9/2023	14:27:00	15.947	4.322	0.998	
2/9/2023	14:28:00	15.951	4.33	0.958	
2/9/2023	14:29:00	15.952	4.331	0.9	
2/9/2023	14:30:00	15.95	4.327	0.892	
2/9/2023	14:31:00	15.956	4.317	0.891	1
2/9/2023	14:32:00	15.943	4.325	0.912	
2/9/2023	14:33:00	15.948	4.329	0.989	
2/9/2023	14:34:00	15.946	4.335	1.365	
2/9/2023	14:35:00	15.932	4.346	1.295	
2/9/2023	14:36:00	15.933	4.332	1.368	
2/9/2023	14:37:00	15.953	4.312	1.013	
2/9/2023	14:38:00	15.95	4.319	0.878	
2/9/2023	14:39:00	15.958	4.314	0.876	
2/9/2023	14:40:00	15.959	4.316	0.86	
2/9/2023	14:41:00	15.957	4.317	0.854	
2/9/2023	14:42:00	15.941	4.326	0.926	
2/9/2023	14:43:00	15.953	4.319	0.882	
2/9/2023	14:44:00	15.949	4.319	0.866	
2/9/2023	14:45:00	15.956	4.324	0.882	
2/9/2023	14:46:00	15.954	4.319	0.898	
2/9/2023	14:47:00	14.953	4.354	0.87	
2/9/2023	14:48:00	10.056	4.871	0.149	
2/9/2023	14:49:00	10.098	4.973	-0.048	< System O2, CO2
2/9/2023	14:50:00	7.216	3.341	-0.167	
2/9/2023	14:51:00	-0.034	-0.106	3.284	
2/9/2023	14:52:00	-0.043	-0.116	4.494	
2/9/2023	14:53:00	-0.044	-0.012	4.639	< System CO
2/9/2023	14:54:00	11.616	3.17	3.899	
2/9/2023	14:55:00	15.937	4.31	1.24	< Resume
2/9/2023	14:56:00	15.935	4.323	1.07	12
2/9/2023	14:57:00	15.936	4.327	1.097	
2/9/2023	14:58:00	15.944	4.325	1.027	
2/9/2023	14:59:00	15.948	4.327	0.979	
2/9/2023	15:00:00	15.95	4.325	1.105	
2/9/2023	15:01:00	15.949	4.318	0.937	
2/9/2023	15:02:00	15.943	4.329	0.927	
2/9/2023	15:03:00	15.941	4.332	1.024	
2/9/2023	15:04:00	15.938	4.331	0.998	

2/9/2023	15:05:00	15.927	4.342	1.031	
2/9/2023	15:06:00	15.93	4.327	1.234	11
2/9/2023	15:07:00	15.946	4.302	1.001	
2/9/2023	15:08:00	15.94	4.325	0.983	
2/9/2023	15:09:00	15.932	4.336	1.114	
2/9/2023	15:10:00	15.946	4.322	1.421	
2/9/2023	15:11:00	15.949	4.318	0.966	
2/9/2023	15:12:00	15.944	4.324	1.006	
2/9/2023	15:13:00	15.931	4.336	1.046	
2/9/2023	15:14:00	15.931	4.337	1.121	
2/9/2023	15:15:00	15.945	4.325	1.671	
2/9/2023	15:16:00	15.933	4.324	1.15	10
2/9/2023	15:17:00	15.954	4.3	1.181	
2/9/2023	15:18:00	15.941	4.332	0.94	
2/9/2023	15:19:00	15.944	4.319	0.985	
2/9/2023	15:20:00	15.952	4.307	1.056	
2/9/2023	15:21:00	15.942	4.311	1.013	
2/9/2023	15:22:00	15.955	4.289	1.042	
2/9/2023	15:23:00	15.957	4.291	0.991	
2/9/2023	15:24:00	15.945	4.301	0.887	
2/9/2023	15:25:00	15.945	4.3	0.924	
2/9/2023	15:26:00	15.948	4.303	0.965	9
2/9/2023	15:27:00	15.926	4.326	0.907	
2/9/2023	15:28:00	15.918	4.322	1.088	
2/9/2023	15:29:00	15.927	4.322	0.973	
2/9/2023	15:30:00	15.936	4.312	1.188	
2/9/2023	15:31:00	15.952	4.31	1.332	
2/9/2023	15:32:00	15.946	4.322	1.015	
2/9/2023	15:33:00	15.949	4.321	0.94	
2/9/2023	15:34:00	15.957	4.317	0.945	
2/9/2023	15:35:00	15.958	4.318	0.894	
2/9/2023	15:36:00	15.949	4.323	0.898	8
2/9/2023	15:37:00	15.928	4.342	0.923	
2/9/2023	15:38:00	15.944	4.323	0.918	
2/9/2023	15:39:00	15.947	4.322	0.995	
2/9/2023	15:40:00	15.936	4.335	1	
2/9/2023	15:41:00	15.942	4.327	1.44	
2/9/2023	15:42:00	15.948	4.321	0.921	
2/9/2023	15:43:00	15.944	4.34	0.955	
2/9/2023	15:44:00	15.944	4.337	0.979	
2/9/2023	15:45:00	15.943	4.339	1.02	
2/9/2023	15:46:00	15.937	4.342	1.039	7
2/9/2023	15:47:00	15.934	4.346	1.001	
2/9/2023	15:48:00	15.942	4.332	0.932	
2/9/2023	15:49:00	15.942	4.339	1.059	
2/9/2023	15:50:00	15.945	4.333	1.193	
2/9/2023	15:51:00	15.956	4.318	1.061	
2/9/2023	15:52:00	15.951	4.329	0.941	
2/9/2023	15:53:00	15.956	4.325	0.909	
2/9/2023	15:54:00	15.946	4.332	1.048	
2/9/2023	15:55:00	15.946	4.346	0.924	
2/9/2023	15:56:00	15.937	4.349	0.991	6
2/9/2023	15:57:00	15.947	4.341	1.007	
2/9/2023	15:58:00	15.939	4.342	1.102	
2/9/2023	15:59:00	15.948	4.353	1.198	

2/9/2023	16:00:00	15.944	4.359	1.168	
2/9/2023	16:01:00	15.941	4.345	1.438	
2/9/2023	16:02:00	15.941	4.343	1.185	
2/9/2023	16:03:00	15.927	4.362	1.219	
2/9/2023	16:04:00	15.951	4.348	1.005	
2/9/2023	16:05:00	15.949	4.348	0.943	
2/9/2023	16:06:00	15.947	4.347	1.025	5
2/9/2023	16:07:00	15.937	4.359	0.939	
2/9/2023	16:08:00	15.942	4.354	0.955	
2/9/2023	16:09:00	15.94	4.361	0.979	
2/9/2023	16:10:00	15.934	4.352	1.304	
2/9/2023	16:11:00	15.938	4.344	1.028	
2/9/2023	16:12:00	15.925	4.357	1.068	
2/9/2023	16:13:00	15.927	4.368	1.147	
2/9/2023	16:14:00	15.948	4.36	1.076	
2/9/2023	16:15:00	15.939	4.364	0.992	
2/9/2023	16:16:00	15.941	4.361	0.941	4
2/9/2023	16:17:00	15.941	4.364	1.028	
2/9/2023	16:18:00	15.944	4.348	1.009	
2/9/2023	16:19:00	15.933	4.356	1.08	
2/9/2023	16:20:00	15.935	4.362	1.085	
2/9/2023	16:21:00	15.93	4.368	1.029	
2/9/2023	16:22:00	15.938	4.357	1.159	
2/9/2023	16:23:00	15.942	4.345	1.035	
2/9/2023	16:24:00	15.951	4.343	1.036	
2/9/2023	16:25:00	15.935	4.36	0.934	
2/9/2023	16:26:00	15.943	4.36	0.92	3
2/9/2023	16:27:00	15.946	4.349	0.928	
2/9/2023	16:28:00	15.943	4.356	1.027	
2/9/2023	16:29:00	15.937	4.353	1.081	
2/9/2023	16:30:00	15.944	4.358	0.947	
2/9/2023	16:31:00	15.947	4.336	0.987	
2/9/2023	16:32:00	15.94	4.335	0.973	
2/9/2023	16:33:00	15.937	4.341	1.011	
2/9/2023	16:34:00	15.945	4.333	0.984	
2/9/2023	16:35:00	15.939	4.333	1.41	
2/9/2023	16:36:00	15.937	4.334	1.313	2
2/9/2023	16:37:00	15.923	4.341	1.22	
2/9/2023	16:38:00	15.935	4.319	1.182	
2/9/2023	16:39:00	15.926	4.324	1.095	
2/9/2023	16:40:00	15.948	4.325	1.029	
2/9/2023	16:41:00	15.94	4.336	1.044	
2/9/2023	16:42:00	15.941	4.34	1.02	
2/9/2023	16:43:00	15.932	4.34	0.94	
2/9/2023	16:44:00	15.933	4.335	0.952	
2/9/2023	16:45:00	15.938	4.316	0.994	
2/9/2023	16:46:00	15.923	4.327	1.157	1
2/9/2023	16:47:00	15.932	4.33	1.071	
2/9/2023	16:48:00	15.941	4.323	1.415	
2/9/2023	16:49:00	15.937	4.322	1.228	
2/9/2023	16:50:00	15.933	4.329	0.999	
2/9/2023	16:51:00	15.933	4.321	1.092	
2/9/2023	16:52:00	15.945	4.302	1.301	
2/9/2023	16:53:00	15.947	4.293	1.006	
2/9/2023	16:54:00	15.938	4.298	1.015	

2/9/2023	16:55:00	14.749	4.236	1.045
2/9/2023	16:56:00	11.264	4.716	0.378
2/9/2023	16:57:00	10.097	4.932	-0.027
2/9/2023	16:58:00	3.69	1.987	0.028
2/9/2023	16:59:00	-0.009	-0.2	3.806
2/9/2023	17:00:00	-0.01	-0.019	4.645
2/9/2023	17:01:00	-0.009	-0.015	4.632
2/9/2023	17:02:00	12.186	5.164	4.1
2/9/2023	17:03:00	19.294	9.646	7.687
2/9/2023	17:04:00	19.3	9.629	9.637
2/9/2023	17:05:00	18.776	9.38	9.683
2/9/2023	17:06:00	10.106	4.917	6.969
2/9/2023	17:07:00	10.098	4.92	4.703
2/9/2023	17:08:00	6.578	3.453	4.681
2/9/2023	17:09:00	-0.038	-0.001	1.438
2/9/2023	17:10:00	-0.037	-0.009	-0.041

Date	Time	O2%	CO2%	CO ppm	
2/10/2023	7:33:00	2.379	0.275	1.326	
2/10/2023	7:34:00	-0.048	-0.01	0.341	
2/10/2023	7:35:00	-0.045	-0.028	-0.063	
2/10/2023	7:36:00	-0.033	-0.039	-0.065	< Direct Zero
2/10/2023	7:37:00	14.024	6.668	1.988	
2/10/2023	7:38:00	19.286	9.641	9.753	
2/10/2023	7:39:00	19.289	9.646	9.597	
2/10/2023	7:40:00	19.291	9.634	9.665	< Direct High
2/10/2023	7:41:00	10.37	5.064	6.661	
2/10/2023	7:42:00	10.112	4.908	4.624	< Direct Mid
2/10/2023	7:43:00	14.292	4.496	3.913	
2/10/2023	7:44:00	10.143	4.935	0.324	
2/10/2023	7:45:00	10.106	4.941	-0.01	< System O2, CO2
2/10/2023	7:46:00	1.837	0.971	1.22	
2/10/2023	7:47:00	-0.01	-0.069	4.399	
2/10/2023	7:48:00	-0.011	-0.069	4.607	< System CO
2/10/2023	7:49:00	14.905	4.075	3.353	
2/10/2023	7:50:00	15.965	4.42	1.056	< Start Run 6
2/10/2023	7:51:00	15.96	4.429	1.011	12
2/10/2023	7:52:00	15.962	4.428	0.831	
2/10/2023	7:53:00	15.95	4.435	1.04	
2/10/2023	7:54:00	15.96	4.433	1.029	
2/10/2023	7:55:00	15.956	4.439	0.91	
2/10/2023	7:56:00	15.962	4.435	0.897	
2/10/2023	7:57:00	15.969	4.448	0.848	
2/10/2023	7:58:00	15.957	4.474	0.779	
2/10/2023	7:59:00	15.956	4.466	0.963	
2/10/2023	8:00:00	15.947	4.473	0.938	
2/10/2023	8:01:00	15.969	4.464	0.825	11
2/10/2023	8:02:00	15.96	4.467	0.806	
2/10/2023	8:03:00	15.954	4.472	0.701	
2/10/2023	8:04:00	15.952	4.477	0.77	
2/10/2023	8:05:00	15.958	4.478	0.785	
2/10/2023	8:06:00	15.959	4.493	0.772	
2/10/2023	8:07:00	15.962	4.479	0.717	
2/10/2023	8:08:00	15.958	4.481	1.015	
2/10/2023	8:09:00	15.954	4.489	0.737	
2/10/2023	8:10:00	15.965	4.478	0.631	
2/10/2023	8:11:00	15.97	4.474	0.719	10
2/10/2023	8:12:00	15.966	4.483	0.673	
2/10/2023	8:13:00	15.949	4.519	0.69	
2/10/2023	8:14:00	15.952	4.512	0.743	
2/10/2023	8:15:00	15.961	4.497	0.628	
2/10/2023	8:16:00	15.968	4.498	0.689	
2/10/2023	8:17:00	15.977	4.499	0.703	
2/10/2023	8:18:00	15.973	4.489	0.684	
2/10/2023	8:19:00	15.962	4.494	0.636	
2/10/2023	8:20:00	15.97	4.489	0.699	
2/10/2023	8:21:00	15.97	4.503	0.648	9
2/10/2023	8:22:00	15.969	4.517	0.55	
2/10/2023	8:23:00	15.96	4.509	0.579	
2/10/2023	8:24:00	15.974	4.49	0.628	
2/10/2023	8:25:00	15.97	4.498	0.609	
2/10/2023	8:26:00	15.965	4.508	0.556	

2/10/2023	8:27:00	15.965	4.509	0.482	
2/10/2023	8:28:00	15.978	4.5	0.546	
2/10/2023	8:29:00	15.971	4.512	0.619	
2/10/2023	8:30:00	15.98	4.515	0.619	
2/10/2023	8:31:00	15.973	4.519	0.631	8
2/10/2023	8:32:00	15.963	4.515	0.536	
2/10/2023	8:33:00	15.975	4.501	0.504	
2/10/2023	8:34:00	15.974	4.496	0.524	
2/10/2023	8:35:00	15.965	4.501	0.499	
2/10/2023	8:36:00	15.975	4.498	0.583	
2/10/2023	8:37:00	15.978	4.506	0.576	
2/10/2023	8:38:00	15.972	4.52	0.513	
2/10/2023	8:39:00	15.973	4.525	0.598	
2/10/2023	8:40:00	15.968	4.528	0.52	
2/10/2023	8:41:00	15.98	4.51	0.46	7
2/10/2023	8:42:00	15.978	4.5	0.495	
2/10/2023	8:43:00	15.973	4.492	0.572	
2/10/2023	8:44:00	15.983	4.491	0.439	
2/10/2023	8:45:00	15.97	4.521	0.43	
2/10/2023	8:46:00	15.973	4.532	0.522	
2/10/2023	8:47:00	15.967	4.53	0.531	
2/10/2023	8:48:00	15.98	4.514	0.522	
2/10/2023	8:49:00	15.978	4.522	0.596	
2/10/2023	8:50:00	15.973	4.525	0.6	
2/10/2023	8:51:00	15.962	4.52	0.42	6
2/10/2023	8:52:00	15.982	4.497	0.489	
2/10/2023	8:53:00	15.975	4.52	0.353	
2/10/2023	8:54:00	15.979	4.525	0.429	
2/10/2023	8:55:00	15.981	4.52	0.423	
2/10/2023	8:56:00	15.985	4.513	0.428	
2/10/2023	8:57:00	15.988	4.513	0.377	
2/10/2023	8:58:00	15.98	4.524	0.325	
2/10/2023	8:59:00	15.983	4.526	0.437	
2/10/2023	9:00:00	15.983	4.528	0.43	
2/10/2023	9:01:00	15.983	4.539	0.488	5
2/10/2023	9:02:00	15.985	4.528	0.459	
2/10/2023	9:03:00	15.994	4.517	0.464	
2/10/2023	9:04:00	15.988	4.523	0.396	
2/10/2023	9:05:00	15.975	4.518	0.255	
2/10/2023	9:06:00	15.967	4.534	0.464	
2/10/2023	9:07:00	15.976	4.54	0.395	
2/10/2023	9:08:00	15.983	4.54	0.423	
2/10/2023	9:09:00	15.981	4.542	0.462	
2/10/2023	9:10:00	15.986	4.533	0.551	
2/10/2023	9:11:00	15.988	4.513	0.499	4
2/10/2023	9:12:00	15.979	4.506	0.495	
2/10/2023	9:13:00	15.978	4.502	0.384	
2/10/2023	9:14:00	15.973	4.525	0.383	
2/10/2023	9:15:00	15.973	4.548	0.67	
2/10/2023	9:16:00	15.977	4.551	0.924	
2/10/2023	9:17:00	15.982	4.552	0.662	
2/10/2023	9:18:00	15.977	4.559	0.539	
2/10/2023	9:19:00	15.978	4.555	0.991	
2/10/2023	9:20:00	15.991	4.546	0.887	
2/10/2023	9:21:00	15.973	4.565	0.861	3

2/10/2023	9:22:00	15.988	4.549	0.855	
2/10/2023	9:23:00	15.975	4.557	0.867	
2/10/2023	9:24:00	15.977	4.567	0.848	
2/10/2023	9:25:00	15.985	4.556	0.671	
2/10/2023	9:26:00	15.97	4.577	0.816	
2/10/2023	9:27:00	15.992	4.564	0.628	
2/10/2023	9:28:00	15.999	4.572	1.089	
2/10/2023	9:29:00	16.002	4.58	-0.017	
2/10/2023	9:30:00	15.984	4.603	0.983	
2/10/2023	9:31:00	15.966	4.601	0.794	2
2/10/2023	9:32:00	15.971	4.61	0.492	
2/10/2023	9:33:00	15.94	4.646	0.622	
2/10/2023	9:34:00	15.994	4.596	0.6	
2/10/2023	9:35:00	15.984	4.601	1.015	
2/10/2023	9:36:00	16	4.587	0.999	
2/10/2023	9:37:00	15.998	4.572	1.333	
2/10/2023	9:38:00	15.995	4.575	0.675	
2/10/2023	9:39:00	15.996	4.586	0.439	
2/10/2023	9:40:00	15.976	4.617	0.387	
2/10/2023	9:41:00	15.961	4.64	0.605	1
2/10/2023	9:42:00	15.983	4.623	0.751	
2/10/2023	9:43:00	15.984	4.599	0.888	
2/10/2023	9:44:00	15.997	4.582	0.599	
2/10/2023	9:45:00	16.013	4.58	0.858	
2/10/2023	9:46:00	15.985	4.549	0.488	
2/10/2023	9:47:00	15.978	4.646	0.761	
2/10/2023	9:48:00	15.982	4.497	0.883	
2/10/2023	9:49:00	16.011	4.597	1.009	
2/10/2023	9:50:00	15.989	4.604	0.792	
2/10/2023	9:51:00	11.31	4.885	0.269	
2/10/2023	9:52:00	10.111	5.003	-0.037	< System O2, CO2
2/10/2023	9:53:00	7.252	3.908	0.088	
2/10/2023	9:54:00	-0.017	0.066	3.908	
2/10/2023	9:55:00	-0.017	0.003	4.675	< System CO
2/10/2023	9:56:00	14.122	3.891	3.893	
2/10/2023	9:57:00	15.981	4.618	1.757	
2/10/2023	9:58:00	15.959	4.632	1.358	
2/10/2023	9:59:00	16.01	4.573	0.42	
2/10/2023	10:00:00	15.998	4.573	0.186	< Resume
2/10/2023	10:01:00	16.006	4.576	0.331	12
2/10/2023	10:02:00	16.01	4.574	0.556	
2/10/2023	10:03:00	15.961	4.595	0.418	
2/10/2023	10:04:00	15.995	4.582	0.282	
2/10/2023	10:05:00	15.997	4.566	0.106	
2/10/2023	10:06:00	15.989	4.573	0.352	
2/10/2023	10:07:00	15.98	4.584	0.232	
2/10/2023	10:08:00	15.981	4.582	0.417	
2/10/2023	10:09:00	16.013	4.553	0.509	
2/10/2023	10:10:00	16	4.564	0.657	
2/10/2023	10:11:00	15.999	4.557	0.173	11
2/10/2023	10:12:00	15.983	4.561	0.146	
2/10/2023	10:13:00	15.993	4.556	0.14	
2/10/2023	10:14:00	16.003	4.561	0.213	
2/10/2023	10:15:00	15.986	4.579	0.166	
2/10/2023	10:16:00	16.005	4.554	-0.052	

2/10/2023	10:17:00	15.998	4.567	-0.055	
2/10/2023	10:18:00	15.997	4.564	0.148	
2/10/2023	10:19:00	15.984	4.576	0.27	
2/10/2023	10:20:00	15.984	4.578	0.154	
2/10/2023	10:21:00	15.992	4.564	0.116	10
2/10/2023	10:22:00	16.012	4.549	0.508	
2/10/2023	10:23:00	16.012	4.537	0.146	
2/10/2023	10:24:00	16.002	4.524	0.486	
2/10/2023	10:25:00	15.998	4.538	0.05	
2/10/2023	10:26:00	15.979	4.57	0.243	
2/10/2023	10:27:00	15.973	4.556	-0.054	
2/10/2023	10:28:00	15.991	4.558	0.057	
2/10/2023	10:29:00	16.006	4.53	0.066	
2/10/2023	10:30:00	15.988	4.536	0.125	
2/10/2023	10:31:00	15.983	4.547	0.422	9
2/10/2023	10:32:00	15.984	4.541	0.034	
2/10/2023	10:33:00	15.978	4.54	0.082	
2/10/2023	10:34:00	15.971	4.536	0.051	
2/10/2023	10:35:00	15.981	4.532	-0.031	
2/10/2023	10:36:00	16.013	4.472	0.433	
2/10/2023	10:37:00	16.005	4.468	0.056	
2/10/2023	10:38:00	15.996	4.474	0.338	
2/10/2023	10:39:00	16.012	4.477	-0.035	
2/10/2023	10:40:00	16.011	4.483	-0.025	
2/10/2023	10:41:00	16.01	4.489	0.073	8
2/10/2023	10:42:00	16	4.492	-0.108	
2/10/2023	10:43:00	15.983	4.495	0.175	
2/10/2023	10:44:00	15.981	4.5	0.12	
2/10/2023	10:45:00	15.98	4.502	0.028	
2/10/2023	10:46:00	16.015	4.503	0.026	
2/10/2023	10:47:00	15.978	4.547	0.278	
2/10/2023	10:48:00	15.967	4.556	-0.077	
2/10/2023	10:49:00	15.973	4.541	-0.143	
2/10/2023	10:50:00	15.993	4.518	0.025	
2/10/2023	10:51:00	16.011	4.502	0.346	7
2/10/2023	10:52:00	16.008	4.521	0.057	
2/10/2023	10:53:00	15.958	4.564	0.239	
2/10/2023	10:54:00	15.995	4.506	0.214	
2/10/2023	10:55:00	16.022	4.5	0.341	
2/10/2023	10:56:00	16.017	4.518	-0.12	
2/10/2023	10:57:00	16.006	4.533	0.127	
2/10/2023	10:58:00	15.964	4.567	0.06	
2/10/2023	10:59:00	15.994	4.545	0.006	
2/10/2023	11:00:00	15.988	4.54	0.029	
2/10/2023	11:01:00	15.914	4.59	0.078	6
2/10/2023	11:02:00	15.984	4.539	0.209	
2/10/2023	11:03:00	16.015	4.514	0.728	
2/10/2023	11:04:00	16.026	4.527	0.134	
2/10/2023	11:05:00	16.028	4.522	0.117	
2/10/2023	11:06:00	16.02	4.522	0.1	
2/10/2023	11:07:00	16.034	4.515	1.015	
2/10/2023	11:08:00	16.014	4.529	0.317	
2/10/2023	11:09:00	15.992	4.554	0.309	
2/10/2023	11:10:00	16.014	4.551	0.254	
2/10/2023	11:11:00	16.008	4.568	0.449	5

2/10/2023	11:12:00	16.014	4.559	0.727	
2/10/2023	11:13:00	16	4.564	0.386	
2/10/2023	11:14:00	16.007	4.559	0.072	
2/10/2023	11:15:00	16.029	4.543	0.265	
2/10/2023	11:16:00	16.007	4.565	0.123	
2/10/2023	11:17:00	16.018	4.567	0.493	
2/10/2023	11:18:00	16.017	4.561	0.028	
2/10/2023	11:19:00	16.033	4.552	0.155	
2/10/2023	11:20:00	16.026	4.56	0.17	
2/10/2023	11:21:00	16.019	4.555	0.145	4
2/10/2023	11:22:00	16.017	4.563	0.078	
2/10/2023	11:23:00	16.022	4.571	0.067	
2/10/2023	11:24:00	16.024	4.573	0.112	
2/10/2023	11:25:00	16.021	4.558	0.155	
2/10/2023	11:26:00	16.019	4.549	0.101	
2/10/2023	11:27:00	16.022	4.548	0.093	
2/10/2023	11:28:00	16.02	4.57	0.044	
2/10/2023	11:29:00	16.028	4.569	0.097	
2/10/2023	11:30:00	16.021	4.584	0.089	
2/10/2023	11:31:00	16.02	4.586	0.076	3
2/10/2023	11:32:00	16.023	4.579	0.137	
2/10/2023	11:33:00	16.028	4.579	0.152	
2/10/2023	11:34:00	16.028	4.554	0.164	
2/10/2023	11:35:00	16.029	4.559	0.121	
2/10/2023	11:36:00	16.023	4.579	0.055	
2/10/2023	11:37:00	16.016	4.593	0.168	
2/10/2023	11:38:00	16.016	4.589	0.453	
2/10/2023	11:39:00	16.026	4.569	0.073	
2/10/2023	11:40:00	16.026	4.568	0.03	
2/10/2023	11:41:00	16.026	4.564	0.271	2
2/10/2023	11:42:00	16.027	4.566	0.316	
2/10/2023	11:43:00	16.033	4.566	0.001	
2/10/2023	11:44:00	16.03	4.554	0.049	
2/10/2023	11:45:00	16.023	4.543	0.106	
2/10/2023	11:46:00	16.029	4.539	0.119	
2/10/2023	11:47:00	16.019	4.556	0.085	
2/10/2023	11:48:00	16.029	4.552	0.356	
2/10/2023	11:49:00	16.027	4.561	0.049	
2/10/2023	11:50:00	16.027	4.56	0.144	
2/10/2023	11:51:00	16.026	4.55	0.009	1
2/10/2023	11:52:00	16.022	4.547	0.164	
2/10/2023	11:53:00	16.016	4.565	0.068	
2/10/2023	11:54:00	16.018	4.569	0.167	
2/10/2023	11:55:00	16.022	4.575	0.127	
2/10/2023	11:56:00	16.013	4.598	0.059	
2/10/2023	11:57:00	16.022	4.581	0.185	
2/10/2023	11:58:00	16.027	4.555	0.191	
2/10/2023	11:59:00	16.015	4.594	0.249	
2/10/2023	12:00:00	16.13	4.097	0.585	
2/10/2023	12:01:00	14.122	5.111	0.115	
2/10/2023	12:02:00	10.122	5.001	-0.007	< System O2, CO2
2/10/2023	12:03:00	10.123	5.133	-0.014	
2/10/2023	12:04:00	15.773	4.622	0.619	
2/10/2023	12:05:00	16	4.579	1.197	
2/10/2023	12:06:00	15.99	4.579	1.054	

2/10/2023	12:07:00	15.985	4.558	0.201	
2/10/2023	12:08:00	15.982	4.553	0.154	
2/10/2023	12:09:00	15.981	4.559	0.144	
2/10/2023	12:10:00	13.245	3.95	0.093	
2/10/2023	12:11:00	-0.001	0.021	3.283	
2/10/2023	12:12:00	-0.002	0.019	4.786	
2/10/2023	12:13:00	0	0.008	4.632	< System CO
2/10/2023	12:14:00	12.88	3.565	3.947	
2/10/2023	12:15:00	16.037	4.545	0.844	< Start Run 7 1215
2/10/2023	12:16:00	16.031	4.552	0.052	12
2/10/2023	12:17:00	16.036	4.555	0.045	
2/10/2023	12:18:00	16.029	4.564	0.017	
2/10/2023	12:19:00	16.035	4.561	0.017	
2/10/2023	12:20:00	16.022	4.578	0.119	
2/10/2023	12:21:00	16.036	4.565	0.029	
2/10/2023	12:22:00	16.039	4.547	0.024	
2/10/2023	12:23:00	16.04	4.55	0.082	
2/10/2023	12:24:00	16.029	4.587	0.048	
2/10/2023	12:25:00	16.032	4.584	0.059	
2/10/2023	12:26:00	16.032	4.589	0.034	11
2/10/2023	12:27:00	16.022	4.591	0.08	
2/10/2023	12:28:00	16.02	4.581	0.045	
2/10/2023	12:29:00	16.016	4.57	0.128	
2/10/2023	12:30:00	16.037	4.552	0.302	
2/10/2023	12:31:00	16.035	4.549	0.401	
2/10/2023	12:32:00	16.036	4.564	0.361	
2/10/2023	12:33:00	16.021	4.576	0.175	
2/10/2023	12:34:00	16.04	4.563	0.547	
2/10/2023	12:35:00	16.044	4.579	0.043	
2/10/2023	12:36:00	16.023	4.59	0.06	10
2/10/2023	12:37:00	16.026	4.577	0.133	
2/10/2023	12:38:00	16.037	4.57	0.006	
2/10/2023	12:39:00	16.021	4.581	0.181	
2/10/2023	12:40:00	16.032	4.566	0.019	
2/10/2023	12:41:00	16.031	4.585	0.044	
2/10/2023	12:42:00	16.049	4.568	0.025	
2/10/2023	12:43:00	16.049	4.578	0.064	
2/10/2023	12:44:00	16.033	4.601	0.125	
2/10/2023	12:45:00	16.038	4.608	0.015	
2/10/2023	12:46:00	16.022	4.622	0.252	9
2/10/2023	12:47:00	16.041	4.622	0.014	
2/10/2023	12:48:00	16.039	4.643	0.346	
2/10/2023	12:49:00	16.031	4.654	0.383	
2/10/2023	12:50:00	16.026	4.644	0.234	
2/10/2023	12:51:00	16.031	4.625	0.257	
2/10/2023	12:52:00	16.042	4.608	0.806	
2/10/2023	12:53:00	16.043	4.619	0.254	
2/10/2023	12:54:00	16.022	4.645	0.146	
2/10/2023	12:55:00	16.039	4.646	0.407	
2/10/2023	12:56:00	16.037	4.648	0.501	8
2/10/2023	12:57:00	16.044	4.641	0.622	
2/10/2023	12:58:00	16.044	4.629	0.378	
2/10/2023	12:59:00	16.038	4.618	0.089	
2/10/2023	13:00:00	16.039	4.609	0.098	
2/10/2023	13:01:00	16.043	4.604	0.033	

2/10/2023	13:02:00	16.039	4.613	0.487	
2/10/2023	13:03:00	16.047	4.619	0.433	
2/10/2023	13:04:00	16.034	4.646	0.641	
2/10/2023	13:05:00	16.032	4.646	0.698	
2/10/2023	13:06:00	16.048	4.639	0.288	7
2/10/2023	13:07:00	16.043	4.651	0.043	
2/10/2023	13:08:00	16.026	4.676	0.263	
2/10/2023	13:09:00	16.027	4.679	0.329	
2/10/2023	13:10:00	16.041	4.666	0.12	
2/10/2023	13:11:00	16.041	4.669	0.129	
2/10/2023	13:12:00	16.047	4.663	0.127	
2/10/2023	13:13:00	16.039	4.66	0.137	
2/10/2023	13:14:00	16.046	4.64	0.008	
2/10/2023	13:15:00	16.038	4.652	0.162	
2/10/2023	13:16:00	16.042	4.653	0.135	6
2/10/2023	13:17:00	16.043	4.655	0.298	
2/10/2023	13:18:00	16.037	4.658	0.234	
2/10/2023	13:19:00	16.041	4.663	0.035	
2/10/2023	13:20:00	16.044	4.674	0.018	
2/10/2023	13:21:00	16.031	4.684	0.046	
2/10/2023	13:22:00	16.034	4.677	0.045	
2/10/2023	13:23:00	16.036	4.68	0.271	
2/10/2023	13:24:00	16.046	4.676	0.162	
2/10/2023	13:25:00	16.047	4.68	0.278	
2/10/2023	13:26:00	16.045	4.686	0.018	5
2/10/2023	13:27:00	16.047	4.664	0.472	
2/10/2023	13:28:00	16.04	4.653	0.008	
2/10/2023	13:29:00	16.045	4.639	0.022	
2/10/2023	13:30:00	16.045	4.644	0.421	
2/10/2023	13:31:00	16.039	4.668	0.389	
2/10/2023	13:32:00	16.052	4.658	0.034	
2/10/2023	13:33:00	16.046	4.678	0.04	
2/10/2023	13:34:00	16.038	4.685	0.145	
2/10/2023	13:35:00	16.043	4.683	0.651	
2/10/2023	13:36:00	16.037	4.687	0.285	4
2/10/2023	13:37:00	16.054	4.673	0.061	
2/10/2023	13:38:00	16.042	4.696	0.379	
2/10/2023	13:39:00	16.051	4.67	0.483	
2/10/2023	13:40:00	16.04	4.661	0.383	
2/10/2023	13:41:00	16.045	4.646	0.14	
2/10/2023	13:42:00	16.042	4.652	0.25	
2/10/2023	13:43:00	16.055	4.64	0.02	
2/10/2023	13:44:00	16.05	4.644	0.039	
2/10/2023	13:45:00	16.035	4.661	0.098	
2/10/2023	13:46:00	16.042	4.649	0.004	3
2/10/2023	13:47:00	16.033	4.657	0.073	
2/10/2023	13:48:00	16.023	4.656	0.205	
2/10/2023	13:49:00	16.029	4.666	0.145	
2/10/2023	13:50:00	16.048	4.671	0.054	
2/10/2023	13:51:00	16.04	4.667	0.099	
2/10/2023	13:52:00	16.048	4.653	0.085	
2/10/2023	13:53:00	16.063	4.639	0.059	
2/10/2023	13:54:00	16.061	4.641	0.187	
2/10/2023	13:55:00	16.055	4.632	0.055	
2/10/2023	13:56:00	16.055	4.627	0.065	2

2/10/2023	13:57:00	16.054	4.621	0.378	
2/10/2023	13:58:00	16.051	4.627	0.061	
2/10/2023	13:59:00	16.06	4.622	0.282	
2/10/2023	14:00:00	16.063	4.621	0.096	
2/10/2023	14:01:00	16.056	4.638	0.062	
2/10/2023	14:02:00	16.046	4.664	0.038	
2/10/2023	14:03:00	16.043	4.653	0.01	
2/10/2023	14:04:00	16.056	4.639	0.149	
2/10/2023	14:05:00	16.049	4.65	0.053	
2/10/2023	14:06:00	16.053	4.655	0.01	1
2/10/2023	14:07:00	16.047	4.669	0.133	
2/10/2023	14:08:00	16.043	4.659	0.173	
2/10/2023	14:09:00	16.043	4.645	0.024	
2/10/2023	14:10:00	16.06	4.622	0.075	
2/10/2023	14:11:00	16.052	4.621	0.063	
2/10/2023	14:12:00	16.049	4.631	0.044	
2/10/2023	14:13:00	16.042	4.647	0.097	
2/10/2023	14:14:00	16.042	4.639	0.221	
2/10/2023	14:15:00	16.04	4.639	0.525	
2/10/2023	14:16:00	13.883	4.786	0.023	
2/10/2023	14:17:00	10.148	5.005	-0.029	< System O2, CO2
2/10/2023	14:18:00	11.016	5.111	-0.034	
2/10/2023	14:19:00	16.034	4.67	1.267	
2/10/2023	14:20:00	16.047	4.67	1.525	
2/10/2023	14:21:00	4.145	2.061	2.064	
2/10/2023	14:22:00	0	0.057	4.611	
2/10/2023	14:23:00	0.002	0.04	4.683	< System CO
2/10/2023	14:24:00	9.108	2.466	4.508	
2/10/2023	14:25:00	16.071	4.605	1.626	< Resume
2/10/2023	14:26:00	16.066	4.621	0.137	12
2/10/2023	14:27:00	16.056	4.623	0.243	
2/10/2023	14:28:00	16.041	4.644	0.554	
2/10/2023	14:29:00	16.057	4.635	0.549	
2/10/2023	14:30:00	16.059	4.647	0.212	
2/10/2023	14:31:00	16.066	4.646	0.165	
2/10/2023	14:32:00	16.059	4.647	0.201	
2/10/2023	14:33:00	16.064	4.639	0.097	
2/10/2023	14:34:00	16.059	4.628	0.121	
2/10/2023	14:35:00	16.037	4.631	0.231	
2/10/2023	14:36:00	16.026	4.644	0.113	11
2/10/2023	14:37:00	16.069	4.605	-0.008	
2/10/2023	14:38:00	16.053	4.614	0.005	
2/10/2023	14:39:00	16.045	4.619	0.303	
2/10/2023	14:40:00	16.057	4.608	0.422	
2/10/2023	14:41:00	16.059	4.597	0.067	
2/10/2023	14:42:00	16.058	4.591	0.07	
2/10/2023	14:43:00	16.062	4.585	0.032	
2/10/2023	14:44:00	16.063	4.585	0.017	
2/10/2023	14:45:00	16.041	4.608	0.156	
2/10/2023	14:46:00	16.06	4.591	0.15	10
2/10/2023	14:47:00	16.053	4.59	0.111	
2/10/2023	14:48:00	16.046	4.609	0.221	
2/10/2023	14:49:00	16.053	4.618	0.183	
2/10/2023	14:50:00	16.049	4.622	0.229	
2/10/2023	14:51:00	16.054	4.619	0.29	

2/10/2023	14:52:00	16.055	4.618	0.611	
2/10/2023	14:53:00	16.058	4.631	0.296	
2/10/2023	14:54:00	16.036	4.661	0.334	
2/10/2023	14:55:00	16.057	4.628	0.505	
2/10/2023	14:56:00	16.059	4.603	0.494	9
2/10/2023	14:57:00	16.05	4.614	0.211	
2/10/2023	14:58:00	16.057	4.618	0.012	
2/10/2023	14:59:00	16.061	4.61	0.008	
2/10/2023	15:00:00	16.061	4.614	0.006	
2/10/2023	15:01:00	16.059	4.608	0.22	
2/10/2023	15:02:00	16.055	4.62	0.267	
2/10/2023	15:03:00	16.054	4.623	0.112	
2/10/2023	15:04:00	16.052	4.627	0.153	
2/10/2023	15:05:00	16.059	4.61	0.074	
2/10/2023	15:06:00	16.057	4.605	0.167	8
2/10/2023	15:07:00	16.054	4.606	0.094	
2/10/2023	15:08:00	16.051	4.605	0.251	
2/10/2023	15:09:00	16.057	4.597	0.457	
2/10/2023	15:10:00	16.055	4.596	0.309	
2/10/2023	15:11:00	16.054	4.611	0.267	
2/10/2023	15:12:00	16.063	4.624	0.124	
2/10/2023	15:13:00	16.054	4.616	0.133	
2/10/2023	15:14:00	16.057	4.619	0.699	
2/10/2023	15:15:00	16.067	4.624	0.196	
2/10/2023	15:16:00	16.065	4.618	0.083	7
2/10/2023	15:17:00	16.064	4.604	0.045	
2/10/2023	15:18:00	16.058	4.602	0.033	
2/10/2023	15:19:00	16.057	4.619	0.089	
2/10/2023	15:20:00	16.065	4.616	0.07	
2/10/2023	15:21:00	16.058	4.629	0.01	
2/10/2023	15:22:00	16.059	4.619	0.255	
2/10/2023	15:23:00	16.058	4.626	0.013	
2/10/2023	15:24:00	16.057	4.64	0.101	
2/10/2023	15:25:00	16.052	4.653	0.35	
2/10/2023	15:26:00	16.053	4.646	0.233	6
2/10/2023	15:27:00	16.055	4.652	0.093	
2/10/2023	15:28:00	16.062	4.651	0.058	
2/10/2023	15:29:00	16.046	4.677	0.05	
2/10/2023	15:30:00	16.055	4.649	0.134	
2/10/2023	15:31:00	16.058	4.642	0.156	
2/10/2023	15:32:00	16.051	4.632	0.039	
2/10/2023	15:33:00	16.061	4.627	0.232	
2/10/2023	15:34:00	16.058	4.627	0.315	
2/10/2023	15:35:00	16.04	4.644	0.296	
2/10/2023	15:36:00	16.052	4.642	0.37	5
2/10/2023	15:37:00	16.061	4.632	0.112	
2/10/2023	15:38:00	16.055	4.641	0.05	
2/10/2023	15:39:00	16.062	4.638	0.164	
2/10/2023	15:40:00	16.062	4.635	0.231	
2/10/2023	15:41:00	16.066	4.609	0.012	
2/10/2023	15:42:00	16.066	4.615	0.02	
2/10/2023	15:43:00	16.06	4.619	0.055	
2/10/2023	15:44:00	16.054	4.625	0.075	
2/10/2023	15:45:00	16.038	4.636	0.063	
2/10/2023	15:46:00	16.052	4.626	0.021	4

2/10/2023	15:47:00	16.056	4.625	0.13	
2/10/2023	15:48:00	16.051	4.647	0.14	
2/10/2023	15:49:00	16.055	4.63	0.221	
2/10/2023	15:50:00	16.047	4.615	0.119	
2/10/2023	15:51:00	16.048	4.59	0.027	
2/10/2023	15:52:00	16.054	4.577	0.036	
2/10/2023	15:53:00	16.05	4.573	0.127	
2/10/2023	15:54:00	16.052	4.568	0.123	
2/10/2023	15:55:00	16.058	4.566	0.222	
2/10/2023	15:56:00	16.055	4.576	0.265	3
2/10/2023	15:57:00	16.059	4.576	0.415	
2/10/2023	15:58:00	16.055	4.569	0.17	
2/10/2023	15:59:00	16.056	4.55	0.149	
2/10/2023	16:00:00	16.061	4.542	0.243	
2/10/2023	16:01:00	16.059	4.548	0.195	
2/10/2023	16:02:00	16.056	4.554	0.274	
2/10/2023	16:03:00	16.055	4.562	0.3	
2/10/2023	16:04:00	16.053	4.567	0.311	
2/10/2023	16:05:00	16.048	4.564	0.326	
2/10/2023	16:06:00	16.057	4.545	0.332	2
2/10/2023	16:07:00	16.058	4.545	0.197	
2/10/2023	16:08:00	16.059	4.55	0.128	
2/10/2023	16:09:00	16.053	4.552	0.267	
2/10/2023	16:10:00	16.05	4.565	0.118	
2/10/2023	16:11:00	16.053	4.581	0.233	
2/10/2023	16:12:00	16.044	4.59	0.32	
2/10/2023	16:13:00	16.053	4.584	0.167	
2/10/2023	16:14:00	16.055	4.569	0.168	
2/10/2023	16:15:00	16.044	4.564	0.282	
2/10/2023	16:16:00	16.051	4.568	0.334	1
2/10/2023	16:17:00	16.048	4.562	0.19	
2/10/2023	16:18:00	16.059	4.565	0.165	
2/10/2023	16:19:00	16.051	4.573	0.061	
2/10/2023	16:20:00	16.051	4.566	0.202	
2/10/2023	16:21:00	16.053	4.554	0.23	
2/10/2023	16:22:00	16.053	4.544	0.12	
2/10/2023	16:23:00	16.052	4.545	0.224	
2/10/2023	16:24:00	16.052	4.542	0.095	
2/10/2023	16:25:00	16.045	4.549	0.194	
2/10/2023	16:26:00	16.044	4.544	0.467	
2/10/2023	16:27:00	16.049	4.535	0.131	
2/10/2023	16:28:00	16.04	4.551	0.087	
2/10/2023	16:29:00	16.047	4.551	0.154	
2/10/2023	16:30:00	16.037	4.552	0.159	
2/10/2023	16:31:00	10.842	4.998	-0.241	
2/10/2023	16:32:00	10.14	5.003	-0.058	< System O2, CO2
2/10/2023	16:33:00	10.136	5.109	-0.538	
2/10/2023	16:34:00	4.065	2.175	0.741	
2/10/2023	16:35:00	-0.003	-0.006	4.377	
2/10/2023	16:36:00	-0.002	-0.013	4.672	< System CO
2/10/2023	16:37:00	11.351	3.099	4.008	
2/10/2023	16:38:00	16.033	4.531	1.495	
2/10/2023	16:39:00	16.025	4.535	1.331	
2/10/2023	16:40:00	16.035	4.542	1.289	
2/10/2023	16:41:00	18.616	8.545	2.892	

2/10/2023	16:42:00	19.321	9.631	9.273	
2/10/2023	16:43:00	19.321	9.656	9.64	< Direct High
2/10/2023	16:44:00	10.604	4.582	6.915	
2/10/2023	16:45:00	10.15	4.998	4.679	< Direct Mid
2/10/2023	16:46:00	8.932	4.284	4.628	
2/10/2023	16:47:00	-0.019	-0.723	2.357	
2/10/2023	16:48:00	-0.008	-0.056	0.147	
2/10/2023	16:49:00	-0.007	-0.073	0.114	
2/10/2023	16:50:00	-0.008	-0.065	-0.004	< Direct Zero
2/10/2023	16:51:00	-0.008	-0.065	0.001	

Appendix A.2.2 CT-5 Data

Date	Time	O2%	CO2%	CO ppm	
2/14/2023	7:44:00	-0.027	-0.026	0.044	< Direct Zero
2/14/2023	7:45:00	11.991	7.517	0.587	
2/14/2023	7:46:00	19.237	11.33	8.005	
2/14/2023	7:47:00	19.28	9.631	9.652	< Direct High
2/14/2023	7:48:00	13.538	6.46	8.703	
2/14/2023	7:49:00	10.079	4.902	4.629	< Direct Mid
2/14/2023	7:50:00	13.61	4.559	4.348	
2/14/2023	7:51:00	16.081	4.311	2.345	
2/14/2023	7:52:00	16.078	4.305	2.153	
2/14/2023	7:53:00	13.397	4.515	1.923	
2/14/2023	7:54:00	10.071	4.928	-0.025	< system O2, CO2
2/14/2023	7:55:00	3.932	2.043	0.013	
2/14/2023	7:56:00	-0.044	-0.075	3.896	
2/14/2023	7:57:00	-0.044	-0.081	4.421	
2/14/2023	7:58:00	-0.043	-0.079	4.607	< system CO
2/14/2023	7:59:00	9.906	3.226	3.801	
2/14/2023	8:00:00	16.067	4.315	1.266	< Start Eng 5 Run 1 08:00
2/14/2023	8:01:00	16.074	4.316	1.162	
2/14/2023	8:02:00	16.072	4.316	1.703	
2/14/2023	8:03:00	16.076	4.314	2.009	
2/14/2023	8:04:00	16.081	4.318	1.546	
2/14/2023	8:05:00	16.083	4.321	1.351	
2/14/2023	8:06:00	16.075	4.32	1.54	
2/14/2023	8:07:00	16.079	4.323	1.512	
2/14/2023	8:08:00	16.078	4.314	1.235	
2/14/2023	8:09:00	16.076	4.313	1.182	
2/14/2023	8:10:00	16.08	4.309	0.986	
2/14/2023	8:11:00	16.082	4.315	0.981	
2/14/2023	8:12:00	16.084	4.317	1.156	
2/14/2023	8:13:00	16.087	4.323	0.919	
2/14/2023	8:14:00	16.084	4.321	0.985	
2/14/2023	8:15:00	16.081	4.323	0.817	
2/14/2023	8:16:00	16.089	4.316	0.932	
2/14/2023	8:17:00	16.084	4.321	1.138	
2/14/2023	8:18:00	16.083	4.306	1.277	
2/14/2023	8:19:00	16.084	4.306	1.371	
2/14/2023	8:20:00	16.085	4.29	1.825	
2/14/2023	8:21:00	16.088	4.286	1.85	
2/14/2023	8:22:00	16.084	4.293	1.312	
2/14/2023	8:23:00	16.086	4.309	1.12	
2/14/2023	8:24:00	16.087	4.316	0.948	
2/14/2023	8:25:00	16.088	4.315	1.34	
2/14/2023	8:26:00	16.088	4.322	1.443	
2/14/2023	8:27:00	16.086	4.314	0.81	
2/14/2023	8:28:00	16.085	4.309	0.673	
2/14/2023	8:29:00	16.087	4.308	0.767	
2/14/2023	8:30:00	16.089	4.301	1.126	
2/14/2023	8:31:00	16.089	4.302	1.124	
2/14/2023	8:32:00	16.089	4.318	0.753	
2/14/2023	8:33:00	16.087	4.336	0.668	
2/14/2023	8:34:00	16.086	4.335	0.968	
2/14/2023	8:35:00	16.091	4.33	0.947	
2/14/2023	8:36:00	16.09	4.333	1.267	
2/14/2023	8:37:00	16.09	4.316	1.143	

2/14/2023	8:38:00	16.085	4.317	0.88
2/14/2023	8:39:00	16.091	4.312	0.828
2/14/2023	8:40:00	16.085	4.316	0.671
2/14/2023	8:41:00	16.085	4.325	0.594
2/14/2023	8:42:00	16.092	4.327	0.746
2/14/2023	8:43:00	16.093	4.338	0.773
2/14/2023	8:44:00	16.092	4.33	0.743
2/14/2023	8:45:00	16.089	4.331	0.966
2/14/2023	8:46:00	16.087	4.331	0.706
2/14/2023	8:47:00	16.09	4.325	0.557
2/14/2023	8:48:00	16.089	4.32	0.6
2/14/2023	8:49:00	16.093	4.315	0.649
2/14/2023	8:50:00	16.086	4.323	0.769
2/14/2023	8:51:00	16.086	4.327	0.627
2/14/2023	8:52:00	16.086	4.346	0.537
2/14/2023	8:53:00	16.09	4.344	0.444
2/14/2023	8:54:00	16.086	4.348	0.521
2/14/2023	8:55:00	16.092	4.348	0.424
2/14/2023	8:56:00	16.092	4.339	0.391
2/14/2023	8:57:00	16.089	4.312	0.38
2/14/2023	8:58:00	16.088	4.307	0.499
2/14/2023	8:59:00	16.089	4.295	0.642
2/14/2023	9:00:00	16.093	4.278	0.826
2/14/2023	9:01:00	16.092	4.277	0.568
2/14/2023	9:02:00	16.093	4.291	0.371
2/14/2023	9:03:00	16.09	4.285	0.477
2/14/2023	9:04:00	16.095	4.294	0.697
2/14/2023	9:05:00	16.093	4.305	0.76
2/14/2023	9:06:00	16.098	4.304	0.699
2/14/2023	9:07:00	16.089	4.296	0.586
2/14/2023	9:08:00	16.097	4.292	0.476
2/14/2023	9:09:00	16.093	4.292	0.44
2/14/2023	9:10:00	16.091	4.29	0.531
2/14/2023	9:11:00	16.088	4.298	0.708
2/14/2023	9:12:00	16.087	4.283	0.661
2/14/2023	9:13:00	16.086	4.273	0.598
2/14/2023	9:14:00	16.09	4.269	0.54
2/14/2023	9:15:00	16.097	4.272	0.456
2/14/2023	9:16:00	16.099	4.272	0.401
2/14/2023	9:17:00	16.098	4.281	0.346
2/14/2023	9:18:00	16.087	4.295	0.347
2/14/2023	9:19:00	16.082	4.299	0.452
2/14/2023	9:20:00	16.078	4.297	0.349
2/14/2023	9:21:00	16.092	4.286	0.296
2/14/2023	9:22:00	16.085	4.283	0.28
2/14/2023	9:23:00	16.083	4.288	0.3
2/14/2023	9:24:00	16.078	4.29	0.275
2/14/2023	9:25:00	16.078	4.277	0.342
2/14/2023	9:26:00	16.077	4.293	0.305
2/14/2023	9:27:00	16.08	4.299	0.275
2/14/2023	9:28:00	16.078	4.31	0.303
2/14/2023	9:29:00	16.079	4.317	0.307
2/14/2023	9:30:00	16.082	4.315	0.314
2/14/2023	9:31:00	16.08	4.306	0.588
2/14/2023	9:32:00	16.09	4.294	0.578

2/14/2023	9:33:00	16.09	4.285	0.453
2/14/2023	9:34:00	16.093	4.28	0.82
2/14/2023	9:35:00	16.087	4.283	0.4
2/14/2023	9:36:00	16.085	4.293	0.448
2/14/2023	9:37:00	16.089	4.305	0.483
2/14/2023	9:38:00	16.089	4.311	0.378
2/14/2023	9:39:00	16.092	4.309	0.79
2/14/2023	9:40:00	16.092	4.293	0.412
2/14/2023	9:41:00	16.099	4.287	0.442
2/14/2023	9:42:00	16.097	4.291	0.242
2/14/2023	9:43:00	16.092	4.295	0.316
2/14/2023	9:44:00	16.093	4.282	0.439
2/14/2023	9:45:00	16.096	4.298	0.225
2/14/2023	9:46:00	16.108	4.289	0.206
2/14/2023	9:47:00	16.106	4.302	0.236
2/14/2023	9:48:00	16.096	4.308	0.295
2/14/2023	9:49:00	16.094	4.294	0.304
2/14/2023	9:50:00	16.099	4.287	0.496
2/14/2023	9:51:00	16.106	4.279	0.238
2/14/2023	9:52:00	16.102	4.28	0.231
2/14/2023	9:53:00	16.102	4.29	0.211
2/14/2023	9:54:00	16.1	4.289	0.198
2/14/2023	9:55:00	16.103	4.28	0.193
2/14/2023	9:56:00	16.106	4.275	0.221
2/14/2023	9:57:00	16.104	4.267	0.198
2/14/2023	9:58:00	16.1	4.278	0.213
2/14/2023	9:59:00	16.09	4.272	0.203
2/14/2023	10:00:00	16.099	4.258	0.199
2/14/2023	10:01:00	16.093	4.262	0.206
2/14/2023	10:02:00	10.534	4.814	-0.203
2/14/2023	10:03:00	10.094	4.94	-0.026
2/14/2023	10:04:00	3.864	1.405	3.459
2/14/2023	10:05:00	-0.025	-0.027	4.636
2/14/2023	10:06:00	1.768	0.294	4.665
2/14/2023	10:07:00	16.086	4.256	2.673
2/14/2023	10:08:00	16.091	4.271	0.873
2/14/2023	10:09:00	16.089	4.276	0.007
2/14/2023	10:10:00	16.097	4.278	0.009
< Resume				
2/14/2023	10:11:00	16.095	4.284	0.163
2/14/2023	10:12:00	16.085	4.293	0.176
2/14/2023	10:13:00	16.097	4.282	0.148
2/14/2023	10:14:00	16.098	4.271	0.003
2/14/2023	10:15:00	16.102	4.267	0.025
2/14/2023	10:16:00	16.102	4.273	0.013
2/14/2023	10:17:00	16.104	4.266	0.029
2/14/2023	10:18:00	16.099	4.277	0.004
2/14/2023	10:19:00	16.101	4.284	0.028
2/14/2023	10:20:00	16.095	4.278	0.011
2/14/2023	10:21:00	16.101	4.266	0.021
2/14/2023	10:22:00	16.098	4.264	0.03
2/14/2023	10:23:00	16.103	4.26	0.053
2/14/2023	10:24:00	16.1	4.267	0.047
2/14/2023	10:25:00	16.101	4.267	0.047
2/14/2023	10:26:00	16.099	4.281	0.04
2/14/2023	10:27:00	16.097	4.282	0.011

2/14/2023	10:28:00	16.093	4.274	0.024
2/14/2023	10:29:00	16.101	4.253	0.045
2/14/2023	10:30:00	16.101	4.25	0.038
2/14/2023	10:31:00	16.099	4.257	0.002
2/14/2023	10:32:00	16.094	4.265	0.063
2/14/2023	10:33:00	16.104	4.275	0.031
2/14/2023	10:34:00	16.104	4.285	0.04
2/14/2023	10:35:00	16.099	4.282	0.04
2/14/2023	10:36:00	16.101	4.267	0.057
2/14/2023	10:37:00	16.095	4.272	0.045
2/14/2023	10:38:00	16.095	4.275	0.019
2/14/2023	10:39:00	16.096	4.272	0.019
2/14/2023	10:40:00	16.104	4.262	0.052
2/14/2023	10:41:00	16.11	4.268	0.062
2/14/2023	10:42:00	16.093	4.274	0.042
2/14/2023	10:43:00	16.098	4.262	0.026
2/14/2023	10:44:00	16.105	4.258	0.03
2/14/2023	10:45:00	16.104	4.254	0.024
2/14/2023	10:46:00	16.092	4.257	0.051
2/14/2023	10:47:00	16.107	4.246	0.057
2/14/2023	10:48:00	16.101	4.249	0.071
2/14/2023	10:49:00	16.106	4.253	0.051
2/14/2023	10:50:00	16.096	4.244	0.051
2/14/2023	10:51:00	16.11	4.234	0.052
2/14/2023	10:52:00	16.107	4.236	0.079
2/14/2023	10:53:00	16.1	4.232	0.066
2/14/2023	10:54:00	16.101	4.242	0.049
2/14/2023	10:55:00	16.099	4.255	0.023
2/14/2023	10:56:00	16.103	4.256	0.043
2/14/2023	10:57:00	16.095	4.262	0.036
2/14/2023	10:58:00	16.088	4.269	0.049
2/14/2023	10:59:00	16.077	4.287	0.007
2/14/2023	11:00:00	16.104	4.26	0.017
2/14/2023	11:01:00	16.107	4.251	0.063
2/14/2023	11:02:00	16.107	4.252	0.066
2/14/2023	11:03:00	16.098	4.266	0.063
2/14/2023	11:04:00	16.099	4.254	0.054
2/14/2023	11:05:00	16.101	4.254	0.062
2/14/2023	11:06:00	16.098	4.255	0.064
2/14/2023	11:07:00	16.104	4.257	0.063
2/14/2023	11:08:00	16.099	4.264	0.053
2/14/2023	11:09:00	16.104	4.265	0.073
2/14/2023	11:10:00	16.102	4.267	0.071
2/14/2023	11:11:00	16.1	4.264	0.082
2/14/2023	11:12:00	16.108	4.258	0.068
2/14/2023	11:13:00	16.091	4.272	0.187
2/14/2023	11:14:00	16.081	4.283	0.025
2/14/2023	11:15:00	16.098	4.271	0.359
2/14/2023	11:16:00	16.096	4.274	0.082
2/14/2023	11:17:00	16.086	4.301	0.387
2/14/2023	11:18:00	16.104	4.292	0.307
2/14/2023	11:19:00	16.106	4.285	0.224
2/14/2023	11:20:00	16.108	4.27	0.032
2/14/2023	11:21:00	16.104	4.273	0.141
2/14/2023	11:22:00	16.118	4.256	0.004

2/14/2023	11:23:00	16.119	4.255	0.08
2/14/2023	11:24:00	16.116	4.26	0.091
2/14/2023	11:25:00	16.113	4.272	0.081
2/14/2023	11:26:00	16.115	4.272	0.095
2/14/2023	11:27:00	16.103	4.263	0.011
2/14/2023	11:28:00	16.112	4.251	0.042
2/14/2023	11:29:00	16.111	4.243	0.081
2/14/2023	11:30:00	16.113	4.243	0.097
2/14/2023	11:31:00	16.105	4.243	0.077
2/14/2023	11:32:00	16.108	4.255	0.087
2/14/2023	11:33:00	16.108	4.266	0.091
2/14/2023	11:34:00	16.112	4.258	0.063
2/14/2023	11:35:00	16.105	4.259	0.043
2/14/2023	11:36:00	16.09	4.275	0.157
2/14/2023	11:37:00	16.115	4.246	0.156
2/14/2023	11:38:00	16.117	4.251	0.029
2/14/2023	11:39:00	16.118	4.258	0.066
2/14/2023	11:40:00	16.114	4.27	0.09
2/14/2023	11:41:00	16.114	4.268	0.1
2/14/2023	11:42:00	16.102	4.271	0.072
2/14/2023	11:43:00	16.111	4.261	0.086
2/14/2023	11:44:00	16.111	4.265	0.094
2/14/2023	11:45:00	16.11	4.261	0.053
2/14/2023	11:46:00	16.113	4.267	0.095
2/14/2023	11:47:00	16.114	4.27	0.087
2/14/2023	11:48:00	16.115	4.275	0.096
2/14/2023	11:49:00	16.11	4.274	0.09
2/14/2023	11:50:00	16.117	4.269	0.104
2/14/2023	11:51:00	16.102	4.284	0.103
2/14/2023	11:52:00	16.114	4.267	0.103
2/14/2023	11:53:00	16.111	4.26	0.012
2/14/2023	11:54:00	16.117	4.255	0.226
2/14/2023	11:55:00	16.122	4.264	0.057
2/14/2023	11:56:00	16.121	4.271	0.071
2/14/2023	11:57:00	16.119	4.265	0.065
2/14/2023	11:58:00	16.117	4.267	0.079
2/14/2023	11:59:00	16.106	4.271	0.326
2/14/2023	12:00:00	16.115	4.264	0.226
2/14/2023	12:01:00	16.109	4.261	0.026
2/14/2023	12:02:00	16.12	4.252	0.039
2/14/2023	12:03:00	16.124	4.256	0.114
2/14/2023	12:04:00	16.123	4.261	0.061
2/14/2023	12:05:00	16.119	4.251	0.085
2/14/2023	12:06:00	16.122	4.246	0.091
2/14/2023	12:07:00	16.115	4.246	0.094
2/14/2023	12:08:00	16.116	4.25	0.077
2/14/2023	12:09:00	16.163	4.285	0.247
2/14/2023	12:10:00	16.082	4.226	0.276
2/14/2023	12:11:00	10.078	4.745	0.009
2/14/2023	12:12:00	10.182	4.926	0.015 < System O2, CO2
2/14/2023	12:13:00	7.247	2.005	1.353
2/14/2023	12:14:00	-0.045	-0.115	4.536
2/14/2023	12:15:00	-0.043	-0.128	4.693
2/14/2023	12:16:00	-0.039	-0.033	4.675 < System CO
2/14/2023	12:17:00	-0.04	-0.12	4.703

2/14/2023	12:18:00	6.176	1.405	4.558	
2/14/2023	12:19:00	16.129	4.268	1.552	
2/14/2023	12:20:00	16.13	4.27	0.017	< Start Eng 5 Run 2 12:20
<hr/>					
2/14/2023	12:21:00	16.125	4.274	0.018	
2/14/2023	12:22:00	16.129	4.263	0.012	
2/14/2023	12:23:00	16.131	4.256	0.003	
2/14/2023	12:24:00	16.124	4.263	0.007	
2/14/2023	12:25:00	16.129	4.269	0.004	
2/14/2023	12:26:00	16.133	4.273	0.01	
2/14/2023	12:27:00	16.134	4.277	0.027	
2/14/2023	12:28:00	16.128	4.27	0.004	
2/14/2023	12:29:00	16.129	4.263	0.023	
2/14/2023	12:30:00	16.123	4.271	0.029	
2/14/2023	12:31:00	16.126	4.274	0.089	
2/14/2023	12:32:00	16.13	4.283	0.027	
2/14/2023	12:33:00	16.133	4.277	0.023	
2/14/2023	12:34:00	16.123	4.293	0.025	
2/14/2023	12:35:00	16.128	4.282	0.267	
2/14/2023	12:36:00	16.126	4.283	0.136	
2/14/2023	12:37:00	16.118	4.29	0.035	
2/14/2023	12:38:00	16.13	4.264	0.001	
2/14/2023	12:39:00	16.121	4.264	0.029	
2/14/2023	12:40:00	16.12	4.267	0.004	
2/14/2023	12:41:00	16.123	4.26	0.026	
2/14/2023	12:42:00	16.126	4.256	0.007	
2/14/2023	12:43:00	16.125	4.253	0.015	
2/14/2023	12:44:00	16.129	4.243	0.01	
2/14/2023	12:45:00	16.123	4.237	0.011	
2/14/2023	12:46:00	16.128	4.228	0.03	
2/14/2023	12:47:00	16.126	4.236	0.034	
2/14/2023	12:48:00	16.131	4.237	0.059	
2/14/2023	12:49:00	16.128	4.229	0.133	
2/14/2023	12:50:00	16.131	4.225	0.172	
2/14/2023	12:51:00	16.128	4.219	0.161	
2/14/2023	12:52:00	16.128	4.223	0.196	
2/14/2023	12:53:00	16.126	4.227	0.158	
2/14/2023	12:54:00	16.127	4.229	0.007	
2/14/2023	12:55:00	16.136	4.239	0.027	
2/14/2023	12:56:00	16.131	4.235	0.034	
2/14/2023	12:57:00	16.131	4.228	0.028	
2/14/2023	12:58:00	16.125	4.243	0.011	
2/14/2023	12:59:00	16.128	4.238	0.059	
2/14/2023	13:00:00	16.13	4.235	0.222	
2/14/2023	13:01:00	16.133	4.231	0.063	
2/14/2023	13:02:00	16.139	4.224	0.008	
2/14/2023	13:03:00	16.136	4.241	0.031	
2/14/2023	13:04:00	16.137	4.256	0.035	
2/14/2023	13:05:00	16.134	4.253	0.039	
2/14/2023	13:06:00	16.129	4.242	0.032	
2/14/2023	13:07:00	16.13	4.239	0.025	
2/14/2023	13:08:00	16.127	4.246	0.024	
2/14/2023	13:09:00	16.126	4.255	0.113	
2/14/2023	13:10:00	16.139	4.251	0.02	
2/14/2023	13:11:00	16.149	4.256	0.036	
2/14/2023	13:12:00	16.115	4.29	0.03	

2/14/2023	13:13:00	16.118	4.282	0.004
2/14/2023	13:14:00	16.128	4.255	0.229
2/14/2023	13:15:00	16.123	4.248	0.19
2/14/2023	13:16:00	16.122	4.244	0.276
2/14/2023	13:17:00	16.143	4.233	0.121
2/14/2023	13:18:00	16.118	4.255	0.092
2/14/2023	13:19:00	16.163	4.224	0.054
2/14/2023	13:20:00	16.116	4.256	0.12
2/14/2023	13:21:00	16.091	4.262	0.052
2/14/2023	13:22:00	16.091	4.221	0.02
2/14/2023	13:23:00	16.153	4.164	0.006
2/14/2023	13:24:00	16.145	4.182	0.005
2/14/2023	13:25:00	16.145	4.229	0.022
2/14/2023	13:26:00	16.093	4.259	0.034
2/14/2023	13:27:00	16.125	4.209	0.006
2/14/2023	13:28:00	16.136	4.186	0.03
2/14/2023	13:29:00	16.134	4.205	0.021
2/14/2023	13:30:00	16.113	4.224	0.031
2/14/2023	13:31:00	16.125	4.218	0.011
2/14/2023	13:32:00	16.13	4.225	0.02
2/14/2023	13:33:00	16.129	4.216	0.003
2/14/2023	13:34:00	16.125	4.228	0.012
2/14/2023	13:35:00	16.125	4.233	0.074
2/14/2023	13:36:00	16.123	4.223	0.018
2/14/2023	13:37:00	16.124	4.211	0.007
2/14/2023	13:38:00	16.122	4.216	0.036
2/14/2023	13:39:00	16.126	4.227	0.022
2/14/2023	13:40:00	16.13	4.236	0.012
2/14/2023	13:41:00	16.127	4.22	0.023
2/14/2023	13:42:00	16.124	4.208	0.025
2/14/2023	13:43:00	16.127	4.21	0.036
2/14/2023	13:44:00	16.123	4.213	0.419
2/14/2023	13:45:00	16.126	4.209	0.152
2/14/2023	13:46:00	16.134	4.199	0.052
2/14/2023	13:47:00	16.133	4.198	0.087
2/14/2023	13:48:00	16.119	4.212	0.063
2/14/2023	13:49:00	16.123	4.204	0.059
2/14/2023	13:50:00	16.129	4.206	0.091
2/14/2023	13:51:00	16.133	4.202	0.043
2/14/2023	13:52:00	16.13	4.203	0
2/14/2023	13:53:00	16.127	4.217	0.032
2/14/2023	13:54:00	16.124	4.222	0.013
2/14/2023	13:55:00	16.13	4.213	0.044
2/14/2023	13:56:00	16.113	4.221	0.018
2/14/2023	13:57:00	16.13	4.202	0.05
2/14/2023	13:58:00	16.127	4.192	0.049
2/14/2023	13:59:00	16.128	4.217	0.001
2/14/2023	14:00:00	16.123	4.229	0.04
2/14/2023	14:01:00	16.122	4.233	0.043
2/14/2023	14:02:00	16.122	4.215	0.039
2/14/2023	14:03:00	16.122	4.221	0.25
2/14/2023	14:04:00	16.13	4.213	0.455
2/14/2023	14:05:00	16.126	4.212	1.647
2/14/2023	14:06:00	16.126	4.221	0.368
2/14/2023	14:07:00	16.13	4.233	0.02

2/14/2023	14:08:00	16.126	4.234	0.06
2/14/2023	14:09:00	16.126	4.234	0.021
2/14/2023	14:10:00	16.125	4.234	0.008
2/14/2023	14:11:00	16.126	4.234	0.002
2/14/2023	14:12:00	16.129	4.239	0.019
2/14/2023	14:13:00	16.123	4.249	0.035
2/14/2023	14:14:00	16.13	4.249	0.015
2/14/2023	14:15:00	16.127	4.251	0.003
2/14/2023	14:16:00	16.127	4.257	0.021
2/14/2023	14:17:00	16.121	4.255	0.046
2/14/2023	14:18:00	16.117	4.263	0.092
2/14/2023	14:19:00	16.109	4.265	0.016
2/14/2023	14:20:00	16.121	4.252	0.001
2/14/2023	14:21:00	16.13	4.254	0.046
2/14/2023	14:22:00	12.47	4.566	0.195
2/14/2023	14:23:00	10.094	4.919	0.246
2/14/2023	14:24:00	10.091	4.914	0.007 System O2,CO2
2/14/2023	14:25:00	2.552	1.443	1.531
2/14/2023	14:26:00	-0.029	-0.136	4.636
2/14/2023	14:27:00	-0.027	-0.041	4.679 < System CO
2/14/2023	14:28:00	10.282	3.448	3.772
2/14/2023	14:29:00	16.116	4.272	0.75
2/14/2023	14:30:00	16.119	4.274	0.057 < Resume
2/14/2023	14:31:00	16.127	4.259	0.03
2/14/2023	14:32:00	16.113	4.255	0.011
2/14/2023	14:33:00	16.105	4.269	0.007
2/14/2023	14:34:00	16.104	4.283	0.135
2/14/2023	14:35:00	16.123	4.259	0.028
2/14/2023	14:36:00	16.125	4.273	0.007
2/14/2023	14:37:00	16.113	4.28	0.086
2/14/2023	14:38:00	16.118	4.273	0.051
2/14/2023	14:39:00	16.116	4.26	0.047
2/14/2023	14:40:00	16.106	4.263	0.019
2/14/2023	14:41:00	16.117	4.245	0.247
2/14/2023	14:42:00	16.113	4.262	0.021
2/14/2023	14:43:00	16.111	4.276	0.008
2/14/2023	14:44:00	16.122	4.268	0.099
2/14/2023	14:45:00	16.125	4.255	0.281
2/14/2023	14:46:00	16.119	4.262	0.072
2/14/2023	14:47:00	16.113	4.249	0.261
2/14/2023	14:48:00	16.126	4.238	0.183
2/14/2023	14:49:00	16.107	4.253	0.634
2/14/2023	14:50:00	16.108	4.26	0.128
2/14/2023	14:51:00	16.111	4.259	0.079
2/14/2023	14:52:00	16.109	4.256	0.007
2/14/2023	14:53:00	16.12	4.245	0.06
2/14/2023	14:54:00	16.118	4.242	0.134
2/14/2023	14:55:00	16.116	4.246	0.008
2/14/2023	14:56:00	16.124	4.241	0.01
2/14/2023	14:57:00	16.122	4.249	0.037
2/14/2023	14:58:00	16.122	4.25	0.031
2/14/2023	14:59:00	16.112	4.263	0.041
2/14/2023	15:00:00	16.12	4.244	0.01
2/14/2023	15:01:00	16.123	4.234	0.017
2/14/2023	15:02:00	16.117	4.243	0.078

2/14/2023	15:03:00	16.12	4.247	0.017
2/14/2023	15:04:00	16.121	4.252	0.039
2/14/2023	15:05:00	16.121	4.252	0.015
2/14/2023	15:06:00	16.127	4.25	0.054
2/14/2023	15:07:00	16.122	4.247	0.033
2/14/2023	15:08:00	16.125	4.238	0.05
2/14/2023	15:09:00	16.119	4.249	0.014
2/14/2023	15:10:00	16.114	4.253	0.033
2/14/2023	15:11:00	16.117	4.253	0.073
2/14/2023	15:12:00	16.121	4.249	0.056
2/14/2023	15:13:00	16.126	4.23	0.032
2/14/2023	15:14:00	16.1	4.253	0.076
2/14/2023	15:15:00	16.122	4.219	0.246
2/14/2023	15:16:00	16.122	4.234	0.036
2/14/2023	15:17:00	16.118	4.252	0.011
2/14/2023	15:18:00	16.11	4.264	0.218
2/14/2023	15:19:00	16.12	4.265	0.261
2/14/2023	15:20:00	16.128	4.243	0.435
2/14/2023	15:21:00	16.12	4.239	0.035
2/14/2023	15:22:00	16.125	4.221	0.01
2/14/2023	15:23:00	16.12	4.226	0.075
2/14/2023	15:24:00	16.118	4.228	0.105
2/14/2023	15:25:00	16.122	4.228	0.072
2/14/2023	15:26:00	16.116	4.239	0.025
2/14/2023	15:27:00	16.115	4.235	0.062
2/14/2023	15:28:00	16.118	4.245	0.015
2/14/2023	15:29:00	16.116	4.23	0.003
2/14/2023	15:30:00	16.112	4.232	0.096
2/14/2023	15:31:00	16.12	4.229	0.16
2/14/2023	15:32:00	16.099	4.255	0.064
2/14/2023	15:33:00	16.117	4.248	0.191
2/14/2023	15:34:00	16.123	4.242	0.121
2/14/2023	15:35:00	16.12	4.242	0.215
2/14/2023	15:36:00	16.125	4.224	0.059
2/14/2023	15:37:00	16.125	4.224	0.187
2/14/2023	15:38:00	16.128	4.226	0.056
2/14/2023	15:39:00	16.122	4.235	0.099
2/14/2023	15:40:00	16.124	4.235	0.049
2/14/2023	15:41:00	16.122	4.241	0.017
2/14/2023	15:42:00	16.129	4.226	0.054
2/14/2023	15:43:00	16.12	4.233	0.04
2/14/2023	15:44:00	16.101	4.245	0.038
2/14/2023	15:45:00	16.099	4.254	0.029
2/14/2023	15:46:00	16.111	4.255	0.037
2/14/2023	15:47:00	16.121	4.247	0.04
2/14/2023	15:48:00	16.11	4.263	0.06
2/14/2023	15:49:00	16.133	4.232	0.013
2/14/2023	15:50:00	16.106	4.244	0.058
2/14/2023	15:51:00	16.121	4.217	0.071
2/14/2023	15:52:00	16.107	4.24	0.038
2/14/2023	15:53:00	16.12	4.227	0.033
2/14/2023	15:54:00	16.119	4.237	0.008
2/14/2023	15:55:00	16.121	4.234	0.115
2/14/2023	15:56:00	16.119	4.227	0.095
2/14/2023	15:57:00	16.121	4.235	0.044

2/14/2023	15:58:00	16.1	4.26	0.058
2/14/2023	15:59:00	16.102	4.257	0.198
2/14/2023	16:00:00	16.125	4.237	0.035
2/14/2023	16:01:00	16.114	4.25	0.193
2/14/2023	16:02:00	16.123	4.239	0.07
2/14/2023	16:03:00	16.113	4.241	0.032
2/14/2023	16:04:00	16.118	4.23	0.01
2/14/2023	16:05:00	16.106	4.248	0.014
2/14/2023	16:06:00	16.11	4.241	0.049
2/14/2023	16:07:00	16.105	4.247	0.05
2/14/2023	16:08:00	16.085	4.269	0.008
2/14/2023	16:09:00	16.116	4.24	0.155
2/14/2023	16:10:00	16.121	4.231	0.061
2/14/2023	16:11:00	16.104	4.231	0.138
2/14/2023	16:12:00	16.126	4.216	0.071
2/14/2023	16:13:00	16.117	4.238	0.042
2/14/2023	16:14:00	16.125	4.239	0.041
2/14/2023	16:15:00	16.119	4.236	0.135
2/14/2023	16:16:00	16.123	4.218	0.213
2/14/2023	16:17:00	16.106	4.248	0.288
2/14/2023	16:18:00	16.081	4.256	0.086
2/14/2023	16:19:00	16.125	4.197	0.371
2/14/2023	16:20:00	16.124	4.206	0.023
2/14/2023	16:21:00	16.112	4.23	0.038
2/14/2023	16:22:00	16.11	4.236	0.174
2/14/2023	16:23:00	16.114	4.235	0.02
2/14/2023	16:24:00	16.113	4.231	0.064
2/14/2023	16:25:00	16.115	4.207	0.343
2/14/2023	16:26:00	16.127	4.191	0.344
2/14/2023	16:27:00	16.122	4.183	0.303
2/14/2023	16:28:00	16.104	4.184	0.067
2/14/2023	16:29:00	16.11	4.188	0.021
2/14/2023	16:30:00	16.1	4.205	0.081
2/14/2023	16:31:00	12.092	4.54	0.086
2/14/2023	16:32:00	10.092	4.895	-0.007 < System O2, CO2
2/14/2023	16:33:00	10.088	4.829	0.314
2/14/2023	16:34:00	8.659	4.329	4.019
2/14/2023	16:35:00	-0.057	-0.226	4.565
2/14/2023	16:36:00	-0.056	-0.032	4.657 < System CO
2/14/2023	16:37:00	-0.058	-0.051	4.655
2/14/2023	16:38:00	11.664	2.993	4.111
2/14/2023	16:39:00	16.315	4.307	0.562
2/14/2023	16:40:00	19.259	9.518	3.516
2/14/2023	16:41:00	19.274	9.646	9.05
2/14/2023	16:42:00	19.273	9.656	9.646 < Direct High
2/14/2023	16:43:00	16.012	7.909	9.525
2/14/2023	16:44:00	10.114	4.711	5.142
2/14/2023	16:45:00	10.113	4.902	4.613 < Direct Mid
2/14/2023	16:46:00	9.348	4.691	4.588
2/14/2023	16:47:00	-0.034	-0.323	2.067
2/14/2023	16:48:00	-0.037	-0.021	-0.023
2/14/2023	16:49:00	-0.037	-0.01	0.011 < Direct Zero
2/14/2023	16:50:00	-0.038	0.001	0.002

Date	Time	O2%	CO2%	CO ppm	
2/15/2023	7:14:00	-0.042	0.028	2.177	
2/15/2023	7:15:00	-0.032	-0.025	-0.031	
2/15/2023	7:16:00	-0.03	-0.031	-0.06	
2/15/2023	7:17:00	-0.03	-0.037	-0.064	
2/15/2023	7:18:00	-0.03	-0.054	2.858	
2/15/2023	7:19:00	-0.027	-0.056	1.1	
2/15/2023	7:20:00	-0.027	-0.038	-0.061	< Zero Direct
2/15/2023	7:21:00	15.851	8.633	2.449	
2/15/2023	7:22:00	19.281	9.83	10.373	
2/15/2023	7:23:00	19.284	9.616	9.622	< Direct High
2/15/2023	7:24:00	12.759	6.219	8.541	
2/15/2023	7:25:00	10.101	4.878	4.588	
2/15/2023	7:26:00	10.102	4.971	4.656	< Direct Mid
2/15/2023	7:27:00	12.922	4.586	4.545	
2/15/2023	7:28:00	16.075	4.266	1.478	
2/15/2023	7:29:00	13.064	4.534	0.532	
2/15/2023	7:30:00	10.094	4.913	-0.023	< System O2, CO2
2/15/2023	7:31:00	1.398	0.751	1.812	
2/15/2023	7:32:00	-0.041	-0.107	4.681	
2/15/2023	7:33:00	-0.041	-0.017	4.608	< System CO
2/15/2023	7:34:00	14.059	3.932	2.853	
2/15/2023	7:35:00	16.069	4.279	0.681	< Start Eng 5 Run 3 0735
2/15/2023	7:36:00	16.075	4.268	0.02	12
2/15/2023	7:37:00	16.068	4.27	0.021	
2/15/2023	7:38:00	16.058	4.283	0.027	
2/15/2023	7:39:00	16.067	4.27	0.044	
2/15/2023	7:40:00	16.071	4.266	0.056	
2/15/2023	7:41:00	16.068	4.273	0.074	
2/15/2023	7:42:00	16.061	4.277	0.046	
2/15/2023	7:43:00	16.061	4.281	0.006	
2/15/2023	7:44:00	16.071	4.272	0.008	
2/15/2023	7:45:00	16.071	4.259	0.008	
2/15/2023	7:46:00	16.074	4.252	0.011	11
2/15/2023	7:47:00	16.072	4.268	0.027	
2/15/2023	7:48:00	16.071	4.277	0.017	
2/15/2023	7:49:00	16.066	4.283	0.064	
2/15/2023	7:50:00	16.065	4.296	0.007	
2/15/2023	7:51:00	16.061	4.287	0.087	
2/15/2023	7:52:00	16.068	4.289	0.027	
2/15/2023	7:53:00	16.066	4.302	0.049	
2/15/2023	7:54:00	16.067	4.288	0.003	
2/15/2023	7:55:00	16.056	4.292	0.068	
2/15/2023	7:56:00	16.062	4.269	0.022	10
2/15/2023	7:57:00	16.065	4.256	0.139	
2/15/2023	7:58:00	16.061	4.243	0.196	
2/15/2023	7:59:00	16.065	4.248	0.16	
2/15/2023	8:00:00	16.061	4.259	0.113	
2/15/2023	8:01:00	16.058	4.269	0.122	
2/15/2023	8:02:00	16.067	4.259	0.149	
2/15/2023	8:03:00	16.052	4.273	0.162	
2/15/2023	8:04:00	16.064	4.253	0.146	
2/15/2023	8:05:00	16.062	4.251	0.17	
2/15/2023	8:06:00	16.057	4.267	0.186	9
2/15/2023	8:07:00	16.054	4.267	0.117	

2/15/2023	8:08:00	16.055	4.264	0.164	
2/15/2023	8:09:00	16.064	4.254	0.185	
2/15/2023	8:10:00	16.067	4.253	0.08	
2/15/2023	8:11:00	16.069	4.257	0.132	
2/15/2023	8:12:00	16.063	4.248	0.313	
2/15/2023	8:13:00	16.064	4.24	0.372	
2/15/2023	8:14:00	16.058	4.242	0.398	
2/15/2023	8:15:00	16.062	4.241	0.351	
2/15/2023	8:16:00	16.049	4.243	0.397	8
2/15/2023	8:17:00	16.073	4.218	0.428	
2/15/2023	8:18:00	16.059	4.236	0.41	
2/15/2023	8:19:00	16.06	4.237	0.421	
2/15/2023	8:20:00	16.059	4.235	0.426	
2/15/2023	8:21:00	16.061	4.215	0.427	
2/15/2023	8:22:00	16.058	4.212	0.427	
2/15/2023	8:23:00	16.052	4.242	0.448	
2/15/2023	8:24:00	16.054	4.236	0.454	
2/15/2023	8:25:00	16.067	4.217	0.454	
2/15/2023	8:26:00	16.067	4.223	0.442	7
2/15/2023	8:27:00	16.061	4.219	0.389	
2/15/2023	8:28:00	16.055	4.222	0.046	
2/15/2023	8:29:00	16.061	4.228	0.04	
2/15/2023	8:30:00	16.062	4.229	0.061	
2/15/2023	8:31:00	16.063	4.227	0.028	
2/15/2023	8:32:00	16.065	4.235	0.057	
2/15/2023	8:33:00	16.065	4.236	0.07	
2/15/2023	8:34:00	16.064	4.23	0.057	
2/15/2023	8:35:00	16.057	4.235	0.084	
2/15/2023	8:36:00	16.062	4.23	0.092	6
2/15/2023	8:37:00	16.043	4.256	0.097	
2/15/2023	8:38:00	16.045	4.262	0.094	
2/15/2023	8:39:00	16.027	4.281	0.083	
2/15/2023	8:40:00	16.074	4.141	0.081	
2/15/2023	8:41:00	16.287	4.018	0.266	
2/15/2023	8:42:00	16.247	4.024	0.278	
2/15/2023	8:43:00	16.238	4.049	0.274	
2/15/2023	8:44:00	16.214	4.093	0.261	
2/15/2023	8:45:00	16.218	4.1	0.273	
2/15/2023	8:46:00	16.208	4.09	0.256	5
2/15/2023	8:47:00	16.21	4.076	0.263	
2/15/2023	8:48:00	16.223	4.075	0.285	
2/15/2023	8:49:00	16.221	4.083	0.276	
2/15/2023	8:50:00	16.223	4.077	0.288	
2/15/2023	8:51:00	16.21	4.06	0.286	
2/15/2023	8:52:00	16.228	4.034	0.291	
2/15/2023	8:53:00	16.207	4.061	0.289	
2/15/2023	8:54:00	16.105	4.167	0.226	
2/15/2023	8:55:00	16.013	4.27	0.123	
2/15/2023	8:56:00	16.031	4.246	0.107	4
2/15/2023	8:57:00	16.039	4.23	0.146	
2/15/2023	8:58:00	16.053	4.199	0.151	
2/15/2023	8:59:00	16.054	4.203	0.167	
2/15/2023	9:00:00	16.055	4.217	0.183	
2/15/2023	9:01:00	16.053	4.227	0.17	
2/15/2023	9:02:00	16.059	4.216	0.178	

2/15/2023	9:03:00	16.054	4.216	0.181	
2/15/2023	9:04:00	16.059	4.198	0.178	
2/15/2023	9:05:00	16.065	4.19	0.195	
2/15/2023	9:06:00	16.059	4.203	0.183	3
2/15/2023	9:07:00	16.061	4.204	0.206	
2/15/2023	9:08:00	16.048	4.202	0.157	
2/15/2023	9:09:00	16.055	4.221	0.17	
2/15/2023	9:10:00	16.066	4.201	0.167	
2/15/2023	9:11:00	16.059	4.196	0.207	
2/15/2023	9:12:00	16.061	4.203	0.203	
2/15/2023	9:13:00	16.051	4.207	0.219	
2/15/2023	9:14:00	16.046	4.217	0.216	
2/15/2023	9:15:00	16.056	4.202	0.21	
2/15/2023	9:16:00	16.052	4.202	0.199	2
2/15/2023	9:17:00	16.059	4.198	0.203	
2/15/2023	9:18:00	16.062	4.199	0.217	
2/15/2023	9:19:00	16.058	4.201	0.222	
2/15/2023	9:20:00	16.063	4.204	0.191	
2/15/2023	9:21:00	16.062	4.193	0.008	
2/15/2023	9:22:00	16.064	4.189	0.029	
2/15/2023	9:23:00	16.065	4.188	0.002	
2/15/2023	9:24:00	16.063	4.189	0.017	
2/15/2023	9:25:00	16.054	4.191	0.011	
2/15/2023	9:26:00	16.053	4.196	0.019	1
2/15/2023	9:27:00	16.056	4.185	0.019	
2/15/2023	9:28:00	16.046	4.199	0.015	
2/15/2023	9:29:00	16.051	4.207	0.005	
2/15/2023	9:30:00	16.049	4.212	0.001	
2/15/2023	9:31:00	16.062	4.196	0.006	
2/15/2023	9:32:00	16.062	4.199	0.033	
2/15/2023	9:33:00	16.056	4.196	0.023	
2/15/2023	9:34:00	16.075	4.173	0.053	
2/15/2023	9:35:00	16.067	4.174	0.019	
2/15/2023	9:36:00	16.053	4.187	0.1	
2/15/2023	9:37:00	16.055	4.194	0.027	
2/15/2023	9:38:00	10.54	4.711	0.354	
2/15/2023	9:39:00	10.053	4.824	0.588	
2/15/2023	9:40:00	10.901	4.917	-0.006	
2/15/2023	9:41:00	10.05	4.814	-0.011	< System O2, CO2
2/15/2023	9:42:00	7.56	2.89	0.261	
2/15/2023	9:43:00	-0.04	-0.121	4.127	
2/15/2023	9:44:00	-0.041	-0.011	4.693	< System CO
2/15/2023	9:45:00	12.926	3.527	3.427	
2/15/2023	9:46:00	16.061	4.223	0.927	< Resume
2/15/2023	9:47:00	16.07	4.212	0.025	12
2/15/2023	9:48:00	16.065	4.215	0.032	
2/15/2023	9:49:00	16.068	4.206	0.033	
2/15/2023	9:50:00	16.074	4.195	0.032	
2/15/2023	9:51:00	16.061	4.189	0.034	
2/15/2023	9:52:00	16.069	4.179	0.043	
2/15/2023	9:53:00	16.068	4.184	0.044	
2/15/2023	9:54:00	16.072	4.178	0.051	
2/15/2023	9:55:00	16.072	4.181	0.045	
2/15/2023	9:56:00	16.073	4.175	0.032	
2/15/2023	9:57:00	16.073	4.172	0.044	11

2/15/2023	9:58:00	16.07	4.191	0.048	
2/15/2023	9:59:00	16.068	4.196	0.05	
2/15/2023	10:00:00	16.057	4.212	0.046	
2/15/2023	10:01:00	16.049	4.211	0.039	
2/15/2023	10:02:00	16.068	4.197	0.008	
2/15/2023	10:03:00	16.075	4.199	0.019	
2/15/2023	10:04:00	16.075	4.203	0.002	
2/15/2023	10:05:00	16.066	4.197	0.036	
2/15/2023	10:06:00	16.068	4.184	0.035	
2/15/2023	10:07:00	16.07	4.181	0.032	10
2/15/2023	10:08:00	16.074	4.172	0.048	
2/15/2023	10:09:00	16.084	4.184	0.053	
2/15/2023	10:10:00	16.074	4.204	0.039	
2/15/2023	10:11:00	16.075	4.203	0.036	
2/15/2023	10:12:00	16.066	4.206	0.029	
2/15/2023	10:13:00	16.069	4.203	0.047	
2/15/2023	10:14:00	16.067	4.198	0.052	
2/15/2023	10:15:00	16.067	4.194	0.055	
2/15/2023	10:16:00	16.073	4.19	0.056	
2/15/2023	10:17:00	16.074	4.202	0.04	9
2/15/2023	10:18:00	16.068	4.217	0.039	
2/15/2023	10:19:00	16.064	4.221	0.042	
2/15/2023	10:20:00	16.064	4.219	0.059	
2/15/2023	10:21:00	16.049	4.225	0.057	
2/15/2023	10:22:00	16.066	4.201	0.017	
2/15/2023	10:23:00	16.066	4.204	0.031	
2/15/2023	10:24:00	16.06	4.216	0.018	
2/15/2023	10:25:00	16.057	4.231	0.059	
2/15/2023	10:26:00	16.065	4.221	0.052	
2/15/2023	10:27:00	16.07	4.22	0.056	8
2/15/2023	10:28:00	16.078	4.203	0.089	
2/15/2023	10:29:00	16.067	4.226	0.056	
2/15/2023	10:30:00	16.069	4.22	0.077	
2/15/2023	10:31:00	16.064	4.211	0.082	
2/15/2023	10:32:00	16.069	4.217	0.074	
2/15/2023	10:33:00	16.056	4.236	0.076	
2/15/2023	10:34:00	16.066	4.234	0.057	
2/15/2023	10:35:00	16.076	4.229	0.082	
2/15/2023	10:36:00	16.064	4.231	0.048	
2/15/2023	10:37:00	16.075	4.212	0.048	7
2/15/2023	10:38:00	16.071	4.209	0.087	
2/15/2023	10:39:00	16.073	4.203	0.093	
2/15/2023	10:40:00	16.073	4.193	0.072	
2/15/2023	10:41:00	16.076	4.193	0.049	
2/15/2023	10:42:00	16.069	4.225	0.024	
2/15/2023	10:43:00	16.086	4.215	0.075	
2/15/2023	10:44:00	16.077	4.218	0.101	
2/15/2023	10:45:00	16.075	4.214	0.095	
2/15/2023	10:46:00	16.071	4.207	0.078	
2/15/2023	10:47:00	16.083	4.193	0.093	6
2/15/2023	10:48:00	16.073	4.208	0.077	
2/15/2023	10:49:00	16.075	4.215	0.054	
2/15/2023	10:50:00	16.077	4.22	0.06	
2/15/2023	10:51:00	16.083	4.228	0.097	
2/15/2023	10:52:00	16.071	4.224	0.092	

2/15/2023	10:53:00	16.075	4.221	0.09	
2/15/2023	10:54:00	16.07	4.222	0.104	
2/15/2023	10:55:00	16.081	4.218	0.097	
2/15/2023	10:56:00	16.074	4.223	0.086	
2/15/2023	10:57:00	16.068	4.236	0.091	5
2/15/2023	10:58:00	16.075	4.239	0.047	
2/15/2023	10:59:00	16.082	4.246	0.068	
2/15/2023	11:00:00	16.069	4.247	0.083	
2/15/2023	11:01:00	16.077	4.231	0.093	
2/15/2023	11:02:00	16.076	4.23	0.019	
2/15/2023	11:03:00	16.079	4.248	0.006	
2/15/2023	11:04:00	16.077	4.245	0.104	
2/15/2023	11:05:00	16.092	4.234	0.105	
2/15/2023	11:06:00	16.084	4.233	0.111	
2/15/2023	11:07:00	16.073	4.233	0.096	4
2/15/2023	11:08:00	16.091	4.218	0.048	
2/15/2023	11:09:00	16.085	4.229	0.089	
2/15/2023	11:10:00	16.074	4.246	0.153	
2/15/2023	11:11:00	16.06	4.26	0.003	
2/15/2023	11:12:00	16.071	4.248	0.068	
2/15/2023	11:13:00	16.081	4.233	0.035	
2/15/2023	11:14:00	16.088	4.223	0.049	
2/15/2023	11:15:00	16.088	4.218	0.097	
2/15/2023	11:16:00	16.085	4.224	0.092	
2/15/2023	11:17:00	16.084	4.233	0.066	3
2/15/2023	11:18:00	16.08	4.228	0.078	
2/15/2023	11:19:00	16.092	4.214	0.105	
2/15/2023	11:20:00	16.092	4.202	0.093	
2/15/2023	11:21:00	16.09	4.208	0.091	
2/15/2023	11:22:00	16.094	4.207	0.101	
2/15/2023	11:23:00	16.092	4.219	0.092	
2/15/2023	11:24:00	16.096	4.225	0.072	
2/15/2023	11:25:00	16.098	4.217	0.093	
2/15/2023	11:26:00	16.097	4.216	0.089	
2/15/2023	11:27:00	16.086	4.215	0.079	2
2/15/2023	11:28:00	16.09	4.206	0.111	
2/15/2023	11:29:00	16.098	4.213	0.094	
2/15/2023	11:30:00	16.099	4.225	0.097	
2/15/2023	11:31:00	16.098	4.22	0.099	
2/15/2023	11:32:00	16.082	4.233	0.087	
2/15/2023	11:33:00	16.096	4.215	0.098	
2/15/2023	11:34:00	16.089	4.227	0.097	
2/15/2023	11:35:00	16.104	4.223	0.112	
2/15/2023	11:36:00	16.1	4.233	0.108	
2/15/2023	11:37:00	16.102	4.222	0.097	1
2/15/2023	11:38:00	16.102	4.211	0.079	
2/15/2023	11:39:00	16.098	4.211	0.071	
2/15/2023	11:40:00	16.099	4.21	0.078	
2/15/2023	11:41:00	16.104	4.214	0.066	
2/15/2023	11:42:00	16.103	4.21	0.064	
2/15/2023	11:43:00	16.101	4.22	0.051	
2/15/2023	11:44:00	16.096	4.216	0.078	
2/15/2023	11:45:00	16.089	4.213	0.079	
2/15/2023	11:46:00	16.099	4.202	0.065	
2/15/2023	11:47:00	12.766	4.492	0.127	

2/15/2023	11:48:00	10.094	4.898	-0.031	< System O2, CO2
2/15/2023	11:49:00	12.335	4.606	-0.031	
2/15/2023	11:50:00	16.083	4.199	0.231	
2/15/2023	11:51:00	15.315	4.259	0.114	
2/15/2023	11:52:00	0.28	0.182	2.594	
2/15/2023	11:53:00	-0.039	-0.138	4.335	
2/15/2023	11:54:00	-0.037	-0.039	4.628	< System CO
2/15/2023	11:55:00	4.597	0.989	4.606	
2/15/2023	11:56:00	16.1	4.171	1.61	
2/15/2023	11:57:00	16.089	4.173	0.213	
2/15/2023	11:58:00	16.101	4.174	0.069	
2/15/2023	11:59:00	16.11	4.179	0.17	
2/15/2023	12:00:00	16.108	4.179	0.191	< Start Eng 5 Run 4
2/15/2023	12:01:00	16.109	4.175	0.212	12
2/15/2023	12:02:00	16.108	4.166	0.046	
2/15/2023	12:03:00	16.111	4.163	0.005	
2/15/2023	12:04:00	16.104	4.174	0	
2/15/2023	12:05:00	16.109	4.173	0.001	
2/15/2023	12:06:00	16.108	4.178	0.002	
2/15/2023	12:07:00	16.111	4.183	0.005	
2/15/2023	12:08:00	16.105	4.179	0.006	
2/15/2023	12:09:00	16.111	4.179	0.033	
2/15/2023	12:10:00	16.111	4.172	0.022	
2/15/2023	12:11:00	16.106	4.18	0.019	11
2/15/2023	12:12:00	16.111	4.186	0.016	
2/15/2023	12:13:00	16.112	4.176	0.024	
2/15/2023	12:14:00	16.116	4.175	0.062	
2/15/2023	12:15:00	16.107	4.176	0.029	
2/15/2023	12:16:00	16.106	4.188	0.003	
2/15/2023	12:17:00	16.112	4.196	0.016	
2/15/2023	12:18:00	16.112	4.199	0.029	
2/15/2023	12:19:00	16.103	4.211	0.045	
2/15/2023	12:20:00	16.109	4.2	0.021	
2/15/2023	12:21:00	16.109	4.193	0.016	10
2/15/2023	12:22:00	16.105	4.199	0.01	
2/15/2023	12:23:00	16.107	4.202	0.023	
2/15/2023	12:24:00	16.091	4.227	0.048	
2/15/2023	12:25:00	16.095	4.221	0.041	
2/15/2023	12:26:00	16.103	4.226	0.037	
2/15/2023	12:27:00	16.105	4.233	0.025	
2/15/2023	12:28:00	16.101	4.224	0.042	
2/15/2023	12:29:00	16.111	4.221	0.013	
2/15/2023	12:30:00	16.108	4.232	0.021	
2/15/2023	12:31:00	16.111	4.24	0.039	9
2/15/2023	12:32:00	16.104	4.26	0.033	
2/15/2023	12:33:00	16.116	4.25	0.052	
2/15/2023	12:34:00	16.114	4.25	0.046	
2/15/2023	12:35:00	16.115	4.238	0.044	
2/15/2023	12:36:00	16.116	4.244	0.004	
2/15/2023	12:37:00	16.116	4.24	0.001	
2/15/2023	12:38:00	16.112	4.247	0.02	
2/15/2023	12:39:00	16.111	4.257	0.038	
2/15/2023	12:40:00	16.098	4.246	0.03	
2/15/2023	12:41:00	16.112	4.226	0.031	8
2/15/2023	12:42:00	16.111	4.245	0.037	

2/15/2023	12:43:00	16.101	4.263	0.021	
2/15/2023	12:44:00	16.107	4.266	0.041	
2/15/2023	12:45:00	16.111	4.256	0.039	
2/15/2023	12:46:00	16.109	4.237	0.12	
2/15/2023	12:47:00	16.108	4.228	0.005	
2/15/2023	12:48:00	16.101	4.229	0.023	
2/15/2023	12:49:00	16.118	4.227	0.046	
2/15/2023	12:50:00	16.113	4.233	0.067	
2/15/2023	12:51:00	16.113	4.244	0.052	7
2/15/2023	12:52:00	16.116	4.232	0.043	
2/15/2023	12:53:00	16.108	4.215	0.014	
2/15/2023	12:54:00	16.11	4.175	0.04	
2/15/2023	12:55:00	16.112	4.157	0.035	
2/15/2023	12:56:00	16.103	4.166	0.002	
2/15/2023	12:57:00	16.103	4.163	0.056	
2/15/2023	12:58:00	16.1	4.177	0.026	
2/15/2023	12:59:00	16.104	4.164	0.173	
2/15/2023	13:00:00	16.105	4.15	0.085	
2/15/2023	13:01:00	16.11	4.144	0.1	6
2/15/2023	13:02:00	16.112	4.139	0.087	
2/15/2023	13:03:00	16.109	4.156	0.08	
2/15/2023	13:04:00	16.107	4.156	0.091	
2/15/2023	13:05:00	16.103	4.147	0.102	
2/15/2023	13:06:00	16.102	4.132	0.111	
2/15/2023	13:07:00	16.104	4.108	0.087	
2/15/2023	13:08:00	16.104	4.106	0.11	
2/15/2023	13:09:00	16.101	4.105	0.09	
2/15/2023	13:10:00	16.105	4.114	0.097	
2/15/2023	13:11:00	16.106	4.107	0.096	5
2/15/2023	13:12:00	16.088	4.118	0.039	
2/15/2023	13:13:00	16.108	4.101	0.072	
2/15/2023	13:14:00	16.106	4.088	0.08	
2/15/2023	13:15:00	16.112	4.092	0.06	
2/15/2023	13:16:00	16.107	4.102	0.072	
2/15/2023	13:17:00	16.103	4.096	0.062	
2/15/2023	13:18:00	16.09	4.103	0.07	
2/15/2023	13:19:00	16.105	4.092	0.077	
2/15/2023	13:20:00	16.108	4.099	0.076	
2/15/2023	13:21:00	16.093	4.11	0.092	4
2/15/2023	13:22:00	16.108	4.109	0.076	
2/15/2023	13:23:00	16.115	4.099	0.074	
2/15/2023	13:24:00	16.116	4.087	0.087	
2/15/2023	13:25:00	16.112	4.08	0.093	
2/15/2023	13:26:00	16.107	4.084	0.075	
2/15/2023	13:27:00	16.111	4.089	0.085	
2/15/2023	13:28:00	16.11	4.1	0.084	
2/15/2023	13:29:00	16.113	4.104	0.076	
2/15/2023	13:30:00	16.117	4.076	0.073	
2/15/2023	13:31:00	16.114	4.07	0.073	3
2/15/2023	13:32:00	16.112	4.071	0.078	
2/15/2023	13:33:00	16.113	4.066	0.044	
2/15/2023	13:34:00	16.114	4.07	0.062	
2/15/2023	13:35:00	16.108	4.083	0.038	
2/15/2023	13:36:00	16.113	4.071	0.045	
2/15/2023	13:37:00	16.107	4.076	0.082	

2/15/2023	13:38:00	16.101	4.08	0.115	
2/15/2023	13:39:00	16.112	4.061	0.08	
2/15/2023	13:40:00	16.103	4.048	0.084	
2/15/2023	13:41:00	16.102	4.062	0.085	2
2/15/2023	13:42:00	16.111	4.077	0.094	
2/15/2023	13:43:00	16.117	4.083	0.061	
2/15/2023	13:44:00	16.118	4.111	0.057	
2/15/2023	13:45:00	16.118	4.102	0.051	
2/15/2023	13:46:00	16.125	4.104	0.007	
2/15/2023	13:47:00	16.116	4.11	0.034	
2/15/2023	13:48:00	16.112	4.124	0.094	
2/15/2023	13:49:00	16.118	4.142	0.065	
2/15/2023	13:50:00	16.112	4.151	0.039	
2/15/2023	13:51:00	16.106	4.151	0.061	1
2/15/2023	13:52:00	16.11	4.141	0.066	
2/15/2023	13:53:00	16.116	4.135	0.08	
2/15/2023	13:54:00	16.116	4.144	0.051	
2/15/2023	13:55:00	16.113	4.154	0.097	
2/15/2023	13:56:00	16.116	4.166	0.096	
2/15/2023	13:57:00	16.127	4.152	0.096	
2/15/2023	13:58:00	16.111	4.156	0.062	
2/15/2023	13:59:00	16.107	4.141	0.011	
2/15/2023	14:00:00	16.116	4.141	0.057	
2/15/2023	14:01:00	14.572	4.253	0.124	
2/15/2023	14:02:00	10.088	4.826	0.553	
2/15/2023	14:03:00	10.083	4.816	0.588	
2/15/2023	14:04:00	10.082	4.816	0.588	
2/15/2023	14:05:00	10.081	4.811	0.588	
2/15/2023	14:06:00	10.091	4.905	-0.019	< System O2, CO2
2/15/2023	14:07:00	6.491	3.239	1.705	
2/15/2023	14:08:00	-0.044	-0.181	4.821	
2/15/2023	14:09:00	-0.041	-0.011	4.637	< System CO
2/15/2023	14:10:00	0.719	-0.148	4.749	
2/15/2023	14:11:00	16.071	4.137	2.371	< Resume
2/15/2023	14:12:00	16.103	4.157	0.914	12
2/15/2023	14:13:00	16.102	4.166	0.932	
2/15/2023	14:14:00	16.103	4.174	0.896	
2/15/2023	14:15:00	16.109	4.166	0.764	
2/15/2023	14:16:00	16.105	4.159	0.01	
2/15/2023	14:17:00	16.116	4.166	0.002	
2/15/2023	14:18:00	16.097	4.188	0.014	
2/15/2023	14:19:00	16.1	4.189	0.031	
2/15/2023	14:20:00	16.105	4.195	0.036	
2/15/2023	14:21:00	16.099	4.205	0.019	
2/15/2023	14:22:00	16.095	4.198	0.01	11
2/15/2023	14:23:00	16.105	4.175	0.028	
2/15/2023	14:24:00	16.103	4.181	0.001	
2/15/2023	14:25:00	16.09	4.194	0.019	
2/15/2023	14:26:00	16.104	4.203	0.022	
2/15/2023	14:27:00	16.115	4.179	0.034	
2/15/2023	14:28:00	16.113	4.177	0.03	
2/15/2023	14:29:00	16.107	4.178	0.046	
2/15/2023	14:30:00	16.111	4.177	0.017	
2/15/2023	14:31:00	16.103	4.198	0.005	
2/15/2023	14:32:00	16.104	4.2	0.029	10

2/15/2023	14:33:00	16.11	4.181	0.031	
2/15/2023	14:34:00	16.113	4.176	0.033	
2/15/2023	14:35:00	16.111	4.17	0.027	
2/15/2023	14:36:00	16.104	4.17	0.047	
2/15/2023	14:37:00	16.091	4.216	0.055	
2/15/2023	14:38:00	16.091	4.227	0.051	
2/15/2023	14:39:00	16.103	4.202	0.058	
2/15/2023	14:40:00	16.108	4.185	0.071	
2/15/2023	14:41:00	16.109	4.177	0.059	
2/15/2023	14:42:00	16.108	4.17	0.066	9
2/15/2023	14:43:00	16.092	4.188	0.063	
2/15/2023	14:44:00	16.104	4.181	0.052	
2/15/2023	14:45:00	16.115	4.189	0.053	
2/15/2023	14:46:00	16.116	4.185	0.071	
2/15/2023	14:47:00	16.104	4.185	0.047	
2/15/2023	14:48:00	16.11	4.18	0.04	
2/15/2023	14:49:00	16.108	4.181	0.057	
2/15/2023	14:50:00	16.109	4.186	0.058	
2/15/2023	14:51:00	16.108	4.188	0.063	
2/15/2023	14:52:00	16.109	4.161	0.065	8
2/15/2023	14:53:00	16.116	4.15	0.07	
2/15/2023	14:54:00	16.103	4.164	0.075	
2/15/2023	14:55:00	16.105	4.164	0.07	
2/15/2023	14:56:00	16.101	4.189	0.061	
2/15/2023	14:57:00	16.106	4.18	0.061	
2/15/2023	14:58:00	16.107	4.17	0.045	
2/15/2023	14:59:00	16.109	4.175	0.034	
2/15/2023	15:00:00	16.105	4.178	0.04	
2/15/2023	15:01:00	16.111	4.17	0.038	
2/15/2023	15:02:00	16.108	4.186	0.041	7
2/15/2023	15:03:00	16.106	4.186	0.029	
2/15/2023	15:04:00	16.113	4.175	0.001	
2/15/2023	15:05:00	16.116	4.169	0.011	
2/15/2023	15:06:00	16.112	4.166	0.022	
2/15/2023	15:07:00	16.111	4.169	0.013	
2/15/2023	15:08:00	16.113	4.189	0.045	
2/15/2023	15:09:00	16.112	4.176	0.048	
2/15/2023	15:10:00	16.105	4.168	0.046	
2/15/2023	15:11:00	16.104	4.155	0.053	
2/15/2023	15:12:00	16.109	4.161	0.026	6
2/15/2023	15:13:00	16.106	4.177	0.066	
2/15/2023	15:14:00	16.106	4.193	0.055	
2/15/2023	15:15:00	16.103	4.186	0.071	
2/15/2023	15:16:00	16.106	4.181	0.078	
2/15/2023	15:17:00	16.109	4.179	0.082	
2/15/2023	15:18:00	16.112	4.17	0.081	
2/15/2023	15:19:00	16.115	4.177	0.072	
2/15/2023	15:20:00	16.084	4.221	0.076	
2/15/2023	15:21:00	16.103	4.193	0.055	
2/15/2023	15:22:00	16.102	4.177	0.076	5
2/15/2023	15:23:00	16.107	4.162	0.066	
2/15/2023	15:24:00	16.118	4.152	0.071	
2/15/2023	15:25:00	16.12	4.18	0.065	
2/15/2023	15:26:00	16.094	4.213	0.028	
2/15/2023	15:27:00	16.087	4.208	0.065	

2/15/2023	15:28:00	16.11	4.17	0.06	
2/15/2023	15:29:00	16.111	4.161	0.083	
2/15/2023	15:30:00	16.118	4.157	0.079	
2/15/2023	15:31:00	16.098	4.188	0.08	
2/15/2023	15:32:00	16.097	4.208	0.073	4
2/15/2023	15:33:00	16.108	4.188	0.057	
2/15/2023	15:34:00	16.112	4.171	0.073	
2/15/2023	15:35:00	16.111	4.169	0.051	
2/15/2023	15:36:00	16.112	4.175	0.056	
2/15/2023	15:37:00	16.111	4.187	0.07	
2/15/2023	15:38:00	16.113	4.204	0.07	
2/15/2023	15:39:00	16.105	4.206	0.061	
2/15/2023	15:40:00	16.108	4.177	0.043	
2/15/2023	15:41:00	16.128	4.155	0.025	
2/15/2023	15:42:00	16.127	4.149	0.036	3
2/15/2023	15:43:00	16.115	4.161	0.051	
2/15/2023	15:44:00	16.106	4.187	0.046	
2/15/2023	15:45:00	16.105	4.202	0.05	
2/15/2023	15:46:00	16.098	4.194	0.063	
2/15/2023	15:47:00	16.119	4.166	0.074	
2/15/2023	15:48:00	16.119	4.16	0.081	
2/15/2023	15:49:00	16.11	4.15	0.08	
2/15/2023	15:50:00	16.108	4.164	0.066	
2/15/2023	15:51:00	16.103	4.181	0.053	
2/15/2023	15:52:00	16.104	4.194	0.032	2
2/15/2023	15:53:00	16.112	4.173	0.011	
2/15/2023	15:54:00	16.11	4.155	0.044	
2/15/2023	15:55:00	16.116	4.149	0.079	
2/15/2023	15:56:00	16.106	4.161	0.077	
2/15/2023	15:57:00	16.107	4.171	0.082	
2/15/2023	15:58:00	16.108	4.177	0.06	
2/15/2023	15:59:00	16.109	4.177	0.053	
2/15/2023	16:00:00	16.104	4.16	0.024	
2/15/2023	16:01:00	16.096	4.168	0.001	
2/15/2023	16:02:00	16.117	4.156	0.051	1
2/15/2023	16:03:00	16.114	4.167	0.071	
2/15/2023	16:04:00	16.111	4.168	0.054	
2/15/2023	16:05:00	16.11	4.162	0.065	
2/15/2023	16:06:00	16.103	4.172	0.062	
2/15/2023	16:07:00	16.114	4.15	0.059	
2/15/2023	16:08:00	16.099	4.157	0.018	
2/15/2023	16:09:00	16.108	4.156	0.031	
2/15/2023	16:10:00	16.094	4.178	0.039	
2/15/2023	16:11:00	16.103	4.161	0.025	
2/15/2023	16:12:00	16.107	4.151	0.017	
2/15/2023	16:13:00	16.102	4.151	0.018	
2/15/2023	16:14:00	10.976	4.652	-0.315	
2/15/2023	16:15:00	10.093	4.925	-0.08	< System O2, CO2
2/15/2023	16:16:00	7.497	3.829	0.753	
2/15/2023	16:17:00	-0.026	-0.013	4.603	< System CO
2/15/2023	16:18:00	1.738	0.141	4.584	
2/15/2023	16:19:00	17.516	6.327	2.305	
2/15/2023	16:20:00	19.276	9.619	7.52	
2/15/2023	16:21:00	19.278	9.647	9.652	
2/15/2023	16:22:00	19.282	9.647	9.655	< Direct High

2/15/2023	16:23:00	14.848	7.47	9.387
2/15/2023	16:24:00	10.096	4.981	5.177
2/15/2023	16:25:00	10.096	4.978	4.582
				< Direct Mid
2/15/2023	16:26:00	10.094	4.964	4.605
2/15/2023	16:27:00	2.206	1.271	3.745
2/15/2023	16:28:00	-0.023	0.049	0.222
2/15/2023	16:29:00	-0.025	0.061	0.108
2/15/2023	16:30:00	-0.026	0.067	-0.014
				< Direct Zero
2/15/2023	16:31:00	-0.027	0.07	-0.024

Date	Time	O2%	CO2%	CO ppm	
2/16/2023	7:17:00	-0.031	-0.009	0.708	
2/16/2023	7:18:00	-0.033	-0.036	-0.032	< Direct Zero
2/16/2023	7:19:00	5.38	2.355	-0.022	
2/16/2023	7:20:00	19.328	9.642	6.294	
2/16/2023	7:21:00	19.287	9.635	9.553	
2/16/2023	7:22:00	19.291	9.63	9.6	< Direct High
2/16/2023	7:23:00	11.442	5.327	7.028	
2/16/2023	7:24:00	10.099	4.911	4.52	
2/16/2023	7:25:00	10.103	4.906	4.611	< Direct Mid
2/16/2023	7:26:00	15.714	3.566	3.882	
2/16/2023	7:27:00	16.094	4.294	0.55	
2/16/2023	7:28:00	10.694	4.827	-0.033	
2/16/2023	7:29:00	10.065	4.943	-0.052	< System O2, CO2
2/16/2023	7:30:00	3.994	1.677	1.918	
2/16/2023	7:31:00	-0.043	-0.048	4.699	
2/16/2023	7:32:00	-0.041	-0.053	4.645	< System CO
2/16/2023	7:33:00	10.46	2.763	3.904	
2/16/2023	7:34:00	16.113	4.28	0.974	
2/16/2023	7:35:00	16.11	4.275	0.813	< Start Eng 5 Run 5 0735
2/16/2023	7:36:00	16.109	4.283	0.802	12
2/16/2023	7:37:00	16.109	4.276	0.773	
2/16/2023	7:38:00	16.109	4.274	0.417	
2/16/2023	7:39:00	16.119	4.276	0.04	
2/16/2023	7:40:00	16.116	4.29	0.04	
2/16/2023	7:41:00	16.099	4.29	0.064	
2/16/2023	7:42:00	16.1	4.292	0.046	
2/16/2023	7:43:00	16.099	4.302	0.041	
2/16/2023	7:44:00	16.103	4.298	0.113	
2/16/2023	7:45:00	16.103	4.292	0.108	
2/16/2023	7:46:00	16.104	4.29	0.084	11
2/16/2023	7:47:00	16.106	4.285	0.052	
2/16/2023	7:48:00	16.111	4.287	0.029	
2/16/2023	7:49:00	16.1	4.293	0.064	
2/16/2023	7:50:00	16.107	4.278	0.058	
2/16/2023	7:51:00	16.106	4.28	0.19	
2/16/2023	7:52:00	16.083	4.296	0.056	
2/16/2023	7:53:00	16.105	4.277	0.047	
2/16/2023	7:54:00	16.111	4.277	0.186	
2/16/2023	7:55:00	16.103	4.275	0.081	
2/16/2023	7:56:00	16.113	4.262	0.081	10
2/16/2023	7:57:00	16.109	4.269	0.102	
2/16/2023	7:58:00	16.117	4.275	0.169	
2/16/2023	7:59:00	16.119	4.259	0.254	
2/16/2023	8:00:00	16.106	4.268	0.328	
2/16/2023	8:01:00	16.106	4.276	0.253	
2/16/2023	8:02:00	16.099	4.282	0.191	
2/16/2023	8:03:00	16.106	4.279	0.295	
2/16/2023	8:04:00	16.115	4.277	0.33	
2/16/2023	8:05:00	16.09	4.296	0.149	
2/16/2023	8:06:00	16.107	4.274	0.09	9
2/16/2023	8:07:00	16.121	4.248	0.027	
2/16/2023	8:08:00	16.133	4.235	0.159	
2/16/2023	8:09:00	16.132	4.24	0.18	
2/16/2023	8:10:00	16.125	4.256	0.156	

2/16/2023	8:11:00	16.117	4.272	0.165	
2/16/2023	8:12:00	16.11	4.275	0.161	
2/16/2023	8:13:00	16.113	4.254	0.196	
2/16/2023	8:14:00	16.111	4.258	0.222	
2/16/2023	8:15:00	16.095	4.26	0.135	
2/16/2023	8:16:00	16.102	4.251	0.1	8
2/16/2023	8:17:00	16.104	4.255	0.204	
2/16/2023	8:18:00	16.109	4.25	0.231	
2/16/2023	8:19:00	16.111	4.241	0.241	
2/16/2023	8:20:00	16.116	4.23	0.244	
2/16/2023	8:21:00	16.109	4.244	0.212	
2/16/2023	8:22:00	16.112	4.249	0.188	
2/16/2023	8:23:00	16.114	4.25	0.194	
2/16/2023	8:24:00	16.111	4.24	0.282	
2/16/2023	8:25:00	16.11	4.242	0.249	
2/16/2023	8:26:00	16.112	4.247	0.063	7
2/16/2023	8:27:00	16.119	4.226	0.166	
2/16/2023	8:28:00	16.116	4.236	0.249	
2/16/2023	8:29:00	16.125	4.228	0.292	
2/16/2023	8:30:00	16.115	4.227	0.242	
2/16/2023	8:31:00	16.116	4.222	0.223	
2/16/2023	8:32:00	16.118	4.227	0.267	
2/16/2023	8:33:00	16.114	4.235	0.217	
2/16/2023	8:34:00	16.114	4.235	0.084	
2/16/2023	8:35:00	16.124	4.218	0.018	
2/16/2023	8:36:00	16.125	4.215	0.037	6
2/16/2023	8:37:00	16.124	4.218	0.002	
2/16/2023	8:38:00	16.113	4.226	0.058	
2/16/2023	8:39:00	16.115	4.224	0.076	
2/16/2023	8:40:00	16.112	4.227	0.078	
2/16/2023	8:41:00	16.113	4.217	0.112	
2/16/2023	8:42:00	16.112	4.228	0.021	
2/16/2023	8:43:00	16.111	4.225	0.029	
2/16/2023	8:44:00	16.104	4.232	0.004	
2/16/2023	8:45:00	16.087	4.243	0.062	
2/16/2023	8:46:00	16.103	4.224	0.04	5
2/16/2023	8:47:00	16.107	4.229	0.096	
2/16/2023	8:48:00	16.119	4.216	0.026	
2/16/2023	8:49:00	16.112	4.221	0.022	
2/16/2023	8:50:00	16.114	4.223	0.062	
2/16/2023	8:51:00	16.06	4.273	0.025	
2/16/2023	8:52:00	16.082	4.244	0.098	
2/16/2023	8:53:00	16.101	4.225	0.096	
2/16/2023	8:54:00	16.105	4.216	0.016	
2/16/2023	8:55:00	16.113	4.208	0.054	
2/16/2023	8:56:00	16.119	4.21	0.006	4
2/16/2023	8:57:00	16.125	4.211	0.07	
2/16/2023	8:58:00	16.116	4.213	0.098	
2/16/2023	8:59:00	16.117	4.212	0.072	
2/16/2023	9:00:00	16.116	4.203	0.068	
2/16/2023	9:01:00	16.111	4.222	0.056	
2/16/2023	9:02:00	16.118	4.215	0.026	
2/16/2023	9:03:00	16.099	4.225	0.008	
2/16/2023	9:04:00	16.114	4.225	0.005	
2/16/2023	9:05:00	16.085	4.242	0.036	

2/16/2023	9:06:00	16.11	4.229	0.049	3
2/16/2023	9:07:00	16.107	4.224	0.092	
2/16/2023	9:08:00	16.115	4.221	0.014	
2/16/2023	9:09:00	16.113	4.225	0.001	
2/16/2023	9:10:00	16.123	4.221	0.098	
2/16/2023	9:11:00	16.107	4.231	0.005	
2/16/2023	9:12:00	16.102	4.231	0.065	
2/16/2023	9:13:00	16.099	4.229	0.036	
2/16/2023	9:14:00	16.113	4.21	0.096	
2/16/2023	9:15:00	16.113	4.224	0.006	
2/16/2023	9:16:00	16.115	4.217	0.139	2
2/16/2023	9:17:00	16.11	4.221	0.099	
2/16/2023	9:18:00	16.115	4.208	0.049	
2/16/2023	9:19:00	16.119	4.213	0.072	
2/16/2023	9:20:00	16.113	4.216	0.073	
2/16/2023	9:21:00	16.105	4.214	0.305	
2/16/2023	9:22:00	16.108	4.203	0.148	
2/16/2023	9:23:00	16.109	4.205	0.125	
2/16/2023	9:24:00	16.107	4.195	0.049	
2/16/2023	9:25:00	16.125	4.173	0.009	
2/16/2023	9:26:00	16.105	4.184	0.147	1
2/16/2023	9:27:00	16.115	4.165	0.196	
2/16/2023	9:28:00	16.122	4.134	0.056	
2/16/2023	9:29:00	16.092	4.157	0.184	
2/16/2023	9:30:00	16.103	4.142	0.335	
2/16/2023	9:31:00	16.109	4.133	0.108	
2/16/2023	9:32:00	16.115	4.137	0.191	
2/16/2023	9:33:00	16.073	4.161	0.017	
2/16/2023	9:34:00	16.116	4.122	0.116	
2/16/2023	9:35:00	16.066	4.169	0.072	
2/16/2023	9:36:00	12.044	4.535	0.206	
2/16/2023	9:37:00	10.051	4.794	0.399	
2/16/2023	9:38:00	10.053	4.9	-0.021	< System O2, CO2
2/16/2023	9:39:00	2.036	1.05	1.779	
2/16/2023	9:40:00	-0.034	-0.025	4.707	< System CO
2/16/2023	9:41:00	1.021	0.119	4.609	
2/16/2023	9:42:00	15.403	4.222	2.841	
2/16/2023	9:43:00	16.089	4.154	1.075	
2/16/2023	9:44:00	16.113	4.159	1.11	
2/16/2023	9:45:00	16.112	4.158	1.07	< Resume
2/16/2023	9:46:00	16.105	4.168	0.93	12
2/16/2023	9:47:00	16.088	4.176	1.151	
2/16/2023	9:48:00	16.105	4.156	0.19	
2/16/2023	9:49:00	16.107	4.16	0.056	
2/16/2023	9:50:00	16.105	4.178	0.053	
2/16/2023	9:51:00	16.108	4.187	0.024	
2/16/2023	9:52:00	16.049	4.255	0.05	
2/16/2023	9:53:00	16.069	4.231	0.073	
2/16/2023	9:54:00	16.082	4.203	0.022	
2/16/2023	9:55:00	16.057	4.231	0.11	
2/16/2023	9:56:00	16.076	4.216	0.315	11
2/16/2023	9:57:00	16.108	4.197	0.635	
2/16/2023	9:58:00	16.081	4.227	0.071	
2/16/2023	9:59:00	16.067	4.236	0.098	
2/16/2023	10:00:00	16.09	4.197	0.158	

2/16/2023	10:01:00	16.102	4.18	0.018	
2/16/2023	10:02:00	16.105	4.178	0.158	
2/16/2023	10:03:00	16.102	4.179	0.097	
2/16/2023	10:04:00	16.049	4.241	0.379	
2/16/2023	10:05:00	16.09	4.193	0.144	
2/16/2023	10:06:00	16.108	4.185	0.04	10
2/16/2023	10:07:00	16.115	4.191	0.06	
2/16/2023	10:08:00	16.103	4.2	0.079	
2/16/2023	10:09:00	16.084	4.216	0.096	
2/16/2023	10:10:00	16.095	4.216	0.076	
2/16/2023	10:11:00	16.079	4.229	0.304	
2/16/2023	10:12:00	16.097	4.212	0.416	
2/16/2023	10:13:00	16.093	4.22	0.142	
2/16/2023	10:14:00	16.092	4.228	0.085	
2/16/2023	10:15:00	16.099	4.222	0.049	
2/16/2023	10:16:00	16.083	4.228	0.039	9
2/16/2023	10:17:00	16.081	4.23	0.133	
2/16/2023	10:18:00	16.082	4.219	0.381	
2/16/2023	10:19:00	16.087	4.203	0.003	
2/16/2023	10:20:00	16.095	4.19	0.151	
2/16/2023	10:21:00	16.069	4.215	0.037	
2/16/2023	10:22:00	16.079	4.203	0.059	
2/16/2023	10:23:00	16.088	4.202	0.049	
2/16/2023	10:24:00	16.095	4.199	0.032	
2/16/2023	10:25:00	16.086	4.206	0.102	
2/16/2023	10:26:00	16.09	4.197	0.02	8
2/16/2023	10:27:00	16.093	4.2	0.06	
2/16/2023	10:28:00	16.09	4.192	0.004	
2/16/2023	10:29:00	16.094	4.182	0.033	
2/16/2023	10:30:00	16.088	4.19	0.029	
2/16/2023	10:31:00	16.1	4.173	0.095	
2/16/2023	10:32:00	16.083	4.18	0.153	
2/16/2023	10:33:00	16.075	4.192	0.029	
2/16/2023	10:34:00	16.07	4.197	0.42	
2/16/2023	10:35:00	16.091	4.176	0.109	
2/16/2023	10:36:00	16.082	4.177	0.005	7
2/16/2023	10:37:00	16.084	4.172	0.163	
2/16/2023	10:38:00	16.089	4.169	0.016	
2/16/2023	10:39:00	16.104	4.162	0.067	
2/16/2023	10:40:00	16.066	4.188	0.11	
2/16/2023	10:41:00	16.084	4.165	0.165	
2/16/2023	10:42:00	16.112	4.144	0.03	
2/16/2023	10:43:00	16.082	4.161	0.095	
2/16/2023	10:44:00	16.096	4.152	0.103	
2/16/2023	10:45:00	16.095	4.152	0.124	
2/16/2023	10:46:00	16.079	4.162	0.03	6
2/16/2023	10:47:00	16.108	4.145	0.134	
2/16/2023	10:48:00	16.101	4.154	0.163	
2/16/2023	10:49:00	16.095	4.152	0.1	
2/16/2023	10:50:00	16.101	4.156	0.086	
2/16/2023	10:51:00	16.112	4.142	0.19	
2/16/2023	10:52:00	16.098	4.145	0.204	
2/16/2023	10:53:00	16.098	4.148	0.195	
2/16/2023	10:54:00	16.093	4.151	0.197	
2/16/2023	10:55:00	16.101	4.148	0.189	

2/16/2023	10:56:00	16.107	4.155	0.162	5
2/16/2023	10:57:00	16.105	4.159	0.106	
2/16/2023	10:58:00	16.087	4.145	0.139	
2/16/2023	10:59:00	16.077	4.152	0.173	
2/16/2023	11:00:00	16.115	4.143	0.197	
2/16/2023	11:01:00	16.102	4.148	0.149	
2/16/2023	11:02:00	16.091	4.153	0.208	
2/16/2023	11:03:00	16.1	4.139	0.188	
2/16/2023	11:04:00	16.093	4.149	0.211	
2/16/2023	11:05:00	16.078	4.158	0.173	
2/16/2023	11:06:00	16.099	4.139	0.037	4
2/16/2023	11:07:00	16.092	4.142	0.153	
2/16/2023	11:08:00	16.088	4.139	0.058	
2/16/2023	11:09:00	16.092	4.132	0.073	
2/16/2023	11:10:00	16.085	4.152	0.053	
2/16/2023	11:11:00	16.108	4.16	0.017	
2/16/2023	11:12:00	16.091	4.173	0.071	
2/16/2023	11:13:00	16.096	4.178	0.267	
2/16/2023	11:14:00	16.092	4.173	0.028	
2/16/2023	11:15:00	16.092	4.164	0.023	
2/16/2023	11:16:00	16.095	4.152	0.003	3
2/16/2023	11:17:00	16.092	4.151	0.022	
2/16/2023	11:18:00	16.097	4.152	0.199	
2/16/2023	11:19:00	16.088	4.153	0.027	
2/16/2023	11:20:00	16.091	4.175	0.168	
2/16/2023	11:21:00	16.087	4.184	0.058	
2/16/2023	11:22:00	16.1	4.188	0.047	
2/16/2023	11:23:00	16.105	4.192	0.018	
2/16/2023	11:24:00	16.097	4.196	0.031	
2/16/2023	11:25:00	16.101	4.179	0.117	
2/16/2023	11:26:00	16.102	4.181	0.074	2
2/16/2023	11:27:00	16.094	4.176	0.022	
2/16/2023	11:28:00	16.101	4.167	0.053	
2/16/2023	11:29:00	16.099	4.176	0.02	
2/16/2023	11:30:00	16.079	4.178	0.386	
2/16/2023	11:31:00	16.105	4.171	0.059	
2/16/2023	11:32:00	16.105	4.152	0.063	
2/16/2023	11:33:00	16.105	4.142	0.007	
2/16/2023	11:34:00	16.103	4.134	0.132	
2/16/2023	11:35:00	16.103	4.124	0.018	
2/16/2023	11:36:00	16.098	4.107	0.061	1
2/16/2023	11:37:00	16.081	4.098	0.083	
2/16/2023	11:38:00	16.12	4.087	0.077	
2/16/2023	11:39:00	16.108	4.101	0.068	
2/16/2023	11:40:00	16.093	4.093	0.014	
2/16/2023	11:41:00	16.104	4.073	0.017	
2/16/2023	11:42:00	16.094	4.069	0.012	
2/16/2023	11:43:00	16.07	4.079	0.008	
2/16/2023	11:44:00	16.089	4.084	0.016	
2/16/2023	11:45:00	16.1	4.1	0.027	
2/16/2023	11:46:00	14.41	4.229	0.083	
2/16/2023	11:47:00	10.086	4.756	0.481	
2/16/2023	11:48:00	10.052	4.952	-0.007	< System O2, CO2
2/16/2023	11:49:00	6.402	3.119	0.162	
2/16/2023	11:50:00	-0.041	-0.142	3.882	

2/16/2023	11:51:00	-0.01	-0.047	4.648	< System CO
2/16/2023	11:52:00	-0.031	-0.049	4.652	
2/16/2023	11:53:00	-0.044	-0.048	4.648	
2/16/2023	11:54:00	14.54	3.635	3.012	
2/16/2023	11:55:00	16.095	4.105	1.085	
2/16/2023	11:56:00	16.091	4.114	0.433	
2/16/2023	11:57:00	16.094	4.111	0.02	
2/16/2023	11:58:00	16.103	4.096	0.168	
2/16/2023	11:59:00	16.088	4.107	0.021	
2/16/2023	12:00:00	16.098	4.096	0.025	< Start Eng 5 Run 6 1200
2/16/2023	12:01:00	16.085	4.112	0.003	12
2/16/2023	12:02:00	16.084	4.125	0.134	
2/16/2023	12:03:00	16.086	4.138	0.02	
2/16/2023	12:04:00	16.09	4.146	0.028	
2/16/2023	12:05:00	16.093	4.127	0.003	
2/16/2023	12:06:00	16.108	4.105	0.034	
2/16/2023	12:07:00	16.092	4.107	0.002	
2/16/2023	12:08:00	16.109	4.076	0.028	
2/16/2023	12:09:00	16.105	4.081	0.275	
2/16/2023	12:10:00	16.093	4.088	0.107	
2/16/2023	12:11:00	16.081	4.097	0.062	11
2/16/2023	12:12:00	16.092	4.095	0.005	
2/16/2023	12:13:00	16.092	4.111	0.02	
2/16/2023	12:14:00	16.099	4.104	0.07	
2/16/2023	12:15:00	16.097	4.106	0.066	
2/16/2023	12:16:00	16.093	4.101	0.037	
2/16/2023	12:17:00	16.091	4.097	0.245	
2/16/2023	12:18:00	16.115	4.101	0.013	
2/16/2023	12:19:00	16.088	4.086	0.027	
2/16/2023	12:20:00	16.092	4.089	0.048	
2/16/2023	12:21:00	16.084	4.105	0.163	10
2/16/2023	12:22:00	16.096	4.11	0.117	
2/16/2023	12:23:00	16.091	4.119	0.058	
2/16/2023	12:24:00	16.083	4.116	0.009	
2/16/2023	12:25:00	16.095	4.101	0.017	
2/16/2023	12:26:00	16.098	4.099	0.068	
2/16/2023	12:27:00	16.079	4.115	0.061	
2/16/2023	12:28:00	16.089	4.118	0.051	
2/16/2023	12:29:00	16.088	4.137	0.003	
2/16/2023	12:30:00	16.097	4.139	0.014	
2/16/2023	12:31:00	16.091	4.143	0.03	9
2/16/2023	12:32:00	16.095	4.135	0.056	
2/16/2023	12:33:00	16.095	4.126	0.036	
2/16/2023	12:34:00	16.09	4.128	0.013	
2/16/2023	12:35:00	16.091	4.119	0.09	
2/16/2023	12:36:00	16.085	4.138	0.024	
2/16/2023	12:37:00	16.093	4.143	0.052	
2/16/2023	12:38:00	16.104	4.142	0.03	
2/16/2023	12:39:00	16.094	4.153	0.054	
2/16/2023	12:40:00	16.083	4.152	0.045	
2/16/2023	12:41:00	16.09	4.138	0.014	8
2/16/2023	12:42:00	16.093	4.124	0.046	
2/16/2023	12:43:00	16.1	4.121	0.037	
2/16/2023	12:44:00	16.096	4.145	0.055	
2/16/2023	12:45:00	16.101	4.16	0.01	

2/16/2023	12:46:00	16.111	4.146	0.048	
2/16/2023	12:47:00	16.104	4.157	0.039	
2/16/2023	12:48:00	16.104	4.152	0.006	
2/16/2023	12:49:00	16.112	4.141	0.013	
2/16/2023	12:50:00	16.106	4.137	0.048	
2/16/2023	12:51:00	16.104	4.137	0.034	7
2/16/2023	12:52:00	16.096	4.153	0.066	
2/16/2023	12:53:00	16.097	4.159	0.038	
2/16/2023	12:54:00	16.105	4.155	0.072	
2/16/2023	12:55:00	16.109	4.135	0.021	
2/16/2023	12:56:00	16.112	4.141	0.079	
2/16/2023	12:57:00	16.104	4.148	0.088	
2/16/2023	12:58:00	16.107	4.129	0.076	
2/16/2023	12:59:00	16.11	4.131	0.087	
2/16/2023	13:00:00	16.1	4.15	0.077	
2/16/2023	13:01:00	16.108	4.154	0.056	6
2/16/2023	13:02:00	16.106	4.16	0.033	
2/16/2023	13:03:00	16.109	4.168	0.093	
2/16/2023	13:04:00	16.111	4.166	0.107	
2/16/2023	13:05:00	16.103	4.169	0.089	
2/16/2023	13:06:00	16.104	4.171	0.056	
2/16/2023	13:07:00	16.085	4.202	0.055	
2/16/2023	13:08:00	16.1	4.192	0.077	
2/16/2023	13:09:00	16.109	4.195	0.082	
2/16/2023	13:10:00	16.109	4.188	0.061	
2/16/2023	13:11:00	16.113	4.17	0.043	5
2/16/2023	13:12:00	16.115	4.174	0.119	
2/16/2023	13:13:00	16.103	4.185	0.088	
2/16/2023	13:14:00	16.109	4.19	0.104	
2/16/2023	13:15:00	16.11	4.2	0.086	
2/16/2023	13:16:00	16.109	4.193	0.067	
2/16/2023	13:17:00	16.096	4.187	0.104	
2/16/2023	13:18:00	16.105	4.168	0.112	
2/16/2023	13:19:00	16.103	4.167	0.094	
2/16/2023	13:20:00	16.113	4.16	0.043	
2/16/2023	13:21:00	16.101	4.175	0.028	4
2/16/2023	13:22:00	16.107	4.183	0.193	
2/16/2023	13:23:00	16.113	4.171	0.058	
2/16/2023	13:24:00	16.1	4.17	0.111	
2/16/2023	13:25:00	16.111	4.155	0.126	
2/16/2023	13:26:00	16.099	4.158	0.112	
2/16/2023	13:27:00	16.102	4.151	0.081	
2/16/2023	13:28:00	16.102	4.156	0.035	
2/16/2023	13:29:00	16.098	4.166	0.044	
2/16/2023	13:30:00	16.105	4.158	0.041	
2/16/2023	13:31:00	16.11	4.154	0.071	3
2/16/2023	13:32:00	16.091	4.165	0.047	
2/16/2023	13:33:00	16.114	4.145	0.294	
2/16/2023	13:34:00	16.099	4.152	0.01	
2/16/2023	13:35:00	16.108	4.155	0.065	
2/16/2023	13:36:00	16.105	4.171	0.067	
2/16/2023	13:37:00	16.092	4.188	0.099	
2/16/2023	13:38:00	16.102	4.168	0.115	
2/16/2023	13:39:00	16.105	4.161	0.074	
2/16/2023	13:40:00	16.105	4.154	0.107	

2/16/2023	13:41:00	16.107	4.158	0.092	2
2/16/2023	13:42:00	16.104	4.178	0.07	
2/16/2023	13:43:00	16.102	4.187	0.076	
2/16/2023	13:44:00	16.104	4.187	0.097	
2/16/2023	13:45:00	16.108	4.182	0.085	
2/16/2023	13:46:00	16.112	4.162	0.109	
2/16/2023	13:47:00	16.111	4.156	0.099	
2/16/2023	13:48:00	16.123	4.148	0.1	
2/16/2023	13:49:00	16.05	4.231	0.008	
2/16/2023	13:50:00	16.083	4.194	0.045	
2/16/2023	13:51:00	16.096	4.166	0.067	1
2/16/2023	13:52:00	16.114	4.139	0.055	
2/16/2023	13:53:00	16.13	4.129	0.099	
2/16/2023	13:54:00	16.121	4.143	0.108	
2/16/2023	13:55:00	16.096	4.179	0.096	
2/16/2023	13:56:00	16.095	4.18	0.077	
2/16/2023	13:57:00	16.121	4.161	0.092	
2/16/2023	13:58:00	16.098	4.183	0.106	
2/16/2023	13:59:00	16.09	4.166	0.056	
2/16/2023	14:00:00	16.099	4.152	0.049	
2/16/2023	14:01:00	16.103	4.152	0.195	
2/16/2023	14:02:00	12.126	4.543	0.139	
2/16/2023	14:03:00	10.076	4.929	-0.027	< System O2, CO2
2/16/2023	14:04:00	8.916	4.532	-0.052	
2/16/2023	14:05:00	-0.036	-0.064	3.095	
2/16/2023	14:06:00	-0.034	-0.072	4.643	
2/16/2023	14:07:00	-0.034	-0.067	4.671	< System CO
2/16/2023	14:08:00	13.042	3.974	3.042	
2/16/2023	14:09:00	16.095	4.192	0.432	
2/16/2023	14:10:00	16.112	4.177	0.013	< Resume
2/16/2023	14:11:00	16.115	4.17	0.113	12
2/16/2023	14:12:00	16.116	4.158	0.357	
2/16/2023	14:13:00	16.12	4.152	0.375	
2/16/2023	14:14:00	16.098	4.182	0.059	
2/16/2023	14:15:00	16.103	4.194	0.23	
2/16/2023	14:16:00	16.098	4.182	0.005	
2/16/2023	14:17:00	16.124	4.154	0.015	
2/16/2023	14:18:00	16.122	4.151	0.002	
2/16/2023	14:19:00	16.113	4.159	0.014	
2/16/2023	14:20:00	16.092	4.193	0.031	
2/16/2023	14:21:00	16.107	4.188	0.013	11
2/16/2023	14:22:00	16.118	4.166	0.044	
2/16/2023	14:23:00	16.115	4.16	0.006	
2/16/2023	14:24:00	16.114	4.166	0.154	
2/16/2023	14:25:00	16.085	4.175	0.03	
2/16/2023	14:26:00	16.109	4.154	0.001	
2/16/2023	14:27:00	16.11	4.166	0.141	
2/16/2023	14:28:00	16.101	4.18	0.04	
2/16/2023	14:29:00	16.107	4.174	0.015	
2/16/2023	14:30:00	16.113	4.172	0.002	
2/16/2023	14:31:00	16.115	4.155	0.062	10
2/16/2023	14:32:00	16.102	4.161	0.076	
2/16/2023	14:33:00	16.099	4.166	0.098	
2/16/2023	14:34:00	16.106	4.193	0.05	
2/16/2023	14:35:00	16.102	4.202	0.049	

2/16/2023	14:36:00	16.113	4.18	0.015	
2/16/2023	14:37:00	16.119	4.165	0.077	
2/16/2023	14:38:00	16.113	4.159	0.001	
2/16/2023	14:39:00	16.113	4.16	0.025	
2/16/2023	14:40:00	16.117	4.173	0.054	
2/16/2023	14:41:00	16.11	4.198	0.011	9
2/16/2023	14:42:00	16.111	4.184	0.009	
2/16/2023	14:43:00	16.119	4.162	0.121	
2/16/2023	14:44:00	16.114	4.16	0.017	
2/16/2023	14:45:00	16.108	4.163	0.001	
2/16/2023	14:46:00	16.099	4.186	0.145	
2/16/2023	14:47:00	16.114	4.18	0.215	
2/16/2023	14:48:00	16.124	4.181	0.149	
2/16/2023	14:49:00	16.125	4.171	0.039	
2/16/2023	14:50:00	16.12	4.158	0.028	
2/16/2023	14:51:00	16.111	4.153	0.052	8
2/16/2023	14:52:00	16.109	4.148	0.062	
2/16/2023	14:53:00	16.112	4.157	0.05	
2/16/2023	14:54:00	16.12	4.164	0.058	
2/16/2023	14:55:00	16.115	4.171	0.057	
2/16/2023	14:56:00	16.107	4.176	0.067	
2/16/2023	14:57:00	16.115	4.162	0.038	
2/16/2023	14:58:00	16.112	4.149	0.013	
2/16/2023	14:59:00	16.118	4.154	0.034	
2/16/2023	15:00:00	16.105	4.177	0.043	
2/16/2023	15:01:00	16.087	4.192	0.029	7
2/16/2023	15:02:00	16.118	4.165	0.039	
2/16/2023	15:03:00	16.11	4.167	0.057	
2/16/2023	15:04:00	16.121	4.146	0.072	
2/16/2023	15:05:00	16.124	4.154	0.063	
2/16/2023	15:06:00	16.117	4.169	0.064	
2/16/2023	15:07:00	16.117	4.173	0.011	
2/16/2023	15:08:00	16.111	4.185	0.003	
2/16/2023	15:09:00	16.115	4.175	0.026	
2/16/2023	15:10:00	16.105	4.172	0.024	
2/16/2023	15:11:00	16.117	4.162	0.059	6
2/16/2023	15:12:00	16.116	4.174	0.038	
2/16/2023	15:13:00	16.119	4.19	0.066	
2/16/2023	15:14:00	16.121	4.182	0.06	
2/16/2023	15:15:00	16.114	4.181	0.003	
2/16/2023	15:16:00	16.105	4.17	0.052	
2/16/2023	15:17:00	16.115	4.165	0.063	
2/16/2023	15:18:00	16.11	4.181	0.041	
2/16/2023	15:19:00	16.115	4.179	0.057	
2/16/2023	15:20:00	16.115	4.183	0.066	
2/16/2023	15:21:00	16.109	4.181	0.028	5
2/16/2023	15:22:00	16.112	4.17	0.06	
2/16/2023	15:23:00	16.115	4.168	0.039	
2/16/2023	15:24:00	16.103	4.202	0.021	
2/16/2023	15:25:00	16.109	4.207	0	
2/16/2023	15:26:00	16.11	4.204	0.077	
2/16/2023	15:27:00	16.122	4.183	0	
2/16/2023	15:28:00	16.122	4.166	0.006	
2/16/2023	15:29:00	16.121	4.158	0.007	
2/16/2023	15:30:00	16.118	4.16	0.046	

2/16/2023	15:31:00	16.117	4.172	0.013		4
2/16/2023	15:32:00	16.112	4.185	0.228		
2/16/2023	15:33:00	16.113	4.171	0.018		
2/16/2023	15:34:00	16.119	4.155	0.022		
2/16/2023	15:35:00	16.11	4.161	0.041		
2/16/2023	15:36:00	16.111	4.159	0.371		
2/16/2023	15:37:00	16.126	4.156	0.011		
2/16/2023	15:38:00	16.117	4.18	0.043		
2/16/2023	15:39:00	16.124	4.171	0.034		
2/16/2023	15:40:00	16.125	4.157	0.071		
2/16/2023	15:41:00	16.117	4.157	0.032	3	
2/16/2023	15:42:00	16.121	4.161	0.021		
2/16/2023	15:43:00	16.111	4.179	0.033		
2/16/2023	15:44:00	16.121	4.173	0.049		
2/16/2023	15:45:00	16.111	4.167	0.06		
2/16/2023	15:46:00	16.114	4.159	0.066		
2/16/2023	15:47:00	16.108	4.161	0.07		
2/16/2023	15:48:00	16.111	4.158	0.053		
2/16/2023	15:49:00	16.109	4.181	0.058		
2/16/2023	15:50:00	16.109	4.185	0.016		
2/16/2023	15:51:00	16.112	4.167	0.009	2	
2/16/2023	15:52:00	16.114	4.158	0.027		
2/16/2023	15:53:00	16.114	4.148	0.064		
2/16/2023	15:54:00	16.111	4.146	0.065		
2/16/2023	15:55:00	16.106	4.157	0.022		
2/16/2023	15:56:00	16.112	4.146	0.031		
2/16/2023	15:57:00	16.108	4.152	0.052		
2/16/2023	15:58:00	16.115	4.138	0.035		
2/16/2023	15:59:00	16.113	4.139	0.151		
2/16/2023	16:00:00	16.108	4.135	0.023		
2/16/2023	16:01:00	16.102	4.131	0.056	1	
2/16/2023	16:02:00	16.102	4.142	0.054		
2/16/2023	16:03:00	16.1	4.15	0.038		
2/16/2023	16:04:00	16.104	4.133	0.066		
2/16/2023	16:05:00	16.107	4.128	0.042		
2/16/2023	16:06:00	16.102	4.114	0.071		
2/16/2023	16:07:00	16.101	4.111	0.038		
2/16/2023	16:08:00	16.105	4.103	0.026		
2/16/2023	16:09:00	16.103	4.121	0.036		
2/16/2023	16:10:00	16.102	4.121	0.045		
2/16/2023	16:11:00	16.108	4.106	0.065		
2/16/2023	16:12:00	16.088	4.113	0.056		
2/16/2023	16:13:00	13.647	4.298	0.104		
2/16/2023	16:14:00	10.077	4.731	0.285		
2/16/2023	16:15:00	10.071	4.931	-0.143		
2/16/2023	16:16:00	10.069	4.937	-0.024	< System O2, CO2	
2/16/2023	16:17:00	4.357	2.094	0.619		
2/16/2023	16:18:00	-0.033	-0.052	4.459		
2/16/2023	16:19:00	0.033	-0.071	4.627	< System CO	
2/16/2023	16:20:00	15.402	5.866	3.221		
2/16/2023	16:21:00	19.248	9.357	7.31		
2/16/2023	16:22:00	19.277	9.627	9.626		
2/16/2023	16:23:00	19.282	9.639	9.62	< Direct High	
2/16/2023	16:24:00	10.679	5.506	6.798		
2/16/2023	16:25:00	10.111	5.322	4.695		

2/16/2023	16:26:00	10.112	4.895	4.694	< Direct Mid
2/16/2023	16:27:00	10.111	4.892	4.698	
2/16/2023	16:28:00	1.137	1.513	3.428	
2/16/2023	16:29:00	-0.037	-0.04	0.07	< DIrect Zero
2/16/2023	16:30:00	-0.037	-0.02	-0.001	

Date	Time	O2%	CO2%	CO ppm
2/17/2023	6:57:00	-0.033	-0.052	-0.094
2/17/2023	6:58:00	-0.033	-0.049	-0.155
2/17/2023	6:59:00	-0.033	-0.045	-0.213
2/17/2023	7:00:00	-0.031	-0.044	-0.286
2/17/2023	7:01:00	-0.032	-0.044	-0.337
2/17/2023	7:02:00	-0.032	-0.051	-0.399
2/17/2023	7:03:00	-0.03	-0.049	-0.446
2/17/2023	7:04:00	-0.03	-0.038	-0.495
2/17/2023	7:05:00	-0.031	-0.051	-0.553
2/17/2023	7:06:00	-0.03	-0.056	-0.588
2/17/2023	7:07:00	-0.032	-0.056	-0.589
2/17/2023	7:08:00	-0.03	-0.054	-0.589
2/17/2023	7:09:00	-0.03	-0.052	-0.589
2/17/2023	7:10:00	-0.03	-0.043	-0.589
2/17/2023	7:11:00	-0.03	-0.046	-0.46
2/17/2023	7:12:00	-0.032	-0.023	-0.033 < Direct Zero
2/17/2023	7:13:00	6.312	2.148	0.011
2/17/2023	7:14:00	19.282	8.471	6.733
2/17/2023	7:15:00	19.275	9.632	9.601 < Direct High
2/17/2023	7:16:00	12.819	6.341	8.472
2/17/2023	7:17:00	10.101	4.909	4.559
2/17/2023	7:18:00	10.102	4.912	4.591 < Direct Mid
2/17/2023	7:19:00	14.697	4.458	3.773
2/17/2023	7:20:00	16.085	4.303	0.711
2/17/2023	7:21:00	16.095	4.256	0.59
2/17/2023	7:22:00	10.407	4.86	-0.191
2/17/2023	7:23:00	10.085	4.945	-0.029 < System O2, CO2
2/17/2023	7:24:00	8.415	4.247	1.385
2/17/2023	7:25:00	-0.039	-0.027	4.674 < System CO
2/17/2023	7:26:00	11.392	2.931	4.126
2/17/2023	7:27:00	16.102	4.298	0.865
2/17/2023	7:28:00	16.118	4.287	-0.048
2/17/2023	7:29:00	16.124	4.291	0
2/17/2023	7:30:00	16.111	4.296	0.182 < Start Run 7 Eng 5
2/17/2023	7:31:00	16.078	4.328	0.206 12
2/17/2023	7:32:00	16.103	4.302	0.031
2/17/2023	7:33:00	16.111	4.299	0.094
2/17/2023	7:34:00	16.113	4.289	0.146
2/17/2023	7:35:00	16.115	4.283	0.061
2/17/2023	7:36:00	16.12	4.282	0.041
2/17/2023	7:37:00	16.096	4.312	0.005
2/17/2023	7:38:00	16.113	4.291	0.017
2/17/2023	7:39:00	16.076	4.328	0.013
2/17/2023	7:40:00	16.082	4.328	0.048
2/17/2023	7:41:00	16.119	4.301	0.096 11
2/17/2023	7:42:00	16.087	4.334	0.16

2/17/2023	7:43:00	16.088	4.326	0.018	
2/17/2023	7:44:00	16.071	4.335	0.016	
2/17/2023	7:45:00	16.12	4.291	0.023	
2/17/2023	7:46:00	16.103	4.309	0.031	
2/17/2023	7:47:00	16.067	4.348	0.08	
2/17/2023	7:48:00	16.103	4.318	0.082	
2/17/2023	7:49:00	16.111	4.316	0.064	
2/17/2023	7:50:00	16.085	4.335	0.051	
2/17/2023	7:51:00	16.029	4.381	0.171	10
2/17/2023	7:52:00	16.056	4.35	0.14	
2/17/2023	7:53:00	16.068	4.334	0.161	
2/17/2023	7:54:00	16.119	4.289	0.015	
2/17/2023	7:55:00	16.1	4.312	0.077	
2/17/2023	7:56:00	16.088	4.319	0.144	
2/17/2023	7:57:00	16.089	4.309	0.163	
2/17/2023	7:58:00	16.103	4.305	0.222	
2/17/2023	7:59:00	16.094	4.314	0.153	
2/17/2023	8:00:00	16.093	4.319	0.145	
2/17/2023	8:01:00	16.107	4.307	0.2	9
2/17/2023	8:02:00	16.105	4.309	0.207	
2/17/2023	8:03:00	16.118	4.305	0.361	
2/17/2023	8:04:00	16.117	4.304	0.327	
2/17/2023	8:05:00	16.075	4.33	0.275	
2/17/2023	8:06:00	16.103	4.305	0.357	
2/17/2023	8:07:00	16.096	4.311	0.084	
2/17/2023	8:08:00	16.088	4.306	0.254	
2/17/2023	8:09:00	16.099	4.308	0.052	
2/17/2023	8:10:00	16.131	4.291	0.307	
2/17/2023	8:11:00	16.119	4.303	0.301	8
2/17/2023	8:12:00	16.121	4.295	0.241	
2/17/2023	8:13:00	16.095	4.318	0.319	
2/17/2023	8:14:00	16.127	4.305	0.333	
2/17/2023	8:15:00	16.076	4.346	0.354	
2/17/2023	8:16:00	16.063	4.343	0.353	
2/17/2023	8:17:00	16.122	4.292	0.364	
2/17/2023	8:18:00	16.109	4.306	0.097	
2/17/2023	8:19:00	16.028	4.376	0.375	
2/17/2023	8:20:00	16.097	4.322	0.402	
2/17/2023	8:21:00	16.103	4.313	0.357	7
2/17/2023	8:22:00	16.094	4.321	0.413	
2/17/2023	8:23:00	16.097	4.311	0.428	
2/17/2023	8:24:00	16.067	4.342	0.404	
2/17/2023	8:25:00	16.11	4.296	0.35	
2/17/2023	8:26:00	16.113	4.293	0.446	
2/17/2023	8:27:00	16.102	4.307	0.435	
2/17/2023	8:28:00	16.109	4.298	0.319	
2/17/2023	8:29:00	16.07	4.326	0.006	

2/17/2023	8:30:00	16.074	4.321	0.073	
2/17/2023	8:31:00	16.106	4.294	0.028	6
2/17/2023	8:32:00	16.135	4.28	0.073	
2/17/2023	8:33:00	16.125	4.281	0.124	
2/17/2023	8:34:00	16.124	4.28	0.198	
2/17/2023	8:35:00	16.121	4.289	0.165	
2/17/2023	8:36:00	16.059	4.342	0.098	
2/17/2023	8:37:00	16.108	4.304	0.023	
2/17/2023	8:38:00	16.109	4.298	0.02	
2/17/2023	8:39:00	16.069	4.341	0.082	
2/17/2023	8:40:00	16.125	4.28	0.135	
2/17/2023	8:41:00	16.115	4.281	0.123	5
2/17/2023	8:42:00	16.07	4.319	0.103	
2/17/2023	8:43:00	16.12	4.285	0.044	
2/17/2023	8:44:00	16.096	4.31	0.083	
2/17/2023	8:45:00	16.115	4.304	0.063	
2/17/2023	8:46:00	16.111	4.303	0.06	
2/17/2023	8:47:00	16.115	4.294	0.146	
2/17/2023	8:48:00	16.103	4.296	0.075	
2/17/2023	8:49:00	16.11	4.298	0.117	
2/17/2023	8:50:00	16.124	4.291	0.066	
2/17/2023	8:51:00	16.106	4.298	0.062	4
2/17/2023	8:52:00	16.104	4.289	0.109	
2/17/2023	8:53:00	16.077	4.317	0.069	
2/17/2023	8:54:00	16.106	4.293	0.152	
2/17/2023	8:55:00	16.125	4.28	0.042	
2/17/2023	8:56:00	16.102	4.302	0.177	
2/17/2023	8:57:00	16.112	4.293	0.067	
2/17/2023	8:58:00	16.117	4.28	0.14	
2/17/2023	8:59:00	16.073	4.316	0.167	
2/17/2023	9:00:00	16.085	4.295	0.12	
2/17/2023	9:01:00	16.105	4.286	0.015	3
2/17/2023	9:02:00	16.069	4.319	0.076	
2/17/2023	9:03:00	16.096	4.286	0.076	
2/17/2023	9:04:00	16.078	4.294	0.111	
2/17/2023	9:05:00	16.082	4.294	0.128	
2/17/2023	9:06:00	16.118	4.261	0.084	
2/17/2023	9:07:00	16.103	4.267	0.205	
2/17/2023	9:08:00	16.093	4.279	0.2	
2/17/2023	9:09:00	16.1	4.265	0.027	
2/17/2023	9:10:00	16.112	4.263	0.233	
2/17/2023	9:11:00	16.09	4.286	0.255	2
2/17/2023	9:12:00	16.052	4.309	0.211	
2/17/2023	9:13:00	16.082	4.278	0.062	
2/17/2023	9:14:00	16.108	4.25	0.104	
2/17/2023	9:15:00	16.069	4.271	0.195	
2/17/2023	9:16:00	16.113	4.24	0.249	

2/17/2023	9:17:00	16.085	4.274	0.194	
2/17/2023	9:18:00	16.084	4.277	0.007	
2/17/2023	9:19:00	16.09	4.268	0.407	
2/17/2023	9:20:00	16.086	4.28	0.022	
2/17/2023	9:21:00	16.087	4.273	0.04	1
2/17/2023	9:22:00	16.081	4.285	0.074	
2/17/2023	9:23:00	16.084	4.273	0.06	
2/17/2023	9:24:00	16.064	4.3	0.16	
2/17/2023	9:25:00	16.036	4.313	0.182	
2/17/2023	9:26:00	16.052	4.303	0.209	
2/17/2023	9:27:00	16.091	4.272	0.123	
2/17/2023	9:28:00	16.072	4.286	0.273	
2/17/2023	9:29:00	16.097	4.271	0.21	
2/17/2023	9:30:00	16.105	4.256	0.18	
2/17/2023	9:31:00	16.089	4.266	0.114	
2/17/2023	9:32:00	14.483	4.359	0.093	
2/17/2023	9:33:00	10.075	4.908	-0.281	
2/17/2023	9:34:00	10.072	4.913	-0.03	< System O2, CO2
2/17/2023	9:35:00	8.224	3.451	0.21	
2/17/2023	9:36:00	-0.048	0.001	4.113	
2/17/2023	9:37:00	-0.047	0.002	4.617	< System Co
2/17/2023	9:38:00	9.973	2.522	4.3	
2/17/2023	9:39:00	16.075	4.282	1.055	
2/17/2023	9:40:00	16.066	4.296	0.004	< Resume
2/17/2023	9:41:00	16.068	4.295	0.335	12
2/17/2023	9:42:00	16.067	4.297	0.104	
2/17/2023	9:43:00	16.09	4.28	0.242	
2/17/2023	9:44:00	16.055	4.32	0.355	
2/17/2023	9:45:00	15.999	4.361	0.339	
2/17/2023	9:46:00	16.094	4.281	0.282	
2/17/2023	9:47:00	16.07	4.292	0.1	
2/17/2023	9:48:00	16.064	4.296	0.195	
2/17/2023	9:49:00	16.072	4.291	0.262	
2/17/2023	9:50:00	16.071	4.28	0.038	
2/17/2023	9:51:00	16.072	4.286	0.206	11
2/17/2023	9:52:00	16.072	4.276	0.017	
2/17/2023	9:53:00	16.087	4.256	0.286	
2/17/2023	9:54:00	16.061	4.282	0.413	
2/17/2023	9:55:00	16.057	4.287	0.095	
2/17/2023	9:56:00	16.041	4.303	0.034	
2/17/2023	9:57:00	16.087	4.27	0.288	
2/17/2023	9:58:00	16.082	4.282	0.448	
2/17/2023	9:59:00	16.067	4.302	0.176	
2/17/2023	10:00:00	16.08	4.283	0.298	
2/17/2023	10:01:00	16.084	4.276	0.388	10
2/17/2023	10:02:00	16.085	4.284	0.476	
2/17/2023	10:03:00	16.03	4.327	0.423	

2/17/2023	10:04:00	16.056	4.297	0.146	
2/17/2023	10:05:00	16.081	4.281	0.243	
2/17/2023	10:06:00	16.079	4.279	0.462	
2/17/2023	10:07:00	16.083	4.288	0.438	
2/17/2023	10:08:00	16.068	4.299	0.11	
2/17/2023	10:09:00	16.021	4.335	0.338	
2/17/2023	10:10:00	16.063	4.299	0.342	
2/17/2023	10:11:00	16.081	4.283	0.294	9
2/17/2023	10:12:00	16.084	4.29	0.502	
2/17/2023	10:13:00	16.036	4.339	0.489	
2/17/2023	10:14:00	16.063	4.292	0.284	
2/17/2023	10:15:00	16.078	4.279	0.279	
2/17/2023	10:16:00	16.101	4.266	0.258	
2/17/2023	10:17:00	16.076	4.294	0.385	
2/17/2023	10:18:00	16.054	4.311	0.278	
2/17/2023	10:19:00	16.065	4.301	0.134	
2/17/2023	10:20:00	16.087	4.266	0.249	
2/17/2023	10:21:00	16.092	4.264	0.488	8
2/17/2023	10:22:00	16.089	4.27	0.41	
2/17/2023	10:23:00	16.069	4.283	0.401	
2/17/2023	10:24:00	16.078	4.287	0.454	
2/17/2023	10:25:00	16.102	4.268	0.562	
2/17/2023	10:26:00	16.097	4.279	0.196	
2/17/2023	10:27:00	16.075	4.293	0.485	
2/17/2023	10:28:00	16.081	4.277	0.411	
2/17/2023	10:29:00	16.072	4.279	0.47	
2/17/2023	10:30:00	16.095	4.264	0.411	
2/17/2023	10:31:00	16.078	4.276	0.49	7
2/17/2023	10:32:00	16.085	4.273	0.506	
2/17/2023	10:33:00	16.077	4.267	0.484	
2/17/2023	10:34:00	16.075	4.256	0.435	
2/17/2023	10:35:00	16.068	4.259	0.49	
2/17/2023	10:36:00	16.099	4.233	0.492	
2/17/2023	10:37:00	16.098	4.237	0.586	
2/17/2023	10:38:00	16.098	4.236	0.552	
2/17/2023	10:39:00	16.08	4.249	0.56	
2/17/2023	10:40:00	16.079	4.248	0.543	
2/17/2023	10:41:00	16.086	4.238	0.57	6
2/17/2023	10:42:00	16.066	4.251	0.504	
2/17/2023	10:43:00	16.082	4.23	0.479	
2/17/2023	10:44:00	16.089	4.223	0.498	
2/17/2023	10:45:00	16.088	4.222	0.536	
2/17/2023	10:46:00	16.091	4.22	0.419	
2/17/2023	10:47:00	16.097	4.216	0.551	
2/17/2023	10:48:00	16.094	4.207	0.492	
2/17/2023	10:49:00	16.09	4.211	0.525	
2/17/2023	10:50:00	16.084	4.213	0.48	

2/17/2023	10:51:00	16.086	4.224	0.539	5
2/17/2023	10:52:00	16.074	4.234	0.518	
2/17/2023	10:53:00	16.089	4.226	0.497	
2/17/2023	10:54:00	16.093	4.216	0.581	
2/17/2023	10:55:00	16.097	4.196	0.587	
2/17/2023	10:56:00	16.095	4.192	0.585	
2/17/2023	10:57:00	16.091	4.184	0.583	
2/17/2023	10:58:00	16.09	4.174	0.577	
2/17/2023	10:59:00	16.079	4.178	0.527	
2/17/2023	11:00:00	16.092	4.169	0.548	
2/17/2023	11:01:00	16.094	4.165	0.584	4
2/17/2023	11:02:00	16.091	4.161	0.576	
2/17/2023	11:03:00	16.091	4.16	0.564	
2/17/2023	11:04:00	16.086	4.16	0.562	
2/17/2023	11:05:00	16.088	4.169	0.341	
2/17/2023	11:06:00	16.091	4.167	0.57	
2/17/2023	11:07:00	16.087	4.16	0.51	
2/17/2023	11:08:00	16.091	4.165	0.443	
2/17/2023	11:09:00	16.093	4.163	0.449	
2/17/2023	11:10:00	16.089	4.165	0.582	
2/17/2023	11:11:00	16.092	4.161	0.578	3
2/17/2023	11:12:00	16.082	4.171	0.491	
2/17/2023	11:13:00	16.093	4.152	0.556	
2/17/2023	11:14:00	16.079	4.168	0.153	
2/17/2023	11:15:00	16.087	4.159	0.388	
2/17/2023	11:16:00	16.083	4.152	0.571	
2/17/2023	11:17:00	16.085	4.149	0.498	
2/17/2023	11:18:00	16.093	4.136	0.588	
2/17/2023	11:19:00	16.091	4.146	0.588	
2/17/2023	11:20:00	16.089	4.152	0.585	
2/17/2023	11:21:00	16.092	4.162	0.588	2
2/17/2023	11:22:00	16.084	4.16	0.588	
2/17/2023	11:23:00	16.086	4.168	0.044	
2/17/2023	11:24:00	16.076	4.176	0.104	
2/17/2023	11:25:00	16.084	4.166	0.226	
2/17/2023	11:26:00	16.097	4.152	0.108	
2/17/2023	11:27:00	16.093	4.15	0.085	
2/17/2023	11:28:00	16.097	4.142	0.089	
2/17/2023	11:29:00	16.091	4.149	0.052	
2/17/2023	11:30:00	16.09	4.143	0.008	
2/17/2023	11:31:00	16.091	4.149	0.01	1
2/17/2023	11:32:00	16.09	4.148	0.016	
2/17/2023	11:33:00	16.078	4.159	0.054	
2/17/2023	11:34:00	16.086	4.141	0.016	
2/17/2023	11:35:00	16.083	4.149	0.02	
2/17/2023	11:36:00	16.08	4.16	0.012	
2/17/2023	11:37:00	16.076	4.156	0.017	

2/17/2023	11:38:00	16.086	4.144	0.043
2/17/2023	11:39:00	16.087	4.136	0.024
2/17/2023	11:40:00	16.084	4.128	0.027
2/17/2023	11:41:00	16.081	4.138	0.017
2/17/2023	11:42:00	14.47	4.252	0.214
2/17/2023	11:43:00	10.064	4.772	0.472
2/17/2023	11:44:00	10.039	4.904	0.027 < System O2, CO2
2/17/2023	11:45:00	11.87	4.585	0.022
2/17/2023	11:46:00	1.223	0.382	2.376
2/17/2023	11:47:00	-0.044	-0.05	4.653 < System CO
2/17/2023	11:48:00	11.519	3.264	4.272
2/17/2023	11:49:00	19.249	9.514	5.941
2/17/2023	11:50:00	19.275	9.636	9.615
2/17/2023	11:51:00	19.279	9.633	9.648 < Direct High
2/17/2023	11:52:00	11.507	6.393	7.485
2/17/2023	11:53:00	10.101	5.357	4.705
2/17/2023	11:54:00	10.103	4.898	4.612
2/17/2023	11:55:00	10.097	4.897	4.633 < Direct Mid
2/17/2023	11:56:00	1.773	1.385	2.887
2/17/2023	11:57:00	-0.039	-0.025	-0.036
2/17/2023	11:58:00	-0.033	-0.024	-0.032 < Direct Zero
2/17/2023	11:59:00	-0.023	-0.03	-0.025

Appendix A.3 Particulate Field and Laboratory Data

Appendix A.3.1 CT-4 Field Data

ENU 4 P1

WWS

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: Engine 41
 DATE: 3/21/13
 RUN NO: EPU 4 RUN 1
 OPERATOR: OH/AS
 METER BOX NO: 12000
 METER ΔH@: 1.384
 METER Yd: 0.212
 STACK AREA, FT²: 55''
 TRAVERSE POINTS, MIN/POINT: 10 24
 ΔH= X ΔP:
 Probe Condition, pre/post test:
 Silica Gel Expended, Y/N:
 Filter Condition after Test:
 Check Weight:

AMBIENT TEMPERATURE: 55°
 BAROMETRIC PRESSURE: 28.34
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF, Cp: 0.94
 PROBE ID NO/MATERIAL: 5000/6004
 PROBE LENGTH: 5'
 NOZZLE ID NO/ MATERIAL: N92-2
 NOZZLE DIAMETER: 0.267
 FILTER NO/TYPE: 83-4417
 PRE-TEST LEAK RATE: 0.000 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.008 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: 0 POST:
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN
 SAMPLER: 88
 SAMPLE CUSTODIAN: 88

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
1	1050	0.191	0.95	1.9	705	748	53	74	75	4	4	-0.65
2	1100	3.9	0.97	0.0	703	747	49	77	74	4	4	
3	1110	15.8	1.0	2.0	704	747	51	81	7			
4	1120	23.9	1.1	2.2	704	749	53	82	7			
5	1130	32.4	1.2	2.4	702	748	53	82	7			
6	1140	41.4	1.1	2.2	703	749	55	82	6			
7	1150	50.3	1.1	2.1	701	749	57	85	6			
8	1160	58.2	1.0	2.0	701	749	57	85	6			
9	1170	66.7	1.1	2.2	704	747	55	82	7			
10	1180	75.1	1.0	2.0	704	749	54	84	6			
11	1190	83.3	0.98	1.9	703	750	51	72	6			
12	1240	91.5	0.75	1.5	701	748	54	88	5			
1	1250/300	98.743	0.92	2.0	903	249	53	86	6			
2	1310	1027.9	1.0	2.0	704	748	54	84	6			
3	1320	116.7	1.1	2.1	704	747	51	82	7			
4	1330	124.4	0.97	1.9	703	749	55	83	7			
5	1340	132.6	0.96	1.9	701	749	56	83	6			
6	1350	140.6	0.96	1.9	701	748	55	82	6			
7	1402	148.3	0.99	2.0	704	748	54	84	6			
8	1410	157.0	1.1	2.2	903	247	53	85	6			
9	1420	165.4	1.1	2.2	705	248	56	84	6			
10	1430	174.7	1.0	2.0	701	748	53	83	6			
11	1440	182.8	0.95	1.9	701	747	53	82	6			
12	1450	171.5	0.82	1.4	704	249	53	84	5			
Average: 150		100.182										

Comments:

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
LOCATION: Englewood
DATE: 2/8/23
RUN NO: Eng 4 Blm 2
OPERATOR: D4 / AS
METER BOX NO: 42 WWS
METER ΔH@: 0.28492
METER Yd:
STACK AREA, FT²: 57"
TRAVERSE POINTS, MIN/POINT: 10/24
ΔH= 1.64 X ΔP: 1988
Probe Condition, pre/post test: /
Silica Gel Expended, Y/N: /
Filter Condition after Test:
Check Weight:

AMBIENT TEMPERATURE: 52°
BAROMETRIC PRESSURE: 28.34
ASSUMED MOISTURE: 78.34
PITOT TUBE COEFF, Cp: 0.967
PROBE ID NO/MATERIAL: S'
PROBE LENGTH: 5'
NOZZLE ID NO/MATERIAL: N4L2 6108
NOZZLE DIAMETER: 0.057
FILTER NO/TYPE: G4 4418
PRE-TEST LEAK RATE: 0.009 CFM @ 10 in. Hg.
POST-TEST LEAK RATE: 0.009 CFM @ 10 in. Hg.
PITOT LEAK CHECK - PRE: POST: 65
CHAIN OF CUSTODY: SAMPLE CUSTODIAN
SAMPLER: 1e / 40
SAMPLE CUSTODIAN

Point	Meter	Time	Volume	ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	In	Out	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
1	0810	200.519	0.96	1.9	705	247	57	57	54	7	7	7	-0.54		
2	0820	206.5	1.0	2.0	703	247	52	52	52	7	7	7			
3	0830	214.4	1.1	2.2	703	248	52	52	52	7	7	7			
4	0840	225.5	1.0	2.0	703	249	51	51	51	7	7	7			
5	0850	235.2	1.1	2.3	704	249	51	51	51	7	7	7			
6	0859	241.2	1.1	2.2	702	249	52	52	52	7	7	7			
7	0910	250.4	1.0	2.0	704	247	53	53	53	7	7	7			
8	0920	258.5	0.99	1.9	704	248	53	53	53	7	7	7			
9	0930	266.2	1.0	2.0	704	250	52	52	52	7	7	7			
10	0940	275.0	1.1	2.2	704	249	53	53	53	7	7	7			
11	0950	281.6	0.96	1.9	705	249	54	54	54	7	7	7			
12	1000	291.5	0.77	1.5	703	248	54	54	54	7	7	7			
1	1000/010	299.025	0.96	1.9	700	249	55	55	55	7	7	7			
2	1030	308.9	1.1	2.2	700	248	55	55	55	7	7	7			
3	1040	314.9	1.1	2.2	301	248	54	54	54	7	7	7			
4	1050	323.4	0.92	1.9	301	247	55	55	55	7	7	7			
5	1100	331.2	0.95	1.9	300	248	53	53	53	7	7	7			
6	1110	340.0	0.92	1.9	300	248	54	54	54	7	7	7			
7	1120	347.5	1.0	2.0	300	246	53	53	53	7	7	7			
8	1130	356.9	1.1	2.2	300	250	51	51	51	7	7	7			
9	1140	365.5	1.0	2.0	300	250	51	51	51	7	7	7			
10	1150	373.9	1.1	2.2	300	248	55	55	55	7	7	7			
11	1160	382.4	0.97	1.9	301	247	54	54	54	7	7	7			
12	1170	390.8	0.84	1.7	300	247	53	53	53	7	7	7			
Average: 1120		398.872				247	53	53	53	53	7	7	7		

Comments:

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Engelhard LOCATION: Engine #4
 DATE: 2/16/11 RUN NO: 3
 OPERATOR: DL / AD METER BOX NO: 42wos
 METER ΔH@: 1.216 METER Yd: 0.932
 STACK AREA, FT²: 55' TRAVERSE POINTS, MINIPOINT: 10/24
 ΔH= X ΔP: 1.283 Probe Condition, pre/post test: -
 Silica Gel Expended, Y/N: -
 Filter Condition after Test: -
 Check Weight: 300.50

AMBIENT TEMPERATURE: 66°
 BAROMETRIC PRESSURE: 28.34
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF. CP: 0.84
 PROBE ID NO/MATERIAL: 0071 glass
 PROBE LENGTH: 5'
 NOZZLE ID NO/MATERIAL: 266 (gallons)
 NOZZLE DIAMETER: 0.057
 FILTER NO/TYPE: 56 - 4419
 PRE-TEST LEAK RATE: 0.008 CFM@ 10 in. Hg.
 POST-TEST LEAK RATE: 0.008 CFM@ 10 in. Hg.
 PITOT LEAK CHECK - PRE: OK POST: OK
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN AD
 SAMPLER AD
 SAMPLE CUSTODIAN AD

Meter Volume, ft³

Point

Time

ΔP

in. H₂O

Stack

Temp, °F

Probe

Temp, °F

Filter

Temp, °F

In

Out

Meter Temp, °F

vacuum

in. Hg.

O₂ %

Pstatic in. H₂O

1 1305 400.681 0.95 1.1 697 248 58 8.5 5 -0.54

2 1315 409.4 1.1 2.2 657 245 56 8.6 6

3 1325 417.7 1.1 2.2 696 249 55 9.0 6

4 1335 426.0 1.0 2.0 689 244 54 9.1 6

5 1345 434.4 1.0 2.0 697 243 52 9.2 6

6 1355 443.0 1.1 2.2 696 247 53 9.2 7

7 1405 452.8 1.0 2.0 698 246 53 9.2 6

8 1415 459.9 1.0 2.0 696 249 54 9.1 6

9 1425 468.0 0.98 1.9 697 241 53 9.0 6

10 1435 476.3 0.94 1.5 697 250 54 7.1 5

11 1445 483.5 0.90 1.9 697 245 54 7.1 6

12 1455 492.8 0.88 1.6 698 248 55 9.2 5

1 1505/515 499.294 0.94 1.9 698 245 55 9.1 5

2 1525 507.1 1.1 2.2 703 249 54 9.0 7

3 1535 515.0 1.0 2.0 704 249 54 9.0 7

4 1545 523.7 0.97 1.9 704 248 55 9.1 6

5 1555 530.0 0.95 1.9 705 247 55 9.2 6

6 1605 538.5 0.98 1.9 705 247 54 9.3 7

7 1615 546.4 1.1 2.3 705 247 54 9.3 7

8 1625 555.1 1.1 2.2 705 247 54 9.4 7

9 1635 563.4 1.0 2.0 704 246 54 9.3 7

10 1645 571.6 1.0 2.0 705 249 55 9.5 7

11 1655 580.1 0.97 1.9 705 246 55 9.5 7

12 1705 588.5 0.95 1.7 703 249 54 9.4 5

Average: 1715 574.757

Comments:

Imp. # Contents Post-Test - Pre-Test = Difference

1 DT 869.1 736.5

2 MT 647.4 620.6

3 MT 635.4 634.7

4 SL 948.8 930.0

Total:

MONROSE
AIR QUALITY PRODUCTS

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: 24244 E 23rd
 DATE: 2/9/23
 RUN NO: 1164 RUN 4
 OPERATOR: OH/AN
 METER BOX NO: 42 WES
 METER ΔH@: 1.184
 METER Yd: 0.997
 STACK AREA, FT²: 85'
 TRAVERSE POINTS, MIN/POINT: 10 24
 $\Delta H = 1.16 \times \Delta P = 1.187$
 Probe Condition, pre/post test:
 Silica Gel Expended, Y/N:
 Filter Condition after Test:
 Check Weight: 500.000

AMBIENT TEMPERATURE: 53°
 BAROMETRIC PRESSURE: 29.32
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF, Cp: 0.84
 PROBE ID NO/MATERIAL: 006/ glass
 PROBE LENGTH: 5'
 NOZZLE ID NO/ MATERIAL: N42-2 / glass
 NOZZLE DIAMETER: 0.251
 FILTER NO/TYPE: GFC 4420
 PRE-TEST LEAK RATE: 0.0007 CFM@ 10 in. Hg.
 POST-TEST LEAK RATE: 0.0022 CFM@ 10 in. Hg.
 PITOT LEAK CHECK - PRE: 0.12
 POST: 0.12
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN:
 SAMPLER: N4/A4
 SAMPLE CUSTODIAN:

Imp. # Contents Post-Test - Pre-Test = Difference
 1 Del 100 886.5 708.5
 2 1164 1038.0 625.5
 3 MT 613.7 649.0 608.9
 4 1012.2 912.9
 Total:

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
1	0905	592.719	1.95	1.9	301	247	57	30	30	7	-0.57	
2	0915	605.4	0.97	1.9	304	248	55	32	32	6		
3	0925	616.4	1.1	2.3	303	248	53	33	33	7		
4	0935	624.9	1.1	2.2	303	247	54	35	35	7		
5	0945	633.5	1.2	2.4	303	249	55	37	37	8		
6	0955	642.2	1.0	2.0	303	249	54	38	38	6		
7	1005	650.8	1.1	2.2	303	248	55	35	35	6		
8	1015	659.4	1.0	2.0	303	248	55	35	35	6		
9	1025	667.7	0.99	2.0	304	249	54	36	36	6		
10	1035	676.1	1.0	2.0	304	248	54	34	34	4		
11	1045	684.2	1.0	2.0	305	247	56	36	36	4		
12	1055	692.4	0.76	1.5	304	249	55	34	34	5		
1	1055/1055	700.073	0.98	1.9	303	248	55	37	37	7		
2	1055	708.4	1.1	2.6	304	248	56	36	36	8		
3	1055	716.0	1.1	2.2	303	249	55	35	35	6		
4	1055	724.4	0.97	1.9	303	247	57	37	37	7		
5	1055	732.8	0.95	1.9	303	247	54	37	37	7		
6	1105	740.1	0.96	1.9	302	248	57	30	30	7		
7	1105	748.3	0.99	2.7	303	250	58	92	92	7		
8	1105	752.4	1.0	2.0	302	243	57	93	93	7		
9	1135	765.7	1.1	2.2	303	248	58	93	93	8		
10	1145	774.2	1.0	2.0	303	247	57	95	95	7		
11	1155	782.7	0.96	1.7	301	248	58	95	95	7		
12	1165	790.8	0.83	1.7	302	248	58	95	95	6		
Average:	1125	799.014			303	247	57					

Comments:



MONTROSE
AIR MONITORING SERVICES

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: Engine 44
 DATE: 2/5/15
 RUN NO.: 00005
 OPERATOR: 04/nws
 METER BOX NO.: 42 nws
 METER ΔH@: 1356
 METER Yd@: 0 ft/L
 STACK AREA, FT²: 55"

TRAVERSE POINTS, MINIPOINT: 10/14
 $\Delta H = 1.14 \times \Delta P$: 1.788
 Probe Condition, pre/post test: ✓
 Silica Gel Expended, Y/N: ✓
 Filter Condition after Test: ✓
 Check Weight: 1500

AMBIENT TEMPERATURE: 73°
 BAROMETRIC PRESSURE: 29.32
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF. Cp: 0.84
 PROBE ID / MATERIAL: 006/glass
 PROBE LENGTH: 5'
 NOZZLE ID NO/ MATERIAL: 264/glass
 NOZZLE DIAMETER: 0.257
 FILTER NO/TYPE: GF 4421
 PRE-TEST LEAK RATE: 0007 CFM@ 10 in. Hg.
 POST-TEST LEAK RATE: 1.00 CFM@ 10 in. Hg.
 PITOT LEAK CHECK - PRE: 0 POST: 0
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN 45
 SAMPLER: 04/10
 SAMPLE CUSTODIAN 45

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P static in. H ₂ O
1	1240	395.327	0.77	703	703	249	59	59	6	-0.57	
2	1250	361.1	1.0	701	701	250	58	58	6		
3	1300	815.2	1.0	704	704	249	56	56	6		
4	1310	823.2	1.1	701	701	250	54	54	7		
5	1320	821.4	1.1	703	704	248	55	55	7		
6	1330	840.2	1.1	704	704	249	54	54	5		
7	1340	849.5	1.0	703	704	248	55	55	6		
8	1350	858.1	1.0	704	704	249	55	55	6		
9	1400	946.3	1.1	704	704	250	55	55	7		
10	1410	825.7	0.97	703	703	250	55	55	6		
11	1410	811.8	0.85	703	703	249	54	54	6		
12	1430	891.6	0.76	703	703	245	55	55	5		
1	1440 /1450	859.844	0.96	704	704	218	54	54	6		
2	1500	904.9	0.77	704	704	248	55	55	6		
3	1510	915.7	1.0	703	703	243	56	56	6		
4	1520	914.7	1.1	703	703	248	54	54	7		
5	1530	937.7	0.98	703	703	247	55	55	6		
6	1540	941.0	0.96	703	703	248	53	53	6		
7	1550	949.0	0.95	703	703	250	56	56	6		
8	1600	953.2	1.0	703	703	249	56	56	7		
9	1610	965.4	1.0	703	703	244	57	57	7		
10	1620	973.7	1.2	703	703	247	57	57	7		
11	1630	982.4	1.0	703	703	245	58	58	7		
12	1640	970.9	0.63	704	704	248	57	57	6		
Average:	1650	948.621	0	704	704	248	57	57	6		

Comments:



N5

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: Engine 4
 DATE: 2/19/17
 RUN NO: 119173
 METER BOX NO: 51150
 METER ΔH@: 1.386
 METER Yd: 0.912
 STACK AREA, FT²: 55²
 TRAVERSE POINTS, MIN/POINT: 10/4
 ΔH = X ΔP: 1.87
 Probe Condition, pre/post test: ✓
 Silica Gel Expended, Y/N: ✓
 Filter Condition after Test: ✓
 Check Weight: 500/500

AMBIENT TEMPERATURE: 53°
 BAROMETRIC PRESSURE:
 ASSUMED MOISTURE:
 PITOT TUBE COEFF, Cp:
 PROBE ID NO/MATERIAL: 0071
 PROBE LENGTH:
 NOZZLE ID NO/ MATERIAL: 244
 NOZZLE DIAMETER:
 FILTER NO/TYPE: 4F 4F22
 PRE-TEST LEAK RATE: 0.005 CFM@ 10 in. Hg.
 POST-TEST LEAK RATE: 0.003 CFM@ 10 in. Hg.
 PITOT LEAK CHECK - PRE: POST: ✓
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN ✓
 SAMPLER: ✓
 SAMPLE CUSTODIAN ✓

Imp. # Contents Post-Test - Pre-Test = Difference
 1 DEK20 847.0 708.3
 2 " 626.3 69.3
 3 MT 603.3 606.7
 4 SC 10522 999.7
 Total: _____

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
1	0350	998.799	0.97	716	247	58	62	5	-0.55		
2	0360	1001.2	1.0	717	248	56	64	5			
3	0370	1014.3	1.1	717	248	55	65	5			
4	0380	1021.5	1.1	715	247	54	67	5			
5	0390	1030.4	1.2	716	248	53	63	7			
6	0400	1039.0	1.0	714	249	52	69	5			
7	0410	1047.1	1.0	717	247	52	71	5			
8	0420	1055.2	0.97	717	247	52	71	5			
9	0430	1063.7	1.1	718	248	53	72	5			
10	0520	1071.7	0.99	716	246	54	73	5			
11	0530	1079.9	0.96	715	247	54	75	5			
12	0540	1088.0	0.74	714	247	55	75	5			
1	0550/0600	1096.181	1.0	715	248	55	76	5			
2	1010	1104.1	1.0	715	249	54	76	5			
3	1020	1112.3	1.2	713	250	54	77	5			
4	1030	1120.4	0.98	714	250	56	77	5			
5	1040	1128.6	0.97	715	249	55	77	5			
6	1050	1136.7	0.94	715	248	56	80	5			
7	1100	1144.7	1.0	715	248	54	80	5			
8	1110	1152.8	1.1	716	249	53	81	5			
9	1120	1161.0	1.2	715	248	50	82	7			
10	1130	1169.4	0.98	715	248	50	81	7			
11	1140	1177.4	0.94	713	247	51	82	7			
12	1150	1185.5	0.88	713	247	51	81	7			
Average:		1193.441		713	248	51	81				

Comments:



WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: Encino #4
 DATE: 2/10/13
 RUN NO: EN64 PWN 7
 OPERATOR: DM/PS
 METER BOX NO: 42205
 METER ΔH@: 1.786
 METER Yd: 0.552
 STACK AREA, FT²: 55
 TRAVERSE POINTS, MINIPOINT: 10/24
 ΔH = X ΔP: 1.983
 Probe Condition, pre/post test: ✓
 Silica Gel Expended, Y/N: ✓
 Filter Condition after Test: ✓
 Check Weight: 100

AMBIENT TEMPERATURE: 67°
 BAROMETRIC PRESSURE: 28.244
 ASSUMED MOISTURE: 5% 0.84
 PITOT TUBE COEFF. Cp: 0.0674/glass
 PROBE ID NO/MATERIAL: S1
 PROBE LENGTH: 5'
 NOZZLE ID NO/ MATERIAL: M2-2 / 61445
 NOZZLE DIAMETER: 0.253
 FILTER NO/TYPE: 4433
 PRE-TEST LEAK RATE: 0.001 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: ✓
 POST: ✓
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: AS
 SAMPLER: AS
 SAMPLE CUSTODIAN: AS

Imp. # Contents Post-Test - Pre-Test = Difference
 1 D1416 866.5 740.6
 2 11 644.2 1625.7
 3 01 643.7 635.5
 4 56 989.4 940.2
 Total: _____

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
1	1215	1193.601	0.93	1.8	70	249	57	61	6	6	-0.55	
2	1225	1201.5	0.98	1.9	71	248	57	60	6	6		
3	1235	1205.5	1.0	2.0	71	250	58	61	6	6		
4	1245	1212.4	1.0	2.0	71	250	58	61	6	6		
5	1255	1228.7	1.2	2.4	71	249	55	62	7	7		
6	1305	1234.0	1.2	2.4	71	249	54	62	7	7		
7	1315	1242.3	1.1	2.2	71	247	55	63	7	7		
8	1325	1250.1	1.0	2.0	71	248	56	63	6	6		
9	1335	1258.5	1.0	2.0	71	249	56	62	6	6		
10	1345	1266.7	1.1	2.2	71	249	55	64	7	7		
11	1355	1274.8	0.97	1.9	71	248	56	65	6	6		
12	1405	1282.7	0.98	1.6	71	248	57	66	5	5		
13	1415/16	1290.4	0.94	1.5	71	249	57	67	6	6		
2	1435	1298.3	0.98	1.9	71	249	56	67	6	6		
3	1445	1306.3	1.0	2.0	71	247	54	69	6	6		
4	1455	1314.3	0.99	2.0	71	248	54	68	6	6		
5	1505	1322.2	0.96	1.9	71	247	55	70	6	6		
6	1515	1330.1	0.97	1.6	71	247	56	71	6	6		
7	1525	1338.0	1.0	2.0	71	248	57	91	6	6		
8	1535	13440	1.1	2.2	71	249	57	92	7	7		
9	1545	13541	1.2	2.4	71	248	56	92	7	7		
10	1555	1362.4	1.1	2.3	71	249	57	91	6	6		
11	1605	1370.4	0.95	1.9	71	248	57	90	6	6		
12	1615	1378.4	0.80	1.6	71	249	57	91	5	5		
Average:		1386.469										

Comments: _____

Appendix A.3.2 CT-5 Field Data



MONROSE

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: EIA Sanchise
LOCATION: Englewood
DATE: 2/14/23
RUN NO: EN15001
OPERATOR: DH/AMO
METER BOX NO: 4200
METER ΔH@: 1.2%
METER Yd: 0.52
STACK AREA, FT²: 55'
TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H =$ 3.03
Probe Condition, pre/post test: -
Silica Gel Expended, Y/N: -
Filter Condition after Test: -
Check Weight: 500/500

AMBENT TEMPERATURE:	48°	BAROMETRIC PRESSURE:	23.903 psia <th>ASSUMED MOISTURE:</th> <td></td>	ASSUMED MOISTURE:	
PITOT TUBE COEFF. Cp:	0.94	PROBE ID NO/MATERIAL:	007 / 00005	PROBE LENGTH:	5'
NOZZLE ID NO/MATERIAL:	NGL-2	Glass		NOZZLE DIAMETER:	0.052
FILTER NOTYPE:	GF 4483	PRE-TEST LEAK RATE:	0.001 CFM @	in. Hg.	
POST-TEST LEAK RATE:	0.002 CFM @	in. Hg.		PITOT LEAK CHECK - PRE:	UR POST:
CHAIN OF CUSTODY:	SAMPLE CUSTODIAN				8

W002AS-023392-RT-4542

132 of 688

Comments:

Date of last revision 21/4/2017

Master Document Storage\Forms\Datasheets\Field Datasheets DS834048

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: Encino #5
 DATE: 2/14/13
 RUN NO.: EN145-BIN 2
 OPERATOR: DA/AD
 METER BOX NO.: 42265
 METER ΔH@: 1.370
 METER Yd.: 0.992
 STACK AREA, FT²: 55
 TRAVERSE POINTS, MIN/POINT: 10/24
 ΔH= X ΔP: 203
 Probe Condition, pre/post/test: /
 Silica Gel Expended, Y/N: /
 Filter Condition after Test: /
 Check Weight: 201.50

AMBIENT TEMPERATURE: 55
 BAROMETRIC PRESSURE: 24.98
 ASSUMED MOISTURE: 0.5%
 PITOT TUBE COEFF, Cp: 0.85
 PROBE ID NO/MATERIAL: 600P glass
 PROBE LENGTH: 5'
 NOZZLE ID NO/MATERIAL: 2661 glass
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: 44184
 PRE-TEST LEAK RATE: 0.002 CFM@ 0 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM@ 0 in. Hg.
 PITOT LEAK CHECK - PRE: POST: ✓
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN ✓
 SAMPLER ✓
 SAMPLE CUSTODIAN ✓

SAMPLE CUSTODIAN

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Vacuum in. Hg.	O ₂ %	P static in. H ₂ O
1	1320	150.018	0.90	202	249	59	241	6		-0.58	
2	1330	177.7	0.80	14	202	58	241	6			
3	1340	205.3	0.85	1.7	201	58	241	6			
4	1350	213.0	0.93	1.4	202	57	241	6			
5	1360	220.8	1.0	2.0	201	57	244	51			
6	1370	228.7	1.1	2.2	202	57	242	51			
7	1380	236.7	1.3	2.6	202	55	248	55			
8	1390	244.9	1.4	2.8	202	55	248	55			
9	1400	252.2	1.0	2.0	202	55	248	55			
10	1350	301.6	0.98	2.0	201	54	247	54			
11	1400	309.0	0.85	1.7	201	54	248	55			
12	1410	326.6	0.75	1.5	201	54	245	54			
13	1420/40	9.81.377	0.92	1.5	202	56	242	56			
2	1430	292.1	0.84	1.3	202	57	250	57			
3	1440	299.6	0.88	1.8	203	57	245	58			
4	1450	307.7	2.94	3.9	202	57	248	57			
5	1540	315.5	1.0	2.0	202	57	247	57			
6	1520	328.4	1.0	2.0	201	58	252	57			
7	1530	331.5	1.2	2.1	201	58	249	58			
8	1540	339.4	1.3	2.4	201	58	245	58			
9	1550	349.9	1.0	2.0	200	59	244	59			
10	1620	355.9	0.97	2.0	200	59	249	60			
11	1640	365.4	0.42	1.7	200	59	249	59			
12	1620	377.8	0.75	1.5	200	59	248	59			
Average: 1630		362.379					248	57			

Comments:



MONTROSE
AIR QUALITY SERVICES

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Vacuum in. Hg.	O ₂ %	P static in. H ₂ O
1	0235	385.77	0.88	1.9	707	747	747	747	746	46	4	-0.48
2	0245	323.5	0.80	1.6	700	749	749	749	745	45	4	
3	0255	401.2	0.85	1.7	701	749	749	749	747	47	4	
4	0305	408.9	0.94	1.9	700	748	748	748	748	48	4	
5	0315	416.7	1.0	2.0	697	749	749	749	748	48	4	
6	0325	424.4	1.2	2.4	692	747	747	747	747	47	4	
7	0335	432.8	1.3	2.6	690	749	749	749	749	49	4	
8	0345	441.1	1.3	2.6	697	750	750	750	750	50	4	
9	0355	449.4	1.0	2.0	695	749	749	749	749	49	4	
10	0306	457.3	0.98	2.0	698	750	750	750	750	50	4	
11	0315	465.2	0.85	1.7	701	749	749	749	749	49	4	
12	0325	472.7	0.75	1.5	701	747	747	747	747	47	4	
1	0335	480.67	0.90	1.8	702	746	746	746	746	46	4	
2	0345	488.3	0.84	1.7	702	748	748	748	748	48	4	
3	1005	496.0	0.86	1.7	702	749	749	749	749	49	4	
4	1015	503.7	0.94	1.9	702	748	748	748	748	48	4	
5	1025	511.4	1.0	2.0	703	749	749	749	749	49	4	
6	1035	519.5	1.1	2.1	703	748	748	748	748	48	4	
7	1045	527.4	1.2	2.1	703	742	742	742	742	42	4	
8	1055	535.8	1.2	2.1	704	748	748	748	748	48	4	
9	1105	544.0	1.1	2.1	704	745	745	745	745	45	4	
10	1115	552.9	0.98	2.0	706	744	744	744	744	44	4	
11	1125	560.7	0.84	1.7	706	748	748	748	748	48	4	
12	1135	568.7	0.73	1.5	706	749	749	749	749	49	4	
Average: 445												TEST

CLIENT: Sunshine
LOCATION: Encino, CA
DATE: 2/15/23
RUN NO: 145 RUN 3
OPERATOR: DA/AD
METER BOX NO: 12WCS
METER ΔH@: 1.386
METER Yd: 0.992
STACK AREA, FT²: 55
TRAVERSE POINTS, MIN/POINT: 10/24
ΔH = X ΔP: 1.03
Probe Condition, pre/post test: ✓
Silica Gel Expended, Y/N: ✓
Filter Condition after Test: ✓
Check Weight: 520/500

AMBIENT TEMPERATURE: 35°
BAROMETRIC PRESSURE: 23.15
ASSUMED MOISTURE: 5%
PITOT TUBE COEFF, Cp: 0.34
PROBE ID NO/MATERIAL: 907/910
PROBE LENGTH: 5'
NOZZLE ID NO/MATERIAL: None
NOZZLE DIAMETER: 0.37
FILTER NO/TYPE: AF 4433
PRE-TEST LEAK RATE: 0.002 CFM@ 10 in. Hg.
POST-TEST LEAK RATE: 0.004 CFM@ 10 in. Hg.
PITOT LEAK CHECK - PRE: ✓
CHAIN OF CUSTODY:
SAMPLE CUSTODIAN: AJ
SAMPLER: DA/AD
SAMPLE CUSTODIAN: AJ

Imp. # Contents Post-Test - Pre-Test = Difference
1 DE 160 870.9 704.8
2 " 627.7 623.9
3 MT 600.0 607.5
4 Sg Total: 1032.8 979.9



MONTROSE
Air Quality Services

CLIENT: Sunshine

LOCATION: Equipment #5

DATE: 2/15/13

RUN NO: ENG 5 DIN 4

OPERATOR: DH/AO

METER BOX NO: 1200CS

METER ΔH@: 1.386

METER Yd: 0.992 35"

STACK AREA, FT²: -

TRAVERSE POINTS, MIN/POINT: 10/24

ΔH= X ΔP: 2.03

Probe Condition, pre/post test: -

Silica Gel Expended, Y/N: -

Filter Condition after Test: -

Check Weight: 500/500

AMBIENT TEMPERATURE: 54°
BAROMETRIC PRESSURE: 29.15
ASSUMED MOISTURE:
PITOT TUBE COEFF. CP: 0.94
PROBE ID NO/MATERIAL: 006 / glass
PROBE LENGTH:
NOZZLE ID NO/ MATERIAL: 266 / 34.9 Glass
NOZZLE DIAMETER: 0.257
FILTER NO/TYPE: GTF 4436
PRE-TEST LEAK RATE: 0.008 CFM @ 0 in. Hg.
POST-TEST LEAK RATE: 0.007 CFM @ 10 in. Hg.
PITOT LEAK CHECK - PRE: -
CHAIN OF CUSTODY: SAMPLE CUSTODIAN
SAMPLE SAMPLER: 04/20
SAMPLE CUSTODIAN: 04/20

54°

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
1	1200	532.306	1.90	1.8	209	244	56	70	-	-	-0.48
2	140	535.1	0.90	1.4	209	246	54	67	-	-	-
3	1220	532.7	0.85	1.7	206	248	52	67	-	-	-
4	1230	530.4	0.93	1.9	208	249	50	67	-	-	-
5	1240	528.3	1.0	2.0	208	250	49	67	-	-	-
6	1250	526.3	1.1	2.2	208	248	49	70	-	-	-
7	1300	524.4	1.3	2.6	207	248	50	71	-	-	-
8	1310	522.4	1.4	2.8	208	247	51	70	-	-	-
9	1320	521.1	1.0	2.0	207	248	52	70	-	-	-
10	1330	519.0	0.94	1.9	207	249	54	71	-	-	-
11	1340	516.9	0.85	1.7	207	247	55	70	-	-	-
12	1350	514.7	0.74	1.5	207	247	55	67	-	-	-
1	1400/10	512.3	0.92	1.9	207	247	54	71	-	-	-
2	1420	510.1	0.74	1.7	207	248	54	73	-	-	-
3	1430	507.4	0.88	1.9	207	248	53	74	-	-	-
4	1440	505.5	0.95	1.9	207	245	54	74	-	-	-
5	1450	503.3	1.0	2.0	207	249	55	75	-	-	-
6	1500	501.3	1.0	2.0	207	250	55	73	-	-	-
7	1510	498.3	1.2	2.4	206	250	54	74	-	-	-
8	1520	492.5	1.3	2.4	208	248	55	76	-	-	-
9	1530	488.9	1.0	2.0	206	249	54	77	-	-	-
10	1540	485.8	0.97	2.0	208	247	55	75	-	-	-
11	1550	482.4	0.80	1.4	207	243	55	76	-	-	-
12	1600	480.9	0.74	1.5	206	249	55	77	-	-	-
Average: 1610 488.64											
Comments: 1/21/2017											
Imp. # Contents Post-Test - Pre-Test = Difference											
1	WT	H 20	91.1	7565							
2	WT	H 20	6489	6364							
3	WT	H 20	6380	6345							
4	56	56	985.3	934.4							
Total:											



MONTROSE QUALITY SERVICES

EPA 5

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sensimine LOCATION: Engine #5
 DATE: 2/10/23 RUN NO: 12UN5
 OPERATOR: DH/AN METER BOX NO: 42 WCE
 METER $\Delta H @:$ 1.346 METER Yd: 2.912
 STACK AREA, FT²: 5511
 TRAVERSE POINTS, MIN/POI:
 $\Delta H =$ X $\Delta P:$ 2.03
 Probe Condition, pre/post test:
 Silica Gel Expended, Y/N: _____
 Filter Condition after Test:
 Check Weight: 5050

AMBIENT TEMPERATURE: 40°
BAROMETRIC PRESSURE: 28.33
ASSUMED MOISTURE: 5%
PILOT TUBE COEFF. Cp: 0.54
PROBE ID NO/MATERIAL: 0127/41458
PROBE LENGTH: 5
NOZZLE ID NO/MATERIAL: MU-2 / 1655
NOZZLE DIAMETER: 0.253
FILTER NOTYPE: G 4487
PRE-TEST LEAK RATE: 0.006 CFM@ 0 in. Hg.
POST-TEST LEAK RATE: 0.002 CFM@ 0 in. Hg.
PILOT LEAK CHECK - PRE: 0 POST: 0
SAMPLE CUSTODIAN: ✓
CHAIN OF CUSTODY: ✓

Filter Condition after Test:
Check Weight: 500/500

Imp. #	Contents	Post-Test - Pre-Test = Difference
1	<u>D14P</u>	<u>80.0</u> / <u>704.2</u>
2	<u>1</u>	<u>1030.1</u> / <u>1031.6</u>
3	<u>WT</u>	<u>600.4</u> / <u>607.8</u>
4	<u>S29</u>	<u>1030.6</u> / <u>979.0</u>
		Total: _____

SAMPLE		OPA		CUSTODIAN	
Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp., °F
1	0735	369.011	0.90	1.8	710
2	0745	376.7	0.82	1.7	710
3	0755	384.4	0.85	1.7	709
4	0805	392.0	0.92	1.9	709
5	0815	397.8	1.1	2.3	709
6	0825	402.8	1.0	2.0	709
7	0835	415.7	1.3	2.6	710
8	0845	424.1	1.4	2.8	710
9	0855	432.4	1.2	2.4	711
10	0905	440.4	0.95	1.7	710
11	0915	448.7	0.84	1.7	709
12	0925	454.5	0.75	1.5	709
1	0935	464.071	0.92	1.9	708
2	0945	371.7	0.80	1.4	709
3	1005	379.5	0.86	1.7	710
4	1015	387.2	0.94	1.9	710
5	1025	395.1	1.0	2.0	708
6	1035	403.0	1.0	2.0	709
7	1045	411.0	1.2	2.4	709
8	1055	419.2	1.2	2.4	708
9	1105	427.5	1.0	2.0	703
10	1115	435.4	0.98	2.0	707
11	1125	443.5	0.84	1.7	707
12	1135	451.2	0.75	1.5	707

W002AS-023392-RT-4542

136 of 688

Comments: 109.553

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT:	Sunshine	AMBIENT TEMPERATURE:	58°
LOCATION:	Examine 45	BAROMETRIC PRESSURE:	28.33
DATE:	2/16/13	ASSUMED MOISTURE:	54
RUN NO:	619 (D) 6	PITOT TUBE COEFF. Cp:	0.84
OPERATOR:	OH (A)	PROBE ID NO/MATERIAL:	075 / 9455
METER BOX NO:	42262	PROBE LENGTH:	5
METER ΔH@:	1.386	NOZZLE ID NO./ MATERIAL:	206 / 16155
METER Yd@:	0.992	NOZZLE DIAMETER:	0.259
STACK AREA, FT ² :	551"	FILTER NO/TYPE:	44388
TRAVERSE POINTS, MIN/POINT:	10/24	PRE-TEST LEAK RATE@:	0.009 CFM@ 10 in. Hg.
ΔH=	X ΔP: 203	POST-TEST LEAK RATE@:	0.002 CFM@ 10 in. Hg.
Probe Condition, pre/post test:	-	PITOT LEAK CHECK - PRE:	POST: 0.2
Silica Gel Expended, Y/N:	-	SAMPLE CUSTODIAN:	AJ
Filter Condition after Test:	-	SAMPLER:	04-10
Check Weight:	500/500	SAMPLE CUSTODIAN:	AB

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Vacuum in. Hg.	O ₂ %	P static in. H ₂ O
1	1200	953.811	0.90	1.8	707	707	349	54	71	6	-0.19	
2	1210	954.4	0.82	1.7	708	748	54	53	70	6	-0.19	
3	1220	954.3	0.84	1.7	708	747	53	53	70	6	-0.19	
4	1230	952.0	0.92	1.9	708	748	53	50	71	6	-0.19	
5	1240	951.8	1.0	2.0	708	750	51	51	73	6	-0.19	
6	1250	951.7	1.1	2.1	707	750	52	52	72	7	-0.19	
7	1300	1003.8	1.3	2.0	707	750	51	73	73	8	-0.19	
8	1310	1014.1	1.4	2.8	706	749	52	73	73	8	-0.19	
9	1320	1022.4	1.6	3.0	707	749	53	75	75	9	-0.19	
10	1330	1030.6	0.98	2.0	706	749	54	76	76	9	-0.19	
11	1340	1038.5	0.82	1.7	706	748	54	75	75	9	-0.19	
12	1350	1046.2	0.75	1.5	706	749	56	77	77	5	-0.19	
1	1400/0	1053.897	0.91	1.8	706	747	55	77	77	9	-0.19	
2	1410	1061.4	0.84	1.7	707	748	56	78	78	9	-0.19	
3	1430	1069.3	0.86	1.7	708	750	57	79	79	8	-0.19	
4	1440	1077.0	0.95	2.0	708	749	56	78	78	6	-0.19	
5	1450	1084.9	0.99	2.0	707	749	56	79	79	7	-0.19	
6	1500	1092.9	1.1	2.1	707	749	57	80	80	7	-0.19	
7	1510	1100.9	1.1	2.6	707	749	57	79	79	8	-0.19	
8	1520	1109.0	1.3	2.6	707	748	55	78	78	6	-0.19	
9	1530	1117.3	1.0	2.0	707	748	56	79	79	5	-0.19	
10	1540	1125.3	0.94	2.0	707	749	57	81	81	6	-0.19	
11	1550	1133.2	0.90	1.6	707	749	57	80	80	4	-0.19	
12	1600	1141.9	0.76	1.5	707	749	58	80	80	5	-0.19	
Average:		1149.743							EN	TEST		

Comments: 170.737

Imp. #	Contents	Post-Test	Pre-Test	Difference
1	DE420	183.5	79.7	
2	MT	637.0	630.9	
3	MT	636.2	635.8	
4	SL	933.4	915.5	
Total:				



WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: Engine 35
 DATE: 2/17/23
 RUN NO: Eng 5 Run 7
 OPERATOR: DH/AD
 METER BOX NO: 42ives
 METER ΔH@: 1.716
 METER Yd: 0.931
 STACK AREA, FT²: 55.1
 ΔH = X ΔP: 2.03
 TRAVERSE POINTS, MIN/POINT: 10/24
 Probe Condition, pre/post test: ✓
 Silica Gel Expended, Y/N: ✓
 Filter Condition after Test: ✓
 Check Weight: 520 (CD)

AMBIENT TEMPERATURE: 45°
 BAROMETRIC PRESSURE: 28.14
 ASSUMED MOISTURE:
 PITOT TUBE COEFF, Cp: 0.84
 PROBE ID NOMATERIAL: 0335 / 01955
 PROBE LENGTH: 5'
 NOZZLE ID NO/ MATERIAL: No 2-2 / Glass
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: GF 4489
 PRE-TEST LEAK RATE: 0.002 CFM@ 15 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM@ 15 in. Hg.
 PITOT LEAK CHECK - PRE: ✓
 POST: ✓
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN
 SAMPLER: DA/AD

SAMPLE CUSTODIAN

Point	Meter	Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Vacuum in. Hg.	O ₂ %	Pstatic in. H ₂ O
1	0730	1150.147	0.90	18	203	249	51	212	6.3	6	-0.19
2	0740	1154.6	0.83	17	203	249	50	211	6.1	6	
3	0750	1165.6	0.85	17	203	250	47	212	6.2	6	
4	0800	1173.4	2.90	18	203	248	46	212	6.2	6	
5	0810	1181.3	1.0	20	204	248	46	213	6.3	7	
6	0820	1189.2	1.1	21	205	247	47	212	6.2	7	
7	0830	1197.3	1.3	21	204	248	45	213	6.3	8	
8	0840	1205.4	1.4	21	205	250	43	214	6.4	8	
9	0850	1214.1	1.0	20	205	249	47	214	6.4	7	
10	0900	1223.1	0.97	20	205	249	46	216	6.6	7	
11	0910	1230.0	0.82	17	205	248	50	215	6.5	6	
12	0920	1237.8	0.74	15	205	247	50	217	6.7	5	
13	0930/10	1245.469	0.90	13	203	248	50	217	6.7	6	
14	0950	1253.2	0.81	14	204	249	51	216	6.9	6	
15	1000	1260.8	0.85	17	204	248	53	216	6.6	6	
16	1010	1268.5	0.96	19	205	250	54	216	6.7	6	
17	1020	1276.4	1.0	20	205	250	54	217	7.2	7	
18	1030	1284.4	1.1	21	205	249	54	217	7.4	7	
19	1040	1292.5	1.1	22	206	247	55	215	7.5	8	
20	1050	1300.4	1.3	20	206	248	54	214	7.4	8	
21	1100	1309.0	1.0	20	206	249	54	215	7.5	7	
22	1110	1312.0	1.0	20	206	246	55	216	7.6	7	
23	1120	1314.9	2.80	14	206	246	57	216	7.7	6	
24	1130	1317.9	0.72	16	206	248	56	216	7.8	5	
Average: 1140		1314.375						E 22	7.5		
Comments: 191.238											

Appendix A.3.3 CT4 and CT-5 Laboratory Data

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 1

Sample Date: Feb 7, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4417	0.3496	0.3496	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9293	31.1518	31.1511	0.7	0.00	100	0.70
Acetone Blank	9309	28.9133	28.9133	0.0		100	
						200	
						200	
						+	

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes	

PARTICULATE EPA METHOD 5

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 1

Sample Date: Feb 7, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4417	0.3496	0.3496	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9293	31.1518	31.1511	0.7	0.00	100	0.7
Acetone Blank	9309	28.9133	28.9133	0.6		100	
						200	
						200	

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 2

Sample Date: Feb 8, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4418	0.3470	0.3457	1.3	-----	-----	1.3
2. Probe and Nozzle Wash	9295	28.3014	28.3012	0.2	0.00	25	0.2
						25	

Total Particulate = 1.5

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 2

Sample Date: Feb 7, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	93-4418	0.3470	0.3457	1.3	-----	-----	1.3
2. Probe and Nozzle Wash	9295	AE 24.2315 28.3014	AC 24.2312 28.3012	0.2	0.00	25 25	0.2

* VM 3/1/23

Total Particulate = 1.5

Method of Sample Prep/Analysis Notes

PARTICULATE EPA METHOD 5

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 3

Sample Date: Feb 8, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4419	0.3466	0.3457	0.9	-----	-----	0.9
2. Probe and Nozzle Wash	9296	29.2315	29.2312	0.3	0.00	60	0.3
						60	

Total Particulate = 1.2

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 3

Sample Date: Feb 7, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	93-4419	0.3466	0.3457	0.9	-----	-----	0.9
2. Probe and Nozzle Wash	9296	29.2315	29.2312	0.3	0.00	60	0.3
						60	

* VM 3/1/23

Total Particulate = 1.2

Method of Sample Prep/Analysis Notes

PARTICULATE EPA METHOD 5

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 4

Sample Date: Feb 9, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4420	0.3431	0.3431	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9297	28.2545	28.2538	0.7	0.00	40	0.7
						40	

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes

PARTICULATE

EPA METHOD 5

Project # PROJ-023392 **Sample Date:** Feb 7, 2023
Client/Location: DTE Energy **Analysis Date:** Feb 23, 2023
Sample Location: Engine 4 **Analyst:** AE
Test # Eng 4 Run 4 Acetone Blank (mg/ml) 0.0000

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	473-4470	0.3431	0.3431	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9297	29.2545	29.2538	0.7	0.00	40	0.7
						40	

* Mr 3/6/23

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 5

Sample Date: Feb 9, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4421	0.3493	0.3485	0.8	-----	-----	0.80
2. Probe and Nozzle Wash	9298	28.9515	28.9510	0.5	0.00	40	0.50
						40	

Total Particulate = 1.3

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 5

Sample Date: Feb 7, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	93-4421	0.3493	0.3495	0.8	-----	-----	0.80
2. Probe and Nozzle Wash	9297	28.9515	28.9510	0.5	0.00	40	0.50
						40	

* LM 3/1/23

Total Particulate = 1.3

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 6

Sample Date: Feb 10, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4422	0.3503	0.3499	0.4	-----	-----	0.4
2. Probe and Nozzle Wash	9299	28.7119	28.7118	0.1	0.00	50	0.1
						50	

Total Particulate = 0.5

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 6

Sample Date: Feb 16th, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	473-4402	0.3503	0.3499	0.4	-----	-----	0.4
2. Probe and Nozzle Wash	9299	28.7119	28.7118	0.1	0.00	50	0.1

* VM 3/1/23

Total Particulate = 0.5

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 7

Sample Date: Feb 10, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4433	0.3509	0.3496	1.3	-----	-----	1.3
2. Probe and Nozzle Wash	9300	31.3633	31.3632	0.1	0.00	50	0.1
						50	

Total Particulate = 1.4

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 Run 7

Sample Date: Feb 7, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4433	0.3509	0.3496	1.3	-----	-----	1.3
2. Probe and Nozzle Wash	9300	31.3633	31.3632	0.1	0.00	50 50	0.1

* VM 3/1/23

Total Particulate = 1.4

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 4
Test # Eng 4 FB

Sample Date: Feb 10, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4499	0.3666	0.3666	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9294	29.7746	29.7743	0.3	0.00	45	0.3
						45	

Total Particulate = 0.3

Method of Sample Prep/Analysis Notes	

PARTICULATE EPA METHOD 5

Project # PROJ-023392
 Client/Location: DTE Energy
 Sample Location: Engine 4
 Test # Eng 4 FB

Sample Date: Feb 1, 2023
 Analysis Date: Feb 23, 2023
 Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4449	0.3666	0.3666	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9294	29.7746	29.7743	0.3	0.00	45	0.3
						45	

✓ Vn 3/1/23

Total Particulate = 0.3

Method of Sample Prep/Analysis Notes

CHAIN OF CUSTODY

CLIENT: DTE Energy PROJ #: 023392 TEST DATE(S): 27/2023 - 2/10/-2023

LOCATION: Sunshine SAMPLER(S): DH/AD/PSJ

SAMPLE LOCATION: SGT Eng 4 Exhaust PROJECT MANAGER: PSJ

TEST METHOD(S): EPA 5 DATE DUE: ASAP

OUTSIDE LAB REQUIRED?: Yes COMPLIANCE TEST?: Yes

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
2/7/2023	10:50	1	Eng 4 Run1	3	DH,AD,PSJ	
2/8/2023	8:10	2	Eng 4 Run2	3	DH,AD,PSJ	
2/8/2023	13:05	3	Eng 4 Run3	3	DH,AD,PSJ	
2/9/2023	8:05	4	Eng 4 Run4	3	DH,AD,PSJ	
2/9/2023	12:40	5	Eng 4 Run5	3	DH,AD,PSJ	
2/10/2023	7:50	6	Eng 4 Run6	3	DH,AD,PSJ	
2/10/2023	12:15	7	Eng 4 Run7	3	DH,AD,PSJ	
2/10/2023		FB	Eng 4 Field Blank	3	DH,AD,PSJ	

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
	2/23/23 13:00	Adrian Lauer	02/23/23 10:30

ANALYSIS REQUIRED: EPA 5



MONITROSE
AIR QUALITY SERVICES
Date of Last Revision 9/1/2017

Chain of Custody - DS834001 - Excel
Master Document Storage\Forms\Datasheets\Lab Forms

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 1

Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4483	0.3642	0.3636	0.6	-----	-----	0.6
2. Probe and Nozzle Wash	9301	28.5975	28.5975	0.0	0.00	50	0.00
						50	
Acetone Blank	9309	28.9133	28.9133	0.0		200	
						200	

Total Particulate = 0.6

Method of Sample Prep/Analysis Notes	

PARTICULATE EPA METHOD 5

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 1

Acetone Blank (mg/ml) 0.0000

Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	93-4483	0.3642	0.3636	0.6	-----	-----	0.6
2. Probe and Nozzle Wash	9301	27.5975	28.5975	0.0	0.00	50	0.00
Acetone Blank	9309	28.9133	28.9133	0.0		50	
						200	
						200	

Total Particulate = 0.6

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 2

Sample Date: Feb 15, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4484	0.3646	0.3635	1.1	-----	-----	1.1
2. Probe and Nozzle Wash	9303	29.9323	29.9323	0.0	0.00	50	0.0
						50	

Total Particulate = 1.1

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 2

15%
Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	43-4484	0.3646	0.3635	1.1	-----	-----	1.1
2. Probe and Nozzle Wash	9303	29.9323	29.9323	0.0	0.00	50 50	0.0

* VM 3/1/23

Total Particulate = 1.1

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 3

Sample Date: Feb 15, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4485	0.3709	0.3701	0.8	-----	-----	0.8
2. Probe and Nozzle Wash	9304	30.6492	30.6492	0.0	0.00	45	0.0
						45	

Total Particulate = 0.8

Method of Sample Prep/Analysis Notes	

PARTICULATE EPA METHOD 5

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 3

¹⁵⁴
Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4465	0.3709	0.3701	0.8	-----	-----	0.8
2. Probe and Nozzle Wash	9304 9305 AE	30.6492	30.6492	0.0	0.00	45 45	0.0

* VM 3/1/23

Total Particulate = 0.8

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 4

Sample Date: Feb 16, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4486	0.3684	0.3678	0.6	-----	-----	0.6
2. Probe and Nozzle Wash	9305	28.7316	28.7315	0.1	0.00	60	0.1
						60	

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 4

164
Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	43-4496	0.3684	0.3678	0.6	-----	-----	0.6
2. Probe and Nozzle Wash	9305 4306 4-1	28.731b	28.7315	0.1	0.00	60 60	0.1

* VM 3/1/23

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 5

Sample Date: Feb 16, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4487	0.3677	0.3677	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9306	28.0209	28.0209	0.0	0.00	60	0.00
						60	

Total Particulate = 0.0

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 5

Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4487	0.3677	0.3677	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9306 9307 4P	28.0209	28.0209	0.0	0.00	60 60	0.00

X VM 3/1/23

Total Particulate = 0.0

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 6

Sample Date: Feb 17, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4488	0.3672	0.3667	0.5	-----	-----	0.5
2. Probe and Nozzle Wash	9307	30.0686	30.0674	1.2	0.00	70	1.2
						70	

Total Particulate = 1.7

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 6

Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4488	0.3672	0.3667	0.5	-----	-----	0.5
2. Probe and Nozzle Wash	AE 8308 9307	30.0686	30.0674	1.2	0.00	70 70	1.2

x VM 3/1/23

Total Particulate = 1.7

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 7

Sample Date: Feb 17, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4489	0.3696	0.3689	0.7	-----	-----	0.7
2. Probe and Nozzle Wash	9308	29.3233	29.3233	0.0	0.00	70	0.0
						70	

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 Run 7

Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4489	0.3696	0.3689	0.7	-----	-----	0.7
2. Probe and Nozzle Wash	9308 43001 AF	29.3233	29.3233	0.0	0.00	70 70	0.0

VM 3/1/23

Total Particulate = 0.7

Method of Sample Prep/Analysis Notes	

**PARTICULATE
EPA METHOD 5**

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 FB

Sample Date: Feb 17, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	83-4490	0.3691	0.3691	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9302	29.3013	29.3013	0.0	0.00	45	0.0
						45	

Total Particulate = 0.0

Method of Sample Prep/Analysis Notes	

PARTICULATE EPA METHOD 5

Project # PROJ-023392
Client/Location: DTE Energy
Sample Location: Engine 5
Test # Eng 5 FB

Acetone Blank (mg/ml) 0.0000

¹⁷
Sample Date: Feb 14, 2023
Analysis Date: Feb 23, 2023
Analyst: AE

Item	Item Number	Final Weight (g)	Tare Weight (g)	Gain Weight (mg)	Blank Correction (mg)	Aliquot Correction (ml/ml)	Net Gain (mg/sample)
1. Glass Fiber Filter	834440	0.3691	0.3691	0.0	-----	-----	0.0
2. Probe and Nozzle Wash	9302	29.3013	29.3013	0.0	0.00	45	0.0
						45	

* VM 3/1/23

Total Particulate = 0.0

Method of Sample Prep/Analysis Notes

CHAIN OF CUSTODY

CLIENT: DTE Energy PROJ #: 023392 TEST DATE(S): 2/14/2023 - 2/17/2023

LOCATION: Sunshine SAMPLER(S): DH/AD/PSJ

SAMPLE LOCATION: SGT Eng 5 Exhaust PROJECT MANAGER: PSJ

TEST METHOD(S): EPA 5 DATE DUE: ASAP

OUTSIDE LAB REQUIRED?: Yes COMPLIANCE TEST?: EPA

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
2/14/2023	8:00	1	Eng 5 Run1	3	DH,AD,PSJ	
2/15/2023	12:20	2	Eng 5 Run2	3	DH,AD,PSJ	
2/15/2023	7:35	3	Eng 5 Run3	3	DH,AD,PSJ	
2/16/2023	12:00	4	Eng 5 Run4	3	DH,AD,PSJ	
2/16/2023	7:35	5	Eng 5 Run5	3	DH,AD,PSJ	
2/17/2023	12:00	6	Eng 5 Run6	3	DH,AD,PSJ	
2/17/2023	7:30	7	Eng 5 Run7	3	DH,AD,PSJ	
2/17/2023		FB	Eng 5 Field Blank	3	DH,AD,PSJ	

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
	2/23/2023	Darren Enwright	02/23/2023 1030

ANALYSIS REQUIRED: EPA 5



Date of Last Revision 9/1/2017

Chain of Custody - DS834001 - Excel
Master Document Storage\Forms\Datasheets\Lab Forms

Appendix A.4 Metals Field and Laboratory Data

Appendix A.4.1 CT-4 Field Data

ENCL 4 R1

04A25

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Substrate
 LOCATION: 21123
 DATE: 2/1/23
 RUN NO: ENCL 4 P41-1
 OPERATOR: DHAD
 METER BOX NO: 45 WCCS
 METER ΔH@: 1.771
 METER Yd: 1014
 STACK AREA, FT²: 55
 TRAVERSE POINTS, MIN/POINT: 10 (24
 $\Delta H = X \Delta P$: 1.950
 Probe Condition, pre/post test: ✓
 Silica Gel Expended, Y/N: ✓
 Filter Condition after Test: ✓
 Check Weight: 500/500

AMBIENT TEMPERATURE: 55°
 BAROMETRIC PRESSURE: 28.46
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF, Cp: 0.94
 PROBE ID NO/MATERIAL: 120/glass
 PROBE LENGTH: 5'
 NOZZLE ID NO/MATERIAL: N62-15
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: 5-4-41
 PRE-TEST LEAK RATE: 2.00 CFM @ 5 in. Hg.
 POST-TEST LEAK RATE: 0.005 CFM @ 5 in. Hg.
 PITOT LEAK CHECK - PRE: ✓
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN M
 SAMPLER M
 SAMPLE CUSTODIAN M

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1050	230.203	0.97	1.9	305	247	54	58	58	5	5	0.55
2	1100	233.29	1.1	2.1	303	248	52	54	54	5	5	
3	1110	245.5	1.6	2.1	304	248	52	55	58	5	5	
4	1120	255.4	0.99	1.9	304	343	55	51	51	5	5	
5	1130	261.1	0.92	1.9	302	249	51	53	53	5	5	
6	1140	269.2	0.95	1.9	303	247	55	54	54	5	5	
7	1150	277.8	0.0	2.0	301	318	56	55	55	5	5	
8	1200	284.6	1.2	2.7	303	..	55	55	55	6	5	
9	1210	292.8	1.1	2.1	301	343	56	57	57	5	5	
10	1220	298.9	0.75	1.9	302	248	53	55	55	5	5	
11	1230	308.5	0.94	1.8	303	248	56	54	54	4	4	
12	1240	315.7	0.80	1.6	301	249	56	54	54	4	4	
	~	323.611			END	Port						
Average:												

Comments: _____

Date of last revision 4/15/2022

Page 1 of 3

MONTROSE
AIR QUALITY SERVICES

ENL 4 121

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT:	_____	AMBENT TEMPERATURE:	_____	Imp. # Contents	Post-Test - Pre-Test = Difference
LOCATION:	_____	BAROMETRIC PRESSURE:	_____	_____	_____
DATE:	_____	ASSUMED MOISTURE:	_____	_____	_____
RUN NO.:	ENL 4 Run 1	PITOT TUBE COEFF. CP:	_____	_____	_____
OPERATOR:	_____	PROBE ID NOMATERIAL:	_____	_____	_____
METER BOX NO.:	_____	PROBE LENGTH:	_____	_____	_____
METER ΔH@:	_____	NOZZLE ID NO/ MATERIAL:	_____	_____	_____
METER Yd:	_____	NOZZLE DIAMETER:	_____	_____	_____
STACK AREA, FT ² :	_____	FILTER NO/TYPE:	_____	_____	_____
TRAVERSE POINTS, MIN/POINT:	_____	PRE-TEST LEAK RATE:	CFM@ _____ in. Hg.	_____	_____
ΔH=	X ΔP: 1.750	POST-TEST LEAK RATE:	CFM@ _____ in. Hg.	_____	_____
Probe Condition, pre/post test:	_____	PITOT LEAK CHECK - PRE:	_____	POST:	_____
Silica Gel Expended, Y/N:	_____	CHAIN OF CUSTODY:	_____	_____	_____
Filter Condition after Test:	_____	SAMPLE CUSTODIAN	_____	_____	_____
Check Weight:	_____	SAMPLER	_____	_____	_____
Average:	_____	SAMPLE CUSTODIAN	_____	Total:	_____

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1300	223.61	0.75	1.9	305	249	55	55	55	5	5	5
2	1410	851.2	0.98	1.7	304	247	51	51	51	5	5	5
3	1320	837.7	0.61	2.1	301	248	56	56	56	5	5	5
4	1330	846.8	1.1	2.1	303	248	54	54	54	5	5	5
5	1340	851.4	1.2	2.3	301	249	55	55	55	5	5	5
6	1350	862.7	1.0	2.0	304	248	54	54	54	5	5	5
7	1405	670.7	1.0	2.0	301	243	57	57	57	5	5	5
8	1410	828.7	0.97	1.9	303	248	57	57	57	5	5	5
9	1420	886.6	1.1	2.1	305	248	58	58	58	5	5	5
10	1430	834.9	0.99	1.9	303	249	57	57	57	5	5	5
11	1440	902.9	1.0	2.0	301	250	57	57	57	5	5	5
12	1450	911.2	0.43	1.5	304	244	58	58	58	5	5	5
13	1500	919.311	—	—	301	253	57	57	57	5	5	5
Comments: _____												



EPA 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Surveillance
 LOCATION: Engine 64
 DATE: 2/18/23
 RUN NO: 2
 OPERATOR: 94 / 29
 METER BOX NO: 45 wws
 METER ΔH@: 1.291
 METER Yd@: 1.014
 STACK AREA, FT²: 55'
 TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H = 1.950 \times \Delta P:$ 1.950
 Probe Condition, pre/post test: /
 Silica Gel Expanded, Y/N: /
 Filter Condition after Test: /
 Check Weight: 500/500

AMBIENT TEMPERATURE: 52°
 BAROMETRIC PRESSURE: 29.34
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF, Cp: 0.94
 PROBE ID NO/MATERIAL: 120/61443
 PROBE LENGTH: 5'
 NOZZLE ID NO/ MATERIAL: M0015
 NOZZLE DIAMETER: 0.034
 FILTER NO/TYPE: QUAD 2 EMU 4 12W 2
 PRE-TEST LEAK RATE: 0.002 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM @ 10 in. Hg.
 PITOT LEAK CHECK- PRE: 0
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN AD
 SAMPLER 24/20
 SAMPLE CUSTODIAN AD

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	In Out	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	0910	919.902	0.97	1.9	204	248	233	114	64	5	5	5	-0.154
2	0920	922.46	1.0	2.0	203	249	251	114	65	5	5	5	-0.154
3	0930	935.1	1.2	2.3	203	248	250	114	65	5	5	5	-0.154
4	0940	943.4	0.98	1.9	203	247	252	114	66	5	5	5	-0.154
5	0950	950.8	0.95	1.9	204	249	253	114	67	5	5	5	-0.154
6	0100	958.4	0.96	1.9	202	249	251	114	62	5	5	5	-0.154
7	0110	965.9	1.0	2.0	204	248	254	114	69	5	5	5	-0.154
8	0920	945.8	1.2	2.3	204	246	253	114	70	5	5	5	-0.154
9	0930	981.5	1.0	2.0	201	240	251	114	70	5	5	5	-0.154
10	0940	982.3	1.0	2.0	204	245	255	114	71	5	5	5	-0.154
11	0950	972.5	0.93	1.8	205	246	254	114	72	4	4	4	-0.154
12	1000	1005.1	0.82	1.6	203	248	255	114	72	4	4	4	-0.154
13	1010	1012.400											

Average:

Comments:

Date of last revision 4/15/2022

Page 1 of 2

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834071



Aug. 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: SHINE
 LOCATION: Enviro
 DATE: 2/17/23
 RUN NO: 2

OPERATOR: _____
 METER BOX NO: _____
 METER ΔH @: _____
 METER Yd: _____
 STACK AREA, FT²: _____
 TRAVERSE POINTS, MIN/POINT: _____
 $\Delta H =$ _____ X ΔP : 1.950
 Probe Condition, pre/post test: _____
 Silica Gel Expended, Y/N: _____
 Filter Condition after Test: _____
 Check Weight: _____

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE: _____
 PILOT TUBE COEFF, Cp: _____
 PROBE ID NOMATERIAL: _____
 PROBE LENGTH: _____
 NOZZLE ID NO/MATERIAL: _____
 NOZZLE DIAMETER: _____
 FILTER NOTYPE: _____
 PRE-TEST LEAK RATE: _____
 POST-TEST LEAK RATE: _____
 PILOT LEAK CHECK - PRE: _____
 CHAIN OF CUSTODY: _____

Imp. #	Contents	Post-Test	- Pre-Test	= Difference

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P static in. H ₂ O
1	1020	1012.460	0.95	1.9	700		247	57	N/A	10	5	
2	1030	1020.4	0.98	1.9	701		248	56		81	5	
3	1040	1028.2	1.0	2.0	701		248	55		81	4	
4	1050	1034.1	1.2	2.3	709		245	55		84	6	
5	1102	1044.5	1.2	2.3	708		248	52		86	5	
6	1110	1052.4	1.1	2.1	708		250	57		86	6	
7	1120	1060.3	0.98	1.9	708		249	56		72	5	
8	1130	1049.7	0.96	1.9	700		247	53		91	4	
9	1140	1037.4	1.0	2.0	699		247	53		48	4	
10	1150	1035.4	0.97	1.9	699		248	50		89	4	
11	1200	1029.5	1.1	2.1	701		245	58		58	5	
12	1210	1016.8	0.80	1.4	708		248	53		87	4	
-	1220	1019.345								7557		
										5610		

Comments:

Date of last revision 2/14/2017



EPA 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Sunbeam
LOCATION: Eaglewood
DATE: 4/18/22
RUN NO: ENE 4 REN 3
OPERATOR: DAH/AD
METER BOX NO: 4500
METER ΔH@: 1.391
METER Yd: 104
STACK AREA, FT²: 554
TRAVERSE POINTS, MIN/POINT: 15/24
ΔH= 1.950 X ΔP: 950
Probe Condition, pre/post test: ✓
Silica Gel Expended, Y/N: ✓
Filter Condition after Test: 150.5
Check Weight:

AMBIENT TEMPERATURE: 66°
BAROMETRIC PRESSURE: 29.834
ASSUMED MOISTURE: 50%
PILOT TUBE COEFF. CP: 0.84
PROBE LENGTH: 12 ft/65
NOZZLE ID NO/ MATERIAL: 296
NOZZLE DIAMETER: 0.254
FILTER NOTYPE: DURER 0.420N3
PRE-TEST LEAK RATE: 0.005 CFM @ 10 in. Hg.
POST-TEST LEAK RATE: 0.005 CFM @ 10 in. Hg.
PILOT LEAK CHECK - PRE: ✓
CHAIN OF CUSTODY:
SAMPLE CUSTODIAN: AF
SAMPLER: 26/A/20
SAMPLE CUSTODIAN: AF

Imp. # Contents Post-Test - Pre-Test = Difference
1 64.11 76.0 647.2
2 51.00/10% 72.6 744.8
3 " 770.9 768.4
4 " 69.2 616.3
5 100.04 74.8 741.8
6 " 755.6 752.8
7 84 1034.6 987.4
— — — — —
Total: — — — — —

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1305	110.503	0.93	1.9	697	249	52	92	4	5	-0.54	
2	1315	119.5	1.0	2.0	697	249	53	91	5			
3	1325	127.3	1.2	2.3	696	249	53	90	6			
4	1335	135.5	0.99	1.9	698	248	53	89	5			
5	1345	143.7	0.96	1.9	697	248	54	89	5			
6	1355	151.8	0.96	1.9	697	249	54	90	5			
7	1405	160.9	1.0	2.0	697	249	55	90	5			
8	1415	167.8	1.1	2.1	696	248	54	89	5			
9	1425	175.6	1.1	2.1	697	249	54	90	5			
10	1435	183.7	1.0	2.0	697	249	55	91	5			
11	1445	191.9	0.95	1.9	697	249	54	91	5			
12	1455	200.2	0.90	1.9	698	247	55	90	5			
—	1505/1615	207.461	—	—	249	247	—	—	—	—	—	—
Average:												



WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET

CLIENT: Sunshine
 LOCATION: Enviro 44
 DATE: 2/1/13
 RUN NO: 45224
 OPERATOR: 45224
 METER BOX NO: 45224
 METER ΔH@: 1.91
 METER Yd: 1.04
 STACK AREA, FT²: 651
 TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H = \frac{1.91}{10} \times \Delta P$:
 Probe Condition, pre/post test:
 Silica Gel Expended, Y/N:
 Filter Condition after Test:
 Check Weight:

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE: _____
 PITOT TUBE COEFF, Cp: _____
 PROBE LENGTH: _____
 NOZZLE ID NO/MATERIAL: Ah
 NOZZLE DIAMETER: _____
 FILTER NO/TYPE: _____
 PRE-TEST LEAK RATE: : _____ CFM @ _____ in. Hg.
 POST-TEST LEAK RATE: : _____ CFM @ _____ in. Hg.
 PITOT LEAK CHECK - PRE: _____
 CHAIN OF CUSTODY: SAMPLE CUSTODIAN
 SAMPLER: SAMPLE CUSTODIAN

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P _{static} in. H ₂ O
1	1515	202.144	0.94	1.9	203	249	52	21	52	5	5	
2	1525	215.3	0.99	1.9	203	248	55	26	55	5	5	
3	1525	222.8	1.0	2.0	204	247	54	21	54	5	5	
4	1545	231.7	1.1	2.1	204	246	55	21	55	5	5	
5	1555	235.3	1.2	2.3	205	242	55	20	50	4	4	
6	1605	247.3	1.1	2.1	205	249	54	21	51	5	5	
7	1615	255.4	0.99	1.9	205	250	51	21	51	5	5	
8	1625	263.7	0.95	1.9	205	245	55	21	51	5	5	
9	1635	271.2	1.0	2.0	204	249	56	21	51	5	5	
10	1645	279.4	0.99	1.9	208	243	54	21	51	5	5	
11	1655	287.2	1.0	2.0	205	247	55	21	53	5	5	
12	1705	295.9	0.92	1.6	203	242	54	21	54	4	4	
13	1715	303.58	-	-	-	-	-	-	-	-	-	

Average:
Comments:



WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Bushnell
 LOCATION: Craigie
 DATE: 2/9/23
 RUN NO.: 4

OPERATOR: 04 /AD
 METER BOX NO: 1544
 METER AH@: _____
 METER Yd: _____

STACK AREA, FT²: _____
 TRAVERSE POINTS, MIN/POINT: _____
 $\Delta H = \frac{\Delta P}{\rho g} \times \Delta P$: 1.950
 Probe Condition, pre/post test: _____
 Silica Gel Expended Y/N: _____
 Filter Condition after Test: _____
 Check Weight: _____

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE: _____
 PITOT TUBE COEFF. Cp: _____
 PROBE LENGTH: _____
 NOZZLE ID NO/ MATERIAL: 629 09
 NOZZLE DIAMETER: _____
 FILTER NO/TYPE: _____
 PRE-TEST LEAK RATE: : _____ CFM@ _____ in. Hg.
 POST-TEST LEAK RATE: : _____ CFM@ _____ in. Hg.
 PITOT LEAK CHECK - PRE: _____
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: _____
 SAMPLER: _____
 SAMPLE CUSTODIAN: _____
 Total: _____

Point	Meter	Time	Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1015	402.681	0.94	1.9	703	247	56	83	84	4	4	
2	1025	411.2	0.99	2.0	704	249	54	85	85	4	4	
3	1035	418.4	1.1	2.7	701	248	56	87	87	2	2	
4	1045	426.6	1.1	2.7	703	247	52	89	89	8	8	
5	1055	434.8	1.2	2.6	703	249	57	90	90	6	6	
6	1105	443.5	1.0	2.0	702	218	54	91	91	4	4	
7	1115	451.7	0.98	1.9	703	248	56	90	90	4	4	
8	1125	459.9	0.93	1.8	702	245	58	92	92	4	4	
9	1135	468.1	1.0	3.0	659	250	57	92	92	4	4	
10	1145	476.2	0.92	1.9	658	249	58	93	93	6	6	
11	1155	484.5	1.0	2.0	701	248	57	92	92	5	5	
12	1165	492.1	0.75	1.5	702	216	59	75	75	-	-	
	1215	499.543				620	T6-T7					
Average:												

Comments: _____

Date of last revision 4/15/2022

Page 2 of 2

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834049

BA 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Sunshine
 LOCATION: Engine 44
 DATE: 2/9/23
 RUN NO: 4
 OPERATOR: 94140
 METER BOX NO: 45mcs
 METER AH@: 1.731
 METER Yd: 1.041
 STACK AREA, FT²: 55.11
 TRAVERSE POINTS, MIN/POINT: 10/14
 $\Delta H = 4.90 \times \Delta P:$ 1.950
 Probe Condition, pre/post test: -
 Silica Gel Expended, Y/N: -
 Filter Condition after Test: -
 Check Weight: 801500

AMBIENT TEMPERATURE: 53°
 BAROMETRIC PRESSURE: 28.32
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF. Cp: 0.94
 PROBE LENGTH: 5'
 NOZZLE ID NO/ MATERIAL: N62.15
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: 072 ENVIRO DUST 4
 PRE-TEST LEAK RATE: 0.008 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: POST:
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: 60
 SAMPLER: 94140
 SAMPLE CUSTODIAN: 90

Imp. # Contents Post-Test - Pre-Test = Difference
 1 WT 770.0 641.0
 2 6% 16.1 773.7 747.6
 3 11 750.8 749.1
 4 MY 653.4 649.2
 5 MNWY 771.6 717.2
 6 11 747.4 745.3
 7 56 970.4 925.6 58
 8

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	0845	3016.461	0.98	1.1	201	249	55	71	69	-	-	-0.57
2	0845	3141.9	1.1	2.1	201	249	54	72	69	-	-	-
3	0845	322.7	1.0	2.0	203	248	51	73	69	-	-	-
4	0845	330.7	0.98	1.9	203	247	51	74	69	-	-	-
5	0845	338.6	0.99	1.9	203	249	52	74	69	-	-	-
6	0855	346.5	0.95	1.1	203	248	52	75	69	-	-	-
7	0905	354.4	1.1	2.1	203	247	53	74	69	-	-	-
8	0915	362.4	1.2	2.1	203	249	55	77	71	-	-	-
9	0925	370.3	1.0	2.0	202	249	54	78	70	-	-	-
10	0935	378.1	1.0	2.0	201	248	55	79	70	-	-	-
11	0945	387.1	0.94	1.4	205	249	56	80	71	-	-	-
12	0955	395.0	0.81	1.4	201	249	57	81	71	-	-	-
-	1005	402.687			201	247		82				
Average:												

Comments: _____

Date of last revision 4/15/2022

Page ____ of ____

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834071

ERA 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Bushue
 LOCATION: Eng 4 PUN 5
 DATE: 2022/04/20
 RUN NO.: Eng 4 PUN 5
 OPERATOR: DS / AD
 METER BOX NO.: 45000
 METER ΔH@: 1.391
 METER Yd: 1.014
 STACK AREA, FT²: 55
 TRAVERSE POINTS, MIN/POINT: 100
 $\Delta H = 1.05$ X ΔP : 1.755
 Probe Condition, pre/post test: -
 Silica Gel Expended, Y/N: -
 Filter Condition after Test: sooty
 Check Weight: 500g

AMBIENT TEMPERATURE: 73°
 BAROMETRIC PRESSURE: 28.32
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF. Cp: 0.64
 PROBE ID NOMATERIAL: 172 / 4491
 PROBE LENGTH: 5
 NOZZLE ID NO/ MATERIAL: 296
 NOZZLE DIAMETER: 0.255"
 FILTER NO/TYPE: DP2 Only 4 Duct
 PRE-TEST LEAK RATE: 0.001 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.001 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: on
 POST: on
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: CUSTODIAN
 SAMPLER: DS / AD
 SAMPLE CUSTODIAN: CUSTODIAN

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1240	500.066	0.37	1.9	203	242	242	60	60	5	5	-0.54
2	1250	503.3	1.0	2.0	201	218	218	58	58	5	5	
3	1300	515.2	1.1	2.1	204	242	242	57	57	5	5	
4	1310	522.0	1.6	2.0	201	249	249	55	55	5	5	
5	1320	520.8	0.95	1.9	205	248	248	54	54	5	5	
6	1330	538.8	0.75	1.1	204	249	249	54	54	5	5	
7	1340	547.0	1.0	2.0	201	248	248	55	55	5	5	
8	1350	554.3	1.7	2.3	204	218	218	54	54	5	5	
9	1400	562.8	1.2	2.2	201	49	49	53	53	4	4	
10	1410	572.3	1.0	2.0	203	47	47	54	54	5	5	
11	1420	580.5	0.97	1.9	201	50	50	55	55	5	5	
12	1430	588.4	0.95	1.9	204	46	46	55	55	5	5	
13	1440	596.82	0.81	1.4	201	47	47	54	54	5	5	
Average:												

Comments: _____

Date of last revision 4/15/2022

Page ____ of __

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834071



CONTRO
SOCIETY SERVICES

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

	Imp. #	Contents	Post-Test - Pre-Test = Difference
CLIENT:	<u>Sureline</u>		
LOCATION:	<u>Surveillance 4</u>		
DATE:	<u>2/9/23</u>		
RUN NO.:	<u>45623</u>		
OPERATOR:			
METER BOX NO.:			
METER ΔH @:			
METER Yd.:			
STACK AREA, FT ² :			
TRAVERSE POINTS, MIN/POINT:			
ΔH = <u>X</u> ΔP :			
Probe Condition, pre/post test:			
Silica Gel Expended, Y/N:			
Filter Condition after Test:			
Check Weight:			
AMBIENT TEMPERATURE:			
BAROMETRIC PRESSURE:			
ASSUMED MOISTURE:			
PITOT TUBE COEFF, CP:			
PROBE ID NO/MATERIAL:			
PROBE LENGTH:			
NOZZLE ID NO/ MATERIAL:			
NOZZLE DIAMETER:			
FILTER NO/TYPE:			
PRE-TEST LEAK RATE:	<u>CFM @</u>	<u>in. Hg.</u>	
POST-TEST LEAK RATE:	<u>CFM @</u>	<u>in. Hg.</u>	
PITOT LEAK CHECK - PRE:		<u>POST:</u>	
CHAIN OF CUSTODY:	<u>SAMPLE CUSTODIAN</u>		
	<u>SAMPLER</u>		
	<u>SAMPLE CUSTODIAN</u>		

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	14:50	536.682	0.96	1.9	701	204	246	55	90	5	5	
2	15:00	6201.5	0.51	1.5	701	204	250	54	89	5	5	
3	15:10	612.8	1.0	2.0	704	203	248	55	87	5	5	
4	15:20	644.2	1.1	2.1	703	203	249	54	87	5	5	
5	15:30	628.9	1.2	2.3	703	203	248	55	88	4	4	
6	15:40	633.70	1.0	2.0	703	203	248	54	87	5	5	
7	15:50	6445.1	0.95	1.5	703	203	247	53	88	5	5	
8	16:00	652.9	0.95	1.9	703	203	246	54	89	5	5	
9	16:10	641.5	1.1	2.1	703	203	249	54	88	5	5	
10	16:20	649.9	1.0	2.0	703	203	250	53	87	5	5	
11	16:30	676.8	0.98	1.5	703	204	248	53	88	5	5	
12	16:40	681.7	0.95	1.5	704	204	247	58	89	4	4	
	16:50	691.785							85	5	5	

Comments:

Date of last revision 4/15/2022

Page 6 of 6

Master Document Storage\Forms\Datasheets\Eigl Datasheet

EPA 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Saskline
 LOCATION: Englewood
 DATE: 2/10/23
 RUN NO: BNU 472056
 OPERATOR: D.L./ASQ
 METER BOX NO: 415 WCCS
 METER ΔH@: 4246 1.791
 METER Yd: 0.647 1.014
 STACK AREA FT²: 551
 TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H = 1.90 \times \Delta P = 1.950$
 Probe Condition, pre/post test: -
 Silica Gel Expended, Y/N: /
 Filter Condition after Test: 534.50
 Check Weight:

AMBIENT TEMPERATURE: 53°
 BAROMETRIC PRESSURE: 28.256
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF. Cp: 0.84
 PROBE ID NO/MATERIAL: 5' 72/afes1
 PROBE LENGTH: 5'
 NOZZLE ID NO/MATERIAL: Nap-05/16as1
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: 072 154 Party
 PRE-TEST LEAK RATE: 0.005 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: ✓ POST: ✓
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN W
 SAMPLER W
 SAMPLE CUSTODIAN W

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Temp, °F	Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	0750	692.182	0.94	0.8	716	249	249	57	62	5			-0.55
2	0800	595.4	1.0	2.0	714	246	246	55	54	5			
3	0810	202.2	1.1	3.1	715	246	246	54	54	5			
4	0820	714.8	1.0	2.0	715	247	247	53	53	5			
5	0830	222.3	0.94	1.9	714	250	250	52	52	5			
6	0840	329.8	0.92	1.9	714	249	249	52	52	5			
7	0850	327.1	1.0	2.0	713	248	248	53	53	5			
8	0900	244.7	1.2	2.3	713	248	248	54	54	5			
9	0910	752.4	1.0	2.0	718	249	249	55	54	5			
10	0920	359.8	1.0	2.0	714	247	247	55	54	5			
11	0930	367.3	0.96	1.9	715	246	246	50	50	5			
12	0940	274.8	0.82	1.4	714	248	248	55	55	5			
-	0950	382.264			715	247	247	55	55	5			
Average:													

Comments: _____

DS834071

Date of last revision 4/15/2022

Page 1 of 2

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834071



WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Zurich
 LOCATION: Englewood
 DATE: 2/13/23
 RUN NO: 16
 OPERATOR: DA/PD
 METER BOX NO: 45555
 METER ΔH@: _____
 METER Yd: _____
 STACK AREA, FT²: _____
 TRAVERSE POINTS, MIN/POINT: _____
 $\Delta H = \frac{\Delta P}{\rho g}$: 1.50
 Probe Condition, pre/post test: _____
 Silica Gel Expended, Y/N: _____
 Filter Condition after Test: _____
 Check Weight: _____

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE: _____
 PITOT TUBE COEFF. Cp: _____
 PROBE ID NO/MATERIAL: JK
 PROBE LENGTH: _____
 NOZZLE ID NO/MATERIAL: JK
 NOZZLE DIAMETER: _____
 FILTER NO/TYPE: _____
 PRE-TEST LEAK RATE: : _____ CFM@ _____ in. Hg.
 POST-TEST LEAK RATE: : _____ CFM@ _____ in. Hg.
 PITOT LEAK CHECK - PRE: _____
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: _____
 SAMPLER: _____
 SAMPLE CUSTODIAN: _____
 Total: _____

Point	Meter	Time	Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1002	0822	282.244	0.47	1.9	215	247	247	24	28	5	5	
2	1010	090.0	0.93	1.9	214	249	249	249	24	27	5	5	
3	1020	292.4	1.0	2.0	213	245	245	245	24	29	5	5	
4	1030	205.5	1.1	2.1	214	248	248	248	24	30	5	5	
5	1040	813.1	1.2	2.3	215	250	250	250	24	31	4	4	
6	1050	521.4	1.1	2.1	215	245	245	245	24	32	5	5	
7	1060	829.2	1.1	2.1	215	248	248	248	24	34	5	5	
8	1110	5337.1	0.98	1.9	314	245	245	245	24	85	5	5	
9	1120	344.8	1.1	2.1	315	249	249	249	24	84	5	5	
10	1130	852.4	1.0	2.0	215	247	247	247	24	85	5	5	
11	1140	840.4	0.99	1.9	213	240	240	240	24	87	5	5	
12	1150	348.3	0.74	1.5	211	248	248	248	24	88	4	4	
13	1160	547.347	1.5	2.5	211	248	248	248	24	88	4	4	
			875.369										
Average:													

Comments: _____



M 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Sunshine USA
 LOCATION: Enviro 501
 DATE: 2/15/23
 RUN NO.: ENg 4 RUN 7
 OPERATOR: 04 (AO)
 METER BOX NO.: 45 WWS
 METER ΔH@: 1.717
 METER Yd: 1.014
 STACK AREA FT²: 55'
 TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H = \frac{\text{LCD} \times \Delta P}{\text{AP}}$: 19.50
 Probe Condition, pre/post test: ✓
 Silica Gel Expended, Y/N: ✓
 Filter Condition after Test: ✓
 Check Weight: 200/500

AMBIENT TEMPERATURE: 67°
 BAROMETRIC PRESSURE: 28.24
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF. Cp: 0.94
 PROBE ID NO/MATERIAL: 175155
 PROBE LENGTH: 5'
 NOZZLE ID NO/MATERIAL: 29616455
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: 01C 6564 0007
 PRE-TEST LEAK RATE: 0.023 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.027 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: ✓
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: AB
 SAMPLER: OH/100
 SAMPLE CUSTODIAN: AB

	Imp. #	Contents	Post-Test - Pre-Test = Difference
1	Mt	707.7	649.2
2	5610%	717.7	749.7
3	11	715.6	712.2
4	Mt	620.7	619.7
5	KMNDY	134.0	131.8
6	11	758.7	756.6
7	24	949.5	947.9

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Temp, °F	Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1215	835.915	0.96	1.9	715	243	243	59	57	81	5	55	0.55
2	1225	883.7	0.99	1.5	713	248	248	54	54	80	5	5	
3	1235	810.7	1.0	2.0	714	248	248	54	54	81	5	5	
4	1245	898.3	0.98	1.9	714	249	249	54	54	83	5	5	
5	1255	905.8	0.96	1.9	713	250	250	54	54	84	5	5	
6	1305	913.4	0.94	1.9	716	250	250	55	55	82	5	5	
7	1315	920.9	1.1	2.1	714	248	248	54	54	85	5	5	
8	1325	928.4	1.2	2.1	714	247	247	55	55	85	4	4	
9	1335	936.4	1.1	2.1	715	246	246	56	56	86	5	5	
10	1345	944.0	1.0	2.0	713	248	248	56	56	87	5	5	
11	1355	951.4	0.95	1.9	716	245	245	55	55	85	5	5	
12	1405	959.1	0.81	1.9	717	243	243	57	57	86	5	5	
	1415/16	962.146				ENV 0	130	22	22				

Average:

Comments:

Date of last revision 4/15/2022

Page 1 of 1

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834071



MONTROSE
OUR QUALITY SERVICES

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Sunshare
LOCATION: 5 Avenue City
DATE: 2/10/13
RUN NO: 7
OPERATOR: DH/AD
METER BOX NO: 123456
METER Δ @: _____
METER Yd: _____
STACK AREA FT²: _____
TRAVERSE POINTS, MIN/POINT: _____
 Δ H = _____ X Δ P: $\backslash \nearrow \swarrow$
Probe Condition, pre/post test: _____
Silica Gel Expended, Y/N: _____
Filter Condition after Test: _____
Check Weight: _____

	Imp. #	Contents	Post-Test	Pre-Test	Difference
AMBIENT TEMPERATURE:					
BAROMETRIC PRESSURE:					
ASSUMED MOISTURE:					
PITOT TUBE COEFF. Cp:					
PITOT ID NO/MATERIAL:	1				
PROBE LENGTH:	25				
NOZZLE ID NO/ MATE:	2				
NOZZLE DIAMETER:	1/4				
FILTER NO/TYPE:					
PRE-TEST LEAK RATE:	CFM@	in. Hg.			
POST-TEST LEAK RATE:	CFM@	in. Hg.			
PITOT LEAK CHECK - PRE:		POST:			
CHAIN OF CUSTODY:	SAMPLE CUSTODIAN				
SAMPLER	SAMPLE CUSTODIAN				
Total:					

Comments:

Date of last revision 4/15/2022

Page 1 / of 1 /

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834049

Appendix A.4.2 CT-5 Field Data

EPA 29

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Sunshine
LOCATION: Sunshine #5
DATE: 2/14/23
RUN NO: ENA 5 V102
OPERATOR: DA / AD
METER BOX NO: 45200
METER ΔH@: 1.251
METER Yd: 1.014
STACK AREA, FT²: 5577
TRAVERSE POINTS, MIN/POINT: 10/24
ΔH= X ΔP: 2.04
Probe Condition, pre/post test: ✓
Silica Gel Expended, Y/N: ✓
Filter Condition after Test: ✓
Check Weight: 120.500

AMBIENT TEMPERATURE: 48°
BAROMETRIC PRESSURE: 29.98
ASSUMED MOISTURE: 60.84
PILOT TUBE COEFF, Cp: 10.665
PROBE ID NOMATERIAL: 1014665
PROBE LENGTH: 5'
NOZZLE ID NO/ MATERIAL: 14-15 0.254 Glass
NOZZLE DIAMETER, INCH: 0.254
FILTER NOTYPE: CHENGYI'S RUN 1
PRE-TEST LEAK RATE: 0.008 CFM @ 1.0 in. Hg.
POST-TEST LEAK RATE: 0.008 CFM @ 1.0 in. Hg.
PILOT LEAK CHECK - PRE: ✓
POST: ✓
SAMPLE CUSTODIAN: AD
SAMPLELER: AD
SAMPLE CUSTODIAN: AD

Imp. # Contents Post-Test - Pre-Test = Difference
1 117 793.9 648.5
2 58/101 153.0 745.5
3 1 769.5 768.9
4 WK 619.8 618.4
5 11 752.2 751.0
6 11 765.4 763.0
7 56 1001.4 961.0
— — — —
Total: — — — —

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	0500	0.61.525	0.33	1.5	300	249	54	32	52	52	52	-0.58
2	0510	0.68.3	0.85	1.8	301	247	51	51	51	51	51	5
3	0520	0.74.0	0.44.5	1.0	300	249	50	50	50	50	50	5
4	0530	0.83.1	1.0	2.0	300	249	50	50	50	50	50	5
5	0540	0.90.6	1.2	2.5	301	250	53	53	53	53	53	5
6	0550	0.99.3	1.2	2.6	301	248	53	53	53	53	53	5
7	0600	1.07.3	1.1	2.3	301	246	54	54	54	54	54	7
8	0610	1.15.4	0.98	2.0	301	246	54	54	54	54	54	6
9	0620	1.23.4	0.96	2.0	300	248	56	56	56	56	56	6
10	0630	1.31.2	0.84	1.7	301	246	55	55	55	55	55	5
11	0640	1.39.8	0.80	1.6	301	246	55	55	55	55	55	5
12	0650	142.2	0.90	1.9	301	248	54	54	54	54	54	5
	1000/0	154.703			300	247						
Average:												

Comments: _____

Date of last revision 4/15/2022

Page 1 of 2Master Document Storage\Forms\Datasheets\Field Datasheets
DS834071

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Enviro-Max
 LOCATION: Enviro-Max
 DATE: 2/15/21
 RUN NO: 1
 OPERATOR: _____
 METER BOX NO: 45455
 METER ΔH@: _____
 METER Yd: _____
 STACK AREA, FT²: _____
 TRAVERSE POINTS, MIN/POINT: _____
 $\Delta H = \underline{\hspace{2cm}} \times \Delta P = \underline{\hspace{2cm}}$
 Probe Condition, pre/post test: _____
 Silica Gel Expended, Y/N: _____
 Filter Condition after Test: _____
 Check Weight: _____

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE: _____
 PITOT TUBE COEFF. Cp: _____
 PROBE ID NO/MATERIAL: 342 Q5
 PROBE LENGTH: _____
 NOZZLE ID NO/MATERIAL: 342 Q5
 NOZZLE DIAMETER: _____
 FILTER NO/TYPE: _____
 PRE-TEST LEAK RATE: CFM@ _____ in. Hg.
 POST-TEST LEAK RATE: CFM@ _____ in. Hg.
 PITOT LEAK CHECK - PRE: _____
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: _____
 SAMPLER: _____
 SAMPLE CUSTODIAN: _____
 Total: _____

Point	Meter	Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1010	154.203	0.31	1.5	701	245	50	65	65	5	5	
2	1020	162.0	0.55	1.8	701	249	56	65	65	5	5	
3	1010	166.4	0.61	2.0	702	245	55					
4	1040	174.7	1.0	2.0	702	250	53	67	67	4	4	
5	1050	184.2	1.3	2.2	702	248	52	67	67	4	4	
6	1000	171.9	1.2	2.5	702	247	52	66	66	3	3	
7	1110	196.5	1.1	2.3	701	248	58	66	66	7	7	
8	1120	202.0	1.0	2.0	703	245	54	69	69	4	4	
9	1110	214.2	0.84	1.9	703	246	53	70	70	5	5	
10	1140	221.4	0.83	1.7	703	245	58	71	71	5	5	
11	1150	228.8	0.82	1.6	703	247	57	72	72	5	5	
12	1200	236.4	0.64	1.8	703	245	57	72	72	5	5	
13	1210	244.168	1.08	2.0	703	245	57	72	72	5	5	
Average:												

Comments: _____



WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: SunShine
 LOCATION: E 14th & I-23
 DATE: 2/14/23
 RUN NO: ENCE 5 P/N 2
 OPERATOR: DH /PAN
 METER BOX NO: 45005
 METER ΔH@: 1.391
 METER Yd: 1.011
 STACK AREA, FT²: 55"
 TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H = X \Delta P:$ 2.04
 Probe Condition, pre/post test: —
 Silica Gel Expended, Y/N: —
 Filter Condition after Test: —
 Check Weight: 500.000

AMBIENT TEMPERATURE: 55°
 BAROMETRIC PRESSURE: 27.58
 ASSUMED MOISTURE: 5%
 PILOT TUBE COEFF. Cp: 1.00
 PROBE ID NO/MATERIAL: 133/2155
 PROBE LENGTH: 15'
 NOZZLE ID NO/MATERIAL: 296 / 0.254 Glass
 NOZZLE DIAMETER: 0.254
 FILTER NOTYPE: EN 61201-2 452
 PRE-TEST LEAK RATE: 0.003 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM @ 10 in. Hg.
 PILOT LEAK CHECK - PRE: POST:
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: AS
 SAMPLER: ON 1/22
 SAMPLE CUSTODIAN: AS

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1300	244.924	0.74	1.5	302	247	57	31	5	—	—	—
2	1330	252.3	0.75	1.6	302	247	57	32	5	—	—	—
3	1240	240.0	1.0	2.1	301	248	54	31	4	—	—	—
4	1250	262.5	1.1	2.3	301	248	54	30	7	—	—	—
5	1303	275.1	1.2	2.5	301	247	53	30	8	—	—	—
6	1310	282.4	1.3	2.7	301	246	52	31	8	—	—	—
7	1320	280.4	1.0	2.1	302	248	52	32	7	—	—	—
8	1330	298.2	0.99	2.0	302	248	52	31	7	—	—	—
9	1340	305.7	0.65	2.0	302	247	53	31	2	—	—	—
10	1350	313.2	0.64	1.7	301	249	55	32	4	—	—	—
11	1400	320.9	0.82	1.7	301	249	54	32	4	—	—	—
12	1410	328.7	0.73	1.9	301	248	55	33	4	—	—	—
	1420/50	335.761			6~10	20~24	54~57					
Average:												

Comments: _____

Date of last revision 4/15/2022

Page 1 of 2

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834071

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

Imp. # Contents Post-Test - Pre-Test = Difference

CLIENT: <i>Sensible</i>	AMBIENT TEMPERATURE:	
LOCATION: <i>E44145</i>	BAROMETRIC PRESSURE:	
DATE: <i>2/14/23</i>	ASSUMED MOISTURE:	
RUN NO: <i>EN 52002</i>	PITOT TUBE COEFF. Cp:	
OPERATOR:	PROBE ID NO/MATERIAL:	
METER BOX NO: <i>45200</i>	PROBE LENGTH:	
METER ΔH@:	NOZZLE ID NO/MATERIAL:	
METER Yd.	NOZZLE DIAMETER:	
STACK AREA, FT ² :	FILTER NO/TYPE:	
TRAVERSE POINTS, MIN/POINT:	PRE-TEST LEAK RATE: : _____ CFM@ _____ in. Hg.	
ΔH= <i>X ΔP: 200</i>	POST-TEST LEAK RATE: : _____ CFM@ _____ in. Hg.	
Probe Condition, pre/post test:	PITOT LEAK CHECK - PRE:	
Silica Gel Expended, Y/N:	CHAIN OF CUSTODY:	
Filter Condition after Test:	SAMPLE CUSTODIAN	
Check Weight:	SAMPLER	
	SAMPLE CUSTODIAN	Total: _____

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1430	335361	0.72	1.5	702	250	55	n/a	73	5		
2	1440	34227	0.83	1.7	703	249	54	72	7			
3	1450	3503.3	1.0	2.1	703	250	54	73	7			
4	1500	3574.9	1.0	2.1	702	249	55	75	7			
5	1510	3655.5	1.3	2.7	702	247	56	75	8			
6	1520	3732.3	1.2	2.5	701	248	57	75	8			
7	1530	381.0	1.0	2.1	701	248	56	76	7			
8	1540	3885.6	1.0	2.1	701	249	57	77	7			
9	1550	396.8	0.94	2.0	700	247	57	76	7			
10	1600	403.9	0.72	1.7	700	248	58	77	6			
11	1610	411.6	0.90	1.6	700	249	58	76	5			
12	1620	418.8	0.82	1.8	700	247	58	75	5			
/	1630	424.756						END	ST			
Average:												
Comments:												

DA 29
WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Susquehanna
 LOCATION: Enviroline 45
 DATE: 2/15/23
 RUN NO: 50103
 OPERATOR: 04/AD
 METER BOX NO: 415 Wc.
 METER ΔH@: 1.791
 METER Yd: 1014
 STACK AREA, FT²: 55
 TRAVERSE POINTS, MIN/POINT: .6/.24
 $\Delta H = \text{X } \Delta P:$ 2.00
 Probe Condition, pre/post test: -
 Silica Gel Expended, Y/N: -
 Filter Condition after Test: -
 Check Weight: 520/500

AMBIENT TEMPERATURE: 35.0
 BAROMETRIC PRESSURE: 28.91
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF, Cp: 0.91
 PROBE ID NO/MATERIAL: 130/71411
 PROBE LENGTH: 5
 NOZZLE ID NO/MATERIAL: 1645 / 71455
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: 012 6P65 0003
 PRE-TEST LEAK RATE: 0.000 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 0.002 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: ✓
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: AJ
 SAMPLER DN/14260
 SAMPLE CUSTODIAN: DN/14260

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp., °F	Probe Temp., °F	Filter Temp., °F	Imp. Out Temp., °F	Meter Temp., °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	07335	418.623	0.71	1.5	700	246	47	81/2	73	5		-0.46
2	0245	436.0	0.92	1.8	700	248	44		48	5		
3	0355	443.5	0.99	2.0	701	247	45		50	4		
4	0805	451.1	1.0	2.1	700	248	46		52	4		
5	0815	452.8	1.2	2.5	697	248	48		53	8		
6	0425	466.6	1.3	2.7	692	250	49		51	8		
7	0835	474.5	1.0	2.1	690	245	48		51	4		
8	0845	478.1	0.72	2.3	689	249	49		55	4		
9	0905	489.4	0.94	1.9	696	249	50		53	4		
10	0915	493.4	0.85	1.8	693	249	52		51	4		
11	0915	504.7	0.80	1.6	701	243	52		60	4		
12	0925	512.4	0.92	1.7	701	248	52		42	6		
13	0935/45	520.151			END	80+						
Average:												

Comments: _____

Date of last revision 4/15/2022

Page 1 of 2

Master Document Storage\Forms\Datasheets\Field Datasheets

DS83401

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Sunshine
 LOCATION: Englewood 45
 DATE: 2/15/23
 RUN NO: 0465 RUN 3
 OPERATOR: OH/AB
 METER BOX NO: 45 wcs
 METER ΔH@: _____
 METER Yd: _____
 STACK AREA, FT²: _____
 TRAVERSE POINTS, MIN/POINT: _____
 $\Delta H = \frac{\text{in. Hg}}{\text{X } \Delta P} = 2.00$
 Probe Condition, pre/post test: _____
 Silica Gel Expended, Y/N: _____
 Filter Condition after Test: _____
 Check Weight: _____

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE: _____
 PITOT TUBE COEFF, Cp: _____
 PROBE ID NO/MATERIAL: _____
 PROBE LENGTH: _____
 NOZZLE ID NO/ MATERIAL: _____
 NOZZLE DIAMETER: _____
 FILTER NO/TYPE: _____
 PRE-TEST LEAK RATE: _____ CFM@ _____ in. Hg.
 POST-TEST LEAK RATE: _____ CFM@ _____ in. Hg.
 PITOT LEAK CHECK - PRE: _____ POST: _____
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN _____
 SAMPLER _____
 SAMPLE CUSTODIAN _____
 Total: _____

Point	Meter	Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	9	1045	520.51	0.74	1.5	302	248	53	51	42	4	
2	9	1055	522.5	0.64	1.8	302	247	52	51	41	3	
3	10	1055	535.0	1.0	2.1	302	247	52	42	42	3	
4	10	1076	542.4	1.0	2.1	302	248	53	51	43	3	
5	10	1085	560.3	1.2	2.5	303	249	53	53	43	3	
6	10	1135	558.1	1.2	2.5	303	248	53	52	42	3	
7	10	1145	565.9	1.1	2.3	303	249	54	50	40	3	
8	10	1155	573.4	1.1	2.3	304	248	54	51	43	3	
9	11	1205	581.3	0.92	1.7	304	249	54	51	44	3	
10	11	1215	588.7	0.82	1.7	305	248	53	51	44	3	
11	11	1225	596.4	0.81	1.7	305	247	53	51	45	3	
12	11	1235	604.1	0.89	1.8	305	247	53	51	45	3	
-	11	1245	611.678	—	—	305	247	53	51	46	3	
* 5X 31512												
Average:												
Comments:												

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS
CLIENT: *Southern*

LOCATION: *engine #5*
 DATE: *2/15/23*
 RUN NO: *EN 5 PUN4*
 OPERATOR: *DH/AO*
 METER BOX NO: *45wcs*
 METER ΔH@: *1.791*
 METER Yd: *10161*
 STACK AREA, FT²: *55"*
 TRAVERSE POINTS, MIN/POINT: *10/21*
 $\Delta H = \text{X } \Delta P:$ *2.06*
 Probe Condition, pre/post test: *-*
 Silica Gel Expended, Y/N: *-*
 Filter Condition after Test: *-*
 Check Weight: *500/500*

AMBIENT TEMPERATURE: *54°*
 BAROMETRIC PRESSURE: *26.15*
 ASSUMED MOISTURE: *5%*
 PITOT TUBE COEFF, Cp: *0.89*
 PROBE ID NO/MATERIAL: *132/9150*
 PROBE LENGTH: *45"*
 NOZZLE ID NO/MATERIAL: *246/1663*
 NOZZLE DIAMETER: *0.1254*
 FILTER NO/TYPE: *312 3NY5 1004*
 PRE-TEST LEAK RATE: *0.003 CFM @ 20 in. Hg.*
 POST-TEST LEAK RATE: *0.002 CFM @ 20 in. Hg.*
 PITOT LEAK CHECK - PRE: *OK*
 POST: *OK*
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: *AB*
 SAMPLER: *06/40*
 SAMPLE CUSTODIAN: *AB*

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp., °F	Probe Temp., °F	Filter Temp., °F	Imp. Out Temp., °F	Meter Temp., °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	12:20	1012.040	0.22*	1.3	709	250	69	67	67	5		-0.48
2	12:10	1019.3	0.55	1.8	701	249	55	64	64	6		
3	12:20	1016.8	1.0	2.1	709	250	52	62	62	7		
4	12:30	1034.4	1.1	2.3	708	248	47	66	66	7		
5	12:40	1042.1	1.2	2.3	708	248	42	64	64	8		
6	12:50	1049.9	1.1	2.3	708	242	43	68	68	7		
7	1:00	1057.6	1.1	2.3	707	242	43	69	69	7		
8	1:10	1065.4	1.0	2.1	706	247	43	69	69	6		
9	1:20	1073.1	0.94	1.9	707	245	41	70	70	5		
10	1:30	1080.7	0.84	1.7	707	245	41	69	69	5		
11	1:40	1088.2	0.82	1.5	707	245	50	70	70	5		
12	1:50	1095.6	0.86	1.6	707	247	51	70	70	5		
Average:												

Comments: _____

Date of last revision 4/15/2022

Page 1 of 2

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834071

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Sophie
 LOCATION: 5011 Ave W
 DATE: 2/15/23
 RUN NO:
 OPERATOR: OH/AD
 METER BOX NO: 45000
 METER ΔH@: _____
 METER Yd:
 STACK AREA, FT²:
 TRAVERSE POINTS, MIN/POINT:
 $\Delta H = \frac{\Delta P}{\rho g} \cdot 2.06$
 Probe Condition, pre/post test:
 Silica Gel Expended, Y/N:
 Filter Condition after Test:
 Check Weight:

AMBIENT TEMPERATURE: _____

BAROMETRIC PRESSURE: _____

ASSUMED MOISTURE: _____

PIROT TUBE COEFF, Cp: _____

PROBE ID NO/MATERIAL: _____

PROBE LENGTH: _____

NOZZLE ID NO/MATERIAL: _____

NOZZLE DIAMETER: _____

FILTER NO/TYPE: _____

PRE-TEST LEAK RATE: _____ CFM@ _____ in. Hg.

POST-TEST LEAK RATE: _____ CFM@ _____ in. Hg.

PIROT LEAK CHECK - PRE: _____

POST: _____

CHAIN OF CUSTODY:

SAMPLE CUSTODIAN: _____

SAMPLER: _____

SAMPLE CUSTODIAN: _____

Total: _____

Imp. # Contents Post-Test - Pre-Test = Difference

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

_____ - _____

Date of last revision 4/15/2022

Page 0 of 1Y

Master Document Storage\Forms\Datasheets\Field Datasheets

DS834049

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Sunshine
 LOCATION: Enclave US
 DATE: 2/10/23
 RUN NO: 0005
 OPERATOR: DH/AD
 METER BOX NO: 45325
 METER ΔH@: 1.291
 METER Yd.: 1.014
 STACK AREA, FT²: 55
 TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H =$ X ΔP: 2.06
 Probe Condition, pre/post test: -
 Silica Gel Expended, Y/N: -
 Filter Condition after Test: -
 Check Weight: 500/500

AMBIENT TEMPERATURE: 40°
 BAROMETRIC PRESSURE: 28.33
 ASSUMED MOISTURE: 5 1/2
 PITOT TUBE COEFF. Cp: 6.83
 PROBE ID NO/MATERIAL: 02/9 Glass
 PROBE LENGTH: 5'
 NOZZLE ID NO/MATERIAL: N45 / C1455
 NOZZLE DIAMETER: 0.251
 FILTER NO/TYPE: 022 6016 6 mm
 PRE-TEST LEAK RATE: 0.02 CFM@ 10 in. Hg.
 POST-TEST LEAK RATE: 0.022 CFM@ 10 in. Hg.
 PITOT LEAK CHECK - PRE: POST: 2.05
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: 205
 SAMPLER: 044/42
 SAMPLE CUSTODIAN: 605

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	In	Out	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	0735	801.219	0.74	1.5	710	247	50	52	53	5	5	-0.44		
2	0745	8086	0.65	1.8	710	250	49	53	53	6	5			
3	0755	8140	0.91	2.0	705	250	48	55	55	6	5			
4	0805	8133	1.0	2.1	705	249	47	54	55	6	5			
5	0815	831.6	1.1	2.3	705	248	49	54	54	7	5			
6	0825	834.5	1.2	2.5	710	247	50	55	55	7	5			
7	0835	837.4	1.1	2.3	710	249	52	55	55	7	5			
8	0845	855.7	0.98	2.0	710	247	51	54	54	6	5			
9	0855	862.8	0.95	2.0	711	248	51	54	54	6	5			
10	0905	870.3	0.82	1.7	710	246	52	57	57	6	5			
11	0915	873.8	0.80	1.6	705	249	53	57	57	6	5			
12	0925	885.3	0.92	1.9	707	247	53	57	57	6	5			
-	0935/05	892.64	-	-	ENR	605.4	-	605	605	6	5			

Average:

Comments:

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT:	Sunshine
LOCATION:	2nd Avenue S
DATE:	2/16/23
RUN NO:	Run 5
OPERATOR:	DH/AQ
METER BOX NO:	45wce
METER ΔH@:	
METER Yd:	
STACK AREA, FT ² :	
TRAVERSE POINTS, MIN/POINT:	
ΔH= $\frac{X \Delta P}{\rho}$: 2.04	
Probe Condition, pre/post test:	
Silica Gel Expended, Y/N:	
Filter Condition after Test:	
Check Weight:	

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE: _____
 PITOT TUBE COEFF. Cp: _____
 PROBE ID NO/MATERIAL: _____
 PROBE LENGTH: _____
 NOZZLE ID NO/MATERIAL: _____
 NOZZLE DIAMETER: _____
 FILTER NO/TYPE: _____
 PRE-TEST LEAK RATE: _____ CFM @ _____ in. Hg.
 POST-TEST LEAK RATE: _____ CFM @ _____ in. Hg.
 PITOT LEAK CHECK - PRE: _____ POST: _____
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: _____
 SAMPLER: _____
 SAMPLE CUSTODIAN: _____
 Total: _____

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	0545	892.144	0.72	1.5	207	249	54	55	5	5	
2	0555	899.5	0.84	1.8	205	250	55	61	4	4	
3	1005	902.1	1.0	2.1	210	244	53	63	3	3	
4	1015	914.8	1.0	2.1	210	245	55	64	2	2	
5	1025	922.6	1.3	2.7	207	247	55	64	2	2	
6	1035	930.6	1.1	2.3	205	248	54	67	1	1	
7	1045	938.5	1.0	2.1	205	245	56	64	2	2	
8	1055	946.3	1.0	2.1	207	245	56	67	2	2	
9	1105	954.2	0.52	1.9	208	249	57	67	2	2	
10	1115	961.9	0.84	1.7	207	242	56	69	2	2	
11	1125	969.4	0.80	1.6	207	248	56	69	2	2	
12	1135	976.9	0.88	1.8	207	249	57	71	2	2	
-	1145	984.326									
Average:		183.107									

Comments: _____

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - EXTRA IMPINGERS

CLIENT: Sunshine
 LOCATION: Sunshine
 DATE: 2/18/23
 RUN NO: 145 RUN 6
 OPERATOR: OH/DO
 METER BOX NO: 454003
 METER ΔH@: 1.391
 METER Yd: 1.014
 STACK AREA, FT²: 55'
 TRAVERSE POINTS, MIN/POINT: 10/24
 $\Delta H = X \Delta P:$ 2.04
 Probe Condition, pre/post test: -
 Silica Gel Expended, Y/N: -
 Filter Condition after Test: -
 Check Weight: 500/500

AMBIENT TEMPERATURE: 58°
 BAROMETRIC PRESSURE: 28.33
 ASSUMED MOISTURE: 5%
 PITOT TUBE COEFF. CP: 0.84
 PROBE ID NO/MATERIAL: 172/9455
 PROBE LENGTH:
 NOZZLE ID NO/MATERIAL: 296/10.254 Unless
 NOZZLE DIAMETER: 0.254
 FILTER NO/TYPE: Q+2 Vary 5 Bar 6
 PRE-TEST LEAK RATE: 200 CFM @ 10 in. Hg.
 POST-TEST LEAK RATE: 200 CFM @ 10 in. Hg.
 PITOT LEAK CHECK - PRE: On POST: Off
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN: S
 SAMPLER: Q4/AO
 SAMPLE CUSTODIAN: 167

Total:

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	12:00	6/15/23 0.713	0.71	1.5	707	249	57	70	5	-	-	-0.49
2	12:10	6/15/23 0.86	0.86	1.8	707	249	56	72	6	-	-	-
3	12:20	6/15/23 1.0	1.0	3.1	708	250	54	72	7	-	-	-
4	12:30	6/15/23 1.1	1.1	3.1	708	250	51	73	7	-	-	-
5	12:40	6/15/23 1.2	1.2	3.3	708	250	52	72	8	-	-	-
6	12:50	6/15/23 1.2	1.2	3.3	707	249	53	74	8	-	-	-
7	1:00	6/15/23 1.2	1.2	3.5	707	249	53	73	7	-	-	-
8	1:10	6/15/23 1.4	0.96	2.0	706	248	53	74	6	-	-	-
9	1:20	6/15/23 0.96	0.96	2.0	707	247	54	74	6	-	-	-
10	1:30	6/15/23 0.83	1.7	3.1	706	248	54	75	6	-	-	-
11	1:40	6/15/23 0.80	1.5	3.0	706	249	53	76	5	-	-	-
12	1:50	6/15/23 0.91	1.9	3.0	706	248	54	76	5	-	-	-
-	1:00/10	6/15/23 5.54	-	-	-	-	-	TEST	-	-	-	-

Average:

Comments:

Date of last revision 4/15/2022

Page 1 of 2

 DS834071
 Master Document Storage\Forms\Datasheets\Field Datasheets

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Sunshine
 LOCATION: Esaline #5
 DATE: 2/10/23
 RUN NO: 5 (2) 6
 OPERATOR: D4/AO
 METER BOX NO: 45003
 METER ΔH@: _____
 METER Yd:
 STACK AREA, FT²:
 TRAVERSE POINTS, MIN/POINT: _____
 $\Delta H = \frac{\Delta P}{\rho g}$
 Probe Condition, pre/post test:
 Silica Gel Expended, Y/N:
 Filter Condition after Test:
 Check Weight:

AMBIENT TEMPERATURE: _____
 BAROMETRIC PRESSURE: _____
 ASSUMED MOISTURE:
 PITOT TUBE COEFF, Cp:
 PROBE ID NO/MATERIAL:
 PROBE LENGTH:
 NOZZLE ID NO/MATERIAL:
 NOZZLE DIAMETER:
 FILTER NO/TYPE:
 PRE-TEST LEAK RATE: _____ CFM@ _____ in. Hg.
 POST-TEST LEAK RATE: _____ CFM@ _____ in. Hg.
 PITOT LEAK CHECK - PRE: _____ POST: _____
 CHAIN OF CUSTODY:
 SAMPLE CUSTODIAN _____
 SAMPLER _____
 SAMPLE CUSTODIAN _____
 Total: _____

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	1410	1983.531	0.32	704	250	54	75	75	5		
2	1420	10196.9	0.46	707	248	53	77	77	4		
3	1430	10196.4	0.08	700	249	55	78	78	3		
4	1440	11606.0	1.0	303	243	56	80	80	7		
5	1450	11613.2	1.2	308	245	56	81	81	8		
6	1500	11621.4	1.2	303	249	56	80	80	8		
7	1510	11629.5	1.0	303	250	57	80	80	7		
8	1520	11637.2	1.0	301	246	58	81	81	7		
9	1530	11644.9	0.95	300	247	57	82	82	6		
10	1540	11652.5	0.82	303	247	58	82	82	6		
11	1550	11660.2	0.80	301	248	58	81	81	6		
12	1600	11664.6	0.88	303	243	57	83	83	6		
-	1610	11674.894									
Average: 182.271											

Comments: _____

WET CHEMICAL SAMPLING SYSTEM DATA AND WORKSHEET - STANDARD

CLIENT: Sunshine #5
 LOCATION: Eng 104 2/13/21
 DATE:
 RUN NO: 04607
 OPERATOR: 04/AD
 METER BOX NO: 45WCS
 METER ΔH@: _____
 METER Yd: _____
 STACK AREA, FT²: _____
 TRAVERSE POINTS, MIN/POINT: _____
 $\Delta H = X \Delta P:$ 2.66
 Probe Condition, pre/post test: _____
 Silica Gel Expended, Y/N: _____
 Filter Condition after Test: _____
 Check Weight: _____

AMBIENT TEMPERATURE: _____

BAROMETRIC PRESSURE: _____

ASSUMED MOISTURE: _____

PITOT TUBE COEFF, Cp: _____

PROBE ID NO/MATERIAL: _____

PROBE LENGTH: _____

NOZZLE ID NO/MATERIAL: _____

NOZZLE DIAMETER: _____

FILTER NO/TYPE: _____

PRE-TEST LEAK RATE: _____ CFM @ in. Hg.

POST-TEST LEAK RATE: _____ CFM @ in. Hg.

PITOT LEAK CHECK - PRE: _____

POST: _____

CHAIN OF CUSTODY: SAMPLE CUSTODIAN _____

SAMPLER CUSTODIAN _____

SAMPLE CUSTODIAN _____

Total: _____

Point	Time	Meter Volume, ft ³	ΔP in. H ₂ O	ΔH in. H ₂ O	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Imp. Out Temp, °F	Meter Temp, °F In	Vacuum in. Hg.	O ₂ %	P. static in. H ₂ O
1	0940	230-366	6.74	1.5	203	204	247	224	32	5		
2	0950	333-6	0.53	1.7	204	204	248	231	32	6		
3	1000	235-0	1.0	3.1	204	204	249	233	31	7		
4	1010	323-2	1.0	3.1	205	205	250	234	33	7		
5	1020	300-4	1.2	2.5	205	205	249	235	34	8		
6	1030	305-2	1.2	2.5	205	205	250	235	35	8		
7	1040	310-1	1.1	2.3	206	206	248	235	35	8		
8	1050	323-9	1.0	2.1	206	206	249	235	34	7		
9	1100	331-4	0.92	1.9	206	206	245	234	35	6		
10	1110	332-1	0.84	1.7	206	206	249	233	34	6		
11	1120	346-0	0.96	1.6	206	206	249	236	33	6		
12	1130	354-4	0.86	1.8	206	206	248	236	33	6		
-	1140	361-700	.	.	206	206	248	237	33	6		
Average:												

Comments: _____

Appendix A.4.3 CT-4 and CT-5 Laboratory Data

Montrose Air Quality Services, LLC – Santa Ana

1631 E St Andrew Pl
Santa Ana, CA 92705

DTE Energy
Sunshine – SGT Eng 4 and 5 Exhaust
Client Project # 023392

Analytical Report
(0223-176R)

EPA Method 29

Antimony, Arsenic, Beryllium, Cadmium, Chromium,
Cobalt, Lead, Manganese, Mercury, Nickel, and Selenium



Enthalpy Analytical, LLC

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / www.enthalpy.com
800-1 Capitola Drive Durham, NC 27713-4385

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

This analytical report was prepared in Portable Document Format (.PDF). This report shall not be reproduced except in full without approval of the laboratory. This will provide assurance that parts of a report are not taken out of context.

A handwritten signature in black ink that reads "Amy Cross". The signature is written in a cursive style with a prominent, wavy line extending from the end of the "s" towards the right.

Report Issued: 4/3/23



Summary of Results





EPA Method 29 Summary

EA Project #: 0223-176R

Client: Montrose Air Quality Services, LLC - Santa Ana

Client Project ID: 023392 - DTE Energy - Sunshine

Element / Catch Weight (ug)

Sample ID	Antimony	Arsenic	Beryllium	Cadmium	Chromium
Eng 4 Run 1 - FH	0.343 J	0.671 ND	0.116 J	0.232 J	4.53
Eng 4 Run 1 - BH	0.101 J	0.0593 J	0.0319 J	0.638	0.660
Eng 4 Run 2 - FH	0.251 J	0.671 ND	0.164 J	0.173 J	6.30
Eng 4 Run 2 - BH	0.0702 J	0.120 J	0.0205 J	0.150	0.604
Eng 4 Run 3 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	4.53
Eng 4 Run 3 - BH	0.0675 J	0.0699 J	0.0172 ND	0.0954 J	0.493 J
Eng 4 Run 4 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	6.10
Eng 4 Run 4 - BH	0.0563 ND	0.0563 ND	0.0182 ND	0.133	0.583
Eng 4 Run 5 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	6.28
Eng 4 Run 5 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0281 J	0.559
Eng 4 Run 6 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	4.25
Eng 4 Run 6 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0205 ND	0.512 J
Eng 4 Run 7 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0523 J	6.10
Eng 4 Run 7 - BH	0.0530 ND	0.0530 ND	0.0211 J	0.0205 ND	0.450 J
Eng 4 Field Blank - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	1.27 J
Eng 4 Field Blank - BH	0.0547 ND	0.0547 ND	0.0177 ND	0.0211 ND	0.0547 ND
Eng 4 Reagent Blank - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	1.05 J
Eng 4 Reagent Blank - BH	0.0547 ND	0.0547 ND	0.0177 ND	0.0211 ND	0.228 J

0223-176R Metals Summary



EPA Method 29 Summary

EA Project #: 0223-176R

Client: Montrose Air Quality Services, LLC - Santa Ana

Client Project ID: 023392 - DTE Energy - Sunshine

Element / Catch Weight (ug)

Sample ID	Antimony	Arsenic	Beryllium	Cadmium	Chromium
Eng 5 Run 1 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	4.56
Eng 5 Run 1 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0205 ND	0.532
Eng 5 Run 2 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	6.12
Eng 5 Run 2 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0697 J	0.481 J
Eng 5 Run 3 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	4.58
Eng 5 Run 3 - BH	0.0563 ND	0.0563 ND	0.0182 ND	0.0357 J	0.666
Eng 5 Run 4 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	4.42
Eng 5 Run 4 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0205 ND	0.600
Eng 5 Run 5 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	4.53
Eng 5 Run 5 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0205 ND	0.523 J
Eng 5 Run 6 - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	3.54
Eng 5 Run 6 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0205 ND	0.467 J
Eng 5 Run 7 - FH	0.250 ND	0.671 ND	0.0680 J	0.0523 J	4.59
Eng 5 Run 7 - BH	0.0530 ND	0.0530 ND	0.0172 ND	0.0205 ND	0.925
Eng 5 Field Blank - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	1.15 J
Eng 5 Reagent Blank - FH	0.250 ND	0.671 ND	0.0532 ND	0.0519 ND	1.04 J
Eng 5 Field Blank - 2A + Eng 5 Reagent Blank Composite - 2A	0.0546 ND	0.0546 ND	0.0177 ND	0.0211 ND	0.262 J

0223-176R Metals Summary



EPA Method 29 Summary

EA Project #: 0223-176R

Client: Montrose Air Quality Services, LLC - Santa Ana

Client Project ID: 023392 - DTE Energy - Sunshine

Element / Catch Weight (ug)

Sample ID	Cobalt	Lead	Manganese	Nickel	Selenium
Eng 4 Run 1 - FH	0.142 J	0.633	1.03 J	2.16 J	0.304 ND
Eng 4 Run 1 - BH	0.0837 J	0.736	1.21	1.44	1.13
Eng 4 Run 2 - FH	0.201 J	0.548	0.974 J	1.85 J	0.304 ND
Eng 4 Run 2 - BH	0.0729 J	0.477	0.872	0.591	0.322 J
Eng 4 Run 3 - FH	1.14	0.345 J	0.740 J	1.37 J	0.304 ND
Eng 4 Run 3 - BH	0.0241 J	0.205	0.417 J	0.770	1.16
Eng 4 Run 4 - FH	0.0777 J	0.356 J	0.774 J	1.95 J	0.304 ND
Eng 4 Run 4 - BH	0.0437 J	0.338	0.575	0.746	4.68
Eng 4 Run 5 - FH	0.0562 ND	0.405 J	0.723 J	1.49 J	0.304 ND
Eng 4 Run 5 - BH	0.0370 J	0.208	0.656	0.550	1.16
Eng 4 Run 6 - FH	0.0562 ND	0.311 J	1.45 J	1.25 J	0.304 ND
Eng 4 Run 6 - BH	0.0270 J	0.192	1.02	0.365 J	7.98
Eng 4 Run 7 - FH	0.0562 ND	0.344 J	1.61 J	1.47 J	0.304 ND
Eng 4 Run 7 - BH	0.0348 J	0.122	1.38	0.340 J	0.558
Eng 4 Field Blank - FH	0.0562 ND	0.371 J	0.538 J	1.26 J	0.304 ND
Eng 4 Field Blank - BH	0.0169 ND	0.0229 J	0.121 J	0.0547 ND	0.0875 ND
Eng 4 Reagent Blank - FH	0.0562 ND	0.240 J	0.459 J	1.13 J	0.304 ND
Eng 4 Reagent Blank - BH	0.0169 ND	0.0202 ND	0.216 J	0.173 J	0.0874 ND

0223-176R Metals Summary



EPA Method 29 Summary

EA Project #: 0223-176R

Client: Montrose Air Quality Services, LLC - Santa Ana

Client Project ID: 023392 - DTE Energy - Sunshine

Element / Catch Weight (ug)

Sample ID	Cobalt	Lead	Manganese	Nickel	Selenium
Eng 5 Run 1 - FH	0.0562 ND	0.321 J	0.649 J	1.41 J	0.304 ND
Eng 5 Run 1 - BH	0.0164 ND	0.0990 J	15.4	0.388 J	8.38
Eng 5 Run 2 - FH	0.0562 ND	0.314 J	2.28 J	1.66 J	0.304 ND
Eng 5 Run 2 - BH	0.0164 ND	0.112	0.509 J	0.408 J	2.29
Eng 5 Run 3 - FH	0.0562 ND	0.295 J	0.687 J	1.43 J	0.304 ND
Eng 5 Run 3 - BH	0.0220 J	0.147	1.78	0.435 J	20.2
Eng 5 Run 4 - FH	0.0562 ND	0.279 J	0.696 J	1.40 J	0.304 ND
Eng 5 Run 4 - BH	0.0170 J	0.107	0.424 J	0.539	0.326 J
Eng 5 Run 5 - FH	0.0562 ND	0.348 J	0.673 J	1.94 J	0.304 ND
Eng 5 Run 5 - BH	0.0241 J	0.0949 J	0.910	0.640	0.817
Eng 5 Run 6 - FH	0.0562 ND	0.333 J	2.59	1.37 J	0.304 ND
Eng 5 Run 6 - BH	0.0164 ND	0.0616 J	0.658	0.390 J	0.239 J
Eng 5 Run 7 - FH	0.0562 ND	0.344 J	1.23 J	1.24 J	0.304 ND
Eng 5 Run 7 - BH	0.0263 J	0.0976 J	1.69	0.739	0.925
Eng 5 Field Blank - FH	0.0562 ND	0.281 J	0.560 J	1.88 J	0.304 ND
Eng 5 Reagent Blank - FH	0.0562 ND	0.209 J	0.484 J	1.11 J	0.304 ND
Eng 5 Field Blank - 2A + Eng 5 Reagent Blank Composite - 2A	0.0169 ND	0.0734 J	0.382 J	0.156 J	0.0873 ND

0223-176R Metals Summary



EPA Method 29 Summary

EA Project #: 0223-176

Client: Montrose Air Quality Services, LLC - Santa Ana

Client Project ID: 023392 - DTE Energy - Sunshine - SGT Eng 4 and 5 Exhaust

Total Micrograms of Mercury in Sample (ug)

Sample ID	Frac 1B	Frac 2B	Frac 3A	Frac 3B	Frac 3C
Eng 4 Run 1	0.0250 ND	0.220 ND	0.0232 ND	0.0912 ND	0.396
Eng 4 Run 2	0.0250 ND	0.233 ND	0.0245 ND	0.0612 ND	0.218
Eng 4 Run 3	0.0250 ND	0.219 ND	0.0240 ND	0.0637 ND	0.671
Eng 4 Run 4	0.0250 ND	0.225 ND	0.0255 ND	0.0625 ND	0.191
Eng 4 Run 5	0.0250 ND	0.219 ND	0.0250 ND	0.0600 ND	0.108 J
Eng 4 Run 6	0.0250 ND	0.220 ND	0.0242 ND	0.0650 ND	0.178
Eng 4 Run 7	0.0250 ND	0.223 ND	0.0245 ND	0.0600 ND	0.0827 J
Eng 4 Field Blank	0.0250 ND	0.145 ND	0.0245 ND	0.0600 ND	0.429
Eng 4 Reagent Blank	0.0250 ND	0.147 ND	0.0237 ND	0.0205 ND	0.0650 ND
Eng 5 Run 1	0.0250 ND	0.219 ND	0.0250 ND	0.0600 ND	0.0972 J
Eng 5 Run 2	0.0250 ND	0.223 ND	0.0250 ND	0.0587 ND	0.114 J
Eng 5 Run 3	0.0250 ND	0.225 ND	0.0237 ND	0.0612 ND	0.104 J
Eng 5 Run 4	0.0250 ND	0.222 ND	0.0247 ND	0.0575 ND	0.107 J
Eng 5 Run 5	0.0250 ND	0.224 ND	0.0250 ND	0.0662 ND	0.103 J
Eng 5 Run 6	0.0250 ND	0.222 ND	0.0245 ND	0.0650 ND	0.119 J
Eng 5 Run 7	0.0250 ND	0.219 ND	0.0240 ND	0.0637 ND	0.103 J
Eng 5 Field Blank	0.0250 ND	0.145 ND	0.0242 ND	0.0808 J	1.04
Eng 5 Reagent Blank	0.0250 ND	0.150 ND	0.0245 ND	0.0205 ND	0.0675 ND

0223-176 Hg top

EA Job# 0223-176R Page 8 of 186

W002AS-023392-RT-4542

213 of 688

Results



EA Job# 0223-176R Page 9 of 186

W002AS-023392-RT-4542

214 of 688

Sample ID	Element Client EA Project No. Analysis Date	Sb 121	Methodology			ICP-MS
		MAQS	MDL	LOQ	Postdig'n Spike Conc.	0.50 µg/L 5.0 µg/L 50 µg/L
		0223-176			Analyst(s)	MAL
		3/29/2023				
Front Halves		Test Sol'n (µg/L)	Conc. (µg/L)	FV (mL)	Diln Factor	Total (µg)
Eng 4 Run 1	0223-176.1 -1A	0.69	3.43	100	5	0.34290 J
Eng 4 Run 2	0223-176.2 -1A	0.50	2.51	100	5	0.25140 J
Eng 4 Run 3	0223-176.3 -1A	0.41	2.03	100	5	0.25000 ND
Eng 4 Run 4	0223-176.4 -1A	0.16	0.82	100	5	0.25000 ND
Eng 4 Run 5	0223-176.5 -1A	0.19	0.97	100	5	0.25000 ND
Eng 4 Run 6	0223-176.6 -1A	0.12	0.61	100	5	0.25000 ND
Eng 4 Run 7	0223-176.7 -1A	0.30	1.50	100	5	0.25000 ND
Eng 4 Field Blank	0223-176.8 -1A	0.12	0.62	100	5	0.25000 ND
Eng 4 Reagent Blank	0223-176.9 -1A	0.08	0.38	100	5	0.25000 ND
Eng 5 Run 1	0223-176.10 -1A	0.13	0.66	100	5	0.25000 ND
Eng 5 Run 2	0223-176.11 -1A	0.16	0.81	100	5	0.25000 ND
Eng 5 Run 3	0223-176.12 -1A	0.12	0.62	100	5	0.25000 ND
Eng 5 Run 4	0223-176.13 -1A	0.16	0.80	100	5	0.25000 ND
Eng 5 Run 5	0223-176.14 -1A	0.12	0.61	100	5	0.25000 ND
Eng 5 Run 6	0223-176.15 -1A	0.14	0.70	100	5	0.25000 ND
Eng 5 Run 7	0223-176.16 -1A	0.42	2.12	100	5	0.25000 ND
Eng 5 Field Blank	0223-176.17 -1A	0.09	0.46	100	5	0.25000 ND
Eng 5 Reagent Blank	0223-176.18 -1A	0.07	0.35	100	5	0.25000 ND
Lab Blank Front	0223-176.LB -1A	0.34	0.34	100	1	0.05000 ND
LCS Front	0223-176.LCS -1A	51.11	102.22	100	2	% REC = 102.2%
Spike Front	0223-176.1S -1A	52.98	264.90	100	5	% REC = 104.6%
Duplicate Front	0223-176.2D -1A	0.25				RPD = N/A

Sample ID	Element	Sb 121		Methodology			ICP-MS			
		Client MAQS		MDL	0.50	µg/L				
		EA Project No. 0223-176		LOQ	5.0	µg/L				
		Analysis Date 3/29/2023		Postdig'n Spike Conc.	50	µg/L				
				Analyst(s)			MAL			
					Total	Vol.				
		Test Sol'n	Conc.	FV	Diln Factor	Vol.	Dig'd			
		(µg/L)	(µg/L)	(mL)		(mL)	(mL)			
Back Halves										
Eng 4 Run 1	0223-176.1 -2A	0.95	0.95	100	1	440	415	0.10061	J	
Eng 4 Run 2	0223-176.2 -2A	0.63	0.63	100	1	465	415	0.07015	J	
Eng 4 Run 3	0223-176.3 -2A	0.64	0.64	100	1	437	412	0.06749	J	
Eng 4 Run 4	0223-176.4 -2A	0.37	0.37	100	1	450	400	0.05625	ND	
Eng 4 Run 5	0223-176.5 -2A	0.46	0.46	100	1	438	413	0.05303	ND	
Eng 4 Run 6	0223-176.6 -2A	0.24	0.24	100	1	440	415	0.05301	ND	
Eng 4 Run 7	0223-176.7 -2A	0.30	0.30	100	1	445	420	0.05298	ND	
Eng 4 Field Blank	0223-176.8 -2A	0.05	0.05	100	1	290	265	0.05472	ND	
Eng 4 Reagent Blank	0223-176.9 -2A	0.05	0.05	100	1	294	269	0.05465	ND	
Eng 5 Run 1	0223-176.10 -2A	0.25	0.25	100	1	437	412	0.05303	ND	
Eng 5 Run 2	0223-176.11 -2A	0.22	0.22	100	1	446	421	0.05297	ND	
Eng 5 Run 3	0223-176.12 -2A	0.28	0.28	100	1	450	400	0.05625	ND	
Eng 5 Run 4	0223-176.13 -2A	0.13	0.13	100	1	443	418	0.05299	ND	
Eng 5 Run 5	0223-176.14 -2A	0.20	0.20	100	1	447	422	0.05296	ND	
Eng 5 Run 6	0223-176.15 -2A	0.11	0.11	100	1	443	418	0.05299	ND	
Eng 5 Run 7	0223-176.16 -2A	0.25	0.25	100	1	437	412	0.05303	ND	
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	0.16	0.16	100	1	590	540	0.05463	ND	
Lab Blank Front	0223-176.LB -2A	0.00	0.00	100	1			0.05000	ND	
LCS Front	0223-176.LCS -2A	48.26	96.52	100	2		% REC =	96.5%		
Spike Front	0223-176.1S -2A	52.41	52.41	100	1		% REC =	102.9%		
Duplicate Front	0223-176.2D -2A	0.43					RPD =	N/A		

Element	As 75	Methodology				ICP-MS	
		Client MAQS	MDL	LOQ	Postdig'n Spike Conc.	MAL	1.34 µg/L
			5.0 µg/L	50 µg/L	Analyst(s)	50 µg/L	50 µg/L
		EA Project No. 0223-176					
Analysis Date	3/29/2023						
Sample ID		Test Sol'n	Conc.	FV			Total
		(µg/L)	(µg/L)	(mL)	Diln Factor		(µg)
Front Halves							
Eng 4 Run 1	0223-176.1 -1A	0.51	2.56	100	5		0.67069 ND
Eng 4 Run 2	0223-176.2 -1A	0.52	2.61	100	5		0.67069 ND
Eng 4 Run 3	0223-176.3 -1A	0.28	1.41	100	5		0.67069 ND
Eng 4 Run 4	0223-176.4 -1A	0.18	0.90	100	5		0.67069 ND
Eng 4 Run 5	0223-176.5 -1A	0.25	1.27	100	5		0.67069 ND
Eng 4 Run 6	0223-176.6 -1A	0.16	0.78	100	5		0.67069 ND
Eng 4 Run 7	0223-176.7 -1A	0.24	1.20	100	5		0.67069 ND
Eng 4 Field Blank	0223-176.8 -1A	0.06	0.29	100	5		0.67069 ND
Eng 4 Reagent Blank	0223-176.9 -1A	0.05	0.24	100	5		0.67069 ND
Eng 5 Run 1	0223-176.10 -1A	0.20	1.00	100	5		0.67069 ND
Eng 5 Run 2	0223-176.11 -1A	0.20	0.99	100	5		0.67069 ND
Eng 5 Run 3	0223-176.12 -1A	0.20	1.00	100	5		0.67069 ND
Eng 5 Run 4	0223-176.13 -1A	0.16	0.82	100	5		0.67069 ND
Eng 5 Run 5	0223-176.14 -1A	0.18	0.92	100	5		0.67069 ND
Eng 5 Run 6	0223-176.15 -1A	0.21	1.06	100	5		0.67069 ND
Eng 5 Run 7	0223-176.16 -1A	0.22	1.11	100	5		0.67069 ND
Eng 5 Field Blank	0223-176.17 -1A	0.06	0.32	100	5		0.67069 ND
Eng 5 Reagent Blank	0223-176.18 -1A	0.04	0.18	100	5		0.67069 ND
Lab Blank Front	0223-176.LB -1A	0.32	0.32	100	1		0.13414 ND
LCS Front	0223-176.LCS -1A	48.68	97.37	100	2	% REC =	97.4%
Spike Front	0223-176.1S -1A	48.45	242.26	100	5	% REC =	96.9%
Duplicate Front	0223-176.2D -1A	0.30				RPD =	N/A

Sample ID	Element	As 75		Methodology		ICP-MS		
		Client MAQS		MDL	0.50	µg/L		
		EA Project No. 0223-176		LOQ	5.0	µg/L		
		Analysis Date 3/29/2023		Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)		MAL				
		Total	Vol.	Dig'd				
		Test Sol'n (µg/L)	Conc. (µg/L)	FV (mL)	Diln Factor	Vol. (mL)	Total (µg)	
Back Halves								
Eng 4 Run 1	0223-176.1 -2A	0.56	0.56	100	1	440	415	
Eng 4 Run 2	0223-176.2 -2A	1.07	1.07	100	1	465	415	
Eng 4 Run 3	0223-176.3 -2A	0.66	0.66	100	1	437	412	
Eng 4 Run 4	0223-176.4 -2A	0.40	0.40	100	1	450	400	
Eng 4 Run 5	0223-176.5 -2A	0.28	0.28	100	1	438	413	
Eng 4 Run 6	0223-176.6 -2A	0.23	0.23	100	1	440	415	
Eng 4 Run 7	0223-176.7 -2A	0.34	0.34	100	1	445	420	
Eng 4 Field Blank	0223-176.8 -2A	0.06	0.06	100	1	290	265	
Eng 4 Reagent Blank	0223-176.9 -2A	0.01	0.01	100	1	294	269	
Eng 5 Run 1	0223-176.10 -2A	0.22	0.22	100	1	437	412	
Eng 5 Run 2	0223-176.11 -2A	0.12	0.12	100	1	446	421	
Eng 5 Run 3	0223-176.12 -2A	0.50	0.50	100	1	450	400	
Eng 5 Run 4	0223-176.13 -2A	0.11	0.11	100	1	443	418	
Eng 5 Run 5	0223-176.14 -2A	0.14	0.14	100	1	447	422	
Eng 5 Run 6	0223-176.15 -2A	0.08	0.08	100	1	443	418	
Eng 5 Run 7	0223-176.16 -2A	0.10	0.10	100	1	437	412	
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	0.02	0.02	100	1	590	540	
Lab Blank Front	0223-176.LB -2A	0.23	0.23	100	1		0.05000 ND	
LCS Front	0223-176.LCS -2A	48.42	96.84	100	2	% REC =	96.8%	
Spike Front	0223-176.1S -2A	47.44	47.44	100	1	% REC =	93.8%	
Duplicate Front	0223-176.2D -2A	0.86				RPD =	N/A	

Element	Be 9			Methodology		ICP-MS
Client	MAQS			MDL	0.11	µg/L
EA Project No.	0223-176			LOQ	1.0	µg/L
Analysis Date	3/29/2023			Postdig'n Spike Conc.	50	µg/L
				Analyst(s)	MAL	
Sample ID	Test Sol'n	Conc.	FV		Total	
	(µg/L)	(µg/L)	(mL)	Diln Factor	(µg)	
Front Halves						
Eng 4 Run 1	0223-176.1 -1A	0.23	1.16	100	5	0.11600 J
Eng 4 Run 2	0223-176.2 -1A	0.33	1.64	100	5	0.16360 J
Eng 4 Run 3	0223-176.3 -1A	0.03	0.17	100	5	0.05318 ND
Eng 4 Run 4	0223-176.4 -1A	0.02	0.09	100	5	0.05318 ND
Eng 4 Run 5	0223-176.5 -1A	0.01	0.03	100	5	0.05318 ND
Eng 4 Run 6	0223-176.6 -1A	0.01	0.04	100	5	0.05318 ND
Eng 4 Run 7	0223-176.7 -1A	0.08	0.41	100	5	0.05318 ND
Eng 4 Field Blank	0223-176.8 -1A	0.04	0.18	100	5	0.05318 ND
Eng 4 Reagent Blank	0223-176.9 -1A	0.02	0.11	100	5	0.05318 ND
Eng 5 Run 1	0223-176.10 -1A	0.02	0.11	100	5	0.05318 ND
Eng 5 Run 2	0223-176.11 -1A	0.02	0.08	100	5	0.05318 ND
Eng 5 Run 3	0223-176.12 -1A	0.01	0.06	100	5	0.05318 ND
Eng 5 Run 4	0223-176.13 -1A	0.01	0.06	100	5	0.05318 ND
Eng 5 Run 5	0223-176.14 -1A	0.01	0.05	100	5	0.05318 ND
Eng 5 Run 6	0223-176.15 -1A	0.01	0.04	100	5	0.05318 ND
Eng 5 Run 7	0223-176.16 -1A	0.14	0.68	100	5	0.06795 J
Eng 5 Field Blank	0223-176.17 -1A	0.06	0.30	100	5	0.05318 ND
Eng 5 Reagent Blank	0223-176.18 -1A	0.02	0.12	100	5	0.05318 ND
Lab Blank Front	0223-176.LB -1A	0.20	0.20	100	1	0.02018 J
LCS Front	0223-176.LCS -1A	49.09	98.17	100	2	% REC = 98.2%
Spike Front	0223-176.1S -1A	47.97	239.87	100	5	% REC = 95.5%
Duplicate Front	0223-176.2D -1A	0.09				RPD = N/A

Sample ID	Element	Be 9		Methodology		ICP-MS		
		Client MAQS		MDL	0.16	µg/L		
		EA Project No. 0223-176		LOQ	1.0	µg/L		
		Analysis Date 3/29/2023		Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)		MAL				
				Total	Vol.	Dig'd	Total (µg)	
		Test Sol'n	Conc.	FV	Diln Factor	Vol. (mL)		
		(µg/L)	(µg/L)	(mL)		(mL)		
Back Halves								
Eng 4 Run 1	0223-176.1 -2A	0.30	0.30	100	1	440	415	0.03193 J
Eng 4 Run 2	0223-176.2 -2A	0.18	0.18	100	1	465	415	0.02050 J
Eng 4 Run 3	0223-176.3 -2A	0.00	0.00	100	1	437	412	0.01719 ND
Eng 4 Run 4	0223-176.4 -2A	0.00	0.00	100	1	450	400	0.01823 ND
Eng 4 Run 5	0223-176.5 -2A	0.00	0.00	100	1	438	413	0.01719 ND
Eng 4 Run 6	0223-176.6 -2A	0.00	0.00	100	1	440	415	0.01718 ND
Eng 4 Run 7	0223-176.7 -2A	0.20	0.20	100	1	445	420	0.02112 J
Eng 4 Field Blank	0223-176.8 -2A	0.04	0.04	100	1	290	265	0.01774 ND
Eng 4 Reagent Blank	0223-176.9 -2A	0.00	0.00	100	1	294	269	0.01771 ND
Eng 5 Run 1	0223-176.10 -2A	0.00	0.00	100	1	437	412	0.01719 ND
Eng 5 Run 2	0223-176.11 -2A	0.00	0.00	100	1	446	421	0.01717 ND
Eng 5 Run 3	0223-176.12 -2A	0.00	0.00	100	1	450	400	0.01823 ND
Eng 5 Run 4	0223-176.13 -2A	0.00	0.00	100	1	443	418	0.01718 ND
Eng 5 Run 5	0223-176.14 -2A	0.00	0.00	100	1	447	422	0.01717 ND
Eng 5 Run 6	0223-176.15 -2A	0.00	0.00	100	1	443	418	0.01718 ND
Eng 5 Run 7	0223-176.16 -2A	0.00	0.00	100	1	437	412	0.01719 ND
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	0.00	0.00	100	1	590	540	0.01771 ND
Lab Blank Front	0223-176.LB -2A	0.20	0.20	100	1			0.02022 J
LCS Front	0223-176.LCS -2A	49.13	98.25	100	2		% REC =	98.3%
Spike Front	0223-176.1S -2A	48.92	48.92	100	1		% REC =	97.2%
Duplicate Front	0223-176.2D -2A	0.04					RPD =	N/A

Element	Cd 111				Methodology		ICP-MS
Client	MAQS				MDL	0.10	µg/L
EA Project No.	0223-176				LOQ	1.0	µg/L
Analysis Date	3/29/2023				Postdig'n Spike Conc.	50	µg/L
					Analyst(s)	MAL	
Sample ID		Test Sol'n (µg/L)	Conc. (µg/L)	FV (mL)	Diln Factor		Total (µg)
Front Halves							
Eng 4 Run 1	0223-176.1 -1A	0.46	2.32	100	5		0.23170 J
Eng 4 Run 2	0223-176.2 -1A	0.35	1.73	100	5		0.17320 J
Eng 4 Run 3	0223-176.3 -1A	0.04	0.18	100	5		0.05194 ND
Eng 4 Run 4	0223-176.4 -1A	0.02	0.10	100	5		0.05194 ND
Eng 4 Run 5	0223-176.5 -1A	0.00	0.00	100	5		0.05194 ND
Eng 4 Run 6	0223-176.6 -1A	0.00	0.00	100	5		0.05194 ND
Eng 4 Run 7	0223-176.7 -1A	0.10	0.52	100	5		0.05230 J
Eng 4 Field Blank	0223-176.8 -1A	0.03	0.16	100	5		0.05194 ND
Eng 4 Reagent Blank	0223-176.9 -1A	0.00	0.00	100	5		0.05194 ND
Eng 5 Run 1	0223-176.10 -1A	0.01	0.03	100	5		0.05194 ND
Eng 5 Run 2	0223-176.11 -1A	0.00	0.00	100	5		0.05194 ND
Eng 5 Run 3	0223-176.12 -1A	0.01	0.03	100	5		0.05194 ND
Eng 5 Run 4	0223-176.13 -1A	0.00	0.01	100	5		0.05194 ND
Eng 5 Run 5	0223-176.14 -1A	0.00	0.00	100	5		0.05194 ND
Eng 5 Run 6	0223-176.15 -1A	0.00	0.01	100	5		0.05194 ND
Eng 5 Run 7	0223-176.16 -1A	0.10	0.52	100	5		0.05230 J
Eng 5 Field Blank	0223-176.17 -1A	0.03	0.17	100	5		0.05194 ND
Eng 5 Reagent Blank	0223-176.18 -1A	0.00	0.00	100	5		0.05194 ND
Lab Blank Front	0223-176.LB -1A	0.18	0.18	100	1		0.01849 J
LCS Front	0223-176.LCS -1A	51.25	102.51	100	2	% REC =	102.5%
Spike Front	0223-176.1S -1A	50.70	253.50	100	5	% REC =	100.5%
Duplicate Front	0223-176.2D -1A	0.10				RPD =	N/A

Sample ID	Element Cd 111 Client MAQS EA Project No. 0223-176 Analysis Date 3/29/2023	Methodology				ICP-MS		
				MDL	0.19	µg/L		
				LOQ	1.0	µg/L		
		Postdig'n Spike Conc.		Analyst(s)	50	µg/L	MAL	
		Test Sol'n	Conc.	FV	Total	Vol.	Dig'd	Total
		(µg/L)	(µg/L)	(mL)	Diln Factor	(mL)	(mL)	(µg)
Back Halves								
Eng 4 Run 1	0223-176.1 -2A	6.02	6.02	100	1	440	415	0.63808
Eng 4 Run 2	0223-176.2 -2A	1.34	1.34	100	1	465	415	0.15045
Eng 4 Run 3	0223-176.3 -2A	0.90	0.90	100	1	437	412	0.09539 J
Eng 4 Run 4	0223-176.4 -2A	1.19	1.19	100	1	450	400	0.13331
Eng 4 Run 5	0223-176.5 -2A	0.27	0.27	100	1	438	413	0.02813 J
Eng 4 Run 6	0223-176.6 -2A	0.11	0.11	100	1	440	415	0.02048 ND
Eng 4 Run 7	0223-176.7 -2A	0.15	0.15	100	1	445	420	0.02047 ND
Eng 4 Field Blank	0223-176.8 -2A	0.02	0.02	100	1	290	265	0.02114 ND
Eng 4 Reagent Blank	0223-176.9 -2A	0.00	0.00	100	1	294	269	0.02111 ND
Eng 5 Run 1	0223-176.10 -2A	0.11	0.11	100	1	437	412	0.02049 ND
Eng 5 Run 2	0223-176.11 -2A	0.66	0.66	100	1	446	421	0.06966 J
Eng 5 Run 3	0223-176.12 -2A	0.32	0.32	100	1	450	400	0.03571 J
Eng 5 Run 4	0223-176.13 -2A	0.07	0.07	100	1	443	418	0.02047 ND
Eng 5 Run 5	0223-176.14 -2A	0.16	0.16	100	1	447	422	0.02046 ND
Eng 5 Run 6	0223-176.15 -2A	0.15	0.15	100	1	443	418	0.02047 ND
Eng 5 Run 7	0223-176.16 -2A	0.17	0.17	100	1	437	412	0.02049 ND
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	0.03	0.03	100	1	590	540	0.02111 ND
Lab Blank Front	0223-176.LB -2A	0.00	0.00	100	1			0.01932 ND
LCS Front	0223-176.LCS -2A	47.86	95.73	100	2		% REC =	95.7%
Spike Front	0223-176.1S -2A	58.91	58.91	100	1		% REC =	105.8%
Duplicate Front	0223-176.2D -2A	1.11					RPD =	N/A

Element	Cr 52			Methodology		ICP-MS
Client	MAQS			MDL	0.50	µg/L
EA Project No.	0223-176			LOQ	5.0	µg/L
Analysis Date	3/29/2023			Postdig'n Spike Conc.	50	µg/L
				Analyst(s)	MAL	
Sample ID		Test Sol'n	Conc.	FV		Total
		(µg/L)	(µg/L)	(mL)	Diln Factor	(µg)
Front Halves						
Eng 4 Run 1	0223-176.1 -1A	9.05	45.26	100	5	4.52585
Eng 4 Run 2	0223-176.2 -1A	12.60	63.02	100	5	6.30225
Eng 4 Run 3	0223-176.3 -1A	9.06	45.28	100	5	4.52845
Eng 4 Run 4	0223-176.4 -1A	12.19	60.96	100	5	6.09630
Eng 4 Run 5	0223-176.5 -1A	12.56	62.82	100	5	6.28175
Eng 4 Run 6	0223-176.6 -1A	8.49	42.46	100	5	4.24645
Eng 4 Run 7	0223-176.7 -1A	12.20	61.01	100	5	6.10095
Eng 4 Field Blank	0223-176.8 -1A	2.54	12.72	100	5	1.27175 J
Eng 4 Reagent Blank	0223-176.9 -1A	2.09	10.47	100	5	1.04700 J
Eng 5 Run 1	0223-176.10 -1A	9.12	45.60	100	5	4.56000
Eng 5 Run 2	0223-176.11 -1A	12.24	61.19	100	5	6.11865
Eng 5 Run 3	0223-176.12 -1A	9.15	45.77	100	5	4.57655
Eng 5 Run 4	0223-176.13 -1A	8.83	44.17	100	5	4.41705
Eng 5 Run 5	0223-176.14 -1A	9.06	45.32	100	5	4.53215
Eng 5 Run 6	0223-176.15 -1A	7.07	35.37	100	5	3.53695
Eng 5 Run 7	0223-176.16 -1A	9.18	45.88	100	5	4.58820
Eng 5 Field Blank	0223-176.17 -1A	2.31	11.54	100	5	1.15435 J
Eng 5 Reagent Blank	0223-176.18 -1A	2.09	10.45	100	5	1.04475 J
Lab Blank Front	0223-176.LB -1A	0.36	0.36	100	1	0.05000 ND
LCS Front	0223-176.LCS -1A	48.36	96.72	100	2	% REC = 96.7%
Spike Front	0223-176.1S -1A	54.45	272.26	100	5	% REC = 90.8%
Duplicate Front	0223-176.2D -1A	12.48				RPD = N/A

Sample ID	Element Client MAQS EA Project No. 0223-176 Analysis Date 3/29/2023	Methodology				ICP-MS		
				MDL	0.50	µg/L		
				LOQ	5.0	µg/L		
				Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)		MAL				
		Test Sol'n	Conc.	FV	Diln Factor	Total Vol.	Vol.	Total
		(µg/L)	(µg/L)	(mL)		(mL)	(mL)	(µg)
Back Halves								
Eng 4 Run 1	0223-176.1 -2A	6.22	6.22	100	1	440	415	0.65983
Eng 4 Run 2	0223-176.2 -2A	5.39	5.39	100	1	465	415	0.60402
Eng 4 Run 3	0223-176.3 -2A	4.65	4.65	100	1	437	412	0.49348 J
Eng 4 Run 4	0223-176.4 -2A	5.18	5.18	100	1	450	400	0.58262
Eng 4 Run 5	0223-176.5 -2A	5.27	5.27	100	1	438	413	0.55913
Eng 4 Run 6	0223-176.6 -2A	4.83	4.83	100	1	440	415	0.51222 J
Eng 4 Run 7	0223-176.7 -2A	4.25	4.25	100	1	445	420	0.45029 J
Eng 4 Field Blank	0223-176.8 -2A	0.42	0.42	100	1	290	265	0.05472 ND
Eng 4 Reagent Blank	0223-176.9 -2A	2.09	2.09	100	1	294	269	0.22839 J
Eng 5 Run 1	0223-176.10 -2A	5.01	5.01	100	1	437	412	0.53169
Eng 5 Run 2	0223-176.11 -2A	4.54	4.54	100	1	446	421	0.48134 J
Eng 5 Run 3	0223-176.12 -2A	5.92	5.92	100	1	450	400	0.66641
Eng 5 Run 4	0223-176.13 -2A	5.66	5.66	100	1	443	418	0.60029
Eng 5 Run 5	0223-176.14 -2A	4.94	4.94	100	1	447	422	0.52283 J
Eng 5 Run 6	0223-176.15 -2A	4.41	4.41	100	1	443	418	0.46688 J
Eng 5 Run 7	0223-176.16 -2A	8.72	8.72	100	1	437	412	0.92521
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	2.40	2.40	100	1	590	540	0.26180 J
Lab Blank Front	0223-176.LB -2A	0.37	0.37	100	1			0.05000 ND
LCS Front	0223-176.LCS -2A	49.63	99.26	100	2		% REC =	99.3%
Spike Front	0223-176.1S -2A	53.26	53.26	100	1		% REC =	94.1%
Duplicate Front	0223-176.2D -2A	5.31					RPD =	N/A

Element	Co 59			Methodology		ICP-MS
Client	MAQS			MDL	0.11	µg/L
EA Project No.	0223-176			LOQ	1.0	µg/L
Analysis Date	3/29/2023			Postdig'n Spike Conc.	50	µg/L
				Analyst(s)	MAL	
Sample ID		Test Sol'n	Conc.	FV		Total
		(µg/L)	(µg/L)	(mL)	Diln Factor	(µg)
Front Halves						
Eng 4 Run 1	0223-176.1 -1A	0.28	1.42	100	5	0.14165 J
Eng 4 Run 2	0223-176.2 -1A	0.40	2.01	100	5	0.20130 J
Eng 4 Run 3	0223-176.3 -1A	2.28	11.39	100	5	1.13925
Eng 4 Run 4	0223-176.4 -1A	0.16	0.78	100	5	0.07765 J
Eng 4 Run 5	0223-176.5 -1A	0.07	0.36	100	5	0.05623 ND
Eng 4 Run 6	0223-176.6 -1A	0.01	0.07	100	5	0.05623 ND
Eng 4 Run 7	0223-176.7 -1A	0.08	0.38	100	5	0.05623 ND
Eng 4 Field Blank	0223-176.8 -1A	0.02	0.11	100	5	0.05623 ND
Eng 4 Reagent Blank	0223-176.9 -1A	0.00	0.01	100	5	0.05623 ND
Eng 5 Run 1	0223-176.10 -1A	0.01	0.07	100	5	0.05623 ND
Eng 5 Run 2	0223-176.11 -1A	0.01	0.06	100	5	0.05623 ND
Eng 5 Run 3	0223-176.12 -1A	0.01	0.07	100	5	0.05623 ND
Eng 5 Run 4	0223-176.13 -1A	0.01	0.05	100	5	0.05623 ND
Eng 5 Run 5	0223-176.14 -1A	0.01	0.06	100	5	0.05623 ND
Eng 5 Run 6	0223-176.15 -1A	0.03	0.17	100	5	0.05623 ND
Eng 5 Run 7	0223-176.16 -1A	0.07	0.33	100	5	0.05623 ND
Eng 5 Field Blank	0223-176.17 -1A	0.02	0.08	100	5	0.05623 ND
Eng 5 Reagent Blank	0223-176.18 -1A	0.00	0.02	100	5	0.05623 ND
Lab Blank Front	0223-176.LB -1A	0.19	0.19	100	1	0.01877 J
LCS Front	0223-176.LCS -1A	48.03	96.06	100	2	% REC = 96.1%
Spike Front	0223-176.1S -1A	45.35	226.77	100	5	% REC = 90.1%
Duplicate Front	0223-176.2D -1A	0.21				RPD = N/A

Sample ID	Element	Co 59		Methodology		ICP-MS		
		Client MAQS		MDL	0.15	µg/L		
		EA Project No. 0223-176		LOQ	1.0	µg/L		
		Analysis Date 3/29/2023		Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)		MAL				
		Total	Vol.					
		Test Sol'n (µg/L)	Conc. (µg/L)	FV (mL)	Diln Factor	Vol. (mL)	Dig'd (mL)	
							Total (µg)	
Back Halves								
Eng 4 Run 1	0223-176.1 -2A	0.79	0.79	100	1	440	415	0.08366 J
Eng 4 Run 2	0223-176.2 -2A	0.65	0.65	100	1	465	415	0.07289 J
Eng 4 Run 3	0223-176.3 -2A	0.23	0.23	100	1	437	412	0.02414 J
Eng 4 Run 4	0223-176.4 -2A	0.39	0.39	100	1	450	400	0.04374 J
Eng 4 Run 5	0223-176.5 -2A	0.35	0.35	100	1	438	413	0.03700 J
Eng 4 Run 6	0223-176.6 -2A	0.25	0.25	100	1	440	415	0.02699 J
Eng 4 Run 7	0223-176.7 -2A	0.33	0.33	100	1	445	420	0.03482 J
Eng 4 Field Blank	0223-176.8 -2A	0.06	0.06	100	1	290	265	0.01691 ND
Eng 4 Reagent Blank	0223-176.9 -2A	0.02	0.02	100	1	294	269	0.01689 ND
Eng 5 Run 1	0223-176.10 -2A	0.15	0.15	100	1	437	412	0.01639 ND
Eng 5 Run 2	0223-176.11 -2A	0.14	0.14	100	1	446	421	0.01637 ND
Eng 5 Run 3	0223-176.12 -2A	0.20	0.20	100	1	450	400	0.02204 J
Eng 5 Run 4	0223-176.13 -2A	0.16	0.16	100	1	443	418	0.01701 J
Eng 5 Run 5	0223-176.14 -2A	0.23	0.23	100	1	447	422	0.02410 J
Eng 5 Run 6	0223-176.15 -2A	0.09	0.09	100	1	443	418	0.01638 ND
Eng 5 Run 7	0223-176.16 -2A	0.25	0.25	100	1	437	412	0.02632 J
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	0.02	0.02	100	1	590	540	0.01688 ND
Lab Blank Front	0223-176.LB -2A	0.20	0.20	100	1			0.01983 J
LCS Front	0223-176.LCS -2A	48.06	96.12	100	2		% REC =	96.1%
Spike Front	0223-176.1S -2A	49.22	49.22	100	1		% REC =	96.9%
Duplicate Front	0223-176.2D -2A	0.50					RPD =	N/A

Element	Pb 208	Methodology			ICP-MS	
Client	MAQS	MDL	0.10	µg/L		
EA Project No.	0223-176	LOQ	1.0	µg/L		
Analysis Date	3/29/2023	Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)	MAL			
Sample ID	Test Sol'n	Conc.	FV	Diln Factor	Total (µg)	
	(µg/L)	(µg/L)	(mL)			
Front Halves						
Eng 4 Run 1	0223-176.1 -1A	1.27	6.33	100	5	0.63310
Eng 4 Run 2	0223-176.2 -1A	1.10	5.48	100	5	0.54805
Eng 4 Run 3	0223-176.3 -1A	0.69	3.45	100	5	0.34505 J
Eng 4 Run 4	0223-176.4 -1A	0.71	3.56	100	5	0.35560 J
Eng 4 Run 5	0223-176.5 -1A	0.81	4.05	100	5	0.40460 J
Eng 4 Run 6	0223-176.6 -1A	0.62	3.11	100	5	0.31075 J
Eng 4 Run 7	0223-176.7 -1A	0.69	3.44	100	5	0.34425 J
Eng 4 Field Blank	0223-176.8 -1A	0.74	3.71	100	5	0.37095 J
Eng 4 Reagent Blank	0223-176.9 -1A	0.48	2.40	100	5	0.24000 J
Eng 5 Run 1	0223-176.10 -1A	0.64	3.21	100	5	0.32050 J
Eng 5 Run 2	0223-176.11 -1A	0.63	3.14	100	5	0.31365 J
Eng 5 Run 3	0223-176.12 -1A	0.59	2.95	100	5	0.29490 J
Eng 5 Run 4	0223-176.13 -1A	0.56	2.79	100	5	0.27875 J
Eng 5 Run 5	0223-176.14 -1A	0.70	3.48	100	5	0.34835 J
Eng 5 Run 6	0223-176.15 -1A	0.67	3.33	100	5	0.33330 J
Eng 5 Run 7	0223-176.16 -1A	0.69	3.44	100	5	0.34360 J
Eng 5 Field Blank	0223-176.17 -1A	0.56	2.81	100	5	0.28110 J
Eng 5 Reagent Blank	0223-176.18 -1A	0.42	2.09	100	5	0.20935 J
Lab Blank Front	0223-176.LB -1A	0.18	0.18	100	1	0.01833 J
LCS Front	0223-176.LCS -1A	49.71	99.43	100	2	% REC = 99.4%
Spike Front	0223-176.1S -1A	51.07	255.35	100	5	% REC = 99.6%
Duplicate Front	0223-176.2D -1A	0.90				RPD = N/A

Sample ID	Element	Pb 208		Methodology		ICP-MS		
		Client MAQS		MDL	0.19	µg/L		
		EA Project No. 0223-176		LOQ	1.0	µg/L		
		Analysis Date 3/29/2023		Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)		MAL				
		Total	Vol.					
		Test Sol'n (µg/L)	Conc. (µg/L)	FV (mL)	Diln Factor	Vol. (mL)	Dig'd (mL)	
							Total (µg)	
Back Halves								
Eng 4 Run 1	0223-176.1 -2A	6.94	6.94	100	1	440	415	0.73627
Eng 4 Run 2	0223-176.2 -2A	4.26	4.3	100	1	465	415	0.47682
Eng 4 Run 3	0223-176.3 -2A	1.93	1.93	100	1	437	412	0.20494
Eng 4 Run 4	0223-176.4 -2A	3.01	3.01	100	1	450	400	0.33834
Eng 4 Run 5	0223-176.5 -2A	1.96	1.96	100	1	438	413	0.20751
Eng 4 Run 6	0223-176.6 -2A	1.81	1.81	100	1	440	415	0.19154
Eng 4 Run 7	0223-176.7 -2A	1.15	1.15	100	1	445	420	0.12189
Eng 4 Field Blank	0223-176.8 -2A	0.21	0.21	100	1	290	265	0.02289 J
Eng 4 Reagent Blank	0223-176.9 -2A	0.17	0.17	100	1	294	269	0.02024 ND
Eng 5 Run 1	0223-176.10 -2A	0.93	0.93	100	1	437	412	0.09901 J
Eng 5 Run 2	0223-176.11 -2A	1.06	1.1	100	1	446	421	0.11239
Eng 5 Run 3	0223-176.12 -2A	1.31	1.31	100	1	450	400	0.14698
Eng 5 Run 4	0223-176.13 -2A	1.01	1.01	100	1	443	418	0.10682
Eng 5 Run 5	0223-176.14 -2A	0.90	0.90	100	1	447	422	0.09488 J
Eng 5 Run 6	0223-176.15 -2A	0.58	0.58	100	1	443	418	0.06163 J
Eng 5 Run 7	0223-176.16 -2A	0.92	0.92	100	1	437	412	0.09756 J
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	0.67	0.67	100	1	590	540	0.07339 J
Lab Blank Front	0223-176.LB -2A	0.01	0.01	100	1			0.01852 ND
LCS Front	0223-176.LCS -2A	49.93	99.86	100	2		% REC =	99.9%
Spike Front	0223-176.1S -2A	58.44	58.4	100	1		% REC =	103.0%
Duplicate Front	0223-176.2D -2A	4.09					RPD =	N/A

Sample ID	Element Client EA Project No. Analysis Date	Mn 55	Methodology			ICP-MS
		MAQS	MDL	LOQ	0.80 µg/L	
		0223-176	Postdig'n Spike Conc.	50 µg/L		
		3/29/2023	Analyst(s)	MAL		
Test Sol'n	Conc.	FV	Diln Factor	Total	(µg)	
(µg/L)	(µg/L)	(mL)				
Front Halves						
Eng 4 Run 1	0223-176.1 -1A	2.06	10.31	100	5	1.03050 J
Eng 4 Run 2	0223-176.2 -1A	1.95	9.74	100	5	0.97365 J
Eng 4 Run 3	0223-176.3 -1A	1.48	7.40	100	5	0.74025 J
Eng 4 Run 4	0223-176.4 -1A	1.55	7.74	100	5	0.77435 J
Eng 4 Run 5	0223-176.5 -1A	1.45	7.23	100	5	0.72335 J
Eng 4 Run 6	0223-176.6 -1A	2.89	14.47	100	5	1.44665 J
Eng 4 Run 7	0223-176.7 -1A	3.21	16.06	100	5	1.60645 J
Eng 4 Field Blank	0223-176.8 -1A	1.08	5.38	100	5	0.53775 J
Eng 4 Reagent Blank	0223-176.9 -1A	0.92	4.59	100	5	0.45865 J
Eng 5 Run 1	0223-176.10 -1A	1.30	6.49	100	5	0.64880 J
Eng 5 Run 2	0223-176.11 -1A	4.56	22.81	100	5	2.28055 J
Eng 5 Run 3	0223-176.12 -1A	1.37	6.87	100	5	0.68705 J
Eng 5 Run 4	0223-176.13 -1A	1.39	6.96	100	5	0.69580 J
Eng 5 Run 5	0223-176.14 -1A	1.35	6.73	100	5	0.67285 J
Eng 5 Run 6	0223-176.15 -1A	5.17	25.85	100	5	2.58530
Eng 5 Run 7	0223-176.16 -1A	2.46	12.28	100	5	1.22840 J
Eng 5 Field Blank	0223-176.17 -1A	1.12	5.60	100	5	0.55960 J
Eng 5 Reagent Blank	0223-176.18 -1A	0.97	4.84	100	5	0.48370 J
Lab Blank Front	0223-176.LB -1A	0.32	0.32	100	1	0.07986 ND
LCS Front	0223-176.LCS -1A	50.08	100.16	100	2	% REC = 100.2%
Spike Front	0223-176.1S -1A	49.34	246.72	100	5	% REC = 94.6%
Duplicate Front	0223-176.2D -1A	1.73				RPD = N/A

Sample ID	Element	Mn 55		Methodology			ICP-MS		
		Client MAQS		MDL		0.59	µg/L		
		EA Project No. 0223-176		LOQ		5.0	µg/L		
		Analysis Date 3/29/2023		Postdig'n Spike Conc.		50	µg/L		
				Analyst(s)		MAL			
						Total	Vol.		
		Test Sol'n	Conc.	FV	Diln Factor	Vol.	Dig'd	Total	
		(µg/L)	(µg/L)	(mL)		(mL)	(mL)	(µg)	
Back Halves									
Eng 4 Run 1	0223-176.1 -2A	11.45	11.45	100	1	440	415	1.21388	
Eng 4 Run 2	0223-176.2 -2A	7.78	7.78	100	1	465	415	0.87176	
Eng 4 Run 3	0223-176.3 -2A	3.93	3.93	100	1	437	412	0.41730 J	
Eng 4 Run 4	0223-176.4 -2A	5.11	5.11	100	1	450	400	0.57492	
Eng 4 Run 5	0223-176.5 -2A	6.18	6.18	100	1	438	413	0.65574	
Eng 4 Run 6	0223-176.6 -2A	9.62	9.62	100	1	440	415	1.01943	
Eng 4 Run 7	0223-176.7 -2A	13.07	13.07	100	1	445	420	1.38476	
Eng 4 Field Blank	0223-176.8 -2A	1.11	1.11	100	1	290	265	0.12130 J	
Eng 4 Reagent Blank	0223-176.9 -2A	1.97	1.97	100	1	294	269	0.21584 J	
Eng 5 Run 1	0223-176.10 -2A	14.49	144.87	100	10	437	412	15.3656	
Eng 5 Run 2	0223-176.11 -2A	4.80	4.80	100	1	446	421	0.50858 J	
Eng 5 Run 3	0223-176.12 -2A	15.83	15.83	100	1	450	400	1.78053	
Eng 5 Run 4	0223-176.13 -2A	4.00	4.00	100	1	443	418	0.42409 J	
Eng 5 Run 5	0223-176.14 -2A	8.60	8.60	100	1	447	422	0.91049	
Eng 5 Run 6	0223-176.15 -2A	6.21	6.21	100	1	443	418	0.65844	
Eng 5 Run 7	0223-176.16 -2A	15.91	15.91	100	1	437	412	1.68787	
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	3.50	3.50	100	1	590	540	0.38229 J	
Lab Blank Front	0223-176.LB -2A	0.57	0.57	100	1			0.05887 ND	
LCS Front	0223-176.LCS -2A	48.53	97.06	100	2		% REC =	97.1%	
Spike Front	0223-176.1S -2A	59.64	59.64	100	1		% REC =	96.4%	
Duplicate Front	0223-176.2D -2A	7.73					RPD =	N/A	

Element	Ni 60	Methodology	ICP-MS			
Client	MAQS	MDL	0.65	µg/L		
EA Project No.	0223-176	LOQ	5.0	µg/L		
Analysis Date	3/29/2023	Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)	MAL			
Sample ID	Test Sol'n	Conc.	FV	Total		
	(µg/L)	(µg/L)	(mL)	(µg)		
Front Halves						
Eng 4 Run 1	0223-176.1 -1A	4.31	21.55	100	5	2.15500 J
Eng 4 Run 2	0223-176.2 -1A	3.69	18.46	100	5	1.84635 J
Eng 4 Run 3	0223-176.3 -1A	2.74	13.69	100	5	1.36875 J
Eng 4 Run 4	0223-176.4 -1A	3.91	19.53	100	5	1.95295 J
Eng 4 Run 5	0223-176.5 -1A	2.98	14.90	100	5	1.48970 J
Eng 4 Run 6	0223-176.6 -1A	2.49	12.45	100	5	1.24530 J
Eng 4 Run 7	0223-176.7 -1A	2.95	14.73	100	5	1.47340 J
Eng 4 Field Blank	0223-176.8 -1A	2.51	12.57	100	5	1.25675 J
Eng 4 Reagent Blank	0223-176.9 -1A	2.25	11.25	100	5	1.12515 J
Eng 5 Run 1	0223-176.10 -1A	2.81	14.06	100	5	1.40645 J
Eng 5 Run 2	0223-176.11 -1A	3.32	16.58	100	5	1.65750 J
Eng 5 Run 3	0223-176.12 -1A	2.86	14.31	100	5	1.43110 J
Eng 5 Run 4	0223-176.13 -1A	2.80	14.00	100	5	1.40045 J
Eng 5 Run 5	0223-176.14 -1A	3.88	19.42	100	5	1.94240 J
Eng 5 Run 6	0223-176.15 -1A	2.75	13.75	100	5	1.37460 J
Eng 5 Run 7	0223-176.16 -1A	2.49	12.45	100	5	1.24460 J
Eng 5 Field Blank	0223-176.17 -1A	3.76	18.81	100	5	1.88080 J
Eng 5 Reagent Blank	0223-176.18 -1A	2.23	11.13	100	5	1.11340 J
Lab Blank Front	0223-176.LB -1A	0.42	0.42	100	1	0.06505 ND
LCS Front	0223-176.LCS -1A	47.23	94.46	100	2	% REC = 94.5%
Spike Front	0223-176.1S -1A	47.68	238.41	100	5	% REC = 86.7%
Duplicate Front	0223-176.2D -1A	3.61				RPD = N/A

Sample ID	Element Client EA Project No. Analysis Date	Ni 60 MAQS 0223-176 3/29/2023	Methodology			ICP-MS			
			Postdig'n Spike Conc.	MDL	0.50	µg/L	Total Vol.	Vol.	
				LOQ	5.0	µg/L			
				Spike Conc.	50	µg/L			
			Analyst(s)	MAL			Total	Vol.	
Test Sol'n		(µg/L)	Conc.	FV	Diln Factor	Vol.	Dig'd	Total	
		(µg/L)	(µg/L)	(mL)		(mL)	(mL)	(µg)	
Back Halves									
Eng 4 Run 1	0223-176.1 -2A	13.60	13.60	100	1	440	415	1.44242	
Eng 4 Run 2	0223-176.2 -2A	5.28	5.28	100	1	465	415	0.59122	
Eng 4 Run 3	0223-176.3 -2A	7.26	7.26	100	1	437	412	0.76971	
Eng 4 Run 4	0223-176.4 -2A	6.63	6.63	100	1	450	400	0.74576	
Eng 4 Run 5	0223-176.5 -2A	5.19	5.19	100	1	438	413	0.55042	
Eng 4 Run 6	0223-176.6 -2A	3.44	3.44	100	1	440	415	0.36468 J	
Eng 4 Run 7	0223-176.7 -2A	3.21	3.21	100	1	445	420	0.34047 J	
Eng 4 Field Blank	0223-176.8 -2A	0.43	0.43	100	1	290	265	0.05472 ND	
Eng 4 Reagent Blank	0223-176.9 -2A	1.58	1.58	100	1	294	269	0.17257 J	
Eng 5 Run 1	0223-176.10 -2A	3.65	3.65	100	1	437	412	0.38764 J	
Eng 5 Run 2	0223-176.11 -2A	3.86	3.86	100	1	446	421	0.40849 J	
Eng 5 Run 3	0223-176.12 -2A	3.87	3.87	100	1	450	400	0.43502 J	
Eng 5 Run 4	0223-176.13 -2A	5.09	5.09	100	1	443	418	0.53945	
Eng 5 Run 5	0223-176.14 -2A	6.05	6.05	100	1	447	422	0.64046	
Eng 5 Run 6	0223-176.15 -2A	3.68	3.68	100	1	443	418	0.38997 J	
Eng 5 Run 7	0223-176.16 -2A	6.97	6.97	100	1	437	412	0.73924	
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	1.43	1.43	100	1	590	540	0.15602 J	
Lab Blank Front	0223-176.LB -2A	0.55	0.55	100	1			0.05545 J	
LCS Front	0223-176.LCS -2A	48.92	97.84	100	2		% REC =	97.8%	
Spike Front	0223-176.1S -2A	61.38	61.38	100	1		% REC =	95.6%	
Duplicate Front	0223-176.2D -2A	5.15					RPD =	N/A	

Element	Se 77			Methodology		ICP-MS
Client	MAQS			MDL	0.61	µg/L
EA Project No.	0223-176			LOQ	5.0	µg/L
Analysis Date	3/29/2023			Postdig'n Spike Conc.	50	µg/L
				Analyst(s)	MAL	
Sample ID	Test Sol'n	Conc.	FV	Diln Factor	Total	(µg)
	(µg/L)	(µg/L)	(mL)			
Front Halves						
Eng 4 Run 1	0223-176.1 -1A	0.37	1.87	100	5	0.30361 ND
Eng 4 Run 2	0223-176.2 -1A	0.37	1.84	100	5	0.30361 ND
Eng 4 Run 3	0223-176.3 -1A	0.14	0.72	100	5	0.30361 ND
Eng 4 Run 4	0223-176.4 -1A	0.05	0.27	100	5	0.30361 ND
Eng 4 Run 5	0223-176.5 -1A	0.00	0.00	100	5	0.30361 ND
Eng 4 Run 6	0223-176.6 -1A	0.00	0.00	100	5	0.30361 ND
Eng 4 Run 7	0223-176.7 -1A	0.00	0.00	100	5	0.30361 ND
Eng 4 Field Blank	0223-176.8 -1A	0.00	0.00	100	5	0.30361 ND
Eng 4 Reagent Blank	0223-176.9 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Run 1	0223-176.10 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Run 2	0223-176.11 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Run 3	0223-176.12 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Run 4	0223-176.13 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Run 5	0223-176.14 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Run 6	0223-176.15 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Run 7	0223-176.16 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Field Blank	0223-176.17 -1A	0.00	0.00	100	5	0.30361 ND
Eng 5 Reagent Blank	0223-176.18 -1A	0.00	0.00	100	5	0.30361 ND
Lab Blank Front	0223-176.LB -1A	0.24	0.24	100	1	0.06072 ND
LCS Front	0223-176.LCS -1A	48.99	97.97	100	2	% REC = 98.0%
Spike Front	0223-176.1S -1A	47.40	237.00	100	5	% REC = 94.8%
Duplicate Front	0223-176.2D -1A	0.19				RPD = N/A

Sample ID	Element Client EA Project No. Analysis Date	Se 77		Methodology		ICP-MS		
				MDL	0.80	µg/L		
				LOQ	5.0	µg/L		
				Postdig'n Spike Conc.	50	µg/L		
		Analyst(s)		MAL				
				Total	Vol.			
		Test Sol'n	Conc.	FV	Diln Factor	Vol.	Dig'd	
		(µg/L)	(µg/L)	(mL)		(mL)	(mL)	
Back Halves							Total (µg)	
Eng 4 Run 1	0223-176.1 -2A	10.69	10.69	100	1	440	415	1.13376
Eng 4 Run 2	0223-176.2 -2A	2.87	2.87	100	1	465	415	0.32194 J
Eng 4 Run 3	0223-176.3 -2A	10.96	10.96	100	1	437	412	1.16248
Eng 4 Run 4	0223-176.4 -2A	41.62	41.62	100	1	450	400	4.68201
Eng 4 Run 5	0223-176.5 -2A	10.91	10.91	100	1	438	413	1.15747
Eng 4 Run 6	0223-176.6 -2A	75.25	75.25	100	1	440	415	7.97861
Eng 4 Run 7	0223-176.7 -2A	5.27	5.27	100	1	445	420	0.55817
Eng 4 Field Blank	0223-176.8 -2A	0.24	0.24	100	1	290	265	0.08746 ND
Eng 4 Reagent Blank	0223-176.9 -2A	0.23	0.23	100	1	294	269	0.08735 ND
Eng 5 Run 1	0223-176.10 -2A	79.00	79.00	100	1	437	412	8.37910
Eng 5 Run 2	0223-176.11 -2A	21.57	21.57	100	1	446	421	2.28525
Eng 5 Run 3	0223-176.12 -2A	17.98	179.84	100	10	450	400	20.2314
Eng 5 Run 4	0223-176.13 -2A	3.08	3.08	100	1	443	418	0.32611 J
Eng 5 Run 5	0223-176.14 -2A	7.71	7.71	100	1	447	422	0.81670
Eng 5 Run 6	0223-176.15 -2A	2.25	2.25	100	1	443	418	0.23853 J
Eng 5 Run 7	0223-176.16 -2A	8.72	8.72	100	1	437	412	0.92463
Eng 5 Field Blk + Eng 5 Reag. Blk Composite	0223-176.17 -2A	0.30	0.30	100	1	590	540	0.08732 ND
Lab Blank Front	0223-176.LB -2A	0.33	0.33	100	1			0.07992 ND
LCS Front	0223-176.LCS -2A	48.11	96.22	100	2		% REC =	96.2%
Spike Front	0223-176.1S -2A	63.57	63.57	100	1		% REC =	105.8%
Duplicate Front	0223-176.2D -2A	2.56					RPD =	N/A

METHOD 29 MERCURY - CVAA Worksheet

Client: MAQS - Santa Ana

MDL = 0.050 µg/L

EA Project #: 0223-176

RL = 0.10 µg/L

Analysis Date: 2/27/23, 2/28/23, 3/1/23, 3/6/23, 3/7/23

Matrix spike conc. = 5.0 µg/L

Sample ID	Test	Dig'te	Dil'n	Total	Volume	Dig'd	Total
	Sol'n µg/L	Conc µg/L	FV ml	Factor	Volume ml		
FRACTION 1B							
ENG 4 Run 1	0223-176.1 -1B	-0.018	-0.02	50	1	100	10.0
ENG 4 Run 2	0223-176.2 -1B	-0.048	-0.05	50	1	100	10.0
ENG 4 Run 3	0223-176.3 -1B	-0.031	-0.03	50	1	100	10.0
ENG 4 Run 4	0223-176.4 -1B	-0.020	-0.02	50	1	100	10.0
ENG 4 Run 5	0223-176.5 -1B	-0.019	-0.02	50	1	100	10.0
ENG 4 Run 6	0223-176.6 -1B	-0.016	-0.02	50	1	100	10.0
ENG 4 Run 7	0223-176.7 -1B	-0.021	-0.02	50	1	100	10.0
ENG 4 Field Blank	0223-176.8 -1B	-0.017	-0.02	50	1	100	10.0
ENG 4 Reagent Blank	0223-176.9 -1B	-0.027	-0.03	50	1	100	10.0
ENG 5 Run 1	0223-176.10 -1B	-0.028	-0.03	50	1	100	10.0
ENG 5 Run 2	0223-176.11 -1B	-0.023	-0.02	50	1	100	10.0
ENG 5 Run 3	0223-176.12 -1B	-0.031	-0.03	50	1	100	10.0
ENG 5 Run 4	0223-176.13 -1B	-0.030	-0.03	50	1	100	10.0
ENG 5 Run 5	0223-176.14 -1B	-0.031	-0.03	50	1	100	10.0
ENG 5 Run 6	0223-176.15 -1B	-0.030	-0.03	50	1	100	10.0
ENG 5 Run 7	0223-176.16 -1B	-0.027	-0.03	50	1	100	10.0
ENG 5 Field Blank	0223-176.17 -1B	-0.025	-0.03	50	1	100	10.0
ENG 5 Reagent Blank	0223-176.18 -1B	-0.029	-0.03	50	1	100	10.0
Matrix Spike	0223-176.1S -1B	4.650			% REC =	93.0%	
Duplicate	0223-176.2D -1B	-0.014			% RPD =	N/A	
FRACTION 2B							
ENG 4 Run 1	0223-176.1 -2B	0.009	0.01	50	1	440	5.0
ENG 4 Run 2	0223-176.2 -2B	0.029	0.03	50	1	465	5.0
ENG 4 Run 3	0223-176.3 -2B	0.011	0.01	50	1	437	5.0
ENG 4 Run 4	0223-176.4 -2B	0.038	0.04	50	1	450	5.0
ENG 4 Run 5	0223-176.5 -2B	0.013	0.01	50	1	438	5.0
ENG 4 Run 6	0223-176.6 -2B	0.020	0.02	50	1	440	5.0
ENG 4 Run 7	0223-176.7 -2B	0.002	0.00	50	1	445	5.0
ENG 4 Field Blank	0223-176.8 -2B	-0.001	0.00	50	1	290	5.0
ENG 4 Reagent Blank	0223-176.9 -2B	0.035	0.04	50	1	294	5.0
ENG 5 Run 1	0223-176.10 -2B	0.007	0.01	50	1	437	5.0
ENG 5 Run 2	0223-176.11 -2B	0.028	0.03	50	1	446	5.0
ENG 5 Run 3	0223-176.12 -2B	0.021	0.02	50	1	450	5.0
ENG 5 Run 4	0223-176.13 -2B	0.017	0.02	50	1	443	5.0
ENG 5 Run 5	0223-176.14 -2B	0.013	0.01	50	1	447	5.0
ENG 5 Run 6	0223-176.15 -2B	0.014	0.01	50	1	443	5.0
ENG 5 Run 7	0223-176.16 -2B	0.010	0.01	50	1	437	5.0
ENG 5 Field Blank	0223-176.17 -2B	0.003	0.00	50	1	290	5.0
ENG 5 Reagent Blank	0223-176.18 -2B	0.032	0.03	50	1	300	5.0
Matrix Spike	0223-176.1S -2B	5.100			% REC =	102.0%	
Duplicate	0223-176.2D -2B	0.032			% RPD =	N/A	

METHOD 29 MERCURY - CVAA Worksheet

Client: MAQS - Santa Ana

MDL = 0.050 µg/L

EA Project #: 0223-176

RL = 0.10 µg/L

Analysis Date: 2/27/23, 2/28/23, 3/1/23, 3/6/23, 3/7/23

Matrix spike conc. = 5.0 µg/L

Sample ID	Test Sol'n µg/L	Dig'te Conc µg/L	FV ml	Dil'n Factor	Total Volume ml	Volume Dig'd ml	Total µg
FRACTION 3A							
ENG 4 Run 1	0223-176.1 -3A	0.033	0.03	50	1 93	10.0	0.0232 ND
ENG 4 Run 2	0223-176.2 -3A	0.026	0.03	50	1 98	10.0	0.0245 ND
ENG 4 Run 3	0223-176.3 -3A	-0.002	0.00	50	1 96	10.0	0.0240 ND
ENG 4 Run 4	0223-176.4 -3A	0.010	0.01	50	1 102	10.0	0.0255 ND
ENG 4 Run 5	0223-176.5 -3A	0.000	0.00	50	1 100	10.0	0.0250 ND
ENG 4 Run 6	0223-176.6 -3A	0.002	0.00	50	1 97	10.0	0.0242 ND
ENG 4 Run 7	0223-176.7 -3A	0.003	0.00	50	1 98	10.0	0.0245 ND
ENG 4 Field Blank	0223-176.8 -3A	-0.002	0.00	50	1 98	10.0	0.0245 ND
ENG 4 Reagent Blank	0223-176.9 -3A	-0.003	0.00	50	1 95	10.0	0.0237 ND
ENG 5 Run 1	0223-176.10 -3A	-0.002	0.00	50	1 100	10.0	0.0250 ND
ENG 5 Run 2	0223-176.11 -3A	0.011	0.01	50	1 100	10.0	0.0250 ND
ENG 5 Run 3	0223-176.12 -3A	-0.001	0.00	50	1 95	10.0	0.0237 ND
ENG 5 Run 4	0223-176.13 -3A	0.004	0.00	50	1 99	10.0	0.0247 ND
ENG 5 Run 5	0223-176.14 -3A	0.002	0.00	50	1 100	10.0	0.0250 ND
ENG 5 Run 6	0223-176.15 -3A	0.002	0.00	50	1 98	10.0	0.0245 ND
ENG 5 Run 7	0223-176.16 -3A	0.001	0.00	50	1 96	10.0	0.0240 ND
ENG 5 Field Blank	0223-176.17 -3A	0.000	0.00	50	1 97	10.0	0.0242 ND
ENG 5 Reagent Blank	0223-176.18 -3A	-0.001	0.00	50	1 98	10.0	0.0245 ND
Matrix Spike	0223-176.1S -3A	5.030			% REC =	100.6%	
Duplicate	0223-176.2D -3A	0.028			% RPD =	N/A	

Sample ID	Test Sol'n µg/L	Dig'te Conc µg/L	FV ml	Dil'n Factor	Total Volume ml	Volume Dig'd ml	Total µg
FRACTION 3B							
ENG 4 Run 1	0223-176.1 -3B	-0.001	0.00	50	1 365	10.0	0.0912 ND
ENG 4 Run 2	0223-176.2 -3B	0.014	0.01	50	1 245	10.0	0.0612 ND
ENG 4 Run 3	0223-176.3 -3B	0.017	0.02	50	1 255	10.0	0.0637 ND
ENG 4 Run 4	0223-176.4 -3B	0.021	0.02	50	1 250	10.0	0.0625 ND
ENG 4 Run 5	0223-176.5 -3B	0.017	0.02	50	1 240	10.0	0.0600 ND
ENG 4 Run 6	0223-176.6 -3B	0.026	0.03	50	1 260	10.0	0.0650 ND
ENG 4 Run 7	0223-176.7 -3B	0.022	0.02	50	1 240	10.0	0.0600 ND
ENG 4 Field Blank	0223-176.8 -3B	0.021	0.02	50	1 240	10.0	0.0600 ND
ENG 4 Reagent Blank	0223-176.9 -3B	0.020	0.02	50	1 82	10.0	0.0205 ND
ENG 5 Run 1	0223-176.10 -3B	0.022	0.02	50	1 240	10.0	0.0600 ND
ENG 5 Run 2	0223-176.11 -3B	0.019	0.02	50	1 235	10.0	0.0587 ND
ENG 5 Run 3	0223-176.12 -3B	0.018	0.02	50	1 245	10.0	0.0612 ND
ENG 5 Run 4	0223-176.13 -3B	0.021	0.02	50	1 230	10.0	0.0575 ND
ENG 5 Run 5	0223-176.14 -3B	0.021	0.02	50	1 265	10.0	0.0662 ND
ENG 5 Run 6	0223-176.15 -3B	0.022	0.02	50	1 260	10.0	0.0650 ND
ENG 5 Run 7	0223-176.16 -3B	0.020	0.02	50	1 255	10.0	0.0637 ND
ENG 5 Field Blank	0223-176.17 -3B	0.061	0.06	50	1 265	10.0	0.0808 J
ENG 5 Reagent Blank	0223-176.18 -3B	0.022	0.02	50	1 82	10.0	0.0205 ND
Matrix Spike	0223-176.1S -3B	5.290			% REC =	105.8%	
Duplicate	0223-176.2D -3B	0.017			% RPD =	N/A	

METHOD 29 MERCURY - CVAA Worksheet

Client: MAQS - Santa Ana

MDL = 0.050 µg/L

EA Project #: 0223-176

RL = 0.10 µg/L

Analysis Date: 2/27/23, 2/28/23, 3/1/23, 3/6/23, 3/7/23

Matrix spike conc. = 5.0 µg/L

Sample ID	Test Sol'n µg/L	Dig'te Conc µg/L	FV ml	Dil'n Factor	Total Volume ml	Volume Dig'd ml	Total µg
FRACTION 3C							
ENG 4 Run 1	0223-176.1 -3C	0.288	0.29	50	1 275	10.0	0.3960
ENG 4 Run 2	0223-176.2 -3C	0.153	0.15	50	1 285	10.0	0.2180
ENG 4 Run 3	0223-176.3 -3C	0.471	0.47	50	1 285	10.0	0.6712
ENG 4 Run 4	0223-176.4 -3C	0.134	0.13	50	1 285	10.0	0.1910
ENG 4 Run 5	0223-176.5 -3C	0.072	0.07	50	1 300	10.0	0.1080 J
ENG 4 Run 6	0223-176.6 -3C	0.115	0.12	50	1 310	10.0	0.1783
ENG 4 Run 7	0223-176.7 -3C	0.058	0.06	50	1 285	10.0	0.0827 J
ENG 4 Field Blank	0223-176.8 -3C	0.301	0.30	50	1 285	10.0	0.4289
ENG 4 Reagent Blank	0223-176.9 -3C	0.020	0.02	50	1 260	10.0	0.0650 ND
ENG 5 Run 1	0223-176.10 -3C	0.067	0.07	50	1 290	10.0	0.0972 J
ENG 5 Run 2	0223-176.11 -3C	0.083	0.08	50	1 275	10.0	0.1141 J
ENG 5 Run 3	0223-176.12 -3C	0.072	0.07	50	1 290	10.0	0.1044 J
ENG 5 Run 4	0223-176.13 -3C	0.075	0.08	50	1 285	10.0	0.1069 J
ENG 5 Run 5	0223-176.14 -3C	0.070	0.07	50	1 295	10.0	0.1033 J
ENG 5 Run 6	0223-176.15 -3C	0.085	0.09	50	1 280	10.0	0.1190 J
ENG 5 Run 7	0223-176.16 -3C	0.072	0.07	50	1 285	10.0	0.1026 J
ENG 5 Field Blank	0223-176.17 -3C	0.733	0.73	50	1 285	10.0	1.0445
ENG 5 Reagent Blank	0223-176.18 -3C	0.018	0.02	50	1 270	10.0	0.0675 ND
Matrix Spike	0223-176.1S -3C	5.130			% REC =	96.8%	
Duplicate	0223-176.2D -3C	0.156			% RPD =	N/A	

Batch Quality Control

Lab Blank	0223-176.LB1	-0.002	0.00	50	1 50	20	0.00625 ND
Lab Control Sample	0223-176.LCS1	5.000			% REC =	100.0%	
Lab Blank	0223-176.LB2	0.000	0.00	50	1 50	20	0.00625 ND
Lab Control Sample	0223-176.LCS2	5.140			% REC =	102.8%	
Lab Blank	0223-176.LB3	0.000	0.00	50	1 50	20	0.00625 ND
Lab Control Sample	0223-176.LCS3	5.070			% REC =	101.4%	
Lab Blank	0223-176.LB4	0.009	0.009	50	1 50	20	0.00625 ND
Lab Control Sample	0223-176.LCS4	5.080			% REC =	101.6%	
Lab Blank	0223-176.LB5	0.001	0.00	50	1 50	20	0.00625 ND
Lab Control Sample	0223-176.LCS5	4.970			% REC =	99.4%	

Narrative Summary



EA Job# 0223-176R Page 33 of 186

W002AS-023392-RT-4542

238 of 688

Enthalpy Analytical Narrative Summary

Company Job No. Client ID.	Montrose Air Quality Services, LLC – Santa Ana 0223-176R EPA Method 29 023392 Site: DTE Energy – Sunshine – SGT Eng 4 and 5 Exhaust
Custody	<p>Conor Benson received the samples on 2/20/23 after being relinquished by Montrose Air Quality Services, LLC – Santa Ana. He then delivered the samples to Enthalpy's Durham Laboratory on 2/24/23. Alyssa Miller logged the samples in on 2/24/23 at 20.5 °C in good condition.</p> <p>Prior to, during, and after analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, LLC.</p>
Analysis	<p>The samples were prepared and analyzed for antimony, arsenic, beryllium, cadmium, chromium, cobalt, lead, manganese, nickel, selenium, and mercury using the procedures in EPA Method 29, Determination of Metals Emissions from Stationary Sources.</p> <p>The Inductively Coupled Plasma Mass Spectrometer "X" and the Cold Vapor Atomic Absorption Spectrometer "Walt Jr." were used for these analyses.</p>
Calibration	The calibration curves met all method-specified precision criteria.
QC Notes	<p>The elements were not identified at concentrations greater than the reporting limit in the analyses of the laboratory blanks.</p> <p>The Laboratory Control Spikes were within the acceptance limits of 80% to 120%.</p> <p>The Matrix Spike recovery values were within the acceptance range of 75% to 125%.</p> <p>The required duplicate samples had a relative percent difference of 20% or less or were less than five times the limit of quantitation.</p> <p>All of the samples were analyzed at least in duplicate.</p>
Reporting Notes	<p>The revision is due to client request that front half and back half fractions are analyzed and reported separately.</p> <p>Inadvertently, samples Eng 5 Field Blank – 2A and Eng 5 Reagent Blank – Composite were combined during digestion.</p> <p>These analyses met the requirements of the TNI Standard. Any deviations from the requirements of the reference method or TNI Standard have been stated above.</p> <p>The results presented in this report are representative of the sample as provided to the laboratory.</p>

General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, LLC data reports, unless specifically noted otherwise.

- Any analysis which refers to the method as “**Type**” represents a planned deviation from the reference method. For instance a Hydrogen Sulfide assay from a Tedlar bag would be labeled as “EPA Method 16-Type” because Tedlar bags are not mentioned as one of the collection options in EPA Method 16.
- The acronym **MDL** represents the Minimum Detection Limit. Below this value the laboratory cannot determine the presence of the analyte of interest reliably.
- The acronym **LOQ** represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The acronym **ND** following a value indicates a non-detect or analytical result below the MDL.
- The letter **J** in the Qualifier or Flag column in the results indicates that the value is between the MDL and the LOQ. The laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The letter **E** in the Qualifier or Flag column indicates an analytical result exceeding 100% of the highest calibration point. The associated value should be considered as an estimate.
- Sample results are presented ‘as measured’ for single injection methodologies, or an average value if multiple injections are made. If all injections are below the MDL, the sample is considered non-detect and the ND value is presented. If one, but not all, are below the MDL, the MDL value is used for any injections that are below the MDL. For example, if the MDL is 0.500 and LOQ is 1.00, and the instrument measures 0.355, 0.620, and 0.442 - the result reported is the average of 0.500, 0.620, and 0.500 - - - i.e. 0.540 with a J flag.
- When a spike recovery (Bag Spike, Collocated Spike Train, or liquid matrix spike) is being calculated, the native (unspiked) sample result is used in the calculations, as long as the value is above the MDL. If a sample is ND, then 0 is used as the native amount (not the MDL value).
- The acronym **DF** represents Dilution Factor. This number represents dilution of the sample during the preparation and/or analysis process. The analytical result taken from a laboratory instrument is multiplied by the DF to determine the final undiluted sample results.
- The addition of **MS** to the Sample ID represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. The MS analysis indicates what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix interferes with the analysis of the analyte(s).



General Reporting Notes

(continued)

- The addition of **MSD** to the Sample ID represents a Matrix Spike Duplicate. Prepared in the same manner as a MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times.
- The addition of **LD** to the Sample ID represents a Laboratory Duplicate. The analyst prepares an additional aliquot of sample for testing and the results of the duplicate analysis are compared to the initial result. The result should have a difference value of within 10% of the initial result (if the results of the original analysis are greater than the LOQ).
- The addition of **AD** to the Sample ID represents an Alternate Dilution. The analyst prepares an additional aliquot at a different dilution factor (usually double the initial factor). This analysis helps confirm that no additional compound is present and coeluting or sharing absorbance with the analyte of interest, as they would have a different response/absorbance than the analyte of interest.
- The Sample ID **LCS** represents a Laboratory Control Sample. Clean matrix, similar to the client sample matrix, prepared and analyzed by the laboratory using the same reagents, spiking standards and procedures used for the client samples. The LCS is used to assess the control of the laboratory's analytical system. Whenever spikes are prepared for our client projects, two spikes are retained as LCSs. The LCSs are labeled with the associated project number and kept in-house at the appropriate temperature conditions. When the project samples are received for analysis, the LCSs are analyzed to confirm that the analyte could be recovered from the media, separate from the samples which were used on the project and which may have been affected by source matrix, sample collection, and/or sample transport.
- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed, the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits displayed, but no confidence should be placed on more than two significant digits. In the case of small numbers, generally 3 significant figures are presented, but still only 2 should be used with confidence. Many neat materials are only certified to 3 digits, and as the mathematically correct final result is always 1 digit less than all its pre-cursors - 2 significant figures are what are most defensible.
- **Manual Integration:** The data systems used for processing will flag manually integrated peaks with an "M". There are several reasons a peak may be manually integrated. These reasons will be identified by the following two letter designations on sample chromatograms, if provided in the report. The peak was *not integrated* by the software "NI", the peak was *integrated incorrectly* by the software "II" or the *wrong peak* was integrated by the software "WP". These codes will accompany the analyst's manual integration stamp placed next to the compound name on the chromatogram.



Sample Custody



EA Job# 0223-176R Page 37 of 186

W002AS-023392-RT-4542

242 of 688

CHAIN OF CUSTODY

CLIENT:	DTE Energy	PROJ #:	023392	TEST DATE(S):	<u>2/7/2023 - 2/10/2023</u>
LOCATION:	Sunshine	SAMPLER(S):	<u>DH/AD/PSJ</u>		
SAMPLE LOCATION:	SGT Eng 4 Exhaust	PROJECT MANAGER:	<u>PSJ</u>		
TEST METHOD(S):	EPA 29	DATE DUE:	<u>ASAP</u>		
OUTSIDE LAB REQUIRED?	<u>Yes</u>	COMPLIANCE TEST?	<u>Yes</u>		

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
2/7/2023	10:50	1	Eng 4 Run1	6	DH,AD,PSJ	
2/8/2023	8:10	2	Eng 4 Run2	6	DH,AD,PSJ	
2/8/2023	13:05	3	Eng 4 Run3	6	DH,AD,PSJ	
2/9/2023	8:05	4	Eng 4 Run4	6	DH,AD,PSJ	
2/9/2023	12:40	5	Eng 4 Run5	6	DH,AD,PSJ	
2/10/2023	7:50	6	Eng 4 Run6	6	DH,AD,PSJ	
2/10/2023	12:15	7	Eng 4 Run7	6	DH,AD,PSJ	
2/10/2023		FB / RB	Eng 4 Field Blank	12	DH,AD,PSJ	
			<u>Ammonium 3 02-24-23</u>			

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
<u>D. H. Moon</u>	<u>2/2/23</u>	<u>2/4/23 13:45</u>	<u>2/10/23 11:00</u>
<u>W.H. H.</u>	<u>2/4/23</u>	<u>Alayna Monroe</u>	<u>02-24-23 13:45</u>

ANALYSIS REQUIRED: EPA 29 Metals include: Antimony (Sb), Arsenic (As), Beryllium (Be), Cadmium (Cd), Chromium (Cr), Cobalt (Co), Lead (Pb), Manganese (Mn), Mercury (Hg), Nickel (Ni), and Selenium (Se).

 AIA MOON PROPS	Date of Last Revision	9/1/2017	Chain of Custody - DS834001 - Excel Master Document Storage\Forms\Datasheets\Lab Forms
80.5°C	Revolv 2	good condition	mm 3 02-24-23

~~Each RB not tested~~ ~~mm 3 02-24-23~~ ~~mm 3 02-24-23~~ ~~mm 3 02-24-23~~

CHAIN OF CUSTODY

CLIENT:	DTE Energy	PROJ #:	023392	TEST DATE(S):	2/14/2023 - 2/17/2023
LOCATION:	Sunshine	SAMPLER(S):	DH/AD/PSJ		
SAMPLE LOCATION:	SGT Eng 5 Exhaust	PROJECT MANAGER:	PSJ		
TEST METHOD(S):	EPA 29	DATE DUE:	ASAP		
OUTSIDE LAB REQUIRED?	Yes	COMPLIANCE TEST?	Yes		

DATE	TIME	TEST #	SAMPLE DESCRIPTION	CONTAINERS	SAMPLER	COMMENTS
2/14/2023	8:00	1	Eng 5 Run1	6	DH,AD,PSJ	
2/15/2023	12:20	2	Eng 5 Run2	6	DH,AD,PSJ	
2/15/2023	7:35	3	Eng 5 Run3	6	DH,AD,PSJ	
2/16/2023	12:00	4	Eng 5 Run4	6	DH,AD,PSJ	
2/16/2023	7:35	5	Eng 5 Run5	6	DH,AD,PSJ	
2/17/2023	12:00	6	Eng 5 Run6	6	DH,AD,PSJ	
2/17/2023	7:30	7	Eng 5 Run7	6	DH,AD,PSJ	
2/17/2023	FB / 108		Eng 5 Field Blank	12	DH,AD,PSJ	
			Battm3 02-24-23			

RELEASED BY	DATE/TIME	RECEIVED BY	DATE/TIME
<i>D. J. Miller</i>	2/20/23 2/19/23 13:46	<i>Alynn Marcella</i>	2/20/23 02/24/23 1345

ANALYSIS REQUIRED: EPA 29 Metals include: Antimony (Sb), Arsenic (As), Beryllium (Be), Cadmium (Cd), Chromium (Cr), Cobalt (Co), Lead (Pb), Manganese (Mn), Mercury (Hg), Nickel (Ni), and Selenium (Se).

MR. J. ROSSI Date of Last Revision 9/1/2017
20.5°C Battm2, good condition 02-24-23

Chain of Custody - DS834001 - Excel
Master Document Storage\Forms\Datasheets\Lab Forms

Raw Data



EA Job# 0223-176R Page 40 of 186

W002AS-023392-RT-4542

245 of 688

Analyst: EWC

Date: 2/27/23

Job #s

0223-176

Describe Work Documented on This Page

m29 ^① prep

Supplies, Ancillary Equipment
Serial #s, Lot #s, Etc

NA

1381 A = M29 Volumes Worksheet

1381 B = M29 Volumes Worksheet


1381 C = M29 PH Prep Sheet

1381 D = M29 BH Prep Sheet

① EEC LMP
2/27/23

② Combined 0223-176.17-2
with 0223-176.18-2 on accident
accident while working down
EWC 2-28-23 added after 2-out

③ EEC EWC
2-28-23



Reviewer's Initials & Date:

Metals Prep
EA Job# 0223-176 Page 41 of 186

W002AS-023392-RT-4542

246 of 688



ENTHALPY
ANALYTICAL

13461 B

LINNAN

W002AS-023392-RT-4542

Method 29 Volumes Worksheet

Client: MAQS - Santa Ana	8N HCl ID:	E5-0845	8N HCl Exp:	8/24/23	2B Digitube ID	J555-S474-7898
EA Project #: 02223-1716	8N HCl Pipette ID:	753474-7898	Pipette Exp:	NA	0.50L/1.0L Bottle ID	L-1-008-05BB
Analyst: EAN/Lmp	Custody Seal is Intact?	(Yes) No	Comments:			
Date: 1/17/23 4:38:23	Leak Check Levels Ok?	(Yes) No	Comments:			
02AS-02339						

3/1/23, 3/4/23

Method 29 Fraction Volumes (mL):

Sample ID	Container	Container	Container	Container	Container	Container	Cont. 3	Amount HNO ₃ Added (mL)	Cont. 4	Amount HNO ₃ Added (mL)
	3	4	2B	3A	3B	3C	pH Initial / Final		Initial / Final	
02123-176.13	95	443	25	99	230	285	212	2	2	2
	.14	97	447	25	100	265	295	<2	<2	<2
	.15	99	443	25	98	260	280	<2	<2	<2
	.16	94	437	25	96	255	285	<2	<2	<2
	.17	91	290	25	97	265	285	<2	<2	<2
	.18	291	solution	25	98	82	270	<2	<2	<2

When possible: the FH Blank should consist of 100 mL of Container 3. The BH Blank should consist of 100 mL of Container 3 + 200 mL of Container 4. If not enough solution provided treat as field sample by digesting entire containers w/o combining.

Reagent & Field
Blank Composites

Container 3		Container 4		Container 5	
Date	Sample ID	Total	Digested	Total	Digested
02/23 - 176.14	191	100	100	300	25
				-	-

If pH is >2

HNO ₃ ID:	HNO ₃ Exp:
HNO ₃ Pip:	HNO ₃ Pip Exp:

Comments:
①EE ENC 2/27/23



1381C

METHOD 29 METALS PREP SHEET
FRONT HALF SAMPLES

DAY 1	Date: 2/27/23	Analyst(s): LMP	DAY 3	Date: 3/2/23	Analyst(s): ENC
DAY 2	Date: 3/1/23	Analyst(s): ENC	DAY 4	Date:	Analyst(s):
Ves. #	Reagents	ID#:	Expiration Date:	Sample ID	Final Volume (mL)
1	HNO ₃ : 6 mL	22400034	10/24	0223-176.1	.1 -1 100
2	HF: 4 mL	SCA2349093	11/25		.2 -1
3	Support Equipment				.3 -1
4		ID#:	Expiration Date:		.4 -1
5	Ag vessels used?	YES / NOT NEEDED			.5 -1
6	Cleaning Cycle Completed?	YES / NO			.6 -1
7	Micro. #	6,7	N/A		.7 -1
8					.8 -1
9	Hotplate #	8	N/A		.9 -1
10					.10 -1
11	HF Pipette	130	3/3/23		.11 -1
12					.12 -1
13	HNO ₃ Pipette	1	1		.13 -1
14					.14 -1
15	Digitube	J553474-7898	N/A		.15 -1
16					.16 -1
17	Comments:				.17 -1
18					.18 -1
					-1
					-1
					-1

Front Half Quality Control

Ves. #	QC	ID:	Expiraton:	Stock Conc. (ppm)	Prepped Conc. (ppb)	Amount Added (mL)	Pip ID:	Pip Exp:
9	Lab Blank-1	--	--	--	--	--	--	--
10	LCS-1	F0814	11/23	10	100	1.0	124	3/4/23

List additional LCS's below as needed. For example: Ag, LCS-High



13810

METHOD 29 METALS PREP SHEET

BACK HALF SAMPLES

DAY 1	Date: 2/27/23	Analyst(s): LMP	DAY 3	Date:	Analyst(s):
DAY 2	Date: 3/2/23	Analyst(s): ENL	DAY 4	Date:	Analyst(s):
Reagents					
1:1 HNO3: 30mL	ES-0832	8/10/23	0223-176.1	-2A	100
H2O2: 1mL	61326206	11/30/23		.2	-2A
				.3	-2A
				.4	-2A
Support Equipment					
Hotplate #	10	N/A		.5	-2A
				.6	-2A
1:1 HNO3 Pipette	J553474 -7898	NA		.7	-2A
				.8	-2A
H2O2 Pipette	130	3/3/23		.9	-2A
				.10	-2A
Hg Aliquot Removed (mL) (-2B)	25.50			.11	-2A
				.12	-2A
Digitube	J553474-7898	N/A		.13	-2A
				.14	-2A
Comments:				.15	-2A
				.16	-2A
				.17	-2A
				.18	-2A
					-2A
					2A

Back Half Quality Control

QC	ID:	Expiration:	Stock Conc. (ppm)	Prepped Conc. (ppb)	Amount Added (mL)	Pip ID:	Pip Exp:
Lab Blank-2A	--	--	--	--	--	--	--
LCS-2A	F0814	11/23	10	100	1.0	124	3/4/23

List additional LCS's below as needed. For example: Ag, LCS-High

ICP-MS Raw Data Coversheet

Doc. No.: RD05

Rev.:G

Effective Date: 08-05-22

Instrument X

Analyst(s):	MAL	Analysis Date(s):	3/29/23
EA Project #s:	0223-176		
Analytes:	$\text{Ba}, \text{Cr}, \text{Mn}, \text{Co}, \text{Ni}, \text{As}, \text{Se}, \text{Cd}, \text{Sb}, \text{Pb}$		
Method:	6020	Smart Tune ID: ES-0804 Internal Standard ID ¹ : F0842	Conc: 1ppb Conc: 10ppm Exp: 7/3/23 Exp: 3/3/24
Diluent:	50 mL HNO ₃ (ID # 62327)	Exp: 11/24	diluted to 1000 mL with DI
Calib. Blk/ICB/CCB:	Diluent		

¹ All samples and standards are spiked with 50 μL of internal std. (pipette 127 exp 6/6/23)

Calibration Standards - Made from EA ID#²: 1/10 F0824 (Stock Concentration: 10ppm)

Exp Date: 3/30/23) and brought up with Diluent

	Final Conc. (ppb)	Amount (μL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
Standard 1	1	100 of Std 6	127 6/6/23					
Standard 2	5	500 of Std 6	124					
Standard 3	10	1000 of Std 6	1					
Standard 4	50	50	127					
Standard 5	100	100	1					
No IS Std 6	100	100	1					

² 10ppm WS = 1mL of Standard F0824 exp 1/25 (pipettes: 124, 143 exp 5/9/23) + 9mL Diluent

Secondary Standards - Made from EA ID#: F0814 (Stock Concentration: 10ppm)

Exp Date: 11/23) and brought up with Diluent

	Final Conc. (ppb)	Amount (μL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
ICV/CCV	50	50	127 6/6/23	10	143 5/9/23	MAL	3/29/23	3/30/23

ICS's- Made from Stock Std ICS-A ID#(F0786 Exp: 1/23)

& 50 ppb Metals Std ID#(F0814 Conc: 10ppm Exp: 11/23) brought up with Diluent

	Conc.	Amount WS (μL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
ICS-A	Multi	100	127 6/6/23					
ICS-AB	Multi	100	1					
	50 ppb	50	1					

Post Dig Matrix Spike Samples - Diluted with Diluent (Metals Mix ID# F0814 Conc: 10ppm Exp: 11/23)

Sample ID	Dilution Factor of Field Sample	Aliquot of Sample (mL)	Final Conc. (ppb)	Amount of Spike Added (μL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst
0223-176.1-1A	5x	2	50	50	127 6/6/23	10	143 5/9/23	MAL
0223-176.1-2A	—	9.90	50	50	1	10	1	MAL
						10		
						10		
						10		
						10		
						10		

ICP-MS Raw Data Coversheet

Doc. No.: RD05

Rev.:G

Effective Date: 08-05-22

Sample Dilution Tracker - Diluted with Diluent

Comments:

All analytical sequences use the same calibration standards & ICSA/B. The check Standards (W/ICB) were prepared for each set of analyses.


202 3/29/23

Calibration for 001CALB.d

Batch Folder: D:\Agilent\ICPMH\1\DATA\2023\0223-176 032923 low mass FH.b\
Analysis File: 0223-176 032923 low mass FH.batch.bin
DA Date-Time: 3/29/2023 10:04:08 AM
Calibration Title:
Calibration Method: External Calibration
VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	001CALB.d	Cal Blank	3/29/2023 9:46:26 AM
2	002CALS.d	1 ppb	3/29/2023 9:50:05 AM
3	003CALS.d	5 ppb	3/29/2023 9:53:32 AM
4	004CALS.d	10 ppb	3/29/2023 9:57:02 AM
5	005CALS.d	50 ppb	3/29/2023 10:00:30 AM
6	006CALS.d	100 ppb	3/29/2023 10:04:00 AM

Calibration for 001CALB.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	0.000	0.000	20.02	0.0000	P	87.8
2	1.000	1.059	10577.89	0.0050	P	5.6
3	5.000	5.301	53769.85	0.0252	P	0.6
4	10.000	9.951	107581.36	0.0473	P	3.5
5	50.000	50.360	530841.33	0.2396	P	3.1
6	100.000	99.809	1057329.23	0.4748	A	3.5

$$y = 0.0048 * x + 8.7471E-006$$


R = 1.0000

DL = 0.004843

BEC = 0.001839

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	0.000	0.000	12828.74	0.0149	P	3.6
2			78308.31	0.0967	P	4.5
3	5.000	5.028	346960.26	0.4235	P	4.2
4	10.000	9.864	674088.03	0.8165	P	1.2
5	50.000	48.903	3263859.76	3.9890	A	3.4
6	100.000	100.561	6839379.50	8.1869	A	2.2

$$y = 0.0813 * x + 0.0149$$

R = 0.9999


DL = 0.01974

BEC = 0.1832

Weight: <None>

Min Conc: 0

Calibration for 001CALB.d



	Rjct	Canc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	14131.37	0.0164	P	5.3
2	<input type="checkbox"/>			105196.65	0.1298	P	3.8
3	<input type="checkbox"/>	5.000	5.154	474232.48	0.5787	P	2.0
4	<input type="checkbox"/>	10.000	10.041	917971.57	1.1119	A	2.0
5	<input type="checkbox"/>	50.000	49.303	4416107.88	5.3954	A	2.5
6	<input type="checkbox"/>	100.000	100.337	9159364.14	10.9634	A	0.8

$$y = 0.1091 * x + 0.0164$$


R = 1.0000

DL = 0.02398

BEC = 0.1503

Weight: <None>

Min Conc: 0



	Rjct	Canc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	3030.08	0.0035	P	12.2
2	<input type="checkbox"/>	1.000	1.023	77903.66	0.0961	P	3.0
3	<input type="checkbox"/>	5.000	5.105	381434.04	0.4655	P	2.8
4	<input type="checkbox"/>	10.000	9.895	742176.45	0.8990	P	2.4
5	<input type="checkbox"/>	50.000	49.493	3668493.00	4.4823	A	2.3
6	<input type="checkbox"/>	100.000	100.259	7583424.46	9.0764	A	1.9

$$y = 0.0905 * x + 0.0035$$

R = 1.0000


DL = 0.01423

BEC = 0.03884

Weight: <None>

Min Conc: 0

Calibration for 001CALB.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	887.60	0.0010	P	3.5
2	<input type="checkbox"/>			16663.35	0.0205	P	1.7
3	<input type="checkbox"/>	5.000	4.882	81232.17	0.0991	P	1.4
4	<input type="checkbox"/>	10.000	9.762	162789.84	0.1972	P	2.0
5	<input type="checkbox"/>	50.000	48.877	804650.78	0.9832	M	1.9
6	<input type="checkbox"/>	100.000	100.591	1689656.88	2.0224	A	2.2

$$y = 0.0201 * x + 0.0010$$


R = 0.9999

DL = 0.005317

BEC = 0.05125

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	914.29	0.0011	P	8.6
2	<input type="checkbox"/>			2993.34	0.0037	P	9.7
3	<input type="checkbox"/>	5.000	4.968	12581.67	0.0153	P	1.6
4	<input type="checkbox"/>	10.000	10.051	24740.03	0.0300	P	1.9
5	<input type="checkbox"/>	50.000	49.975	118497.64	0.1448	P	1.0
6	<input type="checkbox"/>	100.000	100.009	241164.40	0.2887	P	2.5

$$y = 0.0029 * x + 0.0011$$

R = 1.0000


DL = 0.09524

BEC = 0.3691

Weight: <None>

Min Conc: 0

Calibration for 001CALB.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD	
1	<input type="checkbox"/>	0.000	0.000	110.11	0.0001	P	8.3
2	<input type="checkbox"/>			8654.78	0.0107	P	2.3
3	<input type="checkbox"/>	5.000	5.181	43498.41	0.0531	P	2.4
4	<input type="checkbox"/>	10.000	10.452	88287.43	0.1070	P	2.7
5	<input type="checkbox"/>	50.000	50.910	425932.78	0.5204	P	0.6
6	<input type="checkbox"/>	100.000	99.491	849624.99	1.0169	A	0.4

$$y = 0.0102 * x + 1.2773E-004$$


R = 0.9999

DL = 0.003107

BEC = 0.0125

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD	
1	<input type="checkbox"/>	0.000	0.000	133.47	0.0002	P	35.8
2	<input type="checkbox"/>			613.97	0.0008	P	21.5
3	<input type="checkbox"/>	5.000	5.561	2779.75	0.0034	P	2.5
4	<input type="checkbox"/>	10.000	11.418	5613.46	0.0068	P	2.3
5	<input type="checkbox"/>	50.000	51.047	24439.52	0.0299	P	0.3
6	<input type="checkbox"/>	100.000	99.307	48409.57	0.0579	P	0.4

$$y = 5.8191E-004 * x + 1.5515E-004$$

R = 0.9999


DL = 0.2867

BEC = 0.2666

Weight: <None>

Min Conc: 0

Calibration for 001CALB.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD	
1	<input type="checkbox"/>	0.000	0.000	13530.27	0.0157	P	3.3
2	<input type="checkbox"/>			14198.20	0.0175	P	1.5
3	<input type="checkbox"/>	5.000	4.889	20168.27	0.0246	P	2.5
4	<input type="checkbox"/>	10.000	10.213	28330.71	0.0343	P	2.6
5	<input type="checkbox"/>	50.000	50.481	88147.65	0.1077	P	2.5
6	<input type="checkbox"/>	100.000	99.744	165026.81	0.1975	P	2.4

$$y = 0.0018 * x + 0.0157$$


R = 1.0000

DL = 0.8442

BEC = 8.614

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD	
1	<input type="checkbox"/>	0.000	0.000	2.00	0.0000	P	2765.2
2	<input type="checkbox"/>			572.42	0.0008	P	3.9
3	<input type="checkbox"/>	5.000	5.302	3251.75	0.0040	P	6.5
4	<input type="checkbox"/>	10.000	9.893	5109.25	0.0074	P	3.6
5	<input type="checkbox"/>	50.000	50.113	30680.21	0.0375	P	0.8
6	<input type="checkbox"/>	100.000	99.939	62438.89	0.0747	P	3.1

$$y = 7.4793E-004 * x + 1.9025E-006$$

R = 1.0000


DL = 0.211

BEC = 0.002544


Weight: <None>

Min Conc: 0

Calibration for 001CALB.d


83 Kr [tune 1] No available calibration points

	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>			170.17		P	15.6
2	<input type="checkbox"/>			206.87		P	15.6
3	<input type="checkbox"/>			253.59		P	14.9
4	<input type="checkbox"/>			216.89		P	44.8
5	<input type="checkbox"/>			246.92		P	11.7
6	<input type="checkbox"/>			230.23		P	13.0


6 Li (ISTD) [tune 1]

	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		174977.22		P	2.1
2	<input type="checkbox"/>	1.000		164410.22		P	4.1
3	<input type="checkbox"/>	1.000		161264.40		P	0.6
4	<input type="checkbox"/>	1.000		162946.03		P	1.2
5	<input type="checkbox"/>	1.000		162720.39		P	2.0
6	<input type="checkbox"/>	1.000		166373.91		P	2.7

Calibration for 001CALB.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		2306091.71		A	3.4
2	<input type="checkbox"/>	1.000		2100528.76		A	6.8
3	<input type="checkbox"/>	1.000		2131555.81		A	0.1
4	<input type="checkbox"/>	1.000		2272818.73		A	0.9
5	<input type="checkbox"/>	1.000		2217929.44		A	4.3
6	<input type="checkbox"/>	1.000		2228834.15		A	3.8




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		861689.42		A	1.3
2	<input type="checkbox"/>	1.000		810853.99		M	2.9
3	<input type="checkbox"/>	1.000		819577.71		M	1.5
4	<input type="checkbox"/>	1.000		825554.74		A	0.5
5	<input type="checkbox"/>	1.000		818472.24		A	1.4
6	<input type="checkbox"/>	1.000		835495.52		A	1.1

Calibration for 001CALB.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		3741039.45		A	4.5
2	<input type="checkbox"/>	1.000		3410778.81		A	0.8
3	<input type="checkbox"/>	1.000		3444462.44		A	2.3
4	<input type="checkbox"/>	1.000		3418290.10		A	2.3
5	<input type="checkbox"/>	1.000		3389024.82		A	0.7
6	<input type="checkbox"/>	1.000		3452337.53		A	1.5



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		6534218.68		A	3.0
2	<input type="checkbox"/>	1.000		5989892.34		A	0.5
3	<input type="checkbox"/>	1.000		5987125.51		A	3.1
4	<input type="checkbox"/>	1.000		6233525.91		A	1.6
5	<input type="checkbox"/>	1.000		6039855.53		A	0.4
6	<input type="checkbox"/>	1.000		6120029.71		A	1.4

Acq. Date/Time	Sample Name	9 Be [tune 1]			52 Cr [tune 1]			55 Mn [tune 1]			59 Co [tune 1]			60 Ni [t]		
		Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	
3/29/2023 9:46	Cal Blank	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	
3/29/2023 9:50	1 ppb	1.0594	5.5743	1.0062	5.3479	1.0395	4.3618	1.0233	3.1014	0.9714	0.9714	0.9714	0.9714	0.9714	0.9714	
3/29/2023 9:53	5 ppb	5.3014	0.6130	5.0284	4.3868	5.1543	2.0726	5.1055	2.8241	4.8816	4.8816	4.8816	4.8816	4.8816	4.8816	
3/29/2023 9:57	10 ppb	9.9513	3.4673	9.8644	1.2525	10.0412	1.9809	9.8952	2.3959	9.7618	9.7618	9.7618	9.7618	9.7618	9.7618	
3/29/2023 10:00	50 ppb	50.3605	3.0830	48.9031	3.3954	49.3027	2.5064	49.4928	2.3291	48.8773	48.8773	48.8773	48.8773	48.8773	48.8773	
3/29/2023 10:04	100 ppb	99.8090	3.5209	100.5606	2.2170	100.3368	0.7839	100.2586	1.8779	100.5911	100.5911	100.5911	100.5911	100.5911	100.5911	
3/29/2023 10:07	ICV	53.6463	3.1809	52.7313	2.5076	53.3127	1.9661	52.3051	1.3539	50.5722	50.5722	50.5722	50.5722	50.5722	50.5722	
3/29/2023 10:10	ICB	0.4197	10.6015	0.3853	15.4098	0.3961	14.9517	0.3781	14.1539	0.3506	0.3506	0.3506	0.3506	0.3506	0.3506	
3/29/2023 10:14	ICSA	0.1110	9.0758	0.2499	2.5248	0.1309	2.1620	0.1053	1.8818	0.2379	0.2379	0.2379	0.2379	0.2379	0.2379	
3/29/2023 10:17	ICSAB	50.6537	2.4646	46.7078	1.3950	46.9004	2.5684	47.2657	2.7797	45.5868	45.5868	45.5868	45.5868	45.5868	45.5868	
3/29/2023 10:21	0223-1761LB-1A	0.2018	18.2435	0.3599	6.6441	0.3185	10.4720	0.1877	12.6470	0.4191	0.4191	0.4191	0.4191	0.4191	0.4191	
3/29/2023 10:24	0223-176LCS-1A2X	49.0859	0.9463	48.3614	2.6115	50.0811	1.7310	48.0322	2.1662	47.2289	47.2289	47.2289	47.2289	47.2289	47.2289	
3/29/2023 10:28	0223-176-1-1A-5X	0.2320	2.1730	9.0517	1.1560	2.0610	1.0244	0.2833	7.2542	4.3100	4.3100	4.3100	4.3100	4.3100	4.3100	
3/29/2023 10:31	0223-1761-1-1A-MS-5X	47.9742	4.2174	54.4513	3.9408	49.3441	3.3053	45.3331	4.2916	47.6816	47.6816	47.6816	47.6816	47.6816	47.6816	
3/29/2023 10:34	0223-176-2-1A-5X	0.3272	19.1462	12.6045	3.0805	1.9473	1.1262	0.4026	7.3209	3.6927	3.6927	3.6927	3.6927	3.6927	3.6927	
3/29/2023 10:38	0223-176-2-1A-DUP-5X	0.0907	11.9596	12.4789	1.1475	1.7263	2.5844	0.2058	2.0063	3.6083	3.6083	3.6083	3.6083	3.6083	3.6083	
3/29/2023 10:41	0223-176-3-1A-5X	0.0331	23.0387	9.0569	1.9797	1.4805	0.6471	2.2785	2.0407	2.7375	2.7375	2.7375	2.7375	2.7375	2.7375	
3/29/2023 10:45	0223-176-4-1A-5X	0.0178	12.3094	12.1926	1.1426	1.5487	1.3985	0.1553	4.2993	3.9059	3.9059	3.9059	3.9059	3.9059	3.9059	
3/29/2023 10:48	0223-176-5-1A-5X	0.0060	15.1201	12.5635	3.8221	1.4467	2.0894	0.0729	5.0237	2.9794	2.9794	2.9794	2.9794	2.9794	2.9794	
3/29/2023 10:52	0223-176-6-1A-5X	0.0082	2.0146	8.4929	1.5803	2.8933	2.7468	0.0134	29.5328	2.4906	2.4906	2.4906	2.4906	2.4906	2.4906	
3/29/2023 10:55	ICV	47.6095	2.0487	46.3115	3.8995	48.4339	2.0544	47.8400	1.0945	46.1669	46.1669	46.1669	46.1669	46.1669	46.1669	
3/29/2023 10:58	ICB	0.2587	9.2197	0.2480	5.5937	0.2651	6.2669	0.2254	4.5559	0.2428	0.2428	0.2428	0.2428	0.2428	0.2428	
3/29/2023 11:02	0223-176-7-1A-5X	0.0816	6.1733	12.2019	2.0492	3.2129	1.4061	0.0763	4.6882	2.9468	2.9468	2.9468	2.9468	2.9468	2.9468	
3/29/2023 11:05	0223-176-8-1A-5X	0.0357	13.7807	2.5435	2.1695	1.0755	3.1543	0.0221	20.5863	2.5135	2.5135	2.5135	2.5135	2.5135	2.5135	
3/29/2023 11:09	0223-176-9-1A-5X	0.0224	2.4426	2.0940	2.7287	0.9173	3.0779	0.0029	93.6994	2.2503	2.2503	2.2503	2.2503	2.2503	2.2503	
3/29/2023 11:12	0223-176-10-1A-5X	0.0217	7.2777	9.1200	2.0803	1.2976	4.3154	0.0137	6.3784	2.8129	2.8129	2.8129	2.8129	2.8129	2.8129	
3/29/2023 11:16	0223-176-11-1A-5X	0.0150	26.4268	12.2373	3.6562	4.5611	2.8344	0.0118	40.4257	3.3150	3.3150	3.3150	3.3150	3.3150	3.3150	
3/29/2023 11:19	0223-176-12-1A-5X	0.0120	10.8180	9.1531	0.3226	1.3741	1.3817	0.0139	8.2541	2.8622	2.8622	2.8622	2.8622	2.8622	2.8622	
3/29/2023 11:22	0223-176-13-1A-5X	0.0115	46.9162	8.8341	3.4078	1.3916	4.8420	0.0094	52.0683	2.8009	2.8009	2.8009	2.8009	2.8009	2.8009	
3/29/2023 11:26	0223-176-14-1A-5X	0.0097	84.0568	9.0643	1.0391	1.3457	2.2476	0.0112	34.6670	3.8848	3.8848	3.8848	3.8848	3.8848	3.8848	
3/29/2023 11:29	0223-176-15-1A-5X	0.0074	38.1792	7.0739	0.7630	5.1706	2.5313	0.0342	3.2017	2.7492	2.7492	2.7492	2.7492	2.7492	2.7492	
3/29/2023 11:33	ICV	46.2799	2.2124	46.0595	1.0567	48.1214	0.7268	47.0891	1.7279	45.0927	45.0927	45.0927	45.0927	45.0927	45.0927	
3/29/2023 11:36	ICB	0.2799	10.3690	0.2501	15.5591	0.2589	10.8997	0.2129	11.0974	0.2219	0.2219	0.2219	0.2219	0.2219	0.2219	
3/29/2023 11:40	0223-176-16-1A-5X	0.1359	9.2919	9.1764	1.1660	2.4568	1.9490	0.0666	4.8021	2.4892	2.4892	2.4892	2.4892	2.4892	2.4892	
3/29/2023 11:43	0223-176-17-2A-5X	0.0591	13.6236	2.3087	1.4287	1.1192	1.1369	0.0164	30.7618	3.7616	3.7616	3.7616	3.7616	3.7616	3.7616	
3/29/2023 11:46	0223-176-18-1A-5X	0.0231	31.5780	2.0895	2.0099	0.9674	4.0311	0.0040	92.8650	2.2268	2.2268	2.2268	2.2268	2.2268	2.2268	
3/29/2023 11:50	ICV	46.3570	1.7188	46.6169	2.3579	48.8213	1.5651	48.4642	2.2743	45.1561	45.1561	45.1561	45.1561	45.1561	45.1561	
3/29/2023 11:53	ICB	0.2797	7.8056	0.2489	11.9078	0.2770	12.0394	0.2461	8.8606	0.2359	0.2359	0.2359	0.2359	0.2359	0.2359	

	Line 1]	62 Ni [tune 1]	75 As [tune 1]	77 Se [tune 1]	78 Se [tune 1]	82 Se [tune 1]
Sample Name	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]
Cal/Blank	N/A	0.0000	N/A	0.0000	N/A	0.0000
1 ppb	1.7747	0.9161	13.5416	1.0322	2.3643	1.0400
5 ppb	1.4281	4.9678	1.6721	5.1806	2.4521	5.5607
10 ppb	1.9737	10.0512	1.9874	10.4525	2.6667	11.4177
50 ppb	1.8869	49.9753	0.9708	50.9101	0.6255	51.0468
100 ppb	2.2498	100.0088	2.5396	99.4907	0.4323	99.3068
ICV	0.1628	52.2878	1.0044	51.5855	2.0539	51.8124
ICB	15.6495	0.3889	29.8791	0.3956	9.1493	0.4227
ICSA	0.8806	0.2723	15.0538	0.2395	5.2804	0.6315
ICSAB	1.4350	47.3997	0.5940	49.3297	0.7772	50.0153
0223-176.1B-1A	12.7457	0.4216	19.1836	0.3236	20.7204	0.2443
0223-176.LCS-1A 2X	2.5452	48.9058	0.5256	48.6827	1.9707	48.9860
0223-176.1-1A 5X	1.9074	4.3392	4.1200	0.5128	0.5647	0.3734
0223-176.1-1A MS 5X	2.3916	49.3751	1.7587	48.4526	1.6607	47.4002
0223-176.2-1A 5X	1.0456	3.8302	5.1848	0.5229	3.9480	0.3680
0223-176.2-1A DUP 5X	2.6949	3.5394	3.0138	0.3015	4.5538	0.1852
0223-176.3-1A 5X	3.7174	2.6831	2.9352	0.2811	1.0297	0.1445
0223-176.4-1A 5X	0.2162	3.7909	3.8048	0.1799	10.0024	0.0538
0223-176.5-1A 5X	2.2901	2.9881	3.2805	0.2549	5.0525	<0.000
0223-176.6-1A 5X	2.2820	2.5308	6.7246	0.1556	9.1273	<0.000
ICV	1.6213	47.2971	0.7468	49.2441	0.6006	50.3894
ICB	16.3630	0.1678	9.6207	0.2725	9.5487	0.1116
0223-176.7-1A 5X	1.3719	2.9658	0.9944	0.2394	7.1556	<0.000
0223-176.8-1A 5X	0.5972	2.5468	2.7849	0.0585	9.1792	<0.000
0223-176.9-1A 5X	1.9728	2.1878	6.8906	0.0480	18.1394	<0.000
0223-176.10-1A 5X	3.3272	2.8195	1.5761	0.1990	4.1047	<0.000
0223-176.11-1A 5X	2.1627	3.2932	3.2199	0.1985	7.9695	<0.000
0223-176.12-1A 5X	2.1202	2.9216	8.4778	0.1998	3.8032	<0.000
0223-176.13-1A 5X	3.3460	2.7598	5.4606	0.1649	7.2182	<0.000
0223-176.14-1A 5X	2.1815	3.9322	4.2457	0.1844	7.7505	<0.000
0223-176.15-1A 5X	2.3828	2.6371	5.5509	0.2120	3.9769	<0.000
ICV	0.7768	46.5811	1.2782	48.9261	0.5747	50.3910
ICB	12.6110	0.1464	39.0559	0.2653	9.9010	0.0852
0223-176.16-1A 5X	2.6844	2.6115	2.0045	0.2217	11.3707	<0.000
0223-176.17-2A 5X	1.1852	3.8814	3.5114	0.0633	5.8671	<0.000
0223-176.18-1A 5X	2.2622	2.2172	0.8427	0.0364	15.9340	<0.000
ICV	2.0661	47.3004	3.6657	48.5398	2.1551	50.3101
ICB	3.1261	0.1024	16.9342	0.3135	7.8281	0.1802

Sample 0223-176.17 was the 1A analysis not the 2A analysis. - MAL 4/3/23
EA Job# 0223-176R Page 58 of 186

	6 Li (ISTD) [tune 1]			7 Li (ISTD) [tune 1]			72 Ge (ISTD) [tune 1]			85 Rb (ISTD) [tune 1]			89 Y (IS)		
Sample Name	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS
Cal Blank	174977.22	100.00	2306091.71	100.00	861689.42	100.00	3741039.45	100.00	6534218.68	100.00	3410778.81	91.17	5989892.34	91.17	5987125.51
1 ppb	164410.22	93.96	2100528.76	91.09	810853.99	94.10	3410778.81	91.17	6233525.91	92.07	3414462.44	95.11	6039855.53	90.59	6120029.71
5 ppb	161264.40	92.16	2131555.81	92.43	819577.71	95.11	3418290.10	95.81	5781143.13	92.28	3388024.82	90.59	6139558.36	93.68	6074249.97
10 ppb	162946.03	93.12	2272818.73	98.56	8225554.74	95.81	3467762.93	95.54	6118507.30	92.70	3199047.61	85.51	6139558.36	93.68	6139558.36
50 ppb	162720.39	93.00	2217929.44	96.18	818472.24	94.98	3452337.53	96.96	3464487.39	93.62	3464487.39	93.62	6074249.97	92.70	6074249.97
100 ppb	166373.91	95.08	2228834.15	96.65	835495.52	96.96	3199047.61	91.13	5781143.13	92.28	3463490.59	87.77	5911677.66	93.33	5911677.66
ICV	162359.39	92.79	2156190.44	93.50	806704.56	93.62	3464487.39	93.62	6314573.88	95.82	3464487.39	93.62	6139558.36	93.68	6139558.36
ICB	159318.07	91.05	2128171.61	92.28	823271.67	95.54	3464487.39	93.62	6105453.89	93.33	3464487.39	93.62	6139558.36	93.68	6139558.36
ICSA	145597.01	83.21	1996593.76	86.58	785247.51	91.13	3464487.39	93.62	6118507.30	92.70	3464487.39	93.62	6139558.36	93.68	6139558.36
ICSAB	153249.34	87.58	2077631.97	90.09	793090.54	92.04	3464487.39	93.62	6139558.36	93.68	3464487.39	93.62	6139558.36	93.68	6139558.36
0223-176.LB-1A	169313.25	96.76	2223010.87	96.40	830628.79	96.40	3584784.89	95.58	6134076.05	95.82	3464487.39	93.62	6139558.36	93.68	6139558.36
0223-176.LCS-1A 2X	169441.43	96.84	2246730.84	97.43	823586.35	95.58	3491349.19	94.41	3498530.67	91.11	3498530.67	92.61	6107015.97	92.61	6107015.97
0223-176.1-1A 5X	160638.17	91.83	2156911.97	93.53	815504.28	94.64	3322931.12	95.28	3464540.07	92.49	3464540.07	92.49	6253382.74	92.49	6253382.74
0223-176.1-1A MS 5X	165987.97	94.86	2205215.79	95.63	821034.43	94.41	3464540.07	92.49	6134076.05	92.49	3464540.07	92.49	6253382.74	92.49	6253382.74
0223-176.2-1A 5X	160903.17	91.96	2099919.00	91.06	813514.22	94.25	3464540.07	92.49	6134076.05	92.49	3464540.07	92.49	6253382.74	92.49	6253382.74
0223-176.2-1A DUP 5X	160800.67	91.90	2107053.25	91.37	812129.48	94.25	3464540.07	92.49	6134076.05	92.49	3464540.07	92.49	6253382.74	92.49	6253382.74
0223-176.3-1A 5X	163504.19	93.44	2205693.43	95.65	823026.81	95.51	3460264.70	92.78	6134076.05	92.49	3460264.70	92.49	6253382.74	92.49	6253382.74
0223-176.4-1A 5X	163150.43	93.24	2220124.60	96.27	838636.41	97.32	3423800.03	91.52	6134076.05	92.49	3423800.03	92.49	6253382.74	92.49	6253382.74
0223-176.5-1A 5X	168752.60	96.44	2247700.22	97.21	817838.84	94.91	3401955.09	90.94	6134076.05	92.49	3401955.09	90.94	6134076.05	92.49	6134076.05
0223-176.6-1A 5X	172891.69	98.81	2311681.26	100.24	830188.41	96.34	3457561.66	92.78	6134076.05	92.49	3457561.66	92.49	6243799.25	92.49	6243799.25
ICV	174536.15	99.75	2288164.54	99.22	798947.07	97.32	3400772.53	90.90	6060322.82	91.52	3400772.53	90.90	6060322.82	91.52	6060322.82
ICB	175266.79	100.17	2329090.13	101.00	7886859.04	91.32	3465878.59	92.64	6160964.18	90.94	3465878.59	92.64	6160964.18	90.94	6160964.18
0223-176.7-1A 5X	179378.87	102.52	2335482.54	101.27	826503.69	95.92	35530776.75	94.38	6491761.90	94.38	35530776.75	94.38	6491761.90	94.38	6491761.90
0223-176.8-1A 5X	182449.81	104.27	2355676.04	102.15	859437.18	99.74	3476560.69	92.93	6383614.17	92.93	3476560.69	92.93	6383614.17	92.93	6383614.17
0223-176.9-1A 5X	184238.39	105.29	2432242.52	105.47	8575588.48	99.52	3507658.21	93.76	6443387.27	93.76	3507658.21	93.76	6443387.27	93.76	6443387.27
0223-176.10-1A 5X	185923.78	106.26	2408796.97	104.45	847026.18	98.30	3540393.21	94.64	6507966.18	94.64	3540393.21	94.64	6507966.18	94.64	6507966.18
0223-176.11-1A 5X	187055.72	106.90	2418126.46	104.86	845728.82	98.15	3449153.77	92.20	6339052.37	92.20	3449153.77	92.20	6339052.37	92.20	6339052.37
0223-176.12-1A 5X	184802.09	105.61	2433817.79	105.54	848985.47	98.53	3554544.32	94.77	6483338.45	94.77	3554544.32	94.77	6483338.45	94.77	6483338.45
0223-176.13-1A 5X	188393.83	107.67	2432090.10	105.46	848952.57	98.52	3561822.35	95.21	6550330.41	95.21	3561822.35	95.21	6550330.41	95.21	6550330.41
0223-176.14-1A 5X	186354.52	106.50	2423024.92	105.07	866400.37	100.55	3613881.20	96.60	6637481.26	96.60	3613881.20	96.60	6637481.26	96.60	6637481.26
0223-176.15-1A 5X	188901.36	107.96	2428634.74	105.31	869704.57	100.93	3693567.92	98.73	6560577.06	98.73	3693567.92	98.73	6560577.06	98.73	6560577.06
ICV	177137.95	101.23	2332098.32	101.13	801969.98	93.07	3555486.61	95.84	6284733.58	95.84	3555486.61	95.84	6284733.58	95.84	6284733.58
ICB	174157.68	99.53	2274607.37	98.63	799830.34	92.82	3510621.15	93.84	6294186.15	93.84	3510621.15	93.84	6294186.15	93.84	6294186.15
0223-176.16-1A 5X	182187.57	104.12	2364954.66	102.55	871641.28	101.15	3506410.69	93.73	6376597.57	93.73	3506410.69	93.73	6376597.57	93.73	6376597.57
0223-176.17-2A 5X	183450.00	104.84	2371093.01	102.82	863860.90	100.48	3632412.39	97.10	6588775.68	97.10	3632412.39	97.10	6588775.68	97.10	6588775.68
0223-176.18-1A 5X	183740.42	105.01	2370838.91	102.81	873524.47	101.37	3707147.96	99.09	6515115.09	99.09	3707147.96	99.09	6515115.09	99.09	6515115.09
ICV	170183.27	97.26	2252178.06	97.66	786635.27	91.29	3550334.90	94.37	6227740.54	94.37	3550334.90	94.37	6227740.54	94.37	6227740.54
ICB	168182.26	96.12	2192369.95	95.07	782601.14	90.82	3408920.52	91.12	6078460.02	91.12	3408920.52	91.12	6078460.02	91.12	6078460.02


		D) [tune 1]
Sample Name		ISTD Recovery %
Cal Blank		100.00
1 ppb		91.67
5 ppb		91.63
10 ppb		95.40
50 ppb		92.43
100 ppb		93.66
ICV		93.96
ICB		92.96
ICSA		88.47
ICSAB		90.47
0223-176.1B-1A		96.64
0223-176.1CS-1A 2X		93.44
0223-176.1-1A 5X		93.64
0223-176.1-1A MS 5X		93.88
0223-176.2-1A 5X		95.48
0223-176.2-1A DUP 5X		93.46
0223-176.3-1A 5X		95.71
0223-176.4-1A 5X		96.69
0223-176.5-1A 5X		96.65
0223-176.6-1A 5X		95.56
ICV		92.75
ICB		94.29
0223-176.7-1A 5X		99.35
0223-176.8-1A 5X		97.70
0223-176.9-1A 5X		98.61
0223-176.10-1A 5X		99.60
0223-176.11-1A 5X		97.01
0223-176.12-1A 5X		99.22
0223-176.13-1A 5X		100.25
0223-176.14-1A 5X		101.58
0223-176.15-1A 5X		100.40
ICV		96.18
ICB		96.33
0223-176.16-1A 5X		97.59
0223-176.17-2A 5X		100.83
0223-176.18-1A 5X		99.71
ICV		95.31
ICB		93.03

Calibration for 039SMPL.d

Batch Folder: D:\Agilent\CPMH\1\DATA\2023\0223-176 032923 high mass FH.b\
Analysis File: 0223-176 032923 high mass FH.batch.bin
DA Date-Time: 3/29/2023 2:41:58 PM
Calibration Title:
Calibration Method: External Calibration
VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	001CALB.d	Cal Blank	3/29/2023 12:07:43 PM
2	002CALS.d	1 ppb	3/29/2023 12:11:28 PM
3	003CALS.d	5 ppb	3/29/2023 12:14:56 PM
4	004CALS.d	10 ppb	3/29/2023 12:18:22 PM
5	005CALS.d	50 ppb	3/29/2023 12:21:51 PM
6	006CALS.d	100 ppb	3/29/2023 12:25:16 PM

Calibration for 039SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	0.000	0.000	230.23	0.0000	P	15.6
2	1.000	1.023	9486.24	0.0018	P	1.6
3	5.000	5.226	47728.53	0.0089	P	2.3
4	10.000	10.779	93813.78	0.0183	P	1.8
5	50.000	49.982	448727.38	0.0845	P	3.3
6	100.000	99.920	888224.53	0.1689	A	1.6

$$y = 0.0017 * x + 3.9343E-005$$


R = 1.0000

DL = 0.01088

BEC = 0.02328

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	0.000	0.000	650.51	0.0001	P	41.2
2	1.000	0.986	21657.29	0.0040	P	2.5
3	5.000	5.098	109924.41	0.0204	P	1.6
4	10.000	10.598	217570.59	0.0423	P	2.6
5	50.000	49.571	1049555.46	0.1976	A	2.6
6	100.000	100.150	2100260.77	0.3991	A	1.8

$$y = 0.0040 * x + 1.1113E-004$$

R = 1.0000


DL = 0.03444

BEC = 0.02789


Weight: <None>

Min Conc: 0

Calibration for 039SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1			740.77		P	1.4
2			804.17		P	6.3
3			1227.96		P	9.7
4			2035.55		P	7.1
5			880.92		P	7.5
6			927.63		P	2.7



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	0.000	0.000	1054.45	0.0002	P	31.6
2			34274.55	0.0064	P	1.7
3	5.000	5.137	167532.09	0.0311	P	3.2
4	10.000	10.768	334475.63	0.0651	P	1.7
5	50.000	49.913	1598552.72	0.3010	A	2.4
6	100.000	99.960	3170172.01	0.6026	A	0.8

$$y = 0.0060 * x + 1.8025E-004$$

R = 1.0000



DL = 0.02838

BEC = 0.02991


Weight: <None>

Min Conc: 0

Calibration for 039SMPL.d



Calibration for 039SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	1004.39	0.0003	P	26.0
2	<input type="checkbox"/>	1.000	0.964	24066.91	0.0065	P	0.5
3	<input type="checkbox"/>	5.000	4.857	117766.96	0.0315	P	1.2
4	<input type="checkbox"/>	10.000	10.047	237219.39	0.0649	P	2.2
5	<input type="checkbox"/>	50.000	49.388	1147069.16	0.3180	A	1.6
6	<input type="checkbox"/>	100.000	100.309	2307756.58	0.6456	A	1.7

$$y = 0.0064 * x + 2.5091E-004$$


R = 1.0000

DL = 0.0304

BEC = 0.039

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	797.50	0.0002	P	28.5
2	<input type="checkbox"/>	1.000	0.990	20804.59	0.0056	P	2.7
3	<input type="checkbox"/>	5.000	5.029	102828.26	0.0275	P	3.6
4	<input type="checkbox"/>	10.000	10.322	205773.46	0.0563	P	1.2
5	<input type="checkbox"/>	50.000	49.642	973279.48	0.2698	A	1.1
6	<input type="checkbox"/>	100.000	100.146	1944874.47	0.5441	A	2.0

$$y = 0.0054 * x + 1.9966E-004$$

R = 1.0000



DL = 0.03142

BEC = 0.03676


Weight: <None>

Min Conc: 0


Calibration for 039SMPL.d




Calibration for 039SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		7831415.20		A	2.8
2	<input type="checkbox"/>	1.000		6892924.14		A	5.3
3	<input type="checkbox"/>	1.000		6977916.84		A	4.5
4	<input type="checkbox"/>	1.000		6706427.03		A	1.2
5	<input type="checkbox"/>	1.000		6603883.08		A	0.7
6	<input type="checkbox"/>	1.000		6824196.72		A	1.2



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		7455265.01		A	3.8
2	<input type="checkbox"/>	1.000		6499956.19		A	3.9
3	<input type="checkbox"/>	1.000		6611197.74		A	2.5
4	<input type="checkbox"/>	1.000		6572185.60		A	2.1
5	<input type="checkbox"/>	1.000		6364986.22		A	0.3
6	<input type="checkbox"/>	1.000		6428770.52		A	1.9



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		4010424.06		A	2.2
2	<input type="checkbox"/>	1.000		3730654.95		A	1.5
3	<input type="checkbox"/>	1.000		3739428.93		A	2.5
4	<input type="checkbox"/>	1.000		3657278.97		A	3.2
5	<input type="checkbox"/>	1.000		3608256.85		A	3.0
6	<input type="checkbox"/>	1.000		3574924.02		A	0.6

Acq. Date-Time	Sample Name	111 Cd [tune 1]			114 Cd [tune 1]			121 Sb [tune 1]			123 Sb [tune 1]			125 Sb [tune 1]			206 Pb [tune 1]		
		Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD		
3/29/2023 12:07	Cal Blank	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A		
3/29/2023 12:11	1 ppb	1.0235	1.6285	0.9857	2.5806	1.0306	1.7714	1.0059	3.7152	0.9637	1.0059	3.7152	0.9637	1.0059	3.7152	0.9637	1.0059		
3/29/2023 12:14	5 ppb	5.2258	2.3441	5.0982	1.5696	5.1366	3.2390	5.1001	3.6242	4.8565	5.1001	3.6242	4.8565	5.1001	3.6242	4.8565	5.1001		
3/29/2023 12:18	10 ppb	10.7786	1.8067	10.5982	2.5570	10.7681	1.7437	10.5986	2.7505	10.0471	10.5986	2.7505	10.0471	10.5986	2.7505	10.0471	10.5986		
3/29/2023 12:21	50 ppb	49.9817	3.2592	49.5707	2.5720	49.9129	2.3611	49.1903	3.6566	49.3880	49.9129	2.3611	49.1903	3.6566	49.3880	49.9129	2.3611		
3/29/2023 12:25	100 ppb	99.9198	1.6174	100.1501	1.8112	99.9599	0.8030	100.3439	0.3636	100.3088	99.9599	0.8030	100.3439	0.3636	100.3088	99.9599	0.8030		
3/29/2023 12:28	ICV	52.3403	1.6716	51.2165	1.5754	51.8535	0.9552	51.4468	0.3165	50.8494	51.8535	0.9552	51.4468	0.3165	50.8494	51.8535	0.9552		
3/29/2023 12:32	ICB	0.5398	4.9561	0.5379	6.3267	0.6115	6.1744	0.6197	5.7952	0.5663	6.1744	0.6197	5.7952	0.5663	6.1744	0.6197	5.7952		
3/29/2023 12:35	ICSA	0.2292	6.1897	0.2227	14.6972	0.2845	14.4192	0.2861	22.2055	0.1962	0.2861	22.2055	0.1962	0.2861	22.2055	0.1962	0.2861		
3/29/2023 12:38	ICSAB	52.4919	0.6902	50.0057	2.1638	51.4573	2.3208	51.2551	2.8151	48.8433	50.0057	2.1638	51.4573	2.3208	51.2551	2.8151	48.8433		
3/29/2023 12:42	0223-176.1B-1A	0.1849	19.3455	0.1676	17.4282	0.3429	11.4877	0.3407	11.0842	0.1787	0.1842	11.0842	0.1787	0.1842	11.0842	0.1787	0.1842		
3/29/2023 12:45	0223-176.1C-S-1A 2X	51.2228	4.7455	49.6663	0.9969	51.1110	1.4282	51.2125	2.1087	49.4470	51.1110	1.4282	51.2125	2.1087	49.4470	51.1110	1.4282		
3/29/2023 12:49	0223-176.1-1A 5X	0.4634	2.1915	0.4352	2.8564	0.6358	6.9137	0.6593	9.7895	1.2996	0.4352	2.8564	0.6358	6.9137	0.6593	9.7895	1.2996		
3/29/2023 12:52	0223-176.1-1A MS 5X	50.6590	2.5730	48.9400	2.9822	52.9802	0.4145	52.9322	1.7290	50.5488	48.9400	2.9822	52.9802	0.4145	52.9322	1.7290	50.5488		
3/29/2023 12:55	0223-176.2-1A 5X	0.3464	12.1102	0.3460	12.7560	0.5028	7.7171	0.5076	7.0967	1.1097	0.3460	12.7560	0.5028	7.7171	0.5076	7.0967	1.1097		
3/29/2023 12:59	0223-176.2-1A DUP 5X	0.1040	32.4939	0.0891	2.4354	0.2506	8.8439	0.2451	3.6466	0.9294	0.0891	2.4354	0.2506	8.8439	0.2451	3.6466	0.9294		
3/29/2023 13:02	0223-176.3-1A 5X	0.0367	4.2583	0.0164	56.3846	0.4067	2.4603	0.3933	3.3786	0.6993	0.0164	56.3846	0.4067	2.4603	0.3933	3.3786	0.6993		
3/29/2023 13:06	0223-176.4-1A 5X	0.0193	42.0035	0.0078	162.6860	0.1647	1.9294	0.1677	3.1562	0.7481	0.0078	162.6860	0.1647	1.9294	0.1677	3.1562	0.7481		
3/29/2023 13:09	0223-176.5-1A 5X	<0.000	N/A	<0.000	N/A	<0.000	N/A	0.1934	7.5408	0.1846	<0.000	N/A	<0.000	N/A	0.1934	7.5408	0.1846		
3/29/2023 13:12	0223-176.6-1A 5X	<0.000	N/A	<0.000	N/A	<0.000	N/A	0.1214	4.6677	0.6434	<0.000	N/A	<0.000	N/A	0.1214	4.6677	0.6434		
3/29/2023 13:16	ICV	49.7680	2.8268	49.1341	1.0598	49.2591	0.7896	50.2040	1.1396	49.1850	49.7680	2.8268	49.2591	0.7896	50.2040	1.1396	49.1850		
3/29/2023 13:19	ICB	0.3038	13.6273	0.2953	13.1232	0.2837	12.3841	0.2982	13.2382	0.2920	0.3038	13.6273	0.2953	13.1232	0.2837	12.3841	0.2982	13.2382	
3/29/2023 13:23	0223-176.7-1A 5X	0.1046	15.6272	0.1112	7.9078	0.3007	3.2053	0.2973	4.9881	0.7086	0.1112	7.9078	0.3007	3.2053	0.2973	4.9881	0.7086		
3/29/2023 13:26	0223-176.8-1A 5X	0.0321	5.2487	0.0154	16.0026	0.1243	5.8573	0.1234	6.2465	0.7509	0.0154	5.2487	0.0154	16.0026	0.1243	5.8573	0.1234		
3/29/2023 13:29	0223-176.9-1A 5X	<0.000	N/A	<0.000	N/A	<0.000	N/A	0.0760	6.1140	0.0800	<0.000	N/A	<0.000	N/A	0.0760	6.1140	0.0800		
3/29/2023 13:33	0223-176.10-1A 5X	0.0062	29.7161	<0.000	N/A	<0.000	N/A	0.1322	1.0635	0.1161	0.0062	29.7161	<0.000	N/A	0.1322	1.0635	0.1161		
3/29/2023 13:36	0223-176.11-1A 5X	<0.000	N/A	<0.000	N/A	<0.000	N/A	0.1626	4.9432	0.1607	<0.000	N/A	<0.000	N/A	0.1626	4.9432	0.1607		
3/29/2023 13:40	0223-176.12-1A 5X	0.0059	96.9882	<0.000	N/A	<0.000	N/A	0.1235	0.4066	0.1248	0.0059	96.9882	<0.000	N/A	0.1235	0.4066	0.1248		
3/29/2023 13:43	0223-176.13-1A 5X	0.0028	288.2580	<0.000	N/A	<0.000	N/A	0.1600	7.2674	0.1618	0.0028	288.2580	<0.000	N/A	0.1600	7.2674	0.1618		
3/29/2023 13:46	0223-176.14-1A 5X	<0.000	N/A	<0.000	N/A	<0.000	N/A	0.1223	8.9062	0.1328	<0.000	N/A	<0.000	N/A	0.1223	8.9062	0.1328		
3/29/2023 13:50	0223-176.15-1A 5X	0.0013	278.0579	<0.000	N/A	<0.000	N/A	0.1406	1.9167	0.1362	0.0013	278.0579	<0.000	N/A	0.1406	1.9167	0.1362		
3/29/2023 13:53	ICV	49.8554	2.1179	48.5818	3.3476	50.8967	1.1031	50.2435	3.2433	49.8459	49.8554	2.1179	48.5818	3.3476	50.8967	1.1031	50.2435	3.2433	
3/29/2023 13:57	ICB	0.3568	1.2990	0.3568	6.1814	0.3848	5.3393	0.3567	5.9186	0.3506	0.3568	1.2990	0.3568	6.1814	0.3848	5.3393	0.3567	5.9186	
3/29/2023 14:00	0223-176.16-1A 5X	0.1046	12.7308	0.0893	33.6066	0.4245	5.0647	0.4245	6.8845	0.7322	0.1046	12.7308	0.0893	33.6066	0.4245	5.0647	0.4245	6.8845	
3/29/2023 14:03	0223-176.17-2A 5X	0.0331	12.9424	0.0129	24.6802	0.0921	5.4991	0.0921	7.9976	0.5826	0.0129	24.6802	0.0921	5.4991	0.0921	7.9976	0.5826		
3/29/2023 14:07	0223-176.18-1A 5X	<0.000	N/A	<0.000	N/A	0.0692	12.5074	0.0643	5.1307	0.4454	<0.000	N/A	<0.000	N/A	0.0692	12.5074	0.0643	5.1307	
3/29/2023 14:10	ICV	48.6904	0.9927	48.4844	0.9176	50.3991	1.0477	49.4397	0.7924	49.0666	48.6904	0.9927	48.4844	0.9176	50.3991	1.0477	49.4397	0.7924	
3/29/2023 14:14	ICB	0.3431	3.5191	0.3528	1.8137	0.3570	3.3374	0.3544	3.1412	0.3599	0.3431	3.5191	0.3528	1.8137	0.3570	3.3374	0.3544	3.1412	

Sample 0223-176.17 was the 1A analysis not the 2A analysis#^{MA13-476R3} Page 69 of 186

	tune 1]	207 Pb [tune 1]	208 Pb [tune 1]	208 Pb [tune 1]	115 In (ISTD) [tune 1]	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS
Sample Name	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS
Cal Blank	N/A	0.0000	N/A	0.0000	N/A	5854953.67	100.00	7831415.20	100.00	7455265.01
1 ppb	0.5211	0.9903	2.7495	0.9846	1.0377	5362765.93	91.59	6892924.14	88.02	6499956.19
5 ppb	1.1893	5.0288	3.6417	4.9716	2.7089	5383489.50	91.95	6977916.84	89.10	6611197.74
10 ppb	2.1803	10.3217	1.1744	10.2845	0.7520	5140791.03	87.80	6706427.03	85.63	6572185.60
50 ppb	1.6451	49.6419	1.1288	50.1497	0.8841	5311320.35	90.71	6603883.08	84.33	6364986.22
100 ppb	1.7303	100.1455	2.0128	99.9013	1.3260	5260663.69	89.85	6824196.72	87.14	6428770.52
ICV	1.8520	49.4919	4.4910	50.7785	1.7388	5382635.89	91.93	6941624.35	88.64	6592233.98
ICB	5.4250	0.5469	2.0071	0.5531	4.3707	5382346.49	91.93	6850366.17	87.47	6582772.70
ICSA	17.0226	0.1720	16.7265	0.1901	18.2778	4801846.58	82.01	6419615.64	81.97	6032030.78
ICSA _B	19.170	47.6938	1.5561	48.8451	1.1021	4600441.30	78.57	6200122.82	79.17	5979506.54
0223-176.1B-1A	2.3580	0.1749	13.6040	0.1833	7.1625	5492176.79	93.80	6851816.26	87.49	6606007.02
0223-176.LCS-1A 2X	1.5889	49.1117	1.1353	49.7139	1.9103	5200539.99	88.82	6964702.11	88.93	6720599.11
0223-176.1-1A 5X	4.2762	1.2369	3.5277	1.2662	3.1535	4919891.60	84.03	6607467.18	84.37	6334020.83
0223-176.1-1AMS 5X	1.3660	50.6759	2.4421	51.0700	2.4994	5040839.80	86.10	6724812.75	85.87	6498816.45
0223-176.2-1A 5X	5.0667	1.0647	0.7548	1.0961	3.6781	5076526.39	86.70	6619843.09	84.53	6313519.34
0223-176.2-1A DUP 5X	1.6348	0.9105	2.0117	0.9001	2.1726	5212220.22	89.02	6862500.17	87.63	6694110.39
0223-176.3-1A 5X	1.7546	0.6855	4.6060	0.6901	3.2797	5236400.94	89.44	6924497.17	88.42	6889153.19
0223-176.4-1A 5X	8.9401	0.7040	4.7014	0.7112	5.1644	5109084.47	87.26	7119854.55	90.92	6608931.93
0223-176.5-1A 5X	3.7027	0.7949	4.5453	0.8092	3.9078	5203966.19	88.88	6625811.67	84.61	6439247.77
0223-176.6-1A 5X	2.9267	0.6032	2.1562	0.6215	0.8381	5187634.36	88.60	6608178.52	84.38	6308548.33
ICV	1.3258	47.9271	2.7958	49.0693	2.2643	5211587.18	89.01	6652624.21	84.95	6326015.22
ICB	9.4059	0.2732	13.1739	0.2898	9.3262	5291793.78	90.38	6540477.02	83.52	6346645.35
0223-176.7-1A 5X	1.7104	0.6848	3.1776	0.6885	1.2002	5234127.06	89.40	6846299.11	87.46	6682781.50
0223-176.8-1A 5X	1.6866	0.7280	3.6231	0.7419	2.3069	5137465.49	87.75	6711379.11	85.70	6462125.07
0223-176.9-1A 5X	4.3544	0.4655	6.7394	0.4800	5.6296	5336005.66	91.14	6722593.89	85.87	6456714.77
0223-176.10-1A 5X	2.7083	0.6393	3.9264	0.6410	1.5431	5364487.18	91.62	6751009.63	86.20	6484411.79
0223-176.11-1A 5X	0.4461	0.6107	5.3664	0.6273	1.2216	5209379.26	88.97	6699477.68	85.55	6467356.82
0223-176.12-1A 5X	5.5125	0.5707	4.9020	0.5898	2.8284	5162269.64	88.17	6741781.09	86.16	6521639.60
0223-176.13-1A 5X	5.9276	0.5337	2.4673	0.5575	3.8074	51666314.32	88.24	6705496.72	85.62	6501068.39
0223-176.14-1A 5X	1.4145	0.6793	4.4234	0.6967	2.4232	5144690.07	87.87	6595251.06	84.22	6244873.93
0223-176.15-1A 5X	1.6709	0.6601	3.5687	0.6666	1.3287	5046812.66	86.20	6643718.64	84.83	6292564.53
ICV	3.1865	47.9477	0.4005	49.5090	1.1548	510858.75	87.25	6513678.19	83.17	6097394.21
ICB	9.0246	0.3428	5.5818	0.3499	6.2482	5128113.72	87.59	6552474.17	83.67	6192706.76
0223-176.16-1A 5X	3.0944	0.6764	5.9799	0.6872	3.6478	5215843.54	89.08	6595017.09	84.23	6417633.92
0223-176.17-2A 5X	2.0032	0.5324	1.2001	0.5622	2.3833	5185400.47	88.56	6600025.37	84.28	6317693.83
0223-176.18-1A 5X	5.1715	0.4106	6.0944	0.4187	4.5874	5311940.47	90.73	6639478.05	84.65	632709.15
ICV	2.9130	48.0916	2.5556	49.0304	0.3616	5106985.82	87.23	6062775.96	77.43	5870489.61
ICB	5.5373	0.3374	4.3485	0.3567	4.5731	5114566.03	87.35	6498055.85	82.97	6133275.40

Sample 0223-176.17 was the 1A analysis not the 2A analysis. - MAL 4/3/23

	STD) [tune 1]	209 Bi (ISTD) [tune 1]	CPS	ISTD Recovery %
Sample Name	ISTD Recovery %			
Cal Blank	100.00	4010424.06	100.00	
1 ppb	87.19	3730654.95	93.02	
5 ppb	88.68	3739428.93	93.24	
10 ppb	88.15	3657278.97	91.19	
50 ppb	85.38	3608256.85	89.97	
100 ppb	86.23	3574924.02	89.14	
ICV	88.42	3713749.37	92.60	
ICB	88.30	3675865.55	91.66	
ICSA	80.91	3117912.81	77.75	
ICSA/B	80.21	3231044.91	80.57	
0223-176.LB-1A	88.61	3656923.64	91.19	
0223-176.LCS-1A 2X	90.15	3735041.97	93.13	
0223-176.1-1A 5X	84.96	3557581.13	88.71	
0223-176.1-1A MS 5X	87.17	3647766.99	90.96	
0223-176.2-1A 5X	84.69	3553604.13	88.61	
0223-176.2-1A DUP 5X	89.79	3591501.61	89.55	
0223-176.3-1A 5X	89.72	3612001.48	90.07	
0223-176.4-1A 5X	88.65	3579707.34	89.26	
0223-176.5-1A 5X	86.37	3585105.65	89.39	
0223-176.6-1A 5X	84.62	3484587.77	86.89	
ICV	84.85	3574090.34	89.12	
ICB	85.16	3513335.96	87.61	
0223-176.7-1A 5X	89.64	3703909.43	92.36	
0223-176.8-1A 5X	86.68	3580021.64	89.27	
0223-176.9-1A 5X	86.61	3604718.68	87.39	
0223-176.10-1A 5X	86.98	3507301.68	87.45	
0223-176.11-1A 5X	86.75	3443669.95	85.87	
0223-176.12-1A 5X	87.56	3518111.95	87.72	
0223-176.13-1A 5X	87.20	3566232.07	88.92	
0223-176.14-1A 5X	83.76	3434841.33	85.65	
0223-176.15-1A 5X	84.40	3428226.73	85.48	
ICV	81.79	3319194.52	82.76	
ICB	83.06	3356613.66	83.70	
0223-176.16-1A 5X	86.08	3444585.61	85.89	
0223-176.17-2A 5X	84.74	3484656.10	86.89	
0223-176.18-1A 5X	84.67	3427967.04	85.48	
ICV	78.74	328955.34	82.02	
ICB	82.27	3195211.06	79.67	

Acq. Date/Time	Sample Name	111 Cd [tune 1]			114 Cd [tune 1]			114 Cd [tune 1]			121 Sb [tune 1]			123 Sb [tune 1]			206 Pb [tune 1]			207 Pb [tune 1]		
		Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	
3/29/2023 14:10	ICV	48.6504	0.9827	48.4844	0.9176	50.3991	1.0477	49.4397	0.7924	49.0666	2.9130	48.0916	2.5556	48.0916	2.5556	48.0916	2.5556	48.0916	2.5556	48.0916	2.5556	
3/29/2023 14:14	ICB	0.3431	3.5191	0.3528	1.8137	0.3570	3.3374	0.3644	3.1412	0.3599	5.5373	0.3374	4.3485	0.3374	4.3485	0.3374	4.3485	0.3374	4.3485	0.3374	4.3485	
3/29/2023 14:41	0223-176-1B-2A	<0.000	N/A	<0.000	N/A	<0.000	N/A	<0.000	N/A	<0.000	403.4233	0.0124	44.5910	0.0124	44.5910	0.0124	44.5910	0.0124	44.5910	0.0124	44.5910	
3/29/2023 14:45	0223-176-LCS-2A-2X	47.8646	2.2390	49.2375	2.3537	48.2579	1.5782	48.5307	1.5251	49.9301	1.6816	48.0136	2.3323	48.0136	2.3323	48.0136	2.3323	48.0136	2.3323	48.0136	2.3323	
3/29/2023 14:48	0223-176-1A-2A	6.0183	1.0611	5.9273	7.0797	0.9489	6.7429	0.9334	7.7811	6.7762	2.5542	7.0120	2.6384	7.0120	2.6384	7.0120	2.6384	7.0120	2.6384	7.0120	2.6384	
3/29/2023 14:52	0223-176-1A-MS	58.9669	2.0272	59.5222	1.8817	52.4140	2.2472	52.2946	2.6836	58.7842	3.5791	57.9615	0.5534	57.9615	0.5534	57.9615	0.5534	57.9615	0.5534	57.9615	0.5534	
3/29/2023 14:55	0223-176-2-2A	1.3427	1.3662	0.9466	40.3526	0.6261	3.7559	0.6096	6.7884	4.1886	1.6136	4.3074	1.9815	4.3074	1.9815	4.3074	1.9815	4.3074	1.9815	4.3074	1.9815	
3/29/2023 14:58	0223-176-2-A DUP	1.1110	1.8328	1.0475	11.8966	0.4258	7.2980	0.4103	2.9224	4.1229	1.4383	4.0622	4.3740	4.0622	4.3740	4.0622	4.3740	4.0622	4.3740	4.0622	4.3740	
3/29/2023 15:02	0223-176-3-2A	0.8993	6.3393	0.6693	19.8747	0.6363	3.7338	0.6261	5.9385	1.9346	2.3377	1.9577	1.4314	2.3377	1.4314	2.3377	1.4314	2.3377	1.4314	2.3377	1.4314	
3/29/2023 15:05	0223-176-4-2A	1.1850	7.1887	0.9541	27.1166	0.3730	4.3491	0.3679	6.3975	2.9546	2.8577	3.0373	4.2939	2.8577	3.0373	4.2939	2.8577	3.0373	4.2939	2.8577	3.0373	
3/29/2023 15:09	0223-176-5-2A	0.2652	3.0823	0.1058	290.1274	0.4619	3.4426	0.4648	4.3036	1.9545	1.9336	1.9469	1.2352	1.9469	1.2352	1.9469	1.2352	1.9469	1.2352	1.9469	1.2352	
3/29/2023 15:12	0223-176-6-2A	0.1127	5.4595	<0.000	N/A	0.2400	3.3096	0.2236	2.5406	1.7823	4.9655	1.8115	5.4326	1.8115	5.4326	1.8115	5.4326	1.8115	5.4326	1.8115	5.4326	
3/29/2023 15:15	ICV	49.82303	0.8925	48.0748	1.0373	50.8554	2.3414	51.1018	1.1814	50.5577	3.1923	49.7076	2.4933	49.7076	2.4933	49.7076	2.4933	49.7076	2.4933	49.7076	2.4933	
3/29/2023 15:19	ICB	0.2679	16.5504	0.2585	16.8066	0.2718	19.6473	0.2697	19.3318	0.2723	12.9721	0.2583	12.2105	0.2583	12.2105	0.2583	12.2105	0.2583	12.2105	0.2583	12.2105	
3/29/2023 15:22	0223-176-7-2A	0.1505	16.1008	<0.000	N/A	0.3046	7.8318	0.3267	7.5362	1.1498	6.8716	1.1518	5.1356	6.8716	1.1518	5.1356	6.8716	1.1518	5.1356	6.8716	1.1518	
3/29/2023 15:26	0223-176-8-2A	0.0168	24.7344	<0.000	N/A	0.0503	10.0559	0.0599	4.9778	0.1948	1.7622	0.2134	3.4418	0.2134	3.4418	0.2134	3.4418	0.2134	3.4418	0.2134	3.4418	
3/29/2023 15:29	0223-176-9-2A	<0.000	N/A	<0.000	N/A	0.0534	5.3483	0.0562	9.7194	0.1671	6.5053	0.1669	5.1789	0.1669	5.1789	0.1669	5.1789	0.1669	5.1789	0.1669	5.1789	
3/29/2023 15:32	0223-176-10-2A	0.1063	16.5592	<0.000	N/A	0.2459	2.2337	0.2484	7.5407	0.9295	2.9301	0.9335	3.0521	0.9335	3.0521	0.9335	3.0521	0.9335	3.0521	0.9335	3.0521	
3/29/2023 15:36	0223-176-11-2A	0.6576	0.5720	0.3333	15.8956	0.2243	5.2219	0.2251	4.6838	1.0384	3.6651	1.0194	1.9683	1.0194	1.9683	1.0194	1.9683	1.0194	1.9683	1.0194	1.9683	
3/29/2023 15:39	0223-176-12-2A	0.3174	2.3462	0.1422	184.7978	0.2750	3.4169	0.2717	8.7177	1.2909	1.6280	1.3023	4.4567	1.3023	4.4567	1.3023	4.4567	1.3023	4.4567	1.3023	4.4567	
3/29/2023 15:43	0223-176-13-2A	0.0651	10.4056	<0.000	N/A	0.1301	5.3087	0.1250	5.0708	1.0073	4.2234	1.0051	2.2858	1.0051	2.2858	1.0051	2.2858	1.0051	2.2858	1.0051	2.2858	
3/29/2023 15:46	0223-176-14-2A	0.1611	9.8095	<0.000	N/A	0.2013	7.1748	0.1924	10.9678	0.8669	1.6753	0.8820	1.6221	0.8820	1.6221	0.8820	1.6221	0.8820	1.6221	0.8820	1.6221	
3/29/2023 15:50	0223-176-15-2A	0.1496	7.9404	<0.000	N/A	0.1057	7.4074	0.1030	17.3724	0.5636	1.5017	0.5755	7.8049	0.5755	7.8049	0.5755	7.8049	0.5755	7.8049	0.5755	7.8049	
3/29/2023 15:53	ICV	50.7701	3.9325	48.7152	2.4500	51.3062	6.2507	56.0222	6.3359	50.6016	2.9865	49.8509	0.4573	49.8509	0.4573	49.8509	0.4573	49.8509	0.4573	49.8509	0.4573	
3/29/2023 15:56	ICB	0.2667	3.1240	0.2594	11.0691	0.2555	12.005	0.2636	2.9010	0.2552	10.6788	0.2640	2.1177	0.2640	2.1177	0.2640	2.1177	0.2640	2.1177	0.2640	2.1177	
3/29/2023 16:00	0223-176-16-2A	0.1748	25.7443	0.0225	405.4462	0.2548	10.0337	0.2479	9.4395	0.9248	3.9559	0.9184	2.8266	0.9184	2.8266	0.9184	2.8266	0.9184	2.8266	0.9184	2.8266	
3/29/2023 16:03	0223-176-17-2A	0.0297	18.7822	<0.000	N/A	0.1573	2.1270	0.1616	5.9892	0.6509	7.9790	0.6696	3.6841	0.6696	3.6841	0.6696	3.6841	0.6696	3.6841	0.6696	3.6841	
3/29/2023 16:07	0223-176-18-2A	1.4004	32.7163	2.1184	12.5589	3.9314	7.1004	3.7502	17.5916	2.3661	13.8480	2.0303	18.6345	2.0303	18.6345	2.0303	18.6345	2.0303	18.6345	2.0303	18.6345	
3/29/2023 16:10	ICV	51.1586	2.4196	49.5570	0.5624	51.5101	4.4620	50.8620	2.8684	49.7590	1.5557	49.3503	0.3962	49.3503	0.3962	49.3503	0.3962	49.3503	0.3962	49.3503	0.3962	
3/29/2023 16:13	ICB	0.2912	14.7689	0.2651	13.3965	0.2666	14.5597	0.2784	17.4895	0.2831	12.1506	0.2829	16.9483	0.2829	16.9483	0.2829	16.9483	0.2829	16.9483	0.2829	16.9483	

① There was no hub in the A/S. There is no sample A/S.

1/2 3/31/23

Sample Name	208 Pb [tune 1]	115 In (ISTD) [tune 1]	159 Tb (ISTD) [tune 1]	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %
ICV	49.0304	0.3616	5106935.82	87.23	6063775.96	77.43	5870489.61	78.74	3289155.34	82.02			
ICB	0.3567	4.5731	5114536.03	87.35	6498055.85	82.97	6133275.40	82.27	3195211.06	79.67			
0223-176-1B-2A	0.0131	29.6461	5459132.91	93.24	6778057.33	86.52	6570711.17	88.14	3333640.11	83.12			
0223-176-1CS-2A-2X	49.9312	0.3991	5604570.29	95.72	6867492.87	88.97	6546575.77	87.81	3337067.46	88.20			
0223-176-1-2A	6.9444	1.3266	5343536.97	91.27	7857105.84	100.33	7541006.68	101.15	3883282.12	99.32			
0223-176-1-2A-MS	58.4410	2.2076	5269566.50	90.00	7707216.11	98.41	7455306.24	100.00	3845700.44	95.89			
0223-176-2-2A	4.2655	1.3486	530987.51	90.69	7658378.94	97.79	7512773.86	100.77	3843266.33	98.33			
0223-176-2-2A-DUP	4.0949	2.0608	5246470.00	93.61	7711884.86	98.56	7371967.80	98.88	3808850.98	94.98			
0223-176-3-2A	1.93322	1.4495	5226933.91	89.27	7746285.65	98.91	7513295.74	100.78	3913391.09	97.58			
0223-176-4-2A	3.0075	1.6600	5239649.39	89.49	7777968.06	99.32	7494881.44	100.53	3894189.57	97.10			
0223-176-5-2A	1.9567	0.3887	5288742.94	90.35	7802605.45	99.63	7475148.69	100.27	3894585.93	97.11			
0223-176-6-2A	1.8066	2.5652	5212054.01	89.02	7870835.66	101.78	7588040.44	101.79	3913514.16	97.58			
ICV	50.6302	3.0871	5075028.28	86.88	6430162.80	82.11	6156633.35	82.58	3331380.78	83.08			
ICB	0.2750	11.8511	5025368.90	85.83	6462419.85	82.52	6248581.54	83.81	3298651.28	82.28			
0223-176-7-2A	1.1504	5.1664	5225921.56	89.26	7814917.20	99.79	7540800.59	101.15	3846710.32	98.41			
0223-176-8-2A	0.2092	2.8895	5572080.22	95.17	7139448.36	91.16	6796467.38	91.16	3735342.66	93.14			
0223-176-9-2A	0.1698	3.8914	5312631.10	90.74	7967009.49	101.73	7538191.52	101.11	3262619.75	97.90			
0223-176-10-2A	0.9335	1.6878	4997074.01	85.35	7816654.66	99.81	7441780.42	98.82	386050.98	94.77			
0223-176-11-2A	1.0609	1.9874	5166892.79	88.25	7598894.87	97.03	7298406.48	97.90	3849826.28	98.49			
0223-176-12-2A	1.3065	1.9439	5361619.81	91.57	7740581.09	98.84	7336223.93	98.40	3824107.20	95.35			
0223-176-13-2A	1.0079	2.5271	5450795.85	93.10	8263589.33	105.52	7762734.13	104.12	4048758.75	100.96			
0223-176-14-2A	0.8897	1.3511	5479403.72	93.59	7972155.23	101.80	7624592.08	102.27	3838100.38	98.20			
0223-176-15-2A	0.5815	2.2601	5385373.56	91.98	7736894.19	98.82	7419479.95	99.52	4004561.03	99.85			
ICV	50.5821	1.4296	5084220.06	86.84	6294759.91	80.38	5970429.80	86.08	3319832.53	82.78			
ICB	0.2594	6.5461	5032018.03	85.94	6305142.84	80.51	5946110.69	79.76	3345256.73	83.41			
0223-176-16-2A	0.9198	2.3902	5211070.60	89.00	8023452.44	102.45	7581611.50	101.69	3849293.29	98.48			
0223-176-17-2A	0.6717	2.8296	5405093.98	92.32	8212222.53	104.87	7720687.45	103.56	3806887.55	97.49			
0223-176-18-2A	1.8537	12.9195	12438.03	0.21	17118.43	0.22	16176.26	0.22	10114.21	0.25			
ICV	50.0082	1.1240	4922166.96	84.07	6231572.76	79.57	5836915.30	78.29	3276144.75	81.69			
ICB	0.2794	14.2644	4807040.51	82.10	6280555.08	80.32	6011745.88	80.64	3155085.91	78.67			


① See note on 1st page MZ 3/5/23

Calibration for 040SMPL.d

Batch Folder: D:\Agilent\ICPMH\1\DATA\2023\0223-176 032923 low mass BH.b\
Analysis File: 0223-176 032923 low mass BH.batch.bin
DA Date-Time: 3/29/2023 6:36:46 PM
Calibration Title:
Calibration Method: External Calibration
VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	001CALB.d	Cal Blank	3/29/2023 4:18:51 PM
2	002CALS.d	1 ppb	3/29/2023 4:22:20 PM
3	003CALS.d	5 ppb	3/29/2023 4:25:50 PM
4	004CALS.d	10 ppb	3/29/2023 4:29:18 PM
5	005CALS.d	50 ppb	3/29/2023 4:32:48 PM
6	006CALS.d	100 ppb	3/29/2023 4:36:15 PM

Calibration for 040SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	440.45	0.0002	P	7.9
2	1.000	1.033	9162.12	0.0047	P	1.1
3	5.000	4.951	42253.83	0.0219	P	1.2
4	10.000	9.992	85929.25	0.0440	P	1.8
5	50.000	49.813	426423.17	0.2185	P	1.1
6	100.000	100.096	859281.16	0.4389	A	1.8

$$y = 0.0044 * x + 2.1515E-004$$


R = 1.0000

DL = 0.01159

BEC = 0.04909

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	13252.98	0.0180	P	5.0
2			64833.30	0.0929	P	3.0
3	5.000	4.923	273666.56	0.3794	P	0.6
4	10.000	10.029	536226.08	0.7543	P	2.2
5	50.000	49.883	2613592.38	3.6803	A	1.2
6	100.000	100.059	5341374.57	7.3641	A	2.6

$$y = 0.0734 * x + 0.0180$$

R = 1.0000



DL = 0.03658

BEC = 0.2451


Weight: <None>

Min Conc: 0

Calibration for 040SMPL.d



Calibration for 040SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	1074.46	0.0015	P 17.2
2	<input type="checkbox"/>			13480.07	0.0193	P 2.1
3	<input type="checkbox"/>	5.000	4.853	63815.19	0.0885	P 3.7
4	<input type="checkbox"/>	10.000	9.678	124419.98	0.1750	P 0.7
5	<input type="checkbox"/>	50.000	49.366	629634.47	0.8866	P 1.9
6	<input type="checkbox"/>	100.000	100.357	1306117.14	1.8009	A 3.2

$$y = 0.0179 * x + 0.0015$$


R = 1.0000

DL = 0.04207

BEC = 0.08138

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	920.96	0.0013	P 1.3
2	<input type="checkbox"/>			2592.86	0.0037	P 7.4
3	<input type="checkbox"/>	5.000	4.876	10130.55	0.0140	P 2.4
4	<input type="checkbox"/>	10.000	10.120	19763.80	0.0278	P 1.9
5	<input type="checkbox"/>	50.000	49.549	93209.07	0.1312	P 3.7
6	<input type="checkbox"/>	100.000	100.220	191623.94	0.2642	P 2.0

$$y = 0.0026 * x + 0.0013$$

R = 1.0000


DL = 0.01804

BEC = 0.4765

Weight: <None>

Min Conc: 0

Calibration for 040SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	470.49	0.0006	P	29.7
2	<input type="checkbox"/>			7569.71	0.0108	P	4.0
3	<input type="checkbox"/>	5.000	5.010	35989.47	0.0499	P	2.7
4	<input type="checkbox"/>	10.000	10.286	72363.78	0.1018	P	0.3
5	<input type="checkbox"/>	50.000	49.770	348024.32	0.4900	P	1.9
6	<input type="checkbox"/>	100.000	100.086	714379.00	0.9847	P	0.8

$$y = 0.0098 * x + 6.4240E-004$$


R = 1.0000

DL = 0.0582

BEC = 0.06533

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	46.71	0.0001	P	27.0
2	<input type="checkbox"/>			530.54	0.0008	P	19.0
3	<input type="checkbox"/>	5.000	5.943	2536.13	0.0035	P	8.7
4	<input type="checkbox"/>	10.000	12.523	5222.92	0.0073	P	4.0
5	<input type="checkbox"/>	50.000	49.559	20505.75	0.0289	P	2.2
6	<input type="checkbox"/>	100.000	99.921	42189.62	0.0582	P	0.6

$$y = 5.8135E-004 * x + 6.3643E-005$$

R = 0.9997


DL = 0.08866

BEC = 0.1095

Weight: <None>

Min Conc: 0

Calibration for 040SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	15049.99	0.0204	P	3.3
2			16613.35	0.0238	P	2.6
3	5.000	5.323	21779.02	0.0302	P	3.8
4	10.000	10.470	28193.64	0.0397	P	0.4
5	50.000	50.192	79946.19	0.1126	P	1.8
6	100.000	99.841	147796.73	0.2037	P	1.3

$$y = 0.0018 * x + 0.0204$$


R = 1.0000

DL = 1.116

BEC = 11.13

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	38.50	0.0001	P	67.9
2			438.73	0.0006	P	8.7
3	5.000	5.071	2724.91	0.0038	P	8.4
4	10.000	10.153	5341.61	0.0075	P	4.8
5	50.000	49.917	26079.79	0.0367	P	3.0
6	100.000	100.023	53341.98	0.0735	P	1.8

$$y = 7.3470E-004 * x + 5.1918E-005$$

R = 1.0000


DL = 0.144

BEC = 0.07067


Weight: <None>

Min Conc: 0

Calibration for 040SMPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>			196.87		P	21.2
2	<input type="checkbox"/>			220.22		P	7.9
3	<input type="checkbox"/>			190.19		P	32.9
4	<input type="checkbox"/>			200.20		P	5.0
5	<input type="checkbox"/>			176.84		P	37.7
6	<input type="checkbox"/>			213.55		P	10.8




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		155148.75		P	0.3
2	<input type="checkbox"/>	1.000		151698.83		P	2.0
3	<input type="checkbox"/>	1.000		147910.00		P	1.3
4	<input type="checkbox"/>	1.000		148722.47		P	1.1
5	<input type="checkbox"/>	1.000		150147.59		P	0.8
6	<input type="checkbox"/>	1.000		150186.34		P	0.8

Calibration for 040SMPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		2047408.12		A	1.7
2	<input type="checkbox"/>	1.000		1932005.10		A	0.7
3	<input type="checkbox"/>	1.000		1928355.66		A	2.7
4	<input type="checkbox"/>	1.000		1952992.05		A	1.8
5	<input type="checkbox"/>	1.000		1951462.25		A	1.2
6	<input type="checkbox"/>	1.000		1958321.25		A	2.1




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		736850.09		P	3.1
2	<input type="checkbox"/>	1.000		698583.94		P	3.0
3	<input type="checkbox"/>	1.000		721318.17		P	1.4
4	<input type="checkbox"/>	1.000		710991.40		P	1.0
5	<input type="checkbox"/>	1.000		710194.03		P	0.7
6	<input type="checkbox"/>	1.000		725532.51		P	2.0

Calibration for 040SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		3227910.61		A	1.4
2	<input type="checkbox"/>	1.000		3102731.30		A	2.0
3	<input type="checkbox"/>	1.000		3043956.92		A	1.9
4	<input type="checkbox"/>	1.000		3095933.09		A	1.2
5	<input type="checkbox"/>	1.000		3133278.80		A	2.1
6	<input type="checkbox"/>	1.000		3181105.50		A	1.9



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		5415127.64		A	2.9
2	<input type="checkbox"/>	1.000		5327342.52		A	0.9
3	<input type="checkbox"/>	1.000		5160809.53		A	1.6
4	<input type="checkbox"/>	1.000		5193383.72		A	2.0
5	<input type="checkbox"/>	1.000		5280368.88		A	1.6
6	<input type="checkbox"/>	1.000		5252469.63		A	1.7

Asq. Date-Time	Sample Name	9 Be [tune 1]		52 Cr [tune 1]		55 Mn [tune 1]		59 Co [tune 1]		60 Ni [tune 1]	
		Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD
3/29/2023 16:18	Cal Blank	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A
3/29/2023 16:22	1 ppb	1.1440	1.0329	1.1440	1.0197	3.7445	1.0570	4.0010	1.0022	4.1213	0.9951
3/29/2023 16:25	5 ppb	4.9513	1.1749	4.9227	0.6324	5.0396	1.4936	4.8765	2.0025	4.8530	2.2564
3/29/2023 16:29	10 ppb	9.9916	1.7989	10.0287	2.2739	10.2686	2.3330	9.8305	0.4372	9.6785	0.7285
3/29/2023 16:32	50 ppb	49.8131	1.1453	49.8832	1.2007	49.5187	1.7312	49.6144	1.6691	49.3856	1.8623
3/29/2023 16:36	100 ppb	100.0964	1.8487	100.0594	2.5730	100.2118	3.8738	100.2159	2.0824	100.3567	3.2193
3/29/2023 16:39	ICV① LC	0.6844	18.2855	0.7012	12.2175	0.8534	11.6559	0.6863	13.4349	0.6845	11.9567
3/29/2023 16:43	ICB LC/V	48.1378	2.2191	49.7880	1.5511	49.7117	1.8108	49.6333	2.5773	48.5386	0.7124
3/29/2023 16:46	ICSA	0.3971	16.1001	0.5280	6.8252	0.3959	6.2596	0.3639	4.6806	0.4358	7.4765
3/29/2023 16:50	ICSAB	51.6033	0.9318	48.0742	1.6978	48.0284	1.7895	47.8334	1.0138	47.4330	1.8540
3/29/2023 16:53	0223-176-LB-2A	0.2022	16.8337	0.3710	9.7489	0.5705	8.6448	0.1983	17.6466	0.5545	10.4122
3/29/2023 16:56	0223-176-LCS-2A-2X	49.1269	1.0645	49.6313	1.0436	48.5296	2.2878	48.0609	2.0475	48.9188	1.4919
3/29/2023 17:00	0223-176-1-2A	0.3612	23.2822	6.2234	0.7952	11.4491	2.0302	0.7891	8.5117	13.8046	1.0445
3/29/2023 17:03	0223-176-1.2A-MS	48.9197	0.6957	53.2566	3.3048	59.6381	2.3619	49.2244	2.0764	61.3814	1.6561
3/29/2023 17:07	0223-176-2-2A	0.1830	22.6070	5.3907	0.7333	7.7802	0.9442	0.6505	6.2312	5.2765	1.0498
3/29/2023 17:10	0223-176-2-2A-DUP	0.0400	9.2202	5.3071	2.8979	7.7312	4.0468	0.5012	6.5401	5.1459	2.9719
3/29/2023 17:14	0223-176-3-2A	<0.000	N/A	4.6525	1.7130	3.9343	1.9058	0.2276	1.1884	7.2568	1.4379
3/29/2023 17:17	0223-176-4-2A	<0.000	N/A	5.1788	1.0189	5.1104	2.2338	0.3888	1.5585	6.6290	1.3450
3/29/2023 17:20	0223-176-5-2A	<0.000	N/A	5.2722	0.5398	6.1831	2.1881	0.3489	3.3685	5.1900	3.0865
3/29/2023 17:24	0223-176-6-2A	<0.000	N/A	4.8312	1.4806	9.6151	1.0550	0.2546	2.6767	3.4396	2.0556
3/29/2023 17:27	ICV① LC	<0.000	N/A	0.0528	16.0713	0.1833	5.9153	<0.000	N/A	<0.000	N/A
3/29/2023 17:31	ICB LC/V	50.2282	1.4187	49.5773	2.0469	50.0626	3.6756	49.3878	2.7704	48.8978	3.8106
3/29/2023 17:34	01993	37.2536	4.2499	2.5986	13.0696	2.3607	0.3286	13.9813	3.2134	2.4923	
3/29/2023 17:38	59.7156	0.4179	8.6905	1.1084	0.7678	0.0583	27.4567	0.4309	5.9967		
3/29/2023 17:41	N/A	2.0897	2.0149	1.9749	1.9382	0.0185	8.3548	1.5790	1.7973		
3/29/2023 17:45	N/A	5.0127	0.1700	135.4831	1.4569	0.1493	3.1129	3.6546	0.6854		
3/29/2023 17:48	0223-176-7-2A	<0.000	N/A	4.5436	0.7128	4.8007	2.3060	0.1418	5.3336	3.8559	0.4383
3/29/2023 17:51	0223-176-8-2A	0.0361	59.7156	0.4179	8.6905	1.0582	15.8269	1.0126	0.1959	1.1329	3.8668
3/29/2023 17:55	0223-176-9-2A	<0.000	N/A	5.6641	2.2036	4.0016	1.2268	0.1605	4.7364	5.0901	3.2680
3/29/2023 17:58	0223-176-10-2A	<0.000	N/A	4.9359	3.7640	8.5957	1.0965	0.2275	2.5749	6.0464	0.8809
3/29/2023 18:02	0223-176-11-2A	<0.000	N/A	4.4053	2.7668	6.2128	0.3865	0.0872	3.6285	3.6796	0.7755
3/29/2023 18:05	ICP① LC	<0.000	N/A	0.0326	46.8127	0.1788	5.3790	<0.000	N/A	<0.000	N/A
3/29/2023 18:09	ICB LC/V	51.4096	0.7280	49.9787	1.4288	49.3679	2.2861	49.2318	1.6296	48.5370	1.1036
3/29/2023 18:19	0.0275	46.5391	0.5863	2.6831	14.4856	2.9472	0.0465	19.0769	0.3827	7.1263	
3/29/2023 18:22	0223-176-12-2A-10X	<0.000	N/A	0.6000	4.1558	2.0015	3.1892	<0.000	N/A	0.3565	2.9353
3/29/2023 18:26	0223-176-16-2A	<0.000	N/A	8.7228	1.1401	15.9131	3.6970	0.2481	1.1154	6.9695	0.5980
3/29/2023 18:29	0223-176-17-2A	<0.000	N/A	2.3961	1.9836	3.4989	0.8386	0.0192	19.4830	1.4280	3.5609
3/29/2023 18:33	ICP① LC	<0.000	N/A	0.0331	19.9800	0.1954	7.7247	<0.000	N/A	<0.000	N/A
3/29/2023 18:36	ICB LC/V	50.8522	1.4531	48.8168	0.5217	49.0612	1.3269	48.3693	0.4826	47.9423	1.3101

① Solutions were accidentally swapped *Mo 3/13/29 29*

Sample Name	62 Ni [tune 1]	75 As [tune 1]	Conc. [ppb]	Conc. RSD	6 Li (ISTD) [tune 1]										
Cal Blank	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	155148.75	100.00	
1 ppb	0.9404	11.1731	1.0375	4.2997	1.2018	20.7711	1.8308	18.1684	0.7852	9.4665	151698.83	97.78			
5 ppb	4.8761	2.6661	5.0103	2.6857	5.9434	8.8675	5.3226	11.7453	5.0713	8.5298	147910.00	95.33			
10 ppb	10.1196	1.9610	10.2859	0.2828	12.5231	4.0211	10.4702	0.8078	10.1531	4.7939	148722.47	95.86			
50 ppb	49.5491	3.7169	49.7659	1.9262	49.5587	2.1808	50.1916	2.2100	49.9172	3.0114	150147.59	96.78			
100 ppb	100.2197	1.9984	100.0860	0.8258	99.9212	0.6435	99.8411	1.4053	100.0225	1.7608	150166.34	96.80			
ICV (1)	0.6673	24.6403	0.7351	12.1396	0.7353	22.6432	1.5509	14.3552	0.8263	32.3334	149261.91	96.21			
ICB	49.6711	0.8915	49.1267	2.5661	48.8411	4.4215	49.7107	3.9710	48.2003	2.1326	147225.73	94.89			
ICSA (1) new	0.5209	11.6728	0.5148	10.5347	1.1874	6.5348	1.2237	36.2745	0.3440	36.0317	132814.54	85.60			
ICSA (1) new	47.6791	1.3353	50.6629	2.3818	51.1888	1.4133	51.3271	0.5465	50.9782	0.8117	128326.60	82.71			
0223-176-1B-2A	0.4975	3.5821	0.2319	6.2113	0.3252	14.7634	0.7489	24.8577	0.2395	36.6669	131419.93	84.71			
0223-176-LCS-2A-2X	49.7277	2.0544	48.4175	0.9047	48.1122	1.3376	48.6756	0.8735	47.5901	4.3872	133023.15	85.74			
0223-176-1-2A	13.7807	1.4022	0.5594	12.0279	10.6934	2.0191	11.2085	4.3995	10.6579	2.1201	115934.73	74.72			
0223-176-1-2A-MS	62.6804	0.7706	47.4433	0.2354	63.5714	1.6689	63.7371	0.3708	64.0128	2.9366	117693.52	75.86			
0223-176-2-2A	5.4076	4.6936	1.0701	5.0732	2.8732	8.5559	2.4304	7.9858	2.9079	7.4786	121478.51	78.30			
0223-176-2-2A-DUP	4.9930	1.5074	0.8809	6.3830	2.5558	13.5744	2.6748	3.7844	2.3579	18.0025	122587.99	79.01			
0223-176-3-2A	7.2335	4.0805	0.6590	4.7283	10.9598	3.2352	11.2235	1.0156	11.5094	1.0223	121307.12	78.19			
0223-176-4-2A	6.6590	1.6348	0.4019	11.8173	41.6179	1.5120	41.6979	0.9957	42.2758	5.4105	117804.82	75.93			
0223-176-5-2A	5.1289	4.9842	0.2809	1.9160	10.9140	2.4725	11.0236	3.7926	11.1928	3.0075	118135.54	76.26			
0223-176-6-2A	3.3433	1.0984	0.2306	8.4363	75.2528	1.5011	74.0698	0.6958	76.0625	0.9704	120970.10	77.97			
ICV (1)	<0.0000	N/A	<0.0000	N/A	0.7059	23.4377	0.9237	7.2063	0.4333	12.6197	127536.08	82.20			
ICB	49.3648	2.8794	49.3050	0.9306	48.7104	1.9446	50.5954	1.4347	50.3407	1.2816	126293.71	81.40			
0223-176-7-2A	3.1209	6.9062	0.3380	12.4499	5.2681	13.1090	5.0442	9.5729	5.0755	3.8956	114333.86	73.69			
0223-176-8-2A	0.3565	45.2705	0.0609	33.2982	0.2435	15.4046	0.2396	214.8225	0.1044	53.1169	125832.18	81.10			
0223-176-9-2A	1.7238	4.7796	0.0119	115.1115	0.2308	29.3850	0.2641	53.7555	<0.0000	N/A	122914.85	79.22			
0223-176-10-2A	3.6468	4.2205	0.2227	0.8088	78.9975	1.4344	78.6188	0.8205	80.1884	2.4696	120798.64	77.86			
0223-176-11-2A	3.8216	5.2549	0.1203	12.2907	21.5715	1.8252	21.7015	3.9017	23.0442	1.2609	119432.89	76.98			
0223-176-12-2A	3.8771	2.4377	0.4994	3.0733	198.3134	0.7439	202.0008	0.6937	206.0767	0.3337	119688.24	77.14			
0223-176-13-2A	5.0279	2.2566	0.1089	16.1580	3.0771	5.9863	3.3814	15.1288	2.9237	10.1481	119143.65	76.79			
0223-176-14-2A	6.0213	4.1766	0.1384	17.3598	7.7102	6.3123	7.3676	4.0608	6.8578	8.0455	122655.77	79.06			
0223-176-15-2A	3.5332	2.9219	0.0789	35.2921	2.2507	10.7310	2.1634	15.0875	1.9065	11.1268	126303.25	81.41			
ICV (1)	<0.0000	N/A	<0.0000	N/A	0.2322	14.1000	0.2473	72.6185	<0.0000	N/A	131514.04	84.77			
ICB	49.0091	1.5623	48.7994	1.0708	50.2091	2.9093	50.9195	0.6711	48.2084	1.3254	125347.87	80.79			
0223-176-16-2A-10X	0.4555	9.8194	0.0663	4.0799	7.2572	6.8203	7.8027	7.6778	7.0666	6.5902	128622.97	82.90			
0223-176-12-2A-10X	0.3357	2.2249	0.0191	90.6310	17.9835	5.1351	18.2671	4.1680	17.7032	3.1883	128750.77	82.99			
0223-176-16-2A	6.9860	2.6217	0.0974	7.8799	8.7173	13.5819	9.1357	4.2491	8.7532	11.1761	123035.88	79.30			
0223-176-17-2A	1.4608	4.0217	0.0205	76.0670	0.3019	51.6485	0.3145	96.5565	0.0911	176.1553	122928.40	79.23			
ICV (1)	<0.0000	N/A	<0.0000	N/A	0.1844	23.2065	0.6594	59.9159	<0.0000	N/A	126586.94	81.59			
ICB	49.1669	1.4122	48.8598	0.9898	49.3632	4.3443	50.2916	3.3695	47.7123	1.7354	12.643.64	78.40			

① See p. 1 note ~~MB 31a1a3~~

	7 Li (ISTD) [tune 1]		72 Ge (ISTD) [tune 1]		85 Rb (ISTD) [tune 1]		89 Y (ISTD) [tune 1]	
Sample Name	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %
Cal Blank	2047408.12	100.00	736850.09	100.00	32227910.61	100.00	5415127.64	100.00
1 ppb	1932005.10	94.36	698583.94	94.81	3102731.30	96.12	5327342.52	98.38
5 ppb	1928355.66	94.19	721318.17	97.89	3043956.92	94.30	5160809.53	95.30
10 ppb	1952992.05	95.39	710991.40	96.49	3095933.09	95.91	5193383.72	95.91
50 ppb	1951462.25	95.31	710194.03	96.38	3133278.80	97.07	5280368.88	97.51
100 ppb	1958321.25	95.65	725532.51	98.46	3181105.50	98.55	5252469.63	97.00
ICV (1)	1946203.02	95.06	719839.12	97.69	3245503.29	100.54	5366654.07	99.10
ICB	1972319.18	96.33	704259.59	95.58	3049001.89	94.46	5187733.85	95.80
ICSA	1744318.35	86.66	686295.40	93.14	2909002.91	90.12	4973227.17	91.84
ICSA/B	1677942.58	81.95	690009.17	93.64	2986494.31	92.52	5085324.10	93.91
0223-176.-LB-2A	1729604.97	84.48	726084.50	98.54	3318418.04	102.80	5553611.39	102.56
0223-176.LCS-2A ZX	1789986.07	87.43	728147.18	98.82	3241317.69	100.42	5389540.91	99.53
0223-176.1-2A	1518336.13	74.16	707805.28	96.06	3281791.26	101.67	55933260.35	103.29
0223-176.1-2A MS	1563879.41	76.38	719369.21	97.63	3441655.00	106.62	57562355.90	106.30
0223-176.2-2A	1587855.87	77.55	746721.15	101.34	3416556.05	105.84	5785330.02	106.84
0223-176.2-2A DUP	1605523.28	78.42	737466.77	100.08	3403804.86	105.45	5849533.31	108.02
0223-176.3-2A	1611612.36	78.71	738134.89	100.17	3462755.76	107.28	5887314.56	108.90
0223-176.4-2A	1546092.03	75.51	720655.92	97.80	3372929.35	104.49	5666708.33	104.65
0223-176.5-2A	1533803.85	74.91	715515.44	97.10	3275056.19	101.46	5563636.20	102.74
0223-176.6-2A	1583626.49	77.35	723390.33	98.17	3401976.00	105.39	5792417.42	106.97
ICV (1)	1713557.33	83.69	690558.96	93.72	3007670.69	93.18	5030238.08	92.89
ICB	1686321.35	82.36	684067.11	92.84	3003294.15	93.04	5025200.80	92.80
0223-176.7-2A	1524825.17	74.48	703161.86	95.43	3282257.95	101.68	5522674.72	101.99
0223-176.8-2A	1666573.97	81.50	715580.52	97.11	3302021.73	102.30	5635646.65	104.07
0223-176.9-2A	1625360.18	79.44	725126.79	98.41	3385156.67	104.88	5827566.47	107.62
0223-176.10-2A	1609182.71	78.60	715110.91	97.05	3410350.73	105.65	5692157.53	105.12
0223-176.11-2A	1576047.32	77.08	729604.07	99.02	3384848.20	104.86	5770867.96	106.57
0223-176.12-2A	1626490.34	79.39	720603.23	97.80	3326532.39	103.03	5738206.28	105.97
0223-176.13-2A	1582176.72	77.28	713264.15	96.80	3444694.63	106.72	5750793.51	106.20
0223-176.14-2A	1630999.52	79.66	741692.48	100.66	3422215.52	106.05	5807604.48	107.25
0223-176.15-2A	1682251.94	82.16	758513.76	102.94	3517834.69	108.98	5919076.42	109.31
ICV (1)	1737183.87	84.85	723033.39	98.12	3102870.00	96.13	5161997.02	95.33
ICB	1646687.19	80.43	688846.51	93.49	2976353.77	92.21	5019688.47	92.70
0223-176.10-2A 10X	1729744.94	84.48	690794.04	93.75	3134691.43	97.11	5240857.39	96.78
0223-176.12-2A 10X	1680452.24	82.08	710898.20	96.48	3173512.78	98.31	5343779.53	98.68
0223-176.16-2A	1637258.60	79.97	734137.71	99.63	3443319.84	106.67	5859390.28	108.39
0223-176.17-2A	1641008.05	80.15	742070.55	100.71	3545203.78	109.83	5981912.17	110.47
ICV (1)	1708218.12	83.43	684648.95	92.92	2997441.95	92.86	4988164.24	92.12
ICB	1624410.46	79.34	669306.21	90.83	2845423.19	88.15	4889566.95	90.29

(1) See p.1 note M& 3/29/23

Location: _____


Drawer: _____

Analyst: MAL

Cabinet: _____

Folder: _____

Date: 3/29/23

Job #s	Describe Work Documented on This Page	Supplies, Ancillary Equipment Serial #s, Lot #s, Etc
0223-176	<p>ICP-MS Analysis</p> <p>173A = Analytical Sequence p. 1</p> <p>173B = <u>1</u> p. 2</p> <p>173C = <u>1</u> p. 3</p> 	N/A

Reviewer's Initials & Date:

ICPMS-X
page 173

EA Job# 0223-176R Page 86 of 186

W002AS-023392-RT-4542

291 of 688



Acq. Date-Time	Sample Name
3/29/2023 9:46	Cal Blank
3/29/2023 9:50	1 ppb
3/29/2023 9:53	5 ppb
3/29/2023 9:57	10 ppb
3/29/2023 10:00	50 ppb
3/29/2023 10:04	100 ppb
3/29/2023 10:07	ICV
3/29/2023 10:10	ICB
3/29/2023 10:14	ICSA
3/29/2023 10:17	ICSAB
3/29/2023 10:21	0223-176.LB-1A
3/29/2023 10:24	0223-176.LCS-1A 2X
3/29/2023 10:28	0223-176.1-1A 5X
3/29/2023 10:31	0223-176.1-1A MS 5X
3/29/2023 10:34	0223-176.2-1A 5X
3/29/2023 10:38	0223-176.2-1A DUP 5X
3/29/2023 10:41	0223-176.3-1A 5X
3/29/2023 10:45	0223-176.4-1A 5X
3/29/2023 10:48	0223-176.5-1A 5X
3/29/2023 10:52	0223-176.6-1A 5X
3/29/2023 10:55	ICV
3/29/2023 10:58	ICB
3/29/2023 11:02	0223-176.7-1A 5X
3/29/2023 11:05	0223-176.8-1A 5X
3/29/2023 11:09	0223-176.9-1A 5X
3/29/2023 11:12	0223-176.10-1A 5X
3/29/2023 11:16	0223-176.11-1A 5X
3/29/2023 11:19	0223-176.12-1A 5X
3/29/2023 11:22	0223-176.13-1A 5X
3/29/2023 11:26	0223-176.14-1A 5X
3/29/2023 11:29	0223-176.15-1A 5X
3/29/2023 11:33	ICV
3/29/2023 11:36	ICB
3/29/2023 11:40	0223-176.16-1A 5X
3/29/2023 11:43	0223-176.17-2A 5X
3/29/2023 11:46	0223-176.18-1A 5X
3/29/2023 11:50	ICV
3/29/2023 11:53	ICB

instr. X

173A

MAL
3/29/23

Acq. Date-Time	Sample Name
3/29/2023 12:07	Cal Blank
3/29/2023 12:11	1 ppb
3/29/2023 12:14	5 ppb
3/29/2023 12:18	10 ppb
3/29/2023 12:21	50 ppb
3/29/2023 12:25	100 ppb
3/29/2023 12:28	ICV
3/29/2023 12:32	ICB
3/29/2023 12:35	ICSA
3/29/2023 12:38	ICSAB
3/29/2023 12:42	0223-176.LB-1A
3/29/2023 12:45	0223-176.LCS-1A 2X
3/29/2023 12:49	0223-176.1-1A 5X
3/29/2023 12:52	0223-176.1-1A MS 5X
3/29/2023 12:55	0223-176.2-1A 5X
3/29/2023 12:59	0223-176.2-1A DUP 5X
3/29/2023 13:02	0223-176.3-1A 5X
3/29/2023 13:06	0223-176.4-1A 5X
3/29/2023 13:09	0223-176.5-1A 5X
3/29/2023 13:12	0223-176.6-1A 5X
3/29/2023 13:16	ICV
3/29/2023 13:19	ICB
3/29/2023 13:23	0223-176.7-1A 5X
3/29/2023 13:26	0223-176.8-1A 5X
3/29/2023 13:29	0223-176.9-1A 5X
3/29/2023 13:33	0223-176.10-1A 5X
3/29/2023 13:36	0223-176.11-1A 5X
3/29/2023 13:40	0223-176.12-1A 5X
3/29/2023 13:43	0223-176.13-1A 5X
3/29/2023 13:46	0223-176.14-1A 5X
3/29/2023 13:50	0223-176.15-1A 5X
3/29/2023 13:53	ICV
3/29/2023 13:57	ICB
3/29/2023 14:00	0223-176.16-1A 5X
3/29/2023 14:03	0223-176.17-2A 5X
3/29/2023 14:07	0223-176.18-1A 5X
3/29/2023 14:10	ICV
3/29/2023 14:14	ICB
3/29/2023 14:41	0223-176.-LB-2A
3/29/2023 14:45	0223-176.LCS-2A 2X
3/29/2023 14:48	0223-176.1-2A
3/29/2023 14:52	0223-176.1-2A MS
3/29/2023 14:55	0223-176.2-2A
3/29/2023 14:58	0223-176.2-2A DUP
3/29/2023 15:02	0223-176.3-2A

Insfr. X
 MAL 173B
 3/29/23

3/29/2023 15:05	0223-176.4-2A
3/29/2023 15:09	0223-176.5-2A
3/29/2023 15:12	0223-176.6-2A
3/29/2023 15:15	ICV
3/29/2023 15:19	ICB
3/29/2023 15:22	0223-176.7-2A
3/29/2023 15:26	0223-176.8-2A
3/29/2023 15:29	0223-176.9-2A
3/29/2023 15:32	0223-176.10-2A
3/29/2023 15:36	0223-176.11-2A
3/29/2023 15:39	0223-176.12-2A
3/29/2023 15:43	0223-176.13-2A
3/29/2023 15:46	0223-176.14-2A
3/29/2023 15:50	0223-176.15-2A
3/29/2023 15:53	ICV
3/29/2023 15:56	ICB
3/29/2023 16:00	0223-176.16-2A
3/29/2023 16:03	0223-176.17-2A
3/29/2023 16:07	0223-176.18-2A
3/29/2023 16:10	ICV
3/29/2023 16:13	ICB

Inst. X

MAL
3/29/23

173C

Acq. Date-Time	Sample Name
3/29/2023 16:18	Cal Blank
3/29/2023 16:22	1 ppb
3/29/2023 16:25	5 ppb
3/29/2023 16:29	10 ppb
3/29/2023 16:32	50 ppb
3/29/2023 16:36	100 ppb
3/29/2023 16:39	ICV
3/29/2023 16:43	ICB
3/29/2023 16:46	ICSA
3/29/2023 16:50	ICSAB
3/29/2023 16:53	0223-176.-LB-2A
3/29/2023 16:56	0223-176.LCS-2A 2X
3/29/2023 17:00	0223-176.1-2A
3/29/2023 17:03	0223-176.1-2A MS
3/29/2023 17:07	0223-176.2-2A
3/29/2023 17:10	0223-176.2-2A DUP
3/29/2023 17:14	0223-176.3-2A
3/29/2023 17:17	0223-176.4-2A
3/29/2023 17:20	0223-176.5-2A
3/29/2023 17:24	0223-176.6-2A
3/29/2023 17:27	ICV
3/29/2023 17:31	ICB
3/29/2023 17:34	0223-176.7-2A
3/29/2023 17:38	0223-176.8-2A
3/29/2023 17:41	0223-176.9-2A
3/29/2023 17:45	0223-176.10-2A
3/29/2023 17:48	0223-176.11-2A
3/29/2023 17:51	0223-176.12-2A
3/29/2023 17:55	0223-176.13-2A
3/29/2023 17:58	0223-176.14-2A
3/29/2023 18:02	0223-176.15-2A
3/29/2023 18:05	ICV
3/29/2023 18:09	ICB
3/29/2023 18:19	0223-176.10-2A 10X
3/29/2023 18:22	0223-176.12-2A 10X
3/29/2023 18:26	0223-176.16-2A
3/29/2023 18:29	0223-176.17-2A
3/29/2023 18:33	ICV
3/29/2023 18:36	ICB

8 Cu 63		9 Cu 65		10 Zn 66		11 Zn 68		12 As 75		13 Se 77		14 Se 78		15 Se 82	
#1 4.96040	ppb	#1 5.06950	ppb	#1	ppb	#1 6.13670	ppb	#1 4.96360	ppb	#1 4.33920	ppb	#1 5.36710	ppb	#1 5.45310	#2
#2 5.26770		#2 5.28120		#2		#2 6.23360		#2 5.21630		#2 4.65430		#2 5.50840		#3 5.48170	#3
#3 5.18940		#3 5.24810		#3		#3 5.72080		#3 5.53940		#3 4.55390		#4 4.09110		#4 5.10280	#4
#4 5.21950		#4 5.13870		#4		#4 5.19440		#4 5.40480		#4 5.29240		#5 5.03490		#5 5.46890	#5
#5 4.93760		#5 5.02380		#5		#5 4.98380		#5 5.22280		#6 4.98380		#6 5.22280		#6 5.20410	#6
#6 4.79220		#6 4.89580		#6		#6 4.85660		#6 5.21800		#7 4.85660		#7 5.21800		#7 4.31950	#7
#7 5.01150		#7 4.92170		#7		#7 4.78090		#7 4.98600		#8 4.78090		#8 4.98600		#8 5.22130	#8
#8 4.87970		#8 4.98790		#8		#8 4.98790		#8 4.98790		#9 <1/10 Conc of Std		#9 0.50000		#9 0.50000	#9
#9		#9		#9		#9		#9		#10 <1/10 Conc of Std		#10 0.50000		#10 0.50000	#10
#10		#10		#10		#10		#10		#DIV/0!		#DIV/0!		#DIV/0!	#DIV/0!
0.1723		0.1426		0.1426		0.5665		0.5665		0.000		0.000		0.2025	0.1765
2.998		2.998		2.998		2.998		2.998		#DIV/0!		1.698		0.2998	0.2998
0.517		0.427		0.427		1.698		1.698		#DIV/0!		0.607		0.529	0.601
5 000		5 000		5 000		20 000		20 000		20 000		5 000		5 000	5 000
0.500		0.500		0.500		2,000		2,000		#DIV/0!		0.500		0.500	0.500
Pass		<1/10 Conc of Std		0.50000		#DIV/0!		#DIV/0!		#DIV/0!		Pass		Pass	Pass
0.51660		0.51660		0.51660		1.69827		1.69827		0.60722		0.60722		0.60064	0.60064
102.7%		3.1%		104.0%		2.2%		120.6%		4.5%		104.8%		5.5%	89.8%
														3.5%	108.9%
															1.3% 108.4%

LB is > 5, set LOQ @ 10
until lab repreps.
AMC 2/15/23

Ag 107		Ag 109		Cd 111		Cd 114	
ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppb
1.13220	#1	1.12130	#1	1.12520	#1	1.06210	#1
1.06810	#2	1.05970	#2	1.04910	#2	1.05560	#2
1.05170	#3	1.03280	#3	1.03310	#3	1.00280	#3
1.07130	#4	1.05060	#4	1.05780	#4	0.99920	#4
1.00550	#5	1.04290	#5	1.03840	#5	0.99810	#5
1.05460	#6	1.04310	#6	1.06410	#6	1.01360	#6
1.00480	#7	1.00790	#7	1.01430	#7	1.00950	#7
1.00020	#8	1.00160	#8	1.02180	#8	1.02520	#8
	#9		#9		#9		#9
	#10		#10		#10		#10
0.0448	0.0415	0.0346	0.0259				
2.998	2.998	2.998	2.998				
0.134	0.124	0.104	0.078				
1.000	1.000	1.000	1.000				
0.100	0.100	0.100	0.100				
Pass	Pass	Pass	<1/10 Conc of Std				
0.13431	0.12445	0.10388	0.10000				
3.9%	108.5%	4.3%	4.6%	106.9%	104.0%	3.1%	

Date Analyzed 2/3/23

Logbook Page

Analyst KAH

Date Reviewed 2/15/23

Reviewed By AMC

Enter values into the highlighted cells.

W002AS-023392-RT-4542

Seven (or more) replicates of a low concentration preparation are made. The worst injection(s) (farthest from the mean area) may be removed assuming an appropriate Outlier Test calculation shows the value(s) to be an outlier. At least seven injections must remain.

Date Analyzed 2/3/23
Injector (F,R,NA)
Column
Injector (F,R,NA)
Column

Instrument X - BACK HALF (-2A)

Review Date 2/15/23
Reviewed By AMC

Job #(s)

Applicable Method(s) 29 6020

Matrix

Solvent

Compound #

Compound Name

Notes (if needed)

Units

Test Std Concentrations

LOQ // AVERAGE & RSD 101.3%

Concentration of Std

MDL to Use

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

MDL =

Student's t-value

Calculated MDL = StdDev * t

Lowest Part 136 App B Value*

MDL value <1/10 Std Value?

</div

W002AS-023392-RT-4542

8 Cu 63		9 Cu 65		10 Zn 66		11 Zn 68		12 As 75		13 Se 77		14 Se 78		15 Se 82		
#1	4.95160	#1	5.06260	#1	20.67570	#1	20.40220	#1	4.77280	#1	4.84810	#1	4.20750	#1	4.80130	
#2	4.88770	#2	4.78540	#2	20.21670	#2	20.18220	#2	4.67230	#2	4.28760	#2	4.04800	#2	4.91300	
#3	4.83366	#3	4.86160	#3	19.68340	#3	19.89950	#3	4.62070	#3	4.69190	#3	4.19570	#3	4.75460	
#4	4.87860	#4	4.98630	#4	20.45300	#4	19.96850	#4	4.74540	#4	4.87330	#4	4.15760	#4	4.95520	
#5	5.02820	#5	5.07780	#5	33.94130	#5	33.08090	#5	4.74380	#5	4.71780	#5	4.27370	#5	4.62390	
#6	4.96500	#6	4.89190	#6	20.92690	#6	20.74360	#6	4.77180	#6	4.20030	#6	3.97480	#6	5.20820	
#7	4.81170	#7	4.83920	#7	20.21990	#7	20.07780	#7	4.68530	#7	4.45680	#7	4.22100	#7	4.79230	
#8	4.97150	#8	4.97030	#8	22.63020	#8	22.43950	#8	4.81000	#8	4.83650	#8	4.33670	#8	4.97760	
#9		#9		#9		#9		#9		#9		#9		#9		
#10		#10		#10		#10		#10		#10		#10		#10		
0.0724	0.1065	4.7669	4.5130	0.0628	0.2666	0.1171	0.1768	2.998	2.998	0.2998	0.1711	0.1768	0.1171	0.1768	0.1768	
3.143	2.998	2.998	2.998	0.188	0.188	0.351	0.351	0.188	0.188	0.188	0.351	0.351	0.351	0.351	0.351	
0.228	0.319	14.291	13.550	0.799	0.799	0.799	0.799								0.530	
5.000	5.000	20.000	20.000	5.000	5.000	5.000	5.000	5.000	5.000	5.000	5.000	5.000	5.000	5.000	5.000	
<1/10 Conc of Std	<1/10 Conc of Std	0.50000	0.50000	2.000 Pass	2.000 Pass	<1/10 Conc of Std	<1/10 Conc of Std	0.50000	0.50000	0.50000	<1/10 Conc of Std	0.50000	<1/10 Conc of Std	0.50000	0.50000	0.50000
98.4%	0.92%	98.1%	2.92%	101.0%	2.46%	100.8%	1.25%	93.8%	1.65%	92.2%	6.28%	83.0%	2.14%	96.5%	1.69%	
															107.8%	

302 of 688

¹⁶ Ag 107		¹⁷ Ag 109		¹⁸ Cd 111		¹⁹ Cd 114	
ppb	ppb	ppb	ppb	ppb	ppb	ppb	ppb
1 15640	#1	1 13140	#1	1 18030	#1	1 15320	
1 07970	#2	1 08800	#2	1 08460	#2	1 07310	
0 99800	#3	0 99550	#3	1 03040	#3	1 04340	
1 00950	#4	1 01730	#4	0 98690	#4	0 98180	
0 98640	#5	1 00090	#5	0 99970	#5	0 99840	
1 02770	#6	1 00450	#6	1 06550	#6	0 99820	
1 00180	#7	1 01050	#7	0 99200	#7	1 00150	
1 01340	#8	1 01380	#8	1 02700	#8	0 97670	
	#9				#9		
	#10				#10		
0.0570		0.0494		0.0644		0.0608	
2.998		2.998		2.998		2.998	
0.171		0.148		0.193		0.182	
1 000		1 000		1 000		1 000	
0.100		0.100		0.100		0.100	
Pass		Pass		Pass		Pass	
0.17085		0.14888		0.19318		0.18223	
7.35%	107.2%	6.48%	109.8%	6.91%	109.0%	5.21%	

1.00 validated 12/10/08 VR

Calculation of MDL per SOP ENT-027

Date Analyzed 2/3/23
Analyst KAH
Date Reviewed 2/15/23
Reviewed By AMC

Enter values into the highlighted cells

W002AS-023392-RT-4542

Seven (or more) replicates of a low concentration preparation are made. The worst injection(s) (farthest from the mean area) may be removed assuming an appropriate Outlier Test calculation shows the value(s) to be an outlier. At least seven injections must remain.

Instrument X - BACK HALF (-2A)

Logbook Page
Injector (F,R,NA)
Column
Injector (F,R,NA)
Column

Job #(s)
Applicable Methods(s) 29, 6020
Matrix
Solvent

Compound Name
Compound #
Notes (if needed)

Units	Test Std Concentrations	1	2	3	4	5	6	7	8	
		Sb 121	Sb 123	Ba 137	Ba 138	Tl 205	Pb 206	Pb 207	Pb 208	
ppb	#1 4.95090 #2 4.83370 #3 4.80560 #4 4.81720 #5 4.73740 #6 5.14090 #7 4.81550 #8 4.80400 #9 4.79460 #10	4.87810 4.90380 4.76980 4.87910 4.79890 4.79020 4.85670 4.78570 4.89050 #10	#1 5.31240 #2 5.30310 #3 4.90620 #4 4.79670 #5 4.79880 #6 5.10260 #7 4.71390 #8 4.79460 #9 4.93130 #10	ppb #1 5.22330 #2 5.29670 #3 4.87040 #4 4.78960 #5 4.79020 #6 4.87580 #7 4.81400 #8 4.93130 #9 4.93130 #10	ppb #1 1.14670 #2 1.08190 #3 1.00770 #4 1.00690 #5 1.05720 #6 1.00300 #7 0.98160 #8 1.00150 #9 1.00150 #10	ppb #1 1.14530 #2 1.08180 #3 0.98270 #4 0.98860 #5 1.04030 #6 0.97500 #7 1.00580 #8 0.99550 #9 1.01610 #10	ppb #1 1.16820 #2 1.08060 #3 0.98070 #4 0.99050 #5 0.99660 #6 0.95910 #7 0.97750 #8 1.01610 #9 1.01610 #10	ppb #1 1.14010 #2 1.07990 #3 0.99430 #4 0.97490 #5 1.01630 #6 0.96330 #7 0.97300 #8 0.99460 #9 0.99460 #10	ppb #1 1.0618 #2 2.996 #3 0.209 #4 0.178 #5 0.178 #6 0.178 #7 0.178 #8 0.178 #9 0.178 #10	ppb #1 0.0698 #2 2.998 #3 0.183 #4 0.183 #5 0.183 #6 0.183 #7 0.183 #8 0.183 #9 0.183 #10
Standard Deviation Student's T factor Calculated MDL = StdDev * t	0.1269 2.998 0.380	0.1188 2.998 0.356	0.2225 2.998 0.667	0.1989 2.998 0.596	0.0611 2.998 0.183	0.0595 2.998 0.183	0.0698 2.998 0.209	0.0698 2.998 0.209	0.0698 2.998 0.185	
Concentration of Std Lowest Part 136 App B Value* MDL value <1/10 Std Value?	5.000 0.500	<1/10 Conc of Std	5.000 0.500	5.000 0.500	1.000 0.100	1.000 0.100	1.000 0.100	1.000 0.100	1.000 0.100	
MDL to Use	0.50000	0.50000	0.68697	0.59620	0.18331	0.17829	0.20930	0.18522	0.18522	

LOQ // AVERAGE & RSD 97.3% 1.58% 97.0% 1.58% 103.5% 4.48% 102.6% 4.44% 107.9% 6.45% 107.0% 7.66% 107.7% 8.72% 107.1% 6.84%

*40 CFR Part 136 Appendix B, a common detection limit guidance, indicates that the MDL can not be <1/10 the standard used to set the MDL.

MDL to use is the maximum of the Calculated MDL, lowest integratable concentration and the Lowest Part 136 B value.

Job #s	Describe Work Documented on This Page
MS LOQ.1-8 MAL COOC.1-4	m29 prep
13410A = m29 FH prep sheet 1340B = m29 BH prep sheet	Supplies, Ancillary Equipment Serial #s, Lot #s, Etc
Preparation of LOQ working standard	M2 2/2/23 added

Element Stock ID	exp date	Vol. spiked (mL)	final conc. (ppm)
Be F0734	6/30/27	0.1	1
Cr F0583	4/30/26	0.5	5
Mn F0731	10/31/27	0.5	5
Co F0728	6/30/27	0.1	1
Cu F0739	5/31/29	0.5	5
Ni F0729	5/31/25	0.5	5
Zn F0703	4/30/26	0.5	5
As F0695	4/30/27	2.0	20
Se F0645	12/31/25	0.5	5
Ag F0798	12/23/24	① 0.1	1
Ca F0730	3/31/23	0.1	1
Sb F0820	8/2/23	0.5	5
Ba F0769	4/30/25	0.5	5
Tl F0816	5/9/23	0.1	1
① Zn Pb F0802	6/30/29	① 2.0	1
V F0457	9/30/23	0.5	5
① M2 2/2/23 EE			

0.1mL spike used pipet 127 next cal due 3/4/23

0.5+2mL spikes used pipet 124 next cal due 3/4/23

Final volume 100mL with 5% HNO₃

Reviewer's Initials & Date:

Metals Prep

EA Job# 0223-176 Page 100 of 186

W002AS-023392-RT-4542

305 of 688

ENTHALPY
ANALYTICAL

METHOD 29 METALS PREP SHEET**FRONT HALF SAMPLES**

DAY 1	Date: 2/2/23	Analyst(s): LMP / MAL	DAY 3	Date:	Analyst(s):		
DAY 2	Date: 2/3/23	Analyst(s): LMP	DAY 4	Date:	Analyst(s):		
Ves. #	Reagents	ID#:	Expiration Date:	Sample ID	Final Volume (mL)		
1	HNO ₃ : 6 mL	22330073	8/24	LQ. 1	-1 100		
2	HF: 4 mL	SCA 2118048	4/25	.2	-1		
3	Support Equipment	ID#:	Expiration Date:	.3	-1		
4				.4	-1		
5	Ag vessels used?	YES / NOT NEEDED		.5	-1		
6	Cleaning Cycle Completed?	YES / NO		.6	-1		
7	Micro. #	6, 7	N/A	.7	-1		
8				.8	-1		
9	Hotplate #	8	N/A	MAL CDOC .1	-1		
10				.2	-1		
11	HF Pipette	130	3/3/23	.3	-1		
12				.4	-1		
	HNO ₃ Pipette	1	1		-1		
					-1		
	Digitube	J553470-2258	N/A		-1		
					-1		
	Comments:				-1		
					-1		
					-1		
					-1		
					-1		

Front Half Quality Control

Ves. #	QC	ID:	Expiraton:	Stock Conc. (ppm)	Prepped Conc. (ppb)	Amount Added (mL)	Pip ID:	Pip Exp:
13	Lab Blank-1	--	--	--	--	--	--	--
14	LCS-1	F0814	10/28/23	10	100	1.0	124	3/4/23

List additional LCS's below as needed. For example: Ag, LCS-High



METHOD 29 METALS PREP SHEET

BACK HALF SAMPLES

Back Half Quality Control

QC	ID:	Expiration:	Stock Conc. (ppm)	Prepped Conc. (ppb)	Amount Added (mL)	Pip ID:	Pip Exp:
Lab Blank-2A	--	--	--	--	--	--	--
LCS-2A	F0763	2/24	100	100	0.10	127	3/4/23

List additional LCS's below as needed. For example: Ag, LCS-High

ICP-MS Raw Data Coversheet

Doc. No.: RD05

Rev.:G

Effective Date: 08-05-22

Instrument X)

Analyst(s):	KAH	Analysis Date(s):	2/3/23		
EA Project #s:	LQG Study				
Analytes:	All M29 + V				
Method:	G020	Smart Tune ID: ES-0804	Conc: 1 ppb	Exp: 7/3/23	
		Internal Standard ID ¹ : F0773	Conc: 10 ppm	Exp: 2/23	
Diluent:	50	mL HNO ₃ (ID # 2230073)	Exp: 8/24) diluted to 1000 mL with DI
Calib. Blk/ICB/CCB:	Diluent				

¹ All samples and standards are spiked with 50µL of internal std. (pipette 127 exp 3/4/23)Calibration Standards - Made from EA ID#²: 10F0763 (Stock Concentration: 10 ppm)
Exp Date: 2/4/23) and brought up with Diluent

	Final Conc. (ppb)	Amount (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
Standard 1	1	100 of Std 6	127 3/4/23					
Standard 2	5	500 of Std 6	124					
Standard 3	20	2mL Std 6	1					
Standard 4	50	50	127					
Standard 5	100	100						
No IS Std 6	100	100	—	—				

² 10ppm WS = 1mL of Standard F0763 exp 2/24 (pipettes: 124, 143 exp 3/4/23) + 9mL DiluentSecondary Standards - Made from EA ID#: F0814 + (3) (Stock Concentration: 10 ppm)
ExpDate: 11/23 / 2/4/23) and brought up with Diluent

	Final Conc. (ppb)	Amount (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
ICV/CCV	50	50+50	127 3/4/23	10	143 2/9/23	KAH	2/3/23	2/4/23

(3) 10 ppm V : 100 µL F0457(1000 ppm 9/23) w/ 127 3/4/23 → 10mL w/diluent 143 2/9/23 KAH 2/3/23

ICS's- Made from Stock Std ICS-A ID#(F0786 Exp: 8/23)

& 50 ppb Metals Std ID#(12) 10763 Conc: 10 ppm Exp: 2/4/23) brought up with Diluent

	Conc.	Amount WS (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
ICS-A	Multi	100	127 3/4/23					
ICS-AB	Multi	100						

Post Dig Matrix Spike Samples - Diluted with Diluent (Metals Mix ID# _____ Conc: _____ Exp: _____)

Sample ID	Dilution Factor of Field Sample	Aliquot of Sample (mL)	Final Conc. (ppb)	Amount of Spike Added (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst
						10		
						10		
						10		
						10		
						10		
						10		
						10		
						10		

ICP-MS Raw Data Coversheet

Doc. No.: RD05

Rev.:G

Effective Date: 08-05-22


Comments:

Calibration for 034SMPL.d

Batch Folder: D:\Agilent\ICPMH\1\DATA\2023\LOQ MAL FH IDOC 020323.b\
Analysis File: LOQ MAL FH IDOC 020323.batch.bin
DA Date-Time: 2/3/2023 3:55:01 PM
Calibration Title:
Calibration Method: External Calibration
VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	001CALB.d	CAL BLK	2/3/2023 1:17:15 PM
2	002CALS.d	1 PPB	2/3/2023 1:20:57 PM
3	003CALS.d	5 PPB	2/3/2023 1:24:19 PM
4	004CALS.d	20 PPB	2/3/2023 1:27:40 PM
5	005CALS.d	50 PPB	2/3/2023 1:31:03 PM
6	006CALS.d	100 PPB	2/3/2023 1:34:18 PM

Calibration for 034SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	160.16	0.0001	P	10.7
2	1.000	1.007	15316.91	0.0052	P	3.9
3	5.000	4.863	78963.69	0.0248	P	1.5
4	20.000	20.197	310003.37	0.1027	P	1.1
5	50.000	50.238	809189.97	0.2553	A	1.6
6	100.000	99.849	1614321.80	0.5073	A	7.3

$$y = 0.0051 * x + 5.0182E-005$$


R = 1.0000

DL = 0.003161

BEC = 0.009878

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	523.87	0.0005	P	14.0
2			80701.88	0.0865	P	3.5
3	5.000	4.729	387904.65	0.4082	P	4.3
4	20.000	19.299	1621181.09	1.6642	A	0.4
5	50.000	50.044	4066701.56	4.3148	A	2.6
6	100.000	100.132	8018636.16	8.6328	A	4.3

$$y = 0.0862 * x + 5.3372E-004$$

R = 1.0000


DL = 0.002603

BEC = 0.006191

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD	
1	<input type="checkbox"/>	0.000	0.000	10414.38	0.0106	P	5.9
2	<input type="checkbox"/>			79829.30	0.0856	P	3.1
3	<input type="checkbox"/>	5.000	4.691	349621.02	0.3679	P	3.7
4	<input type="checkbox"/>	20.000	19.082	1425963.45	1.4639	A	1.7
5	<input type="checkbox"/>	50.000	49.797	3584520.23	3.8032	A	1.1
6	<input type="checkbox"/>	100.000	100.300	7107043.25	7.6495	A	2.7

$$y = 0.0762 * x + 0.0106$$


R = 1.0000

DL = 0.02439

BEC = 0.1387

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD	
1	<input type="checkbox"/>	0.000	0.000	24773.44	0.0251	P	5.6
2	<input type="checkbox"/>			120656.47	0.1293	P	0.3
3	<input type="checkbox"/>	5.000	4.804	507734.27	0.5342	P	3.7
4	<input type="checkbox"/>	20.000	19.077	1993468.88	2.0464	A	1.1
5	<input type="checkbox"/>	50.000	49.626	4980861.68	5.2831	A	1.9
6	<input type="checkbox"/>	100.000	100.381	9906928.25	10.6608	A	1.7

$$y = 0.1060 * x + 0.0251$$

R = 0.9999


DL = 0.03988

BEC = 0.2372

Weight: <None>

Min Conc: 0

Calibration for 0345MPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	2753.06	0.0028	P	5.5
2	<input type="checkbox"/>	1.000	0.996	81776.60	0.0877	P	2.6
3	<input type="checkbox"/>	5.000	4.795	390926.73	0.4113	P	3.4
4	<input type="checkbox"/>	20.000	19.221	1597941.96	1.6404	A	3.1
5	<input type="checkbox"/>	50.000	49.253	3958491.45	4.1989	A	0.5
6	<input type="checkbox"/>	100.000	100.540	7961397.32	8.5683	A	2.5

$$y = 0.0852 * x + 0.0028$$


R = 0.9999

DL = 0.005423

BEC = 0.03277

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	4118.09	0.0042	P	3.4
2	<input type="checkbox"/>			21043.65	0.0226	P	5.0
3	<input type="checkbox"/>	5.000	4.818	89255.84	0.0939	P	1.9
4	<input type="checkbox"/>	20.000	18.844	345743.60	0.3550	P	4.9
5	<input type="checkbox"/>	50.000	49.877	878939.39	0.9326	P	1.7
6	<input type="checkbox"/>	100.000	100.302	1738894.81	1.8713	A	3.3

$$y = 0.0186 * x + 0.0042$$

R = 0.9999


DL = 0.02316

BEC = 0.2246

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	2135.66	0.0022	P
2	<input type="checkbox"/>			4498.60	0.0048	P
3	<input type="checkbox"/>	5.000	4.607	14107.97	0.0149	P
4	<input type="checkbox"/>	20.000	18.552	51881.53	0.0533	P
5	<input type="checkbox"/>	50.000	49.738	131082.99	0.1392	P
6	<input type="checkbox"/>	100.000	100.440	259084.64	0.2788	P

$$y = 0.0028 * x + 0.0022$$


R = 0.9999

DL = 0.2483

BEC = 0.785

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	3160.23	0.0032	P
2	<input type="checkbox"/>			43929.58	0.0471	P
3	<input type="checkbox"/>	5.000	4.823	207244.43	0.2181	P
4	<input type="checkbox"/>	20.000	18.364	800199.92	0.8215	P
5	<input type="checkbox"/>	50.000	50.565	2125379.31	2.2563	A
6	<input type="checkbox"/>	100.000	100.053	4145714.48	4.4613	A

$$y = 0.0446 * x + 0.0032$$

R = 0.9998


DL = 0.01008

BEC = 0.07192

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	1438.19	0.0015	P	7.3
2	<input type="checkbox"/>			20652.80	0.0221	P	4.1
3	<input type="checkbox"/>	5.000	4.682	94973.12	0.0999	P	2.6
4	<input type="checkbox"/>	20.000	18.622	382700.16	0.3929	P	3.0
5	<input type="checkbox"/>	50.000	48.134	954273.05	1.0133	A	5.7
6	<input type="checkbox"/>	100.000	101.225	1978304.16	2.1293	A	3.5

$$y = 0.0210 * x + 0.0015$$


R = 0.9996

DL = 0.01523

BEC = 0.06951

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	34788.21	0.0353	P	0.8
2	<input type="checkbox"/>			41416.13	0.0444	P	3.5
3	<input type="checkbox"/>			83699.99	0.0881	P	3.5
4	<input type="checkbox"/>	20.000	19.147	271158.70	0.2784	P	3.3
5	<input type="checkbox"/>	50.000	49.294	622698.31	0.6611	P	4.9
6	<input type="checkbox"/>	100.000	100.524	1218684.22	1.3116	A	2.0

$$y = 0.0127 * x + 0.0353$$

R = 0.9999


DL = 0.07068

BEC = 2.782

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD	
1	<input type="checkbox"/>	0.000	0.000	25201.49	0.0256	P	0.3
2	<input type="checkbox"/>			30423.69	0.0326	P	0.7
3	<input type="checkbox"/>			62147.34	0.0654	P	2.0
4	<input type="checkbox"/>	20.000	19.930	201411.55	0.2068	P	1.5
5	<input type="checkbox"/>	50.000	49.704	449856.62	0.4774	P	2.9
6	<input type="checkbox"/>	100.000	100.162	870022.94	0.9361	A	0.7

$$y = 0.0091 * x + 0.0256$$


R = 1.0000

DL = 0.02815

BEC = 2.814

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD	
1	<input type="checkbox"/>	0.000	0.000	724.08	0.0007	P	7.3
2	<input type="checkbox"/>			10962.08	0.0117	P	6.5
3	<input type="checkbox"/>	5.000	4.921	53663.96	0.0564	P	2.2
4	<input type="checkbox"/>	20.000	19.809	219178.69	0.2250	P	1.5
5	<input type="checkbox"/>	50.000	50.424	538669.91	0.5716	P	1.7
6	<input type="checkbox"/>	100.000	99.830	1050797.71	1.1309	A	2.1

$$y = 0.0113 * x + 7.3371E-004$$

R = 1.0000


DL = 0.01421

BEC = 0.06481

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	243.58	0.0002	P	30.6
2	<input type="checkbox"/>			830.87	0.0009	P	9.0
3	<input type="checkbox"/>	5.000	4.865	3046.74	0.0032	P	4.6
4	<input type="checkbox"/>	20.000	19.561	11826.95	0.0121	P	2.5
5	<input type="checkbox"/>	50.000	49.561	28635.24	0.0304	P	4.5
6	<input type="checkbox"/>	100.000	100.314	56870.72	0.0612	P	4.3

$$y = 6.0787E-004 * x + 2.4923E-004$$


R = 1.0000

DL = 0.3763

BEC = 0.41

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	11018.83	0.0112	P	3.0
2	<input type="checkbox"/>			12114.16	0.0130	P	1.7
3	<input type="checkbox"/>	5.000	4.576	19135.79	0.0202	P	8.0
4	<input type="checkbox"/>	20.000	18.269	45778.02	0.0470	P	2.5
5	<input type="checkbox"/>	50.000	49.996	102843.24	0.1092	P	3.6
6	<input type="checkbox"/>	100.000	100.370	193095.76	0.2079	P	4.2

$$y = 0.0020 * x + 0.0112$$

R = 0.9998



DL = 0.5138

BEC = 5.71


Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



Calibration for 034SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	283.63	0.0000	P	5.5
2	1.000	0.994	48099.99	0.0080	P	0.3
3	5.000	4.994	237121.11	0.0400	P	3.9
4	20.000	20.218	949506.68	0.1617	M	1.9
5	50.000	51.274	2476520.68	0.4100	A	1.7
6	100.000	99.320	4890881.02	0.7941	A	2.3

$$y = 0.0080 * x + 4.7176E-005$$


R = 0.9999

DL = 0.0009749

BEC = 0.005901

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	286.96	0.0000	P	10.8
2	1.000	0.980	45381.55	0.0075	P	4.0
3	5.000	5.048	229178.69	0.0386	P	1.3
4	20.000	20.179	905508.33	0.1542	P	3.6
5	50.000	50.756	2342841.40	0.3878	A	3.2
6	100.000	99.584	4684584.99	0.7609	A	2.4

$$y = 0.0076 * x + 4.7848E-005$$

R = 1.0000


DL = 0.002023

BEC = 0.006262

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	140.14	0.0000	P	5.5
2	<input type="checkbox"/>	1.000	1.028	10508.02	0.0017	P	4.2
3	<input type="checkbox"/>	5.000	5.206	51861.05	0.0087	P	5.9
4	<input type="checkbox"/>	20.000	20.585	202695.14	0.0345	P	2.9
5	<input type="checkbox"/>	50.000	51.775	524184.22	0.0868	P	1.6
6	<input type="checkbox"/>	100.000	98.985	1021375.73	0.1659	A	1.7

$$y = 0.0017 * x + 2.3199E-005$$


R = 0.9997

DL = 0.0023

BEC = 0.01384

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	268.64	0.0000	P	17.7
2	<input type="checkbox"/>	1.000	1.012	24212.97	0.0040	P	2.2
3	<input type="checkbox"/>	5.000	5.037	117827.27	0.0198	P	2.3
4	<input type="checkbox"/>	20.000	20.387	470892.19	0.0802	P	0.4
5	<input type="checkbox"/>	50.000	50.617	1201609.87	0.1990	A	1.1
6	<input type="checkbox"/>	100.000	99.612	2411201.93	0.3916	A	1.2

$$y = 0.0039 * x + 4.4743E-005$$

R = 1.0000


DL = 0.006048

BEC = 0.01138


Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>			3243.67		P	7.1
2	<input type="checkbox"/>			2813.14		P	7.8
3	<input type="checkbox"/>			3143.55		P	3.1
4	<input type="checkbox"/>			2746.39		P	3.0
5	<input type="checkbox"/>			4632.14		P	4.2
6	<input type="checkbox"/>			2846.50		P	1.7



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	977.69	0.0002	P	8.4
2	<input type="checkbox"/>			39905.81	0.0066	P	0.7
3	<input type="checkbox"/>	5.000	5.071	193360.30	0.0326	P	1.1
4	<input type="checkbox"/>	20.000	20.930	786627.82	0.1339	P	0.9
5	<input type="checkbox"/>	50.000	51.137	1974307.11	0.3270	A	4.4
6	<input type="checkbox"/>	100.000	99.242	3906476.84	0.6345	A	1.6

$$y = 0.0064 * x + 1.6251E-004$$

R = 0.9998


DL = 0.006422

BEC = 0.02542

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	0.000	0.000	694.05	0.0001	P	3.8
2	<input type="checkbox"/>			30157.07	0.0050	P	1.7
3	<input type="checkbox"/>	5.000	5.028	144482.46	0.0243	P	3.2
4	<input type="checkbox"/>	20.000	20.763	588378.21	0.1002	P	0.8
5	<input type="checkbox"/>	50.000	49.834	1450766.62	0.2403	A	2.3
6	<input type="checkbox"/>	100.000	99.929	2966317.68	0.4817	A	1.0

$$y = 0.0048 * x + 1.1495E-004$$


R = 1.0000

DL = 0.002703

BEC = 0.02385


Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>			0.00		P	
2	<input type="checkbox"/>			3.34		P	173.2
3	<input type="checkbox"/>			13.35		P	114.6
4	<input type="checkbox"/>			13.35		P	43.3
5	<input type="checkbox"/>			3.34		P	173.2
6	<input type="checkbox"/>			20.02		P	50.0

Calibration for 034SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	597.29	0.0001	P	11.7
2	<input type="checkbox"/>			13998.14	0.0019	P	5.5
3	<input type="checkbox"/>	5.000	5.084	65821.48	0.0091	P	2.8
4	<input type="checkbox"/>	20.000	20.159	266585.80	0.0359	P	4.0
5	<input type="checkbox"/>	50.000	51.403	683869.63	0.0915	P	3.2
6	<input type="checkbox"/>	100.000	99.262	1345986.07	0.1766	A	2.2

$$y = 0.0018 * x + 7.7440E-005$$


R = 0.9998

DL = 0.01527

BEC = 0.04355

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	3506.28	0.0005	P	4.0
2	<input type="checkbox"/>			89401.57	0.0119	P	6.8
3	<input type="checkbox"/>	5.000	5.184	431371.94	0.0598	P	1.6
4	<input type="checkbox"/>	20.000	19.733	1678582.56	0.2262	A	3.2
5	<input type="checkbox"/>	50.000	51.560	4412724.43	0.5902	A	2.2
6	<input type="checkbox"/>	100.000	99.264	8656778.88	1.1359	A	2.1

$$y = 0.0114 * x + 4.5739E-004$$

R = 0.9998


DL = 0.004788

BEC = 0.03999


Weight: <None>

Min Conc: 0

Calibration for 0345MPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>			93.43		P	6.2
2	<input type="checkbox"/>			76.74		P	15.1
3	<input type="checkbox"/>			150.15		P	24.0
4	<input type="checkbox"/>			246.92		P	11.7
5	<input type="checkbox"/>			633.99		P	10.3
6	<input type="checkbox"/>			1084.48		P	5.9



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>			340.35		P	25.1
2	<input type="checkbox"/>			276.95		P	29.0
3	<input type="checkbox"/>			233.57		P	10.8
4	<input type="checkbox"/>			200.20		P	8.7
5	<input type="checkbox"/>			300.31		P	20.3
6	<input type="checkbox"/>			276.95		P	19.9

Calibration for 034SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	1177.91	0.0002	P	10.9
2	1.000	1.001	75377.29	0.0100	P	2.8
3	5.000	5.065	361306.12	0.0500	P	1.7
4	20.000	20.419	1495460.54	0.2013	A	0.5
5	50.000	51.857	3820335.38	0.5109	A	1.7
6	100.000	98.984	7430534.96	0.9751	A	2.1

$$y = 0.0098 * x + 1.5415E-004$$


R = 0.9997

DL = 0.005118

BEC = 0.01565

Weight: <None>

Min Conc: 0



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	0.000	0.000	1081.14	0.0001	P	8.3
2	1.000	0.993	25915.60	0.0034	P	5.9
3	5.000	5.032	122007.30	0.0169	P	1.1
4	20.000	20.485	507216.98	0.0683	P	1.5
5	50.000	50.168	1250852.62	0.1672	A	1.9
6	100.000	99.822	2534280.18	0.3326	A	2.5

$$y = 0.0033 * x + 1.4111E-004$$

R = 1.0000


DL = 0.01052

BEC = 0.04237

Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	900.94	0.0001	P	8.9
2	<input type="checkbox"/>	1.000	0.961	22559.41	0.0030	P	2.5
3	<input type="checkbox"/>	5.000	4.957	108120.19	0.0150	P	1.7
4	<input type="checkbox"/>	20.000	20.093	447822.67	0.0603	P	4.0
5	<input type="checkbox"/>	50.000	50.408	1130686.34	0.1512	A	1.7
6	<input type="checkbox"/>	100.000	99.780	2279376.01	0.2992	A	3.2

$$y = 0.0030 * x + 1.1712E-004$$


R = 1.0000

DL = 0.01043

BEC = 0.03907

Weight: <None>

Min Conc: 0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	4224.54	0.0006	P	8.3
2	<input type="checkbox"/>	1.000	0.960	101765.84	0.0135	P	4.4
3	<input type="checkbox"/>	5.000	5.014	493519.96	0.0684	P	2.1
4	<input type="checkbox"/>	20.000	19.833	1994956.12	0.2688	A	3.3
5	<input type="checkbox"/>	50.000	50.750	5136034.53	0.6869	A	1.5
6	<input type="checkbox"/>	100.000	99.658	10270967.01	1.3483	A	3.6

$$y = 0.0135 * x + 5.5171E-004$$

R = 1.0000


DL = 0.01017

BEC = 0.0408


Weight: <None>

Min Conc: 0

Calibration for 034SMPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		3192463.75		A	3.8
2	<input type="checkbox"/>	1.000		2966195.73		A	0.4
3	<input type="checkbox"/>	1.000		3190010.52		A	0.4
4	<input type="checkbox"/>	1.000		3020031.59		A	1.2
5	<input type="checkbox"/>	1.000		3170237.44		A	1.9
6	<input type="checkbox"/>	1.000		3189276.56		A	4.7




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		985053.55		A	3.8
2	<input type="checkbox"/>	1.000		932925.50		A	1.8
3	<input type="checkbox"/>	1.000		951311.62		A	4.2
4	<input type="checkbox"/>	1.000		974141.14		A	0.9
5	<input type="checkbox"/>	1.000		942677.37		A	2.7
6	<input type="checkbox"/>	1.000		929433.47		A	2.2

Calibration for 034SMPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		6589730.69		A	5.7
2	<input type="checkbox"/>	1.000		6431916.95		A	2.8
3	<input type="checkbox"/>	1.000		6416481.10		A	2.1
4	<input type="checkbox"/>	1.000		6479084.74		A	1.5
5	<input type="checkbox"/>	1.000		6533526.27		A	4.1
6	<input type="checkbox"/>	1.000		6616146.49		A	1.0




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		6028461.51		A	7.5
2	<input type="checkbox"/>	1.000		6018228.41		A	1.3
3	<input type="checkbox"/>	1.000		5936977.21		A	3.6
4	<input type="checkbox"/>	1.000		5873458.59		A	1.6
5	<input type="checkbox"/>	1.000		6039303.56		A	1.7
6	<input type="checkbox"/>	1.000		6158894.07		A	3.1

Calibration for 034SMPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		8095462.21		A	6.5
2	<input type="checkbox"/>	1.000		7875911.52		A	2.9
3	<input type="checkbox"/>	1.000		7521362.55		A	1.2
4	<input type="checkbox"/>	1.000		7710399.40		A	5.2
5	<input type="checkbox"/>	1.000		7800498.25		A	2.1
6	<input type="checkbox"/>	1.000		7875746.20		A	1.3



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det	RSD
1	<input type="checkbox"/>	1.000		7679610.23		A	6.9
2	<input type="checkbox"/>	1.000		7529872.47		A	4.4
3	<input type="checkbox"/>	1.000		7220213.76		A	1.2
4	<input type="checkbox"/>	1.000		7429667.22		A	4.9
5	<input type="checkbox"/>	1.000		7479671.13		A	3.1
6	<input type="checkbox"/>	1.000		7623055.86		A	2.9

Calibration for 034SMPL.d



Acq	Date-Time	Sample Name	9 Be [tune 1]			51 V [tune 1]			52 Cr [tune 1]			55 Mn [tune 1]			59 Co [tune 1]			60 Cu [tune 1]			62 Ni [tune 1]			63 Cu [tune 1]						
			Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD				
23/2/23 13:17	CAL BLK		0.00000	N/A	0.00000	0.00000	N/A	0.00000	3.5913	0.9852	3.5237	0.9876	4.68714	4.3887	4.68714	4.3887	3.98468	3.98234	3.98468	3.98234	2.69866	0.9872	6.1664	0.98678	2.08400	0.9852	3.3317	0.98440	4.39865	
23/2/23 13:20	LFB	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105	1.0065	0.93105			
23/2/23 13:24	SPPB	4.8677	1.48771	4.7288	4.3387	4.8677	1.48771	4.8677	1.48771	4.8677	1.48771	4.8677	1.48771	4.8677	1.48771	4.8677	4.8677	4.8677	4.8677	4.8677	4.8677	4.8677	4.8677	4.8677	4.8677	4.8677	4.8677			
23/2/23 13:27	20 PPB	20.9866	1.1401	19.2986	0.4182	19.0824	1.7567	19.0774	1.5869	19.2212	1.0778	19.6258	1.0778	19.6258	1.0778	19.6258	1.0778	19.8442	1.05906	19.8442	1.05906	18.5818	6.0185	4.93228	1.05906	18.5818	6.0185	4.5576	1.0574	
23/2/23 13:31	50 PPB	23.2377	1.6058	2.6353	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975	49.7975				
23/2/23 13:34	100 PPB	99.8487	7.2887	100.1318	4.2573	100.3092	2.7318	100.3514	1.7089	100.5397	2.4881	100.3016	2.3574	100.4401	2.3069	100.4401	2.3069	100.4401	2.3069	100.4401	2.3069	100.533	1.0283	101.2247	3.4984	100.533	1.0283	101.2247	3.4984	
23/2/23 13:37	ICV	48.4981	3.96205	51.4628	4.0556	49.2195	1.5613	47.4295	1.3179	47.9031	2.1664	49.0566	2.6989	48.3817	1.6695	48.3817	1.6695	48.3817	1.6695	48.3817	1.6695	48.3817	1.6695	48.3817	1.6695	48.3817	1.6695	48.3817	1.6695	
23/2/23 13:40	ICB	0.3697	29.7011	0.34815	24.0461	0.32851	24.8355	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851	0.32851		
23/2/23 13:43	ICSA	0.0605	7.1455	0.2064	3.1719	0.2855	5.9868	0.1337	6.7891	0.0771	6.7821	0.1718	11.0539	0.36553	4.42042	4.53085	4.42042	4.53085	4.42042	4.53085	4.42042	4.53085	4.42042	4.53085	4.42042	4.53085	4.42042	4.53085	4.42042	4.53085
23/2/23 13:47	ICSB	49.33776	1.33855	47.1887	4.46305	46.7597	3.8345	45.3373	5.74703	44.2831	2.9849	45.1668	2.81398	43.6136	2.9849	45.1668	2.81398	45.1668	2.81398	45.1668	2.81398	45.1668	2.81398	45.1668	2.81398	45.1668	2.81398	45.1668	2.81398	
23/2/23 13:51	LB-A	0.02055	12.4520	0.0898	7.2721	0.7673	12.9719	0.31472	4.93467	0.0590	48.9997	0.0878	20.9882	0.0303	23.5779	0.1934	20.9882	0.0878	20.9882	0.0878	20.9882	0.0878	20.9882	0.0878	20.9882	0.0878	20.9882	0.0878	20.9882	
23/2/23 14:11	LCG-1A	48.6171	1.9287	49.8226	3.0608	49.33113	3.1610	48.3762	3.6970	46.8817	3.1610	47.6534	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738	4.86738		
23/2/23 14:14	LCG-1A-2X	1.06120	1.7288	5.0611	4.3098	5.2889	3.7824	5.03096	5.3806	5.09556	6.18666	5.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875	6.9875			
23/2/23 14:17	LCG-1A-4A	0.97660	4.40113	5.2553	4.34775	5.62825	1.2556	5.1372	1.0985	1.0922	4.9447	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058	5.1058			
23/2/23 14:20	LCG2-1A	0.02055	6.86605	5.23373	4.26538	5.3982	3.91537	8.6700	0.6810	1.1102	1.2364	5.6063	2.0722	5.39822	4.2106	5.39822	4.2106	5.39822	4.2106	5.39822	4.2106	5.39822	4.2106	5.39822	4.2106	5.39822	4.2106	5.39822	4.2106	
23/2/23 14:24	LCG3-1A	1.06078	5.06107	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631	5.19865	2.88631			
23/2/23 14:27	LCG4-1A	0.96929	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522			
23/2/23 14:30	LCG5-1A	0.02055	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522	4.93522			
23/2/23 14:33	LCG6-1A	1.07096	4.9769	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245	5.03245			
23/2/23 14:36	LCQ-1A	0.66537	5.89912	5.0794	3.1876	5.2695	5.6813	5.0775	5.2695	5.6813	5.0775	5.2695	5.6813	5.0775	5.2695	5.6813	5.0775	5.2695	5.6813	5.0775	5.2695	5.6813	5.0775	5.2695	5.6813	5.0775	5.2695	5.6813		
23/2/23 14:40	LCQ-1A	0.98640	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544	5.14544			
23/2/23 14:43	CCV	48.8269	2.5154	50.0731	4.6381	48.8897	3.00013	47.4517	4.3707	46.5492	6.2637	46.722	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254	4.67254		
23/2/23 14:46	CCB	0.29033	0.25611	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634	0.30634			
23/2/23 14:50	CCD	0.00687	12.7315	1.00549	22.3178	0.00888	6.90000	0.1405	3.1944	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473	0.49473				
23/2/23 14:53	CCF	1.06124	1.82011	4.9769	49.57184	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550	4.21550			
23/2/23 14:56	CCG-2A	1.07333	1.9733	5.05031	1.8841	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031	5.05031			
23/2/23 14:59	CCG-2A	0.96930	2.64244	4.91980	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017			
23/2/23 15:02	CCG-2A	0.96930	2.64244	4.91980	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017			
23/2/23 15:05	CCG-2A	0.96930	2.64244	4.91980	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017	5.17017			
23/2/23 15:08	CCG-2A	0.96930	2.64244	4																										

Acq. Date-Time	Sample Name	66 Zn [tune 1]		68 Zn [tune 1]		75 As [tune 1]		77 Se [tune 1]		78 Se [tune 1]		82 Se [tune 1]		107 Ag [tune 1]		109 Ag [tune 1]		111 Cd [tune 1]	
		Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD										
2/3/2023 13:17	CAL_U.K	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000										
2/3/2023 13:26	PPB	0.7166	17.2590	0.7732	3.1411	0.9727	6.8995	1.0862	12.4486	0.9173	12.4452	1.2201	5.3267	0.9637	0.2810	4.2464	0.9804	1.0278	4.2200
2/3/2023 13:24	5 PPB	4.1537	5.8950	4.3760	3.3356	4.9207	2.1841	4.8658	4.9400	4.5758	1.7962	4.6025	5.3607	4.5641	3.6830	5.0476	1.2673	5.2061	5.9425
2/3/2023 13:27	20 PPB	19.1474	3.8616	19.2297	1.7628	19.8092	1.5352	19.5612	2.5580	18.2848	18.7814	3.3422	14.1842	20.2178	1.9475	3.6032	20.5845	2.9162	
2/3/2023 13:31	50 PPB	48.2936	5.2273	49.7045	3.0812	50.4244	1.6741	49.5612	4.8259	49.9857	3.9808	50.7448	6.5143	51.2237	1.7251	50.7650	3.1655	51.7747	1.5670
2/3/2023 13:34	100 PPB	100.5923	10.9316	100.1618	0.7485	100.4239	2.0655	100.3139	4.2498	100.3696	4.4335	99.8812	9.0069	99.3199	2.3162	99.3939	2.4454	98.9852	1.8618
2/3/2023 13:37	ICV	48.4100	3.1316	49.0565	1.3966	49.9623	0.4683	50.5002	48.6450	50.5002	48.6777	1.7748	48.2024	2.6042	51.9293	3.1706	52.3954	4.8921	51.5765
2/3/2023 13:40	ICB	<0.0000	N/A	<0.0000	N/A	8.6684	'3.03654	0.45652	33.0058	0.1079	253.7028	0.4249	55.6658	0.3635	18.6856	0.3598	21.8391	0.3416	15.5648
2/3/2023 13:43	ICSA	1.4984	8.6639	1.3122	8.9860	1.2418	5.0447	0.9857	22.5254	0.6914	8028.364	0.1169	125.7448	0.0951	31.0232	3.6171	11.5833	0.3106	2.9461
2/3/2023 13:47	ICSAB	41.4660	6.3115	47.6560	1.0291	48.1960	0.8768	48.4029	3.1988	47.4431	3.7584	47.4353	5.9727	46.1033	1.0346	44.5843	5.7536	51.2639	1.9414
2/3/2023 14:11	IB-IA	3.8629	7.1098	3.7716	3.1600	5.5955	5.1844	0.1688	0.0000	N/A	0.4522	48.2134	0.0361	12.7850	0.6071	49.5626	0.0146	60.9116	
2/3/2023 14:14	I.C-S.1A.2X	65.7083	1.2461	65.6921	1.0692	48.3152	1.1026	49.7138	0.39972	46.4627	3.15181	46.2235	3.4620	50.1110	2.8111	50.9723	2.2839	50.0531	0.7624
2/3/2023 14:17	I.OC1-1A	25.7281	6.6358	24.6536	5.9882	6.1367	2.8470	4.9636	3.3552	4.4302	4.5552	5.3687	5.3658	1.1532	6.8686	1.4113	3.9864	1.1252	
2/3/2023 14:20	LOC2-1A	22.8975	1.2984	23.3557	1.1419	22.5366	0.4569	5.2163	6.2217	5.6543	8.6683	5.4531	1.0794	1.6439	1.0681	3.7158	1.0491	8.2149	
2/3/2023 14:24	LOC3-1A	20.1616	3.8184	34.1864	3.4586	5.7208	2.1161	5.5394	9.5719	4.4817	7.0715	5.5084	6.8630	0.6517	2.0262	1.0236	1.7575	1.0331	4.3848
2/3/2023 14:27	I.OG4-1A	26.1518	1.9568	26.3614	2.0656	5.1944	2.7566	5.0348	0.44478	4.55349	10.2164	5.1028	5.7330	0.0713	3.8466	1.0596	2.5716	1.0578	6.7678
2/3/2023 14:30	LOC5-1A	28.0934	1.9813	21.5175	1.3219	5.2924	3.3124	5.0349	7.2633	4.0911	8.3113	5.6283	4.0704	2.8126	1.0729	3.6122	1.0584	0.7677	
2/3/2023 14:33	LOC6-1A	30.5506	4.3280	20.8721	2.6263	20.8721	2.6263	2.9698	5.2228	5.9573	4.45658	1.0854	5.2041	7.2330	1.0546	5.2287	1.0431	1.7217	1.0641
2/3/2023 14:36	LOC7-1A	28.3819	3.8704	23.9482	2.3726	4.8180	5.2180	3.4706	4.3185	6.7777	4.9408	7.1754	7.2048	2.3967	1.0677	2.4093	1.0143	3.5387	
2/3/2023 14:40	LOC8-1A	43.0634	4.3103	44.0453	2.2782	4.7809	3.1812	4.9860	6.5589	4.4265	5.6198	5.2273	3.4681	1.0002	3.1753	1.0016	2.4398	1.0218	3.3214
2/3/2023 14:43	CCV	41.2647	3.8927	46.6422	4.0806	48.4182	3.1620	47.6653	2.4650	46.6361	4.7650	4.6550	47.7100	1.0226	58.8266	1.2192	51.4569	1.2891	
2/3/2023 14:46	CCB	<0.0000	N/A	<0.0000	N/A	0.2817	0.1725	34.8179	0.1212	103.4699	0.5924	0.2829	2.5685	0.2735	5.5744	0.2921	11.3733		
2/3/2023 15:15	LB-2A	2.3844	6.1115	2.3594	1.3191	<0.0000	N/A	<0.0000	N/A	0.0753	136.4187	0.0050	38.0653	0.0117	26.7071	0.0064	58.8298		
2/3/2023 15:22	LGS.1A.2X	49.1629	2.5513	1.7649	4.04149	1.6541	4.2426	4.64649	3.0299	4.1649	3.0179	2.9691	52.0339	3.1664	51.8754	0.0031	50.6239	1.4302	
2/3/2023 15:25	LOQ1-2A	20.5757	3.4930	20.4022	2.80447	4.7728	1.1745	4.8481	2.4246	4.5739	4.8013	0.5332	1.1564	8.3865	1.114	9.4043	1.1803	8.3930	
2/3/2023 15:28	LOQ2-2A	20.2167	3.5872	20.1822	2.0572	4.6723	4.8340	2.3918	4.1040	10.3749	4.9130	10.5645	1.0797	3.5311	1.0802	2.7400	1.0846	4.3126	
2/3/2023 15:32	LOQ3-2A	19.6834	4.3833	19.6995	3.0258	4.6207	4.6725	4.6319	4.1026	4.1987	4.7546	12.1397	9.9980	2.0666	3.4654	1.0304	5.3662		
2/3/2023 15:35	LOQ4-2A	20.4530	3.1984	19.9685	1.7785	4.7454	1.4072	4.8733	3.9695	4.1516	10.3796	4.9552	6.1271	1.0276	2.6866	0.0064	5.7425		
2/3/2023 15:38	LOQ5-2A	33.9413	2.4238	33.3609	2.8065	4.7181	3.2181	4.7178	5.1785	4.4737	4.0239	5.5459	3.9864	3.3694	1.0069	2.4582	0.9897	5.5121	
2/3/2023 15:41	LOQ6-2A	5.1434	20.7436	4.0320	4.7718	4.2003	5.5588	4.5948	3.3748	5.0852	5.0852	9.8374	1.0277	2.2206	1.0045	4.0103	1.0655	6.5163	
2/3/2023 15:45	LOQ7-2A	20.2199	2.6113	20.9778	3.2460	4.6653	2.9750	4.4368	7.2780	4.2210	10.5710	4.7923	5.6050	1.0018	3.7657	0.9920	1.0548		
2/3/2023 15:48	LOQ8-2A	25.6302	1.7123	22.4395	0.7680	4.8100	2.4131	4.8365	2.8056	4.3367	5.6011	4.9716	3.1238	1.0134	4.1861	1.0138	2.6231	1.0270	8.2147
2/3/2023 15:51	CCV	41.6521	3.1676	48.3315	1.7601	48.2719	2.8290	47.5860	4.1661	46.3668	3.5586	46.5836	0.8400	51.3078	3.5487	51.1922	3.3655	51.4480	2.5810
2/3/2023 15:54	CCB	<0.0000	N/A	<0.0000	N/A	0.2499	12.7627	0.0880	97.7399	0.3033	84.8582	0.5123	18.1597	0.2658	11.4296	0.2551	14.2257	0.2620	17.5324

7 L (STD) [line 1]			72 Ge (STD) [line 1]			69 Y (STD) [line 1]			115 In (STD) [line 1]			158 Tb (STD) [line 1]			165 Ho (STD) [line 1]			209 Bi (STD) [line 1]		
Acq Date	Time	Sample Name	CPS	STD Recovery %	CPS	STD Recovery %	CPS	STD Recovery %	CPS	STD Recovery %	CPS	STD Recovery %	CPS	STD Recovery %	CPS	STD Recovery %	CPS	STD Recovery %		
2/3/2023 13:17		CAL_B1_K	3192463.75	100.00	985055.56	100.00	6539730.69	100.00	60224461.51	100.00	80894642.21	100.00	7629610.23	100.00	44427284.94	100.00	44427284.94	100.00		
2/3/2023 13:20	1 PFB	2866198.73	92.91	937925.50	94.71	6431916.95	97.61	6013228.41	99.63	78781152	97.29	7573872.47	98.65	4225000.53	95.10					
2/3/2023 13:24	5 PFB	3190015.52	99.92	951311.62	96.57	6416486.10	97.31	5235897.21	98.48	751382.55	92.91	7220214.76	94.05	4264724.16	95.99					
2/3/2023 13:27	20 PFB	3020631.59	94.60	974411.14	98.89	6479084.74	98.32	5873458.59	97.43	7710399.40	95.24	7429867.22	96.75	4255674.38	95.34					
2/3/2023 13:31	50 PFB	3170237.44	99.30	942677.37	95.70	6533526.27	99.16	6039303.56	100.18	7800498.25	96.36	7471967.13	97.46	4355365.70	98.03					
2/3/2023 13:34	100 PFB	3188276.56	98.90	929433.47	94.35	6516146.49	100.40	6152804.07	102.16	7875746.20	97.20	7623055.86	99.26	4370279.71	98.37					
2/3/2023 13:37	ICV	294574.26	82.26	8842.50	89.95	66044829.51	91.73	6056864.97	92.17	7184919.57	88.51	6365690.17	89.42	3955334.75	89.03					
2/3/2023 13:40	ICB	3087413.01	96.21	9715814.20	99.83	6050649.54	100.24	6080662.02	101.60	7331565.90	98.05	7521151.31	97.93	4355667.06	98.05					
2/3/2023 13:43	ICSA	2856560.08	90.70	944194.20	95.85	629176.84	95.47	5707280.28	94.61	7539750.08	93.13	7160988.10	95.26	3863151.64	96.96					
2/3/2023 13:47	ICSAB	2852056.58	90.59	910798.98	92.46	6032322.68	91.54	5513011.10	91.45	7271042.30	89.82	6398357.96	91.11	3811574.63	95.79					
2/3/2023 14:01	LB_1A	3006205.53	94.00	979160.03	99.40	709205.03	100.68	6026712.57	100.92	8830006.76	108.07	8183441.80	109.17	4754104.27	107.02					
2/3/2023 14:14	LCG-IA_2X	2903055.16	91.47	958291.07	91.07	6580249.13	101.32	6265119.15	104.26	8322004.59	102.80	7988015.13	102.71	4517164.50	101.58					
2/3/2023 14:17	LQ01-1A	30486762.96	86.89	979301.63	99.47	7153717.47	108.56	6288176.50	104.32	8772753.38	108.37	8234470.01	107.23	4643751.09	104.52					
2/3/2023 14:20	LQ02-1A	30046582.83	94.12	9406351.73	95.49	6902249.04	104.74	6217581.61	103.14	8631764.82	106.40	8244714.11	107.36	4615985.21	103.99					
2/3/2023 14:24	LQ03-1A	2989167.49	91.74	926346.88	94.04	710106.38	107.76	6394821.98	106.08	8371306.11	103.41	8057467.17	104.44	4398950.51	99.07					
2/3/2023 14:27	LQ04-1A	30266282.13	94.81	958313.61	97.29	6947445.79	105.43	63050526.26	104.66	8577082.39	105.71	8127268.75	106.47	4597459.07	103.37					
2/3/2023 14:30	LQ05-1A	30862020.32	96.67	990562.05	100.56	7229051.03	109.70	647247.10	107.48	8304821.61	102.59	7987716.60	104.00	4524555.32	101.84					
2/3/2023 14:33	LQ06-1A	2833917.70	88.77	972492.63	98.12	6626558.45	105.11	631376.70	104.69	8539010.78	106.70	8232099.00	107.19	4596724.70	103.47					
2/3/2023 14:36	LQ07-1A	309401.00	96.80	952995.38	97.95	6927082.31	105.12	6120.17	8680289.77	112.01	8330753.90	108.48	4802948.72	108.11						
2/3/2023 14:40	LQ08-1A	3042313.31	95.30	961908.18	97.65	6776907.94	102.83	6382734.46	109.31	8329623.69	102.89	7971579.95	103.74	4476885.40	100.77					
2/3/2023 14:43	CCV	2760898.02	84.86	493112.10	91.67	6148937.53	93.31	360125.69	92.91	7432901.86	91.82	7146150.29	90.05	4083011.31	91.90					
2/3/2023 14:46	CCB	329724.85	88.67	89319.00	90.89	6188012.64	93.90	5394861.44	96.13	743225.55	91.81	7356850.94	95.95	4083011.31	91.90					
2/3/2023 15:19	LB_3A	3126078.44	98.00	921000.70	94.11	5589244.90	99.99	5801988.57	96.74	7961047.81	98.41	7616021.36	99.95	4260651.84	91.87					
2/3/2023 15:22	(C)5_2A_2X	3040811.15	95.25	911980.35	92.88	637866.30	96.80	5932081.91	98.38	7525458.54	94.52	4180212.21	94.27							
2/3/2023 15:25	LQ01-2A	328199.15	104.27	985565.21	99.75	5858638.47	104.71	6168359.52	105.64	5298891.66	102.53	7922015.89	113.15	4278796.09	98.55					
2/3/2023 15:28	LQ02-2A	3270804.10	101.20	966139.77	98.38	6701945.20	101.70	6152726.25	102.07	7912984.33	97.75	7518458.21	97.90	4156553.60	98.04					
2/3/2023 15:32	LQ03-2A	3294886.27	102.89	953217.66	96.17	6719454.40	101.97	6256534.22	103.78	826722.76	102.12	7719142.26	100.61	4380392.68	98.60					
2/3/2023 15:35	LQ04-2A	3242892.36	101.58	937811.72	94.70	653424.38	99.16	6076522.81	100.80	7959018.91	97.94	773310.11	100.13	4344554.24	97.14					
2/3/2023 15:38	LQ05-2A	3163286.48	99.77	911984.63	92.48	6474855.98	98.26	6003407.33	99.58	8124398.62	100.36	7252458.54	94.44	4260651.84	91.91					
2/3/2023 15:41	LQ06-2A	3153085.45	93.34	911934.90	92.34	5858638.47	99.87	5858542.17	97.64	7541134.67	98.43	4138339.21	93.15							
2/3/2023 15:45	LQ07-2A	3258845.15	102.11	951975.58	97.16	677812.10	102.87	6205870.88	102.94	6185834.20	100.51	7865880.95	102.46	4364776.13	98.24					
2/3/2023 15:48	LQ08-2A	3353045.19	104.95	934367.32	94.85	6807191.64	103.30	6087591.75	100.88	7940577.93	98.09	7610425.68	98.10	4257810.37	95.84					
2/3/2023 15:51	CCV	2903165.28	90.94	874075.50	88.33	603112.78	91.52	5540529.95	92.00	7496724.92	92.60	773676.65	93.43	3687932.43	88.76					
2/3/2023 15:54	CCB	2546852.53	92.31	805067.77	88.76	603067.77	91.52	5716990.57	94.83	7072840.98	87.37	6772848.92	88.19	3696222.20	89.32					

ICP-MS Raw Data Coversheet
Instrument (X)

Doc. No.: RD05

Rev.:G

Effective Date: 08-05-22

Analyst(s):	KAH	Analysis Date(s):	2/16/23
EA Project #s:	M29 G020 X LOGs		
Analytes:	As, Mn, Zn, Ba		EE KAH 2/16/23
Method:	G020	Smart Tune ID: ES-0804 Internal Standard ID ¹ : F0773	Conc: 10 ppm 1ppb Exp: 7/3/23 Conc: 10 ppm Exp: 2/23
Diluent:	50 mL HNO3 (ID # 22380017)	Exp: 9/24) diluted to 1000 mL with DI
Calib. Blk/ICB/CCB:	Diluent		

¹ All samples and standards are spiked with 50µL of internal std. (pipette 127 exp 3/4/23)
 Calibration Standards - Made from EA ID#²: 1:10 F0824 (Stock Concentration: 10 ppm)
 Exp Date: 2/17/23) and brought up with Diluent

	Final Conc. (ppb)	Amount (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
Standard 1	150	100 of Std 6	124 3/4/23					
Standard 2	810	500 of Std 6						
Standard 3	20	2mL Std6	1					
Standard 4	50	50	127					
Standard 5	100	100						
No IS Std 6	100	100	1					

² 10ppm WS = 1mL of Standard F0824 exp 7/125 (pipettes: 124, 141 exp 3/4/23) + 9mL Diluent

Secondary Standards - Made from EA ID#: F0814 (Stock Concentration: 10 ppm)
 Exp Date: 11/23) and brought up with Diluent

	Final Conc. (ppb)	Amount (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
ICV/CCV	50	50	127 3/4/23	10	141 3/4/23	KAH	2/16/23	2/17/23

ICS's- Made from Stock Std ICS-A ID#(F0786 Exp: 9/25)
 & 50 ppb Metals Std ID#(F0814 Conc: 10 ppm Exp: 11/23) brought up with Diluent

	Conc.	Amount WS (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst	Date	Exp. Date
ICS-A	Multi	100	127 3/4/23					
ICS-AB	Multi	100						
	50 ppb	50	1					

Post Dig Matrix Spike Samples - Diluted with Diluent (Metals Mix ID# _____)				Conc: _____	Exp: _____			
Sample ID	Dilution Factor of Field Sample	Aliquot of Sample (mL)	Final Conc. (ppb)	Amount of Spike Added (µL)	Pipette # & Exp:	Final Vol (mL)	Pipette # & Exp:	Analyst
						10		
						10		
						10		
						10		
						10		
						10		
						10		
						10		

③ 5ppb 500 µL Std6 2/16/23

Controlled Document 10ppb 1mL Std6 KAH 2/16/23 Job# 0223176R Page 130 of 186
 Confined to Enthalpy Analytical W002AS023392 RT4542 EE KAH 325 of 688

ICP-MS Raw Data Coversheet
Instrument(X) _____

Doc. No.: RD05

Rev. G

Effective Date: 08-05-22

Comments:

Acq. Date-Time	Sample Name	55 Mn [tune 1]			66 Zn [tune 1]			68 Zn [tune 1]			75 As [tune 1]			137 Ba [tune 1]			138 Ba [tune 1]		
		Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD	Conc. [ppb]	Conc. RSD		
2/16/2023 14:14	CAL BLK	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A	0.0000	N/A		
2/16/2023 14:17	5 PPB	4.9627	2.6817	4.6663	1.3884	4.5814	4.5973	4.6939	1.5824	4.8264	3.6332	4.7508	3.5943	4.7508	3.5943	4.7508	3.5943		
2/16/2023 14:20	10 PPB	10.0068	1.9238	9.9468	4.7953	9.6326	5.3567	9.7236	1.8757	9.5850	3.1201	9.6143	1.1507	9.6143	1.1507	9.6143	1.1507		
2/16/2023 14:23	20 PPB	19.4146	1.5472	20.2086	1.6566	20.1351	2.1689	20.0668	0.9059	19.1407	3.6546	19.3028	1.9194	19.3028	1.9194	19.3028	1.9194		
2/16/2023 14:26	50 PPB	50.4978	2.1817	50.0270	1.8103	49.4470	0.8617	49.7705	0.9302	49.4909	1.0722	48.8829	2.0232	48.8829	2.0232	48.8829	2.0232		
2/16/2023 14:29	100 PPB	99.8694	1.4027	99.9448	1.5750	100.2495	2.9652	100.1443	1.9036	100.4766	1.5843	100.7450	3.9512	100.7450	3.9512	100.7450	3.9512		
2/16/2023 15:12	iCY	50.3502	0.9720	49.7309	3.9383	50.2926	0.2352	50.4107	3.0667	48.5621	3.6698	48.6698	1.5864	48.6698	1.5864	48.6698	1.5864		
2/16/2023 15:15	iCB	0.2365	10.2227	<0.0000	N/A	<0.0000	N/A	0.2526	8.0246	0.1970	0.6594	0.2197	8.0640	0.2197	8.0640	0.2197	8.0640		
2/16/2023 15:18	iCSA	0.2401	13.3435	2.3564	4.1687	2.0928	6.9325	0.4312	4.3133	0.1932	20.5441	0.2078	11.2861	0.2078	11.2861	0.2078	11.2861		
2/16/2023 15:21	iCSAB	49.1888	2.8105	52.1901	1.8027	51.3700	1.9522	51.8181	1.5367	49.3129	2.7093	50.0345	3.9418	50.0345	3.9418	50.0345	3.9418		
2/16/2023 15:27	LB-1	0.3502	8.6982	3.2350	7.7310	3.1409	5.0149	7.4196	3.9204	3.0213	1.0906	3.3538	1.0906	3.3538	1.0906	3.3538	1.0906		
2/16/2023 15:30	LCS-1	52.9262	1.3568	53.0764	3.3200	53.1787	1.2085	53.1225	3.0370	53.0435	1.6448	53.0752	1.8554	53.0752	1.8554	53.0752	1.8554		
2/16/2023 15:33	LOQ1-1	5.9480	2.1350	22.9760	2.4107	22.5432	1.0852	6.6014	4.5264	5.005	0.0617	5.4488	3.7420	5.4488	3.7420	5.4488	3.7420		
2/16/2023 15:36	LOQ2-1	5.1661	3.6439	21.3440	1.4135	21.3638	5.5831	5.9260	5.8895	5.1766	1.0484	5.1507	0.8421	5.1507	0.8421	5.1507	0.8421		
2/16/2023 15:39	LOQ3-1	5.3852	1.5991	22.0374	2.6334	21.6754	1.9302	5.5396	5.6085	4.9709	1.9314	4.9854	2.0292	4.9854	2.0292	4.9854	2.0292		
2/16/2023 15:42	LOQ4-1	5.2467	2.8438	21.7757	1.7535	21.4063	2.6742	5.5867	2.5579	5.2453	3.9683	5.2027	2.8508	5.2027	2.8508	5.2027	2.8508		
2/16/2023 15:46	LOQ5-1	5.2820	3.7171	20.7123	2.8328	20.9882	3.4788	5.5604	3.8335	4.9904	0.4753	4.9827	2.2198	4.9827	2.2198	4.9827	2.2198		
2/16/2023 15:49	LOQ6-1	5.2661	1.2616	23.7768	1.5695	23.8893	0.7627	5.6309	2.1591	5.2901	3.6649	5.4951	1.0479	5.4951	1.0479	5.4951	1.0479		
2/16/2023 15:52	LOQ7-1	5.1042	1.8694	21.4484	1.5465	21.1411	2.3542	5.0863	1.3547	4.9865	1.0618	4.8818	2.9204	4.8818	2.9204	4.8818	2.9204		
2/16/2023 15:55	LOQ8-1	5.1853	1.9751	217.3869	3.2392	213.1079	2.4172	5.3691	4.4130	8.9091	3.1486	8.9534	3.8298	8.9534	3.8298	8.9534	3.8298		
2/16/2023 15:58	CCV	50.1454	0.7375	51.5430	1.8598	51.6782	0.7520	50.3102	2.0518	49.7951	3.6363	50.5881	2.0927	50.5881	2.0927	50.5881	2.0927		
2/16/2023 16:05	CCB	0.2424	18.5524	0.0371	349.2564	0.0574	133.8759	0.4653	12.8897	0.2211	8.6426	0.2060	14.4440	0.2060	14.4440	0.2060	14.4440		
2/16/2023 16:10	LB-1 RP	0.1964	8.8379	2.7433	2.2169	2.5615	5.6244	1.1538	8.4668	0.9733	4.2392	0.9616	4.4076	0.9616	4.4076	0.9616	4.4076		
2/16/2023 16:13	LOQ8-1 RP	5.2032	0.4938	23.8730	2.7269	23.6832	1.7922	5.2859	3.2440	8.5695	4.2223	8.6736	3.0566	8.6736	3.0566	8.6736	3.0566		
2/16/2023 16:16	CCV	49.4981	4.4051	49.8243	1.0245	50.5082	1.2605	51.2277	1.9818	49.0456	1.6145	49.5437	3.2345	49.5437	3.2345	49.5437	3.2345		
2/16/2023 16:20	CCB	0.3117	17.6938	<0.0000	N/A	<0.0000	N/A	0.5256	6.1337	0.3125	31.0339	0.2805	20.3016	0.2805	20.3016	0.2805	20.3016		



Acq. Date-Time	Sample Name	72 Ge (ISTD) [tune 1]		89 Y (ISTD) [tune 1]		115 In (ISTD) [tune 1]		159 Tb (ISTD) [tune 1]	
		CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %	CPS	ISTD Recovery %
2/16/2023 14:14	Cal BLK	185583.00	100.00	1207247.56	100.00	1095157.77	100.00	1407278.44	100.00
2/16/2023 14:17	5 PPB	187245.48	100.90	1213521.98	100.52	1087668.50	99.32	1437748.65	102.17
2/16/2023 14:20	10 PPB	181347.08	97.72	1161336.40	96.20	1056106.72	96.44	1412340.89	100.36
2/16/2023 14:23	20 PPB	184352.94	99.34	1156870.76	95.83	1066004.00	97.34	1387827.15	98.62
2/16/2023 14:26	50 PPB	183462.51	98.86	1161144.70	96.18	1049804.22	95.86	1406473.39	99.94
2/16/2023 14:29	100 PPB	185581.29	100.05	1195138.30	95.68	1034012.21	94.42	1406563.49	99.95
2/16/2023 15:12	ICV	186928.92	100.72	1163128.48	96.35	1039347.71	94.90	1361429.89	96.74
2/16/2023 15:15	ICB	179193.25	96.56	1162764.41	98.32	105780.77	95.49	1337127.40	95.02
2/16/2023 15:18	ICSA	177364.67	95.57	1096382.79	98.87	942567.38	89.72	1276643.17	90.86
2/16/2023 15:21	ICSB	177597.28	95.70	1098148.59	90.96	960248.58	89.51	1326343.80	94.25
2/16/2023 15:27	LB-1	192460.67	103.71	1242944.25	102.96	1166708.03	106.53	1554062.11	110.43
2/16/2023 15:30	LCS-1	181553.04	97.83	1192266.89	98.76	1067663.23	97.49	14769402.12	104.49
2/16/2023 15:33	LOQ1-1	188333.08	101.48	1215515.84	100.68	1125559.16	102.32	1558988.11	110.78
2/16/2023 15:36	LOQ2-1	191755.76	103.33	1201443.76	99.52	1121505.86	102.59	1519539.25	107.98
2/16/2023 15:39	LOQ3-1	191230.26	103.04	1237448.34	102.50	1133154.12	104.38	1580165.81	112.29
2/16/2023 15:42	LOQ4-1	186916.31	108.72	1193391.59	98.85	117882.00	132.07	1522254.68	108.17
2/16/2023 15:46	LOQ5-1	187094.73	100.81	1226067.27	101.56	1128726.60	103.07	1554962.72	110.49
2/16/2023 15:49	LOQ6-1	185162.01	99.93	1222544.40	101.27	116484.33	101.95	1520890.12	108.07
2/16/2023 15:52	LOQ7-1	187121.61	100.88	1234181.38	102.23	1141035.91	104.55	1541835.84	109.56
2/16/2023 15:55	LOQ8-1	192408.76	103.68	1212377.87	100.42	1110550.32	101.41	1576249.55	112.01
2/16/2023 15:58	CCV	180599.38	97.31	1138268.36	94.29	1038980.13	94.87	1402147.78	98.64
2/16/2023 16:05	CCB	176106.79	94.89	1114443.43	92.31	1029862.61	94.04	1347961.85	95.79
2/16/2023 16:10	LB-1 RP	187973.92	101.29	1210377.78	103.26	1112087.72	101.55	1524588.04	108.34
2/16/2023 16:13	LOQ8-1 RP	192833.02	103.91	1237486.69	102.50	1141648.98	104.25	1524779.10	108.35
2/16/2023 16:16	CCV	181092.58	97.58	1144266.57	94.78	1038742.96	94.85	1384272.30	98.37
2/16/2023 16:20	CCB	176396.99	95.05	1122747.69	93.00	1016062.50	92.78	1379605.58	98.03

Calibration for 026SMPL.d



Batch Folder: D:\Agilent\ICPMH\1\DATA\2023\As, Zn, Mn, Ba LOQ RR 021623.b\
Analysis File: As, Zn, Mn, Ba LOQ RR 021623.batch.bin
DA Date-Time: 2/16/2023 4:20:52 PM
Calibration Title:
Calibration Method: External Calibration
VIS Interpolation Fit:

Level	Standard Data File	Sample Name	Acq. Date-Time
1	001CALB.d	CAL BLK	2/16/2023 2:14:08 PM
2	002CALS.d	5 PPB	2/16/2023 2:17:16 PM
3	003CALS.d	10 PPB	2/16/2023 2:20:26 PM
4	004CALS.d	20 PPB	2/16/2023 2:23:35 PM
5	005CALS.d	50 PPB	2/16/2023 2:26:46 PM
6	006CALS.d	100 PPB	2/16/2023 2:29:55 PM



Calibration for 026SMPL.d




Calibration for 026SMPL.d




Calibration for 026SMPL.d



Calibration for 026SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>			123.46		P	30.7
2	<input type="checkbox"/>			90.09		P	19.2
3	<input type="checkbox"/>			353.70		P	8.6
4	<input type="checkbox"/>			180.18		P	20.0
5	<input type="checkbox"/>			80.08		P	21.7
6	<input type="checkbox"/>			86.75		P	24.0



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	0.000	0.000	10.01	0.0000	P	100.1
2	<input type="checkbox"/>	5.000	4.826	13193.15	0.0121	P	3.6
3	<input type="checkbox"/>	10.000	9.585	25446.69	0.0241	P	3.1
4	<input type="checkbox"/>	20.000	19.141	51259.72	0.0481	P	3.7
5	<input type="checkbox"/>	50.000	49.491	130561.54	0.1244	P	1.1
6	<input type="checkbox"/>	100.000	100.477	261034.64	0.2525	P	1.6

$$y = 0.0025 * x + 9.0807E-006$$

R = 0.9999


DL = 0.01085

BEC = 0.003614

Weight: <None>

Min Conc: 0

Calibration for 026SMPL.d



Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	0.000	0.000	96.67	0.0001	P	41.0
2	5.000	4.751	82244.91	0.0757	P	3.6
3	10.000	9.614	161615.51	0.1530	P	1.2
4	20.000	19.303	327351.15	0.3072	P	1.9
5	50.000	48.883	816426.60	0.7777	P	2.0
6	100.000	100.749	1657025.18	1.6028	A	4.0

$$y = 0.0159 * x + 8.7970E-005$$


R = 0.9999

DL = 0.006809

BEC = 0.00553


Weight: <None>

Min Conc: 0




Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1			23.36		P	49.5
2			23.36		P	24.7
3			30.03		P	66.7
4			40.04		P	25.0
5			106.77		P	23.6
6			180.18		P	41.9

Calibration for 026SMPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>			23.36		P	24.7
2	<input type="checkbox"/>			43.38		P	70.5
3	<input type="checkbox"/>			46.71		P	49.5
4	<input type="checkbox"/>			50.05		P	69.3
5	<input type="checkbox"/>			66.73		P	52.7
6	<input type="checkbox"/>			60.06		P	44.1




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		185583.60		P	2.4
2	<input type="checkbox"/>	1.000		187245.48		P	1.0
3	<input type="checkbox"/>	1.000		181347.08		P	1.4
4	<input type="checkbox"/>	1.000		184352.94		P	2.1
5	<input type="checkbox"/>	1.000		183462.51		P	2.1
6	<input type="checkbox"/>	1.000		185681.29		P	0.7

Calibration for 026SMPL.d




	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		1207247.56		A	0.4
2	<input type="checkbox"/>	1.000		1213521.98		A	2.0
3	<input type="checkbox"/>	1.000		1161336.40		A	0.9
4	<input type="checkbox"/>	1.000		1156870.76		A	0.9
5	<input type="checkbox"/>	1.000		1161144.70		A	1.5
6	<input type="checkbox"/>	1.000		1155138.30		A	2.8



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		1095157.77		A	1.3
2	<input type="checkbox"/>	1.000		1087668.50		A	2.8
3	<input type="checkbox"/>	1.000		1056166.72		A	1.4
4	<input type="checkbox"/>	1.000		1066004.00		A	2.0
5	<input type="checkbox"/>	1.000		1049804.22		A	1.1
6	<input type="checkbox"/>	1.000		1034012.21		A	1.8

Calibration for 026SMPL.d



	Rjct	Conc.	Calc Conc.	CPS	Ratio	Det.	RSD
1	<input type="checkbox"/>	1.000		1407278.44		A	3.4
2	<input type="checkbox"/>	1.000		1437748.65		A	1.8
3	<input type="checkbox"/>	1.000		1412340.89		A	2.2
4	<input type="checkbox"/>	1.000		1387827.15		A	1.2
5	<input type="checkbox"/>	1.000		1406473.39		A	0.3
6	<input type="checkbox"/>	1.000		1406563.49		A	0.3

Raw Data



EA Job# 0223-176R Page 143 of 186

W002AS-023392-RT-4542

348 of 688

Analyst: LMP

Date: 2/27/23

Job #s

Describe Work Documented on This Page

0223-176

M29 Hg Analysis

1382A = CVAH Std Prep log

1382B = M29 Hg prep sheet

Supplies, Ancillary Equipment
Serial #s, Lot #s, Etc

NA

LMP 2/27/23


Reviewer's Initials & Date:

Metals Prep

EA Job# 0223-176 Page 2144 of 186

W002AS-023392-RT-4542

349 of 688



ENTHALPY
ANALYTICAL

1382 R

CVAAC Standard Preparation Log *Stds must be prepared fresh daily

EA Std ID# Hg (Job #1, 2, 3, etc.)	Std/Reagent Name	Conc.	Stock Standard/Reagent	Conc.	EA ID# & Exp Date	Amount Added	Final Volume (mL) & Diluent	Pipette & Exp Date	Analyst	Date	Exp. Date
1											
Primary Intermediate Standard											
1	Primary Int. Std.	1000 ppb	Hg Standard	1000 ppm	F0704 4/28/23 ①	0.10 mL	100	133 5/9/23 DI	Lmp	2/27/23	2/28/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23	"	"	"
Secondary Intermediate Standard											
2	Secondary Int. Std.	1000 ppb	Hg Standard (2nd Source)	1000 ppm	F0752 4/28/23 ①	0.10 mL	100	133 5/9/23 DI	Lmp	2/27/23	2/28/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23	"	"	"
Primary Working Standard											
3	Primary Working Std.	50 ppb	Primary Int. Std.	1000 ppb	1 2/28/23 ①	5.0 mL	100	141 3/4/23 DI	Lmp	2/27/23	2/28/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23	"	"	"
Secondary Working Standard											
4	Secondary Working Std.	50 ppb	Secondary Int. Std.	1000 ppb	2 2/28/23 ①	5.0 mL	100	141 3/4/23 DI	Lmp	2/27/23	2/28/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23	"	"	"

W002AS-023392-RT-4542



350 of 688

①22380017
Lmp 2/27/23

1382B

 ENTHALPY ANALYTICAL		Method 29 Hg Prepsheet					
		Job Nos: 0223-176					
		Prep Date(s): 2/27/23					
		Analyst(s) LMP			Instrument: Walt Jr		
Calibration Standards and QC					Samples		
Spike Used	Calibration Standard	Spike Amount (mL)	Pip & Exp	Final Vol. (mL)	Sample ID	Aliquot Volume (mL)	Final Vol. (mL)
--	Calibration Blank	--	N/A	50	0223-176.1-3A	.10	50
1st WS	Standard 1 - 0.1 ppb	0.1	133 5/9/23	50	.2		50
1st WS	Standard 2 - 1.0 ppb	1.0	134 1	50	.3		50
1st WS	Standard 3 - 2.0 ppb	2.0	1	50	.4		50
1st WS	Standard 4 - 5.0 ppb	5.0	141 3/4/23	50	.5		50
1st WS	Standard 5 - 10 ppb	10.0	1	50	.6		50
2nd WS	ICV/CCV - 5.0 ppb	5.0	1	50	.7		50
--	ICB/CCB	--	N/A	50	.8		50
Temp (°C): 95.4		Hotplate # 3			.9		50
1st WS ID: 3		Exp Date: 2/28/23			.10		50
2nd WS ID: 4		Exp Date: 1			.11		50
H2SO4 ID: 622252		Exp Date: 10/24			.12		50
HNO3 ID: 22380017		Exp Date: 9/24			.13		50
KMnO4 ID: ES-0842		Exp Date: 8/23/23			.14		50
K2S2O8 ID: ES-0828		Exp Date: 8/8/23			.15		50
HAS ID: ES-0836		Exp Date: 8/17/23			.16		50
SnCl2 ID: ES-0847		Exp Date: 3/6/23			.17		50
H2SO4 Pip & Exp: 139 3/8/23		HNO3 Pip & Exp: 139 3/8/23			.18		50
KMnO4 Pip & Exp:		K2S2O8 Pip & Exp: 1					50
HAS Pip & Exp: 1		Digitube ID: J506384-4932					50
LCS Pip & Exp: 141 3/4/23		MS Pip & Exp: 141 3/4/23			Digestion Time Start: 10:00am Finish: 12:00pm		
Quality Control							
QC Sample	Sample ID	Aliq. Vol. (mL)	Final Vol. (mL)	Spike ID	ID Exp Date	Stock Conc	Volume Added (mL)
MB	N/A	20	50	N/A	N/A	N/A	N/A
LCS	N/A	20	50	3	2/28/23	50 ppb	5.0
MS	0223-176.1-3A	.10	50	1	1	1	1
Duplicate	1 .2 1	1	50	N/A	N/A	N/A	N/A

File	Edit	View	Log	Analyze	Options	Window	Help	Sample Label	Conc (ppb)
W002AS-023392-RT-45428								0223-176.8-3A	-0.002
								0223-176.9-3A	-0.003
								0223-176.10-3A	-0.002
								0223-176.11-3A	0.011
								0223-176.12-3A	-0.001
								0223-176.13-3A	0.004
								0223-176.14-3A	0.002
								0223-176.15-3A	0.002
								0223-176.16-3A	0.001
								CCV	4.830
								CCB	-0.006
								0223-176.17-3A	0.000
								0223-176.18-3A	-0.001
								CCV	4.860
								CCB	-0.006



B/27/2023 1:41 PM Worksheet Saved

2/27/2023 1:41PM Analysis completed normally

2/27/2023 1:41 PM Sample 'CCB' measured. Conc.: -5.8500E-003 ppb (not diln, corrected)

22/27/2023 1:39 PM QC Sample 'CCV'. Recovery was measured at 97.18 percent

2/27/2023 1:39 PM Sample 'CCV' measured. Conc.: 4.860 ppb (not diln, corrected)

Sample 0223-17-3A' measured. Conc.: -1.040E-003 pbB (not dm, corrected)
0223-17-3A' measured. Conc.: 7.410E-005 pbB (not dm, corrected)

Sample 'CCB' measured. Conc.: -6.4100E-003 ppb (not diln. corrected)

EA Job# 02223-176B Page 147 of 186

Analysis Complete

1

Sample ID	Time Stamp	Sample Type	Dil. Conc.	Average Conc.	%RSD Conc.	Conc. Units
Cal Blank - 0 ug/mL	2/27/2023 12:21	Standard	0	0	0	0 ppb
Std. 1 - 0.1ug/mL	2/27/2023 12:24	Standard	0.1	0.1	0	0 ppb
Std. 2 - 1.0 ug/mL	2/27/2023 12:26	Standard	1	1	0	0 ppb
Std. 3 - 2.0 ug/mL	2/27/2023 12:28	Standard	2	2	0	0 ppb
Std. 4 - 5.0 ug/mL	2/27/2023 12:31	Standard	5	5	0	0 ppb
Std. 5 - 10.0 ug/mL	2/27/2023 12:33	Standard	10	10	0	0 ppb
ICV	2/27/2023 12:35	ICV	4.92	4.92	0	0 ppb
ICB	2/27/2023 12:37	ICB	-0.006	-0.006	0	0 ppb
0223-176.LB	2/27/2023 12:40	Unknown	-0.002	-0.002	0	0 ppb
0223-176.LCS	2/27/2023 12:42	Unknown	5	5	0	0 ppb
0223-176.1-3A	2/27/2023 12:44	Unknown	0.033	0.033	0	0 ppb
0223-176.1-3A MS	2/27/2023 12:46	Unknown	5.03	5.03	0	0 ppb
0223-176.2-3A	2/27/2023 12:49	Unknown	0.026	0.026	0	0 ppb
0223-176.2-3A DUP	2/27/2023 12:51	Unknown	0.028	0.028	0	0 ppb
0223-176.3-3A	2/27/2023 12:53	Unknown	-0.002	-0.002	0	0 ppb
0223-176.4-3A	2/27/2023 12:56	Unknown	0.01	0.01	0	0 ppb
0223-176.5-3A	2/27/2023 12:58	Unknown	0	0	0	0 ppb
0223-176.6-3A	2/27/2023 13:00	Unknown	0.002	0.002	0	0 ppb
CCV	2/27/2023 13:02	CCV	4.92	4.92	0	0 ppb
CCB	2/27/2023 13:05	CCB	-0.005	-0.005	0	0 ppb
0223-176.7-3A	2/27/2023 13:07	Unknown	0.003	0.003	0	0 ppb
0223-176.8-3A	2/27/2023 13:09	Unknown	-0.002	-0.002	0	0 ppb
0223-176.9-3A	2/27/2023 13:12	Unknown	-0.003	-0.003	0	0 ppb
0223-176.10-3A	2/27/2023 13:14	Unknown	-0.002	-0.002	0	0 ppb
0223-176.11-3A	2/27/2023 13:16	Unknown	0.011	0.011	0	0 ppb
0223-176.12-3A	2/27/2023 13:18	Unknown	-0.001	-0.001	0	0 ppb
0223-176.13-3A	2/27/2023 13:21	Unknown	0.004	0.004	0	0 ppb
0223-176.14-3A	2/27/2023 13:23	Unknown	0.002	0.002	0	0 ppb
0223-176.15-3A	2/27/2023 13:25	Unknown	0.002	0.002	0	0 ppb
0223-176.16-3A	2/27/2023 13:28	Unknown	0.001	0.001	0	0 ppb
CCV	2/27/2023 13:30	CCV	4.83	4.83	0	0 ppb
CCB	2/27/2023 13:32	CCB	-0.006	-0.006	0	0 ppb
0223-176.17-3A	2/27/2023 13:34	Unknown	0	0	0	0 ppb
0223-176.18-3A	2/27/2023 13:37	Unknown	-0.001	-0.001	0	0 ppb
CCV	2/27/2023 13:39	CCV	4.86	4.86	0	0 ppb
CCB	2/27/2023 13:41	CCB	-0.006	-0.006	0	0 ppb

Analyst: Lmp

Date: 2/28/23

Job #s	Describe Work Documented on This Page
0223-1762	m29 Hg Analysis

1386a = CVAAT std prep log

1386B = m29 Hg prep sheet

Supplies, Ancillary Equipment
Serial #s, Lot #s, Etc

NA

Lmp 2/28/23

Reviewer's Initials & Date:

Metals Prep

EA Job# 0223-1762 Page 149 of 186

W002AS-023392-RT-4542

354 of 688



ENTHALPY
ANALYTICAL

13800A

CVAA Standard Preparation Log *Stds must be prepared fresh daily

EA Std ID#Hg (Job #1, 2, 3, etc.)	Std/Reagent Name	Conc.	Stock Standard/Reagent	Conc.	EA ID# & Exp Date	Amount Added	Final Volume (mL) & Diluent	Pipette & Exp Date	Analyst	Date	Exp. Date
1											
Primary Intermediate Standard											
1	Primary Int. Std.	1000 ppb	Hg Standard	1000 ppm	F07104 4/28/23 ①	0.10 mL	100	133 5/9/23	Lmp	2/28/23	3/1/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23	"	"	"
Secondary Intermediate Standard											
2	Secondary Int. Std.	1000 ppb	Hg Standard (2nd Source)	1000 ppm	F07152 4/28/23 ①	0.10 mL	100	133 5/9/23	DI	5/9/23	134 5/9/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	"	"	"	"
Primary Working Standard											
3	Primary Working Std.	50 ppb	Primary Int. Std.	1000 ppb	1 3/11/23 ①	5.0 mL	100	141 3/4/23	DI	3/4/23	134 5/9/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	"	"	"	"
Secondary Working Standard											
4	Secondary Working Std.	50 ppb	Secondary Int. Std.	1000 ppb	2 3/11/23 ①	5.0 mL	100	141 3/4/23	DI	3/4/23	134 5/9/23
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	"	"	"	"

W002AS-023392-RT-4542

355 of 688

① 22380017
Lmp 2/28/23

1384eB

 ENTHALPY ANALYTICAL	Method 29 Hg Prepsheet						
	Job Nos: 0223-176						
	Prep Date(s): 2/28/23						
	Analyst(s) LMP			Instrument: NaI T, Jr			
Calibration Standards and QC					Samples		
Spike Used	Calibration Standard	Spike Amount (mL)	Pip & Exp	Final Vol. (mL)	Sample ID	Aliquot Volume (mL)	Final Vol. (mL)
--	Calibration Blank	--	N/A	50	0223-176-1-2B	.5	50
1st WS	Standard 1 - 0.1 ppb	0.1	133 5/9/23	50	.2		50
1st WS	Standard 2 - 1.0 ppb	1.0	134 1	50	.3		50
1st WS	Standard 3 - 2.0 ppb	2.0	1	50	.4		50
1st WS	Standard 4 - 5.0 ppb	5.0	141 3/4/23	50	.5		50
1st WS	Standard 5 - 10 ppb	10.0	1	50	.6		50
2nd WS	ICV/CCV - 5.0 ppb	5.0	1	50	.7		50
--	ICB/CCB	--	N/A	50	.8		50
Temp (°C): 95.5		Hotplate # 3			.9		50
1st WS ID: 3		Exp Date: 2/28/23 3/1/23			.10		50
2nd WS ID: 4		Exp Date: 1 1			.11		50
H2SO4 ID: 62252		Exp Date: 10/24			.12		50
HNO3 ID: 22380017		Exp Date: 9/24			.13		50
KMnO4 ID: ES-0842		Exp Date: 8/23/23			.14		50
K2S2O8 ID: ES-0828		Exp Date: 8/8/23			.15		50
HAS ID: ES-0836		Exp Date: 8/17/23			.16		50
SnCl2 ID: ES-0847		Exp Date: 3/10/23			.17		50
H2SO4 Pip & Exp: 139 3/8/23		HNO3 Pip & Exp: 139 3/8/23			.18		50
KMnO4 Pip & Exp:		K2S2O8 Pip & Exp: 1					50
HAS Pip & Exp:		Digitube ID: J50L384-4932					50
LCS Pip & Exp: 141 3/4/23		MS Pip & Exp: 141 3/4/23			Digestion Time Start: 7:37 am Finish: 9:37 am		
Quality Control							
QC Sample	Sample ID	Aliq. Vol. (mL)	Final Vol. (mL)	Spike ID	ID Exp Date	Stock Conc	Volume Added (mL)
MB	N/A	20	50	N/A	N/A	N/A	N/A
LCS	N/A	20	50	3	3/1/23	50 ppb	5.0
MS	0223-176-1-2B	10	50	1	1	1	1
Duplicate	1 .2 1	1	50	N/A	N/A	N/A	N/A

①EE LMP

EA Job# 0223-176R Page 151 of 186





2/28/23

File Edit View Log Analyze Options Window Help



W002A5

Table Sample Label



2/28/2023 11:21 AM Worksheet Saved

2/28/2023 11:21 AM Analysis completed normally
 2/28/2023 11:21 AM Sample 'CCB' measured. Conc.: -4.0700E-003 ppb (not diln, corrected)
 2/28/2023 11:18 AM QC Sample 'CCV'. Recovery was measured at 97.73 percent
 2/28/2023 11:18 AM Sample 'CCV' measured. Conc.: 4.890 ppb (not diln, corrected)
 2/28/2023 11:16 AM Sample '0223-176,18-2B' measured. Conc.: 3.2200E-002 ppb (not diln, corrected)
 2/28/2023 11:14 AM Sample '0223-176,17-2B' measured. Conc.: 3.0200E-003 ppb (not diln, corrected)
 2/28/2023 11:11 AM Sample 'CCB' measured. Conc.: -2.9600E-003 ppb (not diln, corrected)

0223-176 022823

Analysis Complete

Sample ID	Time Stamp	Sample Type	Dil. Conc.	Average Conc.	%RSD Conc.	Conc. Units
Cal Blank - 0 ug/mL	2/28/2023 10:01	Standard	0	0	0	0 ppb
Std. 1 - 0.1ug/mL	2/28/2023 10:03	Standard	0.1	0.1	0	0 ppb
Std. 2 - 1.0 ug/mL	2/28/2023 10:05	Standard	1	1	0	0 ppb
Std. 3 - 2.0 ug/mL	2/28/2023 10:07	Standard	2	2	0	0 ppb
Std. 4 - 5.0 ug/mL	2/28/2023 10:10	Standard	5	5	0	0 ppb
Std. 5 - 10.0 ug/mL	2/28/2023 10:12	Standard	10	10	0	0 ppb
ICV	2/28/2023 10:14	ICV	5.01	5.01	0	0 ppb
ICB	2/28/2023 10:17	ICB	-0.002	-0.002	0	0 ppb
0223-176.LB	2/28/2023 10:19	Unknown	0	0	0	0 ppb
0223-176.LCS	2/28/2023 10:21	Unknown	5.14	5.14	0	0 ppb
0223-176.1-2B	2/28/2023 10:23	Unknown	0.009	0.009	0	0 ppb
0223-176.1-2B MS	2/28/2023 10:26	Unknown	5.1	5.1	0	0 ppb
0223-176.2-2B	2/28/2023 10:28	Unknown	0.029	0.029	0	0 ppb
0223-176.2-2B DUP	2/28/2023 10:30	Unknown	0.032	0.032	0	0 ppb
0223-176.3-2B	2/28/2023 10:33	Unknown	0.011	0.011	0	0 ppb
0223-176.4-2B	2/28/2023 10:35	Unknown	0.038	0.038	0	0 ppb
0223-176.5-2B	2/28/2023 10:37	Unknown	0.013	0.013	0	0 ppb
0223-176.6-2B	2/28/2023 10:39	Unknown	0.02	0.02	0	0 ppb
CCV	2/28/2023 10:42	CCV	4.95	4.95	0	0 ppb
CCB	2/28/2023 10:44	CCB	-0.004	-0.004	0	0 ppb
0223-176.7-2B	2/28/2023 10:46	Unknown	0.002	0.002	0	0 ppb
0223-176.8-2B	2/28/2023 10:49	Unknown	-0.001	-0.001	0	0 ppb
0223-176.9-2B	2/28/2023 10:51	Unknown	0.035	0.035	0	0 ppb
0223-176.10-2B	2/28/2023 10:53	Unknown	0.007	0.007	0	0 ppb
0223-176.11-2B	2/28/2023 10:55	Unknown	0.028	0.028	0	0 ppb
0223-176.12-2B	2/28/2023 10:58	Unknown	0.021	0.021	0	0 ppb
0223-176.13-2B	2/28/2023 11:00	Unknown	0.017	0.017	0	0 ppb
0223-176.14-2B	2/28/2023 11:02	Unknown	0.013	0.013	0	0 ppb
0223-176.15-2B	2/28/2023 11:04	Unknown	0.014	0.014	0	0 ppb
0223-176.16-2B	2/28/2023 11:07	Unknown	0.01	0.01	0	0 ppb
CCV	2/28/2023 11:09	CCV	4.94	4.94	0	0 ppb
CCB	2/28/2023 11:11	CCB	-0.003	-0.003	0	0 ppb
0223-176.17-2B	2/28/2023 11:14	Unknown	0.003	0.003	0	0 ppb
0223-176.18-2B	2/28/2023 11:16	Unknown	0.032	0.032	0	0 ppb
CCV	2/28/2023 11:18	CCV	4.89	4.89	0	0 ppb
CCB	2/28/2023 11:21	CCB	-0.004	-0.004	0	0 ppb

Analyst: MAL

Date: 3/1/23

Job #s

0223-176

Describe Work Documented on This Page


Hg Analysis

1388A = CVAA Standard Preparation Log

1388B = Method 29 Hg Prepsheet

Supplies, Ancillary Equipment
Serial #s, Lot #s, Etc

N/A




Reviewer's Initials & Date:

Metals Prep
EA Job# 0223-176R Page 54 of 186

W002AS-023392-RT-4542

359 of 688



ENTHALPY
ANALYTICAL

13884

CYAA Standard Preparation Log *Stds must be prepared fresh daily

EA Std ID#Hg (Job #:1, 2, 3, etc.)	Std/Reagent Name	Conc.	Stock Standard/Reagent	Conc.	EA ID# & Exp Date	Amount Added	Final Volume (mL) & Diluent	Pipette & Exp Date	Analyst	Date	Exp. Date
Primary/Intermediate Standard											
Secondary Intermediate Standard											
1	Primary Int. Std.	1000 ppb	Hg Standard	1000 ppm	F0152 4/28/23	0.10 mL	100	133 DI	NHL	3/1/23	3/2/23
"	"	"	HNO3	67-70%	(1)	0.5 mL	"	134 5/9/23			
2	Secondary Int. Std.	1000 ppb	Hg Standard (2nd Source)	1000 ppm	F0764 4/31/23	0.10 mL	100	133 DI			
"	"	"	HNO3	67-70%	(1)	0.5 mL	"	134 5/9/23			
Primary Working Standard											
3	Primary Working Std.	50 ppb	Primary Int. Std.	1000 ppb	1 3/2/23	5.0 mL	100	141 DI			
"	"	"	HNO3	67-70%	(1)	0.5 mL	"	134 5/9/23			
Secondary Working Standard											
4	Secondary Working Std.	50 ppb	Secondary Int. Std.	1000 ppb	2 3/2/23	5.0 mL	100	141 DI			
"	"	"	HNO3	67-70%	(1)	0.5 mL	"	134 5/9/23			

① 223800017 exp. 9/24 cmp formal 3/4/23
 Exp. Sh4t4y lmp for MAL
 3/4/23

② Sh4t4y EE
 Exp. Sh4t4y lmp for MAL
 3/4/23

1388B

 ENTHALPY ANALYTICAL		Method 29 Hg Prepsheet					
		Job Nos:		0223 - 176			
		Prep Date(s):		3/1/23			
		Analyst(s)		MAL		Instrument: Watt Jr.	
Calibration Standards and QC					Samples		
Spike Used	Calibration Standard	Spike Amount (mL)	Pip & Exp	Final Vol. (mL)	Sample ID	Aliquot Volume (mL)	Final Vol. (mL)
--	Calibration Blank	--	N/A	50	0223-176.1-38	10.0	50
1st WS	Standard 1 - 0.1 ppb	0.1	133 5/1/23	50	2		50
1st WS	Standard 2 - 1.0 ppb	1.0	134 1	50	3		50
1st WS	Standard 3 - 2.0 ppb	2.0	134 1	50	4		50
1st WS	Standard 4 - 5.0 ppb	5.0	141 3/1/23	50	5		50
1st WS	Standard 5 - 10 ppb	10.0	1	50	6		50
2nd WS	ICV/CCV - 5.0 ppb	5.0	1	50	7		50
--	ICB/CCB	--	N/A	50	8		50
Temp (°C):	95.8	Hotplate #	3		9		50
1st WS ID:	3	Exp Date:	3/2/23		10		50
2nd WS ID:	4	Exp Date:	1		11		50
H ₂ SO ₄ ID:	62164 22380017	Exp Date:	10/24		12		50
HNO ₃ ID:	62164 22380017	Exp Date:	5/1/23 9/1/23		13		50
KMnO ₄ ID:	ES-0842	Exp Date:	8/23/23		14		50
K ₂ S ₂ O ₈ ID:	ES-0828	Exp Date:	8/8/23		15		50
HAS ID:	ES-0836	Exp Date:	8/17/23		16		50
SnCl ₂ ID:	ES-0847	Exp Date:	3/6/23		17		50
H ₂ SO ₄ Pip & Exp:	139 3/8/23	HNO ₃ Pip & Exp:	139 3/8/23		18		50
KMnO ₄ Pip & Exp:	1	K ₂ S ₂ O ₈ Pip & Exp:	1				50
HAS Pip & Exp:	1	Digitube ID:	J506384-4932				50
LCS Pip & Exp:	141 3/4/23	MS Pip & Exp:	141 3/4/23				
Digestion Time							
Start: 8:33am Finish: 10:33am							


Quality Control

QC Sample	Sample ID	Aliq. Vol. (mL)	Final Vol. (mL)	Spike ID	ID Exp Date	Stock Conc	Volume Added (mL)
MB	N/A	20	50	N/A	N/A	N/A	N/A
LCS	N/A	20	50	3	3/2/23	50ppb	5.0
MS	0223-176.1-38 MS	10	50	4	1	1	1
Duplicate	0223-176.2-38 DUP	10	50	N/A	N/A	N/A	N/A

① EEE LMP for MAL 3/4/23

EA Job# 0223-176R Page 156 of 186

361 of 688



W002AS-023392-RT-4542

362 of 688

Sample ID	Time Stamp	Sample Type	Dil. Conc.	Average Conc.	%RSD	Conc.	Conc. Units
Cal Blank - 0 ug/mL	3/1/2023 11:10	Standard	0	0		0	ppb
Std. 1 - 0.1ug/mL	3/1/2023 11:13	Standard	0.1	0.1		0	ppb
Std. 2 - 1.0 ug/mL	3/1/2023 11:15	Standard	1	1		0	ppb
Std. 3 - 2.0 ug/mL	3/1/2023 11:17	Standard	2	2		0	ppb
Std. 4 - 5.0 ug/mL	3/1/2023 11:19	Standard	5	5		0	ppb
Std. 5 - 10.0 ug/mL	3/1/2023 11:22	Standard	10	10		0	ppb
ICV	3/1/2023 11:24	ICV	5.51	5.51		0	ppb
ICB	3/1/2023 11:26	ICB	-0.004	-0.004		0	ppb
0223-176.LB	3/1/2023 11:29	Unknown	0	0		0	ppb
0223-176.LCS	3/1/2023 11:31	Unknown	5.07	5.07		0	ppb
0223-176.1-3B	3/1/2023 11:33	Unknown	-0.001	-0.001		0	ppb
0233-176.1-3B MS	3/1/2023 11:35	Unknown	5.29	5.29		0	ppb
0223-176.2-3B	3/1/2023 11:38	Unknown	0.014	0.014		0	ppb
0223-176.2-3B DUP	3/1/2023 11:40	Unknown	0.017	0.017		0	ppb
0223-176.3-3B	3/1/2023 11:42	Unknown	0.017	0.017		0	ppb
0223-176.4-3B	3/1/2023 11:45	Unknown	0.021	0.021		0	ppb
0223-176.5-3B	3/1/2023 11:47	Unknown	0.017	0.017		0	ppb
0223-176.6-3B	3/1/2023 11:49	Unknown	0.026	0.026		0	ppb
CCV	3/1/2023 11:51	CCV	5.29	5.29		0	ppb
CCB	3/1/2023 11:54	CCB	-0.002	-0.002		0	ppb
0223-176.7-3B	3/1/2023 11:56	Unknown	0.022	0.022		0	ppb
0223-176.8-3B	3/1/2023 11:58	Unknown	0.021	0.021		0	ppb
0223-176.9-3B	3/1/2023 12:01	Unknown	0.02	0.02		0	ppb
0223-176.10-3B	3/1/2023 12:03	Unknown	0.022	0.022		0	ppb
0223-176.11-3B	3/1/2023 12:05	Unknown	0.019	0.019		0	ppb
0223-176.12-3B	3/1/2023 12:07	Unknown	0.018	0.018		0	ppb
0223-176.13-3B	3/1/2023 12:10	Unknown	0.021	0.021		0	ppb
0223-176.14-3B	3/1/2023 12:12	Unknown	0.021	0.021		0	ppb
0223-176.15-3B	3/1/2023 12:14	Unknown	0.022	0.022		0	ppb
0223-176.16-3B	3/1/2023 12:16	Unknown	0.02	0.02		0	ppb
CCV	3/1/2023 12:19	CCV	5.26	5.26		0	ppb
CCB	3/1/2023 12:21	CCB	-0.004	-0.004		0	ppb
0223-176.17-3B	3/1/2023 12:23	Unknown	0.061	0.061		0	ppb
0223-176.18-3B	3/1/2023 12:26	Unknown	0.022	0.022		0	ppb
CCV	3/1/2023 12:28	CCV	5.25	5.25		0	ppb
CCB	3/1/2023 12:30	CCB	-0.003	-0.003		0	ppb

Analyst: LMP

Date: 3/16/25


Job #s	Describe Work Documented on This Page
0223-176	M29 Hg Analysis

1395A = CVAIA std prep 10g

1395B = M29 Hg prep sheet

Supplies, Ancillary Equipment
Serial #s, Lot #s, Etc

NA



Reviewer's Initials & Date:

Metals Prep

EA Job# 0223-176 Page 159 of 186

W002AS-023392-RT-4542

364 of 688

ENTHALPY
ANALYTICAL

1395A

CVAA Standard Preparation Log *Stds must be prepared fresh daily

EA Std ID#Hg (Job # 1, 2, 3, etc.)	Std/Reagent Name	Conc.	Stock Standard/Reagent	Conc.	EA ID# & Exp Date	Amount Added	Final Volume (mL) & Diluent	Pipette & Exp Date	Analyst	Date	Exp. Date
1											
Primary Intermediate Standard											
1	Primary Int. Std.	1000 ppb	Hg Standard	1000 ppm	F07104 4/28/23	0.10 mL	100	133 DI	Lmp	3/10/23	3/17/23
"	"	"	HNO3	67-70%	① 9/24	0.5 mL	"	134 5/9/23	"	"	"
Secondary Intermediate Standard											
2	Secondary Int. Std.	1000 ppb	Hg Standard (2nd Source)	1000 ppm	F07152 4/28/23	0.10 mL	100	133 DI	5/9/23	134 5/9/23	"
"	"	"	HNO3	67-70%	① 9/24	0.5 mL	"	5/9/23	"	"	"
Primary Working Standard											
3	Primary Working Std.	50 ppb	Primary Int. Std.	1000 ppb	1 3/1/23	5.0 mL	100	143 DI	5/9/23	134 5/9/23	"
"	"	"	HNO3	67-70%	① 9/24	0.5 mL	"	5/9/23	"	"	"
Secondary Working Standard											
4	Secondary Working Std.	50 ppb	Secondary Int. Std.	1000 ppb	2 3/1/23	5.0 mL	100	143 DI	5/9/23	134 5/9/23	"
"	"	"	HNO3	67-70%	① 9/24	0.5 mL	"	5/9/23	"	"	"

W002AS-023392-RT-4542

365 of 688

① 22380017
Lmp 3/10/23

1395B

 ENTHALPY ANALYTICAL		Method 29 Hg Prepsheet						
		Job Nos: 0223-176						
		Prep Date(s): 3/6/23						
		Analyst(s) LMP			Instrument: Walt Jr			
Calibration Standards and QC					Samples			
Spike Used	Calibration Standard	Spike Amount (mL)	Pip & Exp	Final Vol. (mL)	Sample ID	Aliquot Volume (mL)	Final Vol. (mL)	
--	Calibration Blank	--	N/A	50	0223-176.1-3C	.10	50	
1st WS	Standard 1 - 0.1 ppb	0.1	133 5/9/23	50		.2	50	
1st WS	Standard 2 - 1.0 ppb	1.0	134	50		.3	50	
1st WS	Standard 3 - 2.0 ppb	2.0	1	50		.4	50	
1st WS	Standard 4 - 5.0 ppb	5.0	143	50		.5	50	
1st WS	Standard 5 - 10 ppb	10.0	1	50		.6	50	
2nd WS	ICV/CCV - 5.0 ppb	5.0	1	50		.7	50	
--	ICB/CCB	--	N/A	50		.8	50	
Temp (°C): 95.9		Hotplate # 3				.9	50	
1st WS ID: 3		Exp Date: 3/7/23				.10	50	
2nd WS ID: 4		Exp Date: 1				.11	50	
H2SO4 ID: 62252		Exp Date: 10/24				.12	50	
HNO3 ID: 22380017		Exp Date: 9/24				.13	50	
KMnO4 ID: ES-08440		Exp Date: 8/27/23				.14	50	
K2S2O8 ID: ES-084843		Exp Date: 8/24/23				.15	50	
HAS ID: ES-0840		Exp Date: 8/22/23				.16	50	
SnCl2 ID: ES-0847		Exp Date: 3/6/23				.17	50	
H2SO4 Pip & Exp: 139 3/8/23		HNO3 Pip & Exp: 139 3/8/23				.18	50	
KMnO4 Pip & Exp: 1		K2S2O8 Pip & Exp: 1					50	
HAS Pip & Exp: 1		Digitube ID: J5D6384-4932					50	
LCS Pip & Exp: 143 5/9/23		MS Pip & Exp: 143 5/9/23			Digestion Time			
					Start: 7:11 am Finish: 9:11 am			

Quality Control

QC Sample	Sample ID	Aliq. Vol. (mL)	Final Vol. (mL)	Spike ID	ID Exp Date	Stock Conc	Volume Added (mL)
MB	N/A	20	50	N/A	N/A	N/A	N/A
LCS	N/A	20	50	3	3/7/23	50 ppb	5.0
MS	0223-176.1-3C	10	50	1	1	1	1
Duplicate	1 .2 1	1	50	N/A	N/A	N/A	N/A

① DEE LMP


Leeman QuickTrace Mercury Analysis System - 0223-176 03/02/23

File Edit View Log Analyze Options Window Help

W002A



Type	Sample Label	Conc (ppb)	μ Abs	%RSD	Flag	%Residual
S	0223-176.11-3C	0.083	2022.4	0.73		
N	0223-176.12-3C	0.072	1764.2	0.77		
R	0223-176.13-3C	0.075	1829.3	0.45		
T	0223-176.14-3C	0.070	1713.6	1.34		
-458	0223-176.15-3C	0.085	2057.8	1.10		
1542	0223-176.15-3C	0.072	1748.3	1.47		
1:20	0223-176.16-3C	5.020	116849.3	0.83		
S:7	CCV	-0.003	7.0	18.95		
S:8	CCB	0.733	17122.1	1.18		
1:21	0223-176.17-3C	0.018	504.9	4.69		
1:32	0223-176.18-3C	5.050	117618.6	0.98		
Sof	CCV	-0.003	8.7	18.68		
S:88	CCB					



3/6/2023 10:52 AM Sample 'CCB' measured. Conc.: -3.2500E-003 ppb (not diln, corrected)

3/6/2023 10:50 AM QC Sample 'CCV' measured. Conc.: 5.020 ppb (not diln, corrected)


3/6/2023 10:50 AM Sample 'CCV' measured. Conc.: 7.1600E-002 ppb (not diln, corrected)

3/6/2023 10:48 AM Sample '0223-176.16-3C' measured. Conc.: 8.5400E-002 ppb (not diln, corrected)

3/6/2023 10:48 AM Sample '0223-176.15-3C' measured. Conc.: 7.0100E-002 ppb (not diln, corrected)

3/6/2023 10:48 AM Sample '0223-176.13-3C' measured. Conc.: 7.5100E-002 ppb (not diln, corrected)

3/6/2023 10:48 AM Sample '0223-176.12-3C' measured. Conc.: 7.2300E-002 ppb (not diln, corrected)



3/6/2023 10:41 AM Calibration Coeff: 23251.55730X + 82.655, R2: 0.99950, RSE: 4.49%

Sample ID	Time Stamp	Sample Type	Dil. Conc.	Average Conc.	%RSD Conc.	Conc. Units
Cal Blank - 0 ug/mL	3/6/2023 9:41	Standard	0	0	0	0 ppb
Std. 1 - 0.1ug/mL	3/6/2023 9:44	Standard	0.1	0.1	0	0 ppb
Std. 2 - 1.0 ug/mL	3/6/2023 9:46	Standard	1	1	0	0 ppb
Std. 3 - 2.0 ug/mL	3/6/2023 9:48	Standard	2	2	0	0 ppb
Std. 4 - 5.0 ug/mL	3/6/2023 9:50	Standard	5	5	0	0 ppb
Std. 5 - 10.0 ug/mL	3/6/2023 9:53	Standard	10	10	0	0 ppb
ICV	3/6/2023 9:55	ICV	5.12	5.12	0	0 ppb
ICB	3/6/2023 9:57	ICB	-0.005	-0.005	0	0 ppb
0223-176.LB	3/6/2023 10:00	Unknown	0.009	0.009	0	0 ppb
0223-176.LCS	3/6/2023 10:02	Unknown	5.08	5.08	0	0 ppb
0223-176.1-3C	3/6/2023 10:04	Unknown	0.288	0.288	0	0 ppb
0223-176.1-3C MS	3/6/2023 10:06	Unknown	5.13	5.13	0	0 ppb
0223-176.2-3C	3/6/2023 10:09	Unknown	0.153	0.153	0	0 ppb
0223-176.2-3C DUP	3/6/2023 10:11	Unknown	0.156	0.156	0	0 ppb
0223-176.3-3C	3/6/2023 10:13	Unknown	0.471	0.471	0	0 ppb
0223-176.4-3C	3/6/2023 10:16	Unknown	0.134	0.134	0	0 ppb
0223-176.5-3C	3/6/2023 10:18	Unknown	0.072	0.072	0	0 ppb
0223-176.6-3C	3/6/2023 10:20	Unknown	0.115	0.115	0	0 ppb
CCV	3/6/2023 10:22	CCV	5.08	5.08	0	0 ppb
CCB	3/6/2023 10:25	CCB	-0.004	-0.004	0	0 ppb
0223-176.7-3C	3/6/2023 10:27	Unknown	0.058	0.058	0	0 ppb
0223-176.8-3C	3/6/2023 10:29	Unknown	0.301	0.301	0	0 ppb
0223-176.9-3C	3/6/2023 10:32	Unknown	0.02	0.02	0	0 ppb
0223-176.10-3C	3/6/2023 10:34	Unknown	0.067	0.067	0	0 ppb
0223-176.11-3C	3/6/2023 10:36	Unknown	0.083	0.083	0	0 ppb
0223-176.12-3C	3/6/2023 10:38	Unknown	0.072	0.072	0	0 ppb
0223-176.13-3C	3/6/2023 10:41	Unknown	0.075	0.075	0	0 ppb
0223-176.14-3C	3/6/2023 10:43	Unknown	0.07	0.07	0	0 ppb
0223-176.15-3C	3/6/2023 10:45	Unknown	0.085	0.085	0	0 ppb
0223-176.16-3C	3/6/2023 10:48	Unknown	0.072	0.072	0	0 ppb
CCV	3/6/2023 10:50	CCV	5.02	5.02	0	0 ppb
CCB	3/6/2023 10:52	CCB	-0.003	-0.003	0	0 ppb
0223-176.17-3C	3/6/2023 10:54	Unknown	0.733	0.733	0	0 ppb
0223-176.18-3C	3/6/2023 10:57	Unknown	0.018	0.018	0	0 ppb
CCV	3/6/2023 10:59	CCV	5.05	5.05	0	0 ppb
CCB	3/6/2023 11:01	CCB	-0.003	-0.003	0	0 ppb


Analyst: LMP

Date: 3/7/23

Job #s	Describe Work Documented on This Page
0223-176	M29 Hg Analysis

Supplies, Ancillary Equipment Serial #s, Lot #s, Etc
1398A = CVAAT std prep log 1398B = M29 Hg prep sheet

NA



Reviewer's Initials & Date:

Metals Prep

EA Job# 0223-176 RgPage 164 of 186

W002AS-023392-RT-4542

369 of 688

ENTHALPY
ANALYTICAL

1398A

CVAA Standard Preparation Log *Stds must be prepared fresh daily

EA Std ID#Hg (Job #1, 2, 3, etc.)	Std/Reagent Name	Conc.	Stock Standard/Reagent	Conc.	EA ID# & Exp Date	Amount Added	Final Volume (mL) & Diluent	Pipette & Exp Date	Analyst	Date	Exp. Date
Primary Intermediate Standard											
1	Primary Int. Std.	1000 ppb	Hg Standard	1000 ppm	F0704 4/28/23 ①	0.10 mL	100	133 5/9/23 Lmp	3/1/23	3/8/23	
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23 ①			
Secondary Intermediate Standard											
2	Secondary Int. Std.	1000 ppb	Hg Standard (2nd Source)	1000 ppm	F0752 4/28/23 ①	0.10 mL	100	133 5/9/23	DI	5/9/23	
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23			
Primary Working Standard											
3	Primary Working Std.	50 ppb	Primary Int. Std.	1000 ppb	1 3/8/23 ①	5.0 mL	100	143 5/9/23	DI	5/9/23	
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23			
Secondary Working Standard											
4	Secondary Working Std.	50 ppb	Secondary Int. Std.	1000 ppb	2 3/8/23 ①	5.0 mL	100	143 5/9/23	DI	5/9/23	
"	"	"	HNO3	67-70%	9/24	0.5 mL	"	134 5/9/23			

W002AS-023392-RT-4542

370 of 688

① 22380017
Lmp 3/7/23


1398B

 ENTHALPY ANALYTICAL		Method 29 Hg Prepsheet					
		Job Nos: 0223-176					
		Prep Date(s): 3/1/23					
		Analyst(s) LMP			Instrument: Walt Jr		
Calibration Standards and QC				Samples			
Spike Used	Calibration Standard	Spike Amount (mL)	Pip & Exp	Final Vol. (mL)	Sample ID	Aliquot Volume (mL)	Final Vol. (mL)
--	Calibration Blank	--	N/A	50	0223-176.1-1B	10	50
1st WS	Standard 1 - 0.1 ppb	0.1	133 5/9/23	50	-2		50
1st WS	Standard 2 - 1.0 ppb	1.0	134	50	.3		50
1st WS	Standard 3 - 2.0 ppb	2.0	1	50	.4		50
1st WS	Standard 4 - 5.0 ppb	5.0	143	50	.5		50
1st WS	Standard 5 - 10 ppb	10.0	1	50	.6		50
2nd WS	ICV/CCV - 5.0 ppb	5.0	1	50	.7		50
--	ICB/CCB	--	N/A	50	.8		50
Temp (°C): 95.5		Hotplate # 3			.9		50
1st WS ID: 3		Exp Date: 3/8/23			.10		50
2nd WS ID: 4		Exp Date: 1			.11		50
H ₂ SO ₄ ID: 622252		Exp Date: 10/24			.12		50
HNO ₃ ID: 22380017		Exp Date: 9/24			.13		50
KMnO ₄ ID: ES-0846		Exp Date: 8/27/23			.14		50
K ₂ S ₂ O ₈ ID: ES-0843		Exp Date: 8/24/23			.15		50
HAS ID: ES-0840		Exp Date: 8/22/23			.16		50
SnCl ₂ ID: ES-0854		Exp Date: 3/14/23			.17		50
H ₂ SO ₄ Pip & Exp: 139 3/8/23		HNO ₃ Pip & Exp: 139 3/8/23			.18		50
KMnO ₄ Pip & Exp: 1		K ₂ S ₂ O ₈ Pip & Exp: 1					50
HAS Pip & Exp: 1		Digitube ID: J506384-4932					50
LCS Pip & Exp: 143 5/9/23		MS Pip & Exp: 143 5/9/23			Digestion Time Start: 8:02 am Finish: 10:02 am		
Quality Control							
QC Sample	Sample ID	Aliq. Vol. (mL)	Final Vol. (mL)	Spike ID	ID Exp Date	Stock Conc	Volume Added (mL)
MB	N/A	20	50	N/A	N/A	N/A	N/A
LCS	N/A	20	50	3	3/8/23	50 ppb	5.0
MS	0223-176.1-1B	10	50	1	1	1	1
Duplicate	1 .2 1	1	50	N/A	N/A	N/A	N/A

Q Leeman QuickTrace Mercury Analysis System - 0223-176 030723

File Edit View Log Analyze Options Window Help

W002AS



Sample ID	Time Stamp	Sample Type	Average Conc.	%RSD	Conc.	Units
Cal Blank - 0 ug/mL	3/7/2023 10:34	Standard	0	0	0	ppb
Std. 1 - 0.1ug/mL	3/7/2023 10:37	Standard	0.1	0	0	ppb
Std. 2 - 1.0 ug/mL	3/7/2023 10:39	Standard	1	0	0	ppb
Std. 3 - 2.0 ug/mL	3/7/2023 10:41	Standard	2	0	0	ppb
Std. 4 - 5.0 ug/mL	3/7/2023 10:43	Standard	5	0	0	ppb
Std. 5 - 10.0 ug/mL	3/7/2023 10:46	Standard	10	0	0	ppb
ICV	3/7/2023 10:48	ICV	5.09	0	0	ppb
ICB	3/7/2023 10:50	ICB	-0.004	0	0	ppb
0223-176.LB	3/7/2023 10:53	Unknown	0.658	①	0	ppb
0223-176.LCS	3/7/2023 10:55	Unknown	4.97	0	0	ppb
0223-176.1-1B	3/7/2023 10:57	Unknown	-0.018	0	0	ppb
0223-176.1-1B MS	3/7/2023 10:59	Unknown	4.65	0	0	ppb
0223-176.2-1B	3/7/2023 11:02	Unknown	-0.048	0	0	ppb
0223-176.2-1B DUP	3/7/2023 11:04	Unknown	-0.014	0	0	ppb
0223-176.3-1B	3/7/2023 11:06	Unknown	-0.031	0	0	ppb
0223-176.4-1B	3/7/2023 11:09	Unknown	-0.02	0	0	ppb
0223-176.5-1B	3/7/2023 11:11	Unknown	-0.019	0	0	ppb
0223-176.6-1B	3/7/2023 11:13	Unknown	-0.016	0	0	ppb
CCV	3/7/2023 11:15	CCV	5.06	0	0	ppb
CCB	3/7/2023 11:18	CCB	-0.007	0	0	ppb
0223-176.7-1B	3/7/2023 11:20	Unknown	-0.021	0	0	ppb
0223-176.8-1B	3/7/2023 11:22	Unknown	-0.017	0	0	ppb
0223-176.9-1B	3/7/2023 11:25	Unknown	-0.027	0	0	ppb
0223-176.10-1B	3/7/2023 11:27	Unknown	-0.028	0	0	ppb
0223-176.11-1B	3/7/2023 11:29	Unknown	-0.023	0	0	ppb
0223-176.12-1B	3/7/2023 11:32	Unknown	-0.031	0	0	ppb
0223-176.13-1B	3/7/2023 11:34	Unknown	-0.03	0	0	ppb
0223-176.14-1B	3/7/2023 11:36	Unknown	-0.031	0	0	ppb
0223-176.15-1B	3/7/2023 11:39	Unknown	-0.03	0	0	ppb
0223-176.16-1B	3/7/2023 11:41	Unknown	-0.027	0	0	ppb
CCV	3/7/2023 11:43	CCV	5.09	0	0	ppb
CCB	3/7/2023 11:46	CCB	-0.005	0	0	ppb
0223-176.17-1B	3/7/2023 11:48	Unknown	-0.025	0	0	ppb
0223-176.18-1B	3/7/2023 11:50	Unknown	-0.029	0	0	ppb
0223-176.LB Repour	3/7/2023 12:00	Unknown	0.001	①	0	ppb
CCV	3/7/2023 12:02	CCV	5.15	0	0	ppb
CCB	3/7/2023 12:04	CCB	-0.004	0	0	ppb

① See repour + reanalysis

MR 3/1/23

Location: _____

Drawer: _____

Analyst: LMP

Cabinet: _____

Folder: _____

Date: 2/27/23

Job #s
0123-099
0223-176

Describe Work Documented on This Page

m29 Hg Analysis


Walt Jr 201A
1 201B

= Analytical Sequence

1

Supplies, Ancillary Equipment
Serial #s, Lot #s, Etc

NA



Reviewer's Initials & Date:

Walt Jr.
page 201

EA Job# 0223-176R Page 169 of 186

W002AS-023392-RT-4542

374 of 688

ENTHALPY
ANALYTICAL

Walt Jr 201B

Sample ID	Time Stamp	Sample Type
Cal Blank - 0 ug/mL	2/27/2023 12:21	Standard
Std. 1 - 0.1ug/mL	2/27/2023 12:24	Standard
Std. 2 - 1.0 ug/mL	2/27/2023 12:26	Standard
Std. 3 - 2.0 ug/mL	2/27/2023 12:28	Standard
Std. 4 - 5.0 ug/mL	2/27/2023 12:31	Standard
Std. 5 - 10.0 ug/mL	2/27/2023 12:33	Standard
ICV	2/27/2023 12:35	ICV
ICB	2/27/2023 12:37	ICB
0223-176.LB	2/27/2023 12:40	Unknown
0223-176.LCS	2/27/2023 12:42	Unknown
0223-176.1-3A	2/27/2023 12:44	Unknown
0223-176.1-3A MS	2/27/2023 12:46	Unknown
0223-176.2-3A	2/27/2023 12:49	Unknown
0223-176.2-3A DUP	2/27/2023 12:51	Unknown
0223-176.3-3A	2/27/2023 12:53	Unknown
0223-176.4-3A	2/27/2023 12:56	Unknown
0223-176.5-3A	2/27/2023 12:58	Unknown
0223-176.6-3A	2/27/2023 13:00	Unknown
CCV	2/27/2023 13:02	CCV
CCB	2/27/2023 13:05	CCB
0223-176.7-3A	2/27/2023 13:07	Unknown
0223-176.8-3A	2/27/2023 13:09	Unknown
0223-176.9-3A	2/27/2023 13:12	Unknown
0223-176.10-3A	2/27/2023 13:14	Unknown
0223-176.11-3A	2/27/2023 13:16	Unknown
0223-176.12-3A	2/27/2023 13:18	Unknown
0223-176.13-3A	2/27/2023 13:21	Unknown
0223-176.14-3A	2/27/2023 13:23	Unknown
0223-176.15-3A	2/27/2023 13:25	Unknown
0223-176.16-3A	2/27/2023 13:28	Unknown
CCV	2/27/2023 13:30	CCV
CCB	2/27/2023 13:32	CCB
0223-176.17-3A	2/27/2023 13:34	Unknown
0223-176.18-3A	2/27/2023 13:37	Unknown
CCV	2/27/2023 13:39	CCV
CCB	2/27/2023 13:41	CCB

Location: _____

Drawer: _____

Analyst: LMP

Cabinet: _____

Folder: _____

Date: 2/28/23

Job #s	Describe Work Documented on This Page	Supplies, Ancillary Equipment Serial #s, Lot #s, Etc
0223-176	M29 Hy Analysis Walt Jr 203A = Analytical Sequence	NA

Reviewer's Initials & Date:

Walt Jr.
page 203



ENTHALPY
ANALYTICAL

walt jr 203A

Sample ID	Time Stamp	Sample Type
Cal Blank - 0 ug/mL	2/28/2023 10:01	Standard
Std. 1 - 0.1ug/mL	2/28/2023 10:03	Standard
Std. 2 - 1.0 ug/mL	2/28/2023 10:05	Standard
Std. 3 - 2.0 ug/mL	2/28/2023 10:07	Standard
Std. 4 - 5.0 ug/mL	2/28/2023 10:10	Standard
Std. 5 - 10.0 ug/mL	2/28/2023 10:12	Standard
ICV	2/28/2023 10:14	ICV
ICB	2/28/2023 10:17	ICB
0223-176.LB	2/28/2023 10:19	Unknown
0223-176.LCS	2/28/2023 10:21	Unknown
0223-176.1-2B	2/28/2023 10:23	Unknown
0223-176.1-2B MS	2/28/2023 10:26	Unknown
0223-176.2-2B	2/28/2023 10:28	Unknown
0223-176.2-2B DUP	2/28/2023 10:30	Unknown
0223-176.3-2B	2/28/2023 10:33	Unknown
0223-176.4-2B	2/28/2023 10:35	Unknown
0223-176.5-2B	2/28/2023 10:37	Unknown
0223-176.6-2B	2/28/2023 10:39	Unknown
CCV	2/28/2023 10:42	CCV
CCB	2/28/2023 10:44	CCB
0223-176.7-2B	2/28/2023 10:46	Unknown
0223-176.8-2B	2/28/2023 10:49	Unknown
0223-176.9-2B	2/28/2023 10:51	Unknown
0223-176.10-2B	2/28/2023 10:53	Unknown
0223-176.11-2B	2/28/2023 10:55	Unknown
0223-176.12-2B	2/28/2023 10:58	Unknown
0223-176.13-2B	2/28/2023 11:00	Unknown
0223-176.14-2B	2/28/2023 11:02	Unknown
0223-176.15-2B	2/28/2023 11:04	Unknown
0223-176.16-2B	2/28/2023 11:07	Unknown
CCV	2/28/2023 11:09	CCV
CCB	2/28/2023 11:11	CCB
0223-176.17-2B	2/28/2023 11:14	Unknown
0223-176.18-2B	2/28/2023 11:16	Unknown
CCV	2/28/2023 11:18	CCV
CCB	2/28/2023 11:21	CCB

Location: _____


Drawer: _____

Analyst: LMP

Cabinet: _____

Folder: _____

Date: 3/1/23

Job #s	Describe Work Documented on This Page
0223-17e	m29 Hg Analysis
Walt Jr 204A = Analytical Sequence	Supplies, Ancillary Equipment Serial #s, Lot #s, Etc
 NA	

Reviewer's Initials & Date:

Walt Jr.

page 204

EA Job# 0223-176R Page 173 of 186

W002AS-023392-RT-4542

378 of 688

walt jr 204A

Sample ID	Time Stamp
Cal Blank - 0 ug/mL	3/1/2023 11:10
Std. 1 - 0.1ug/mL	3/1/2023 11:13
Std. 2 - 1.0 ug/mL	3/1/2023 11:15
Std. 3 - 2.0 ug/mL	3/1/2023 11:17
Std. 4 - 5.0 ug/mL	3/1/2023 11:19
Std. 5 - 10.0 ug/mL	3/1/2023 11:22
ICV	3/1/2023 11:24
ICB	3/1/2023 11:26
0223-176.LB	3/1/2023 11:29
0223-176.LCS	3/1/2023 11:31
0223-176.1-3B	3/1/2023 11:33
0233-176.1-3B MS	3/1/2023 11:35
0223-176.2-3B	3/1/2023 11:38
0223-176.2-3B DUP	3/1/2023 11:40
0223-176.3-3B	3/1/2023 11:42
0223-176.4-3B	3/1/2023 11:45
0223-176.5-3B	3/1/2023 11:47
0223-176.6-3B	3/1/2023 11:49
CCV	3/1/2023 11:51
CCB	3/1/2023 11:54
0223-176.7-3B	3/1/2023 11:56
0223-176.8-3B	3/1/2023 11:58
0223-176.9-3B	3/1/2023 12:01
0223-176.10-3B	3/1/2023 12:03
0223-176.11-3B	3/1/2023 12:05
0223-176.12-3B	3/1/2023 12:07
0223-176.13-3B	3/1/2023 12:10
0223-176.14-3B	3/1/2023 12:12
0223-176.15-3B	3/1/2023 12:14
0223-176.16-3B	3/1/2023 12:16
CCV	3/1/2023 12:19
CCB	3/1/2023 12:21
0223-176.17-3B	3/1/2023 12:23
0223-176.18-3B	3/1/2023 12:26
CCV	3/1/2023 12:28
CCB	3/1/2023 12:30

Location: _____


Drawer: _____

Analyst: LMP

Cabinet: _____

Folder: _____

Date: 3/16/23

Job #s	Describe Work Documented on This Page	Supplies, Ancillary Equipment Serial #s, Lot #s, Etc
0223-176e	m29 Hy Analysis Walt Jr 205A = Analytical Sequence 	NP

Reviewer's Initials & Date:

Walt Jr.

page 205

EA Job# 0223-176R Page 175 of 186

W002AS-023392-RT-4542

380 of 688



Walt jr 205A

Sample ID	Time Stamp	Sample Type
Cal Blank - 0 ug/mL	3/6/2023 9:41	Standard
Std. 1 - 0.1ug/mL	3/6/2023 9:44	Standard
Std. 2 - 1.0 ug/mL	3/6/2023 9:46	Standard
Std. 3 - 2.0 ug/mL	3/6/2023 9:48	Standard
Std. 4 - 5.0 ug/mL	3/6/2023 9:50	Standard
Std. 5 - 10.0 ug/mL	3/6/2023 9:53	Standard
ICV	3/6/2023 9:55	ICV
ICB	3/6/2023 9:57	ICB
0223-176.LB	3/6/2023 10:00	Unknown
0223-176.LCS	3/6/2023 10:02	Unknown
0223-176.1-3C	3/6/2023 10:04	Unknown
0223-176.1-3C MS	3/6/2023 10:06	Unknown
0223-176.2-3C	3/6/2023 10:09	Unknown
0223-176.2-3C DUP	3/6/2023 10:11	Unknown
0223-176.3-3C	3/6/2023 10:13	Unknown
0223-176.4-3C	3/6/2023 10:16	Unknown
0223-176.5-3C	3/6/2023 10:18	Unknown
0223-176.6-3C	3/6/2023 10:20	Unknown
CCV	3/6/2023 10:22	CCV
CCB	3/6/2023 10:25	CCB
0223-176.7-3C	3/6/2023 10:27	Unknown
0223-176.8-3C	3/6/2023 10:29	Unknown
0223-176.9-3C	3/6/2023 10:32	Unknown
0223-176.10-3C	3/6/2023 10:34	Unknown
0223-176.11-3C	3/6/2023 10:36	Unknown
0223-176.12-3C	3/6/2023 10:38	Unknown
0223-176.13-3C	3/6/2023 10:41	Unknown
0223-176.14-3C	3/6/2023 10:43	Unknown
0223-176.15-3C	3/6/2023 10:45	Unknown
0223-176.16-3C	3/6/2023 10:48	Unknown
CCV	3/6/2023 10:50	CCV
CCB	3/6/2023 10:52	CCB
0223-176.17-3C	3/6/2023 10:54	Unknown
0223-176.18-3C	3/6/2023 10:57	Unknown
CCV	3/6/2023 10:59	CCV
CCB	3/6/2023 11:01	CCB

Location: _____


Drawer: _____

Analyst: LMP

Cabinet: _____

Folder: _____

Date: 3/7/23

Job #s	Describe Work Documented on This Page	Supplies, Ancillary Equipment Serial #s, Lot #s, Etc
0223-176 0123-137	<p>m29 Hg Analysis</p> <p>walt jr 20leA = Analytical sequence</p> <p>↓ 20leB = ↓</p> 	NA

Reviewer's Initials & Date:

Walt Jr.

page 206

EA Job# 0223-176R Page 177 of 186

W002AS-023392-RT-4542

382 of 688



walt jr 20eB

Sample ID	Time Stamp	Sample Type
Cal Blank - 0 ug/mL	3/7/2023 10:34	Standard
Std. 1 - 0.1ug/mL	3/7/2023 10:37	Standard
Std. 2 - 1.0 ug/mL	3/7/2023 10:39	Standard
Std. 3 - 2.0 ug/mL	3/7/2023 10:41	Standard
Std. 4 - 5.0 ug/mL	3/7/2023 10:43	Standard
Std. 5 - 10.0 ug/mL	3/7/2023 10:46	Standard
ICV	3/7/2023 10:48	ICV
ICB	3/7/2023 10:50	ICB
0223-176.LB	3/7/2023 10:53	Unknown
0223-176.LCS	3/7/2023 10:55	Unknown
0223-176.1-1B	3/7/2023 10:57	Unknown
0223-176.1-1B MS	3/7/2023 10:59	Unknown
0223-176.2-1B	3/7/2023 11:02	Unknown
0223-176.2-1B DUP	3/7/2023 11:04	Unknown
0223-176.3-1B	3/7/2023 11:06	Unknown
0223-176.4-1B	3/7/2023 11:09	Unknown
0223-176.5-1B	3/7/2023 11:11	Unknown
0223-176.6-1B	3/7/2023 11:13	Unknown
CCV	3/7/2023 11:15	CCV
CCB	3/7/2023 11:18	CCB
0223-176.7-1B	3/7/2023 11:20	Unknown
0223-176.8-1B	3/7/2023 11:22	Unknown
0223-176.9-1B	3/7/2023 11:25	Unknown
0223-176.10-1B	3/7/2023 11:27	Unknown
0223-176.11-1B	3/7/2023 11:29	Unknown
0223-176.12-1B	3/7/2023 11:32	Unknown
0223-176.13-1B	3/7/2023 11:34	Unknown
0223-176.14-1B	3/7/2023 11:36	Unknown
0223-176.15-1B	3/7/2023 11:39	Unknown
0223-176.16-1B	3/7/2023 11:41	Unknown
CCV	3/7/2023 11:43	CCV
CCB	3/7/2023 11:46	CCB
0223-176.17-1B	3/7/2023 11:48	Unknown
0223-176.18-1B	3/7/2023 11:50	Unknown
0223-176.LB Repour	3/7/2023 12:00	Unknown
CCV	3/7/2023 12:02	CCV
CCB	3/7/2023 12:04	CCB

1015B

Analyst: RRB

Date: 8/5/22

Job #: 0722-161, MOL Study

Describe Work Documented on This Page

Met Hg Prep

Supplies, Ancillary Equipment
Serial #s, Lot #s, Etc

1015 A: CVAA Standard Preparation Log

1015 B: Method 24 Hg Prepsheet

N/A

Reviewer's Initials & Date:

Metals Prep
page 1015



EA Job# 0223-176R Page 180 of 186

W002AS-023392-RT-4542

385 of 688

CVAA Standard Preparation Log *Stds must be prepared fresh daily

EA Std ID# HG (Job #, 1, 2, 3, etc.)	Std/Reagent Name	Conc.	Stock Standard/Reagent	Conc.	EA ID# & Exp Date	Amount Added	Final Volume (mL) & Diluent	Pipette & Exp Date	Analyst	Date	Exp. Date
Primary Intermediate Standard											
1											
Primary Int Std.	1000 ppb	Hg Standard	1000 ppm	F0194	10/11/23	0.10 mL	100	133	DI	9/7/23	8/15/23
"	"	HgO3	67.70%	54202036	3-24	0.5 mL	"	"	134	"	8/16/23
Secondary Intermediate Standard											
2											
Secondary Int Std.	1000 ppb	44% Standard (70% HgO3)	1000 ppm	F0764	10/11/23	0.10 mL	100	133	DI	9/7/23	8/17/23
"	"	HgO3	67.70%	54202036	3-24	0.5 mL	"	"	134	"	8/17/23
Primary Working Standard											
3											
Primary Working Std.	50 ppb	Primary Int. Std.	1000 ppm	①	8/16/23	5.0 mL	100	133	DI	9/6/23	8/16/23
"	"	HgO3	67.70%	54202036	3-24	0.5 mL	"	"	134	"	8/17/23
Secondary Working Standard											
4											
Secondary Working Std.	50 ppb	Secondary Int. Std.	1000 ppb	2	8/16/23	5.0 mL	100	133	DI	9/6/23	8/17/23
"	"	HgO3	67.70%	54202036	3-24	0.5 mL	"	"	134	"	8/17/23

W002AS-023392-RT-4542

386 of 688

 ENTHALPY ANALYTICAL	Method 29 Hg Prepsheet							
	Job Nos: 0722-161, MDL Study							
	Prep Date(s): 8/5/22							
	Analyst(s) RAB				Instrument: Walt Jr.			
Calibration Standards and QC					Samples			
Spike Used	Calibration Standard	Spike Amount (mL)	Pip & Exp	Final Vol. (mL)	Sample ID	Aliquot Volume (mL)	Final Vol. (mL)	
--	Calibration Blank	--		50	0722-161-1-B	10.0	50	
1st WS	Standard 1 - 0.1 ppb	0.1	133 9/6/22	50	.2		50	
1st WS	Standard 2 - 1.0 ppb	1.0	134 9/6/22	50	.3		50	
1st WS	Standard 3 - 2.0 ppb	2.0	1	50	.4		50	
1st WS	Standard 4 - 5.0 ppb	5.0	141 9/6/22	50	MDL.1	0.1 ^①	50	
1st WS	Standard 5 - 10 ppb	10.0	1	50	.2		50	
2nd WS	ICV/CCV - 5.0 ppb	5.0	1	50	.3		50	
--	ICB/CCB	--		50	.4		50	
Temp (°C):	95.1	Hotplate # 3			.5		50	
1st WS ID:	3	Exp Date: 8/6/22			.6		50	
2nd WS ID:	4	Exp Date: 8/6/22			.7		50	
H2SO4 ID:	SCA 134 9977	Exp Date: 6/24 ^②			.8		50	
HNO3 ID:	SCA 208 9036	Exp Date: 3-24					50	
KMnO4 ID:	ES-0689	Exp Date: 2/13/23					50	
K2S2O8 ID:	ES-0689 ^③	Exp Date: 2/13/23 ^④					50	
HAS ID:	ES-0675	Exp Date: 1/19/23					50	
SnCl2 ID:	ES-0688	Exp Date: 8/7/22					50	
H2SO4 Pip & Exp:	139 9/7/22	HNO3 Pip & Exp: 139 9/7/22					50	
KMnO4 Pip & Exp:		K2S2O8 Pip & Exp: 1					50	
HAS Pip & Exp:		Digitube ID: J S 37215-2104					50	
LCS Pip & Exp:	141 9/6/22	MS Pip & Exp: 141 9/6/22			Digestion Time			
					Start: 9:57 AM Finish: 11:57 AM			
Quality Control								
QC Sample	Sample ID	Aliq. Vol. (mL)		Final Vol. (mL)	Spike ID	ID Exp Date	Stock Conc	Volume Added (mL)
MB	N/A	20		50	N/A	N/A	N/A	N/A
LCS	N/A	20		50	3	8/6/22	50 ppb	5.0
MS	0722-161.1-1-B	10.0		50	1	1	1	1
Duplicate	1 .2 1	1		50	N/A	N/A	N/A	N/A



Sample ID	Time Stamp	Sample Type	Average Conc.	%RSD Conc.	Conc. Units
Cal Blank - 0 ug/mL	8/5/2022 12:42	Standard	0	0	ppb
Std. 1 - 0.1ug/mL	8/5/2022 12:45	Standard	0.1	0	ppb
Std. 2 - 1.0 ug/mL	8/5/2022 12:47	Standard	1	0	ppb
Std. 3 - 2.0 ug/mL	8/5/2022 12:49	Standard	2	0	ppb
Std. 4 - 5.0 ug/mL	8/5/2022 12:51	Standard	5	0	ppb
Std. 5 - 10.0 ug/mL	8/5/2022 12:54	Standard	10	0	ppb
ICV	8/5/2022 12:56	ICV	5.12	0.001	ppb
ICB	8/5/2022 12:58	ICB	0.011	0.014	ppb
0722-161.LB	8/5/2022 13:01	Unknown	0	0.79	ppb
0722-161.LCS	8/5/2022 13:03	Unknown	5.01	0.001	ppb
MDL.1	8/5/2022 13:05	Unknown	0.103	0.001	ppb
MDL.2	8/5/2022 13:08	Unknown	0.102	0.001	ppb
MDL.3	8/5/2022 13:10	Unknown	0.085	0.002	ppb
MDL.4	8/5/2022 13:12	Unknown	0.098	0.001	ppb
MDL.5	8/5/2022 13:14	Unknown	0.111	0.002	ppb
MDL.6	8/5/2022 13:17	Unknown	0.126	0.001	ppb
MDL.7	8/5/2022 13:19	Unknown	0.12	0.001	ppb
MDL.8	8/5/2022 13:21	Unknown	0.109	0.002	ppb
CCV	8/5/2022 13:24	CCV	5.43	0.001	ppb
CCB	8/5/2022 13:26	CCB	-0.002	0.04	ppb
0722-161.1-1B	8/5/2022 13:28	Unknown	0.035	0.006	ppb
0722-161.1-1B MS	8/5/2022 13:31	Unknown	4.86	0.001	ppb
0722-161.2-1B	8/5/2022 13:33	Unknown	0.057	0.002	ppb
0722-161.2-1B DUP	8/5/2022 13:35	Unknown	0.063	0.002	ppb
0722-161.3-1B	8/5/2022 13:37	Unknown	0.011	0.006	ppb
0722-161.4-1B	8/5/2022 13:40	Unknown	0.036	0.002	ppb
CCV	8/5/2022 13:42	CCV	4.65	0.001	ppb
CCB	8/5/2022 13:44	CCB	0.01	0.005	ppb

File Edit View Log Analyze Options Window Help



Analysis

Tube	Sample Label	Conc ppb	μAbs	Flag	ZRSD Abs
1.8	MDL.6	0.126	2033.18		0.6
1.9	MDL.7	0.120	1950.14		1.0
1.10	MDL.8	0.109	1807.27		1.7
S.7	CCV	5.430	7407.57		0.5
S.8	CCB	-0.002	293.35		4.0
1.11	0722-161.1-1B	0.035	793.29		3.7
1.12	0722-161.1-1B MS	4.860	66267.06		1.1
1.13	0722-161.2-1B	0.057	1102.79		1.4
1.14	0722-161.2-1B DUP	0.063	1170.92		1.7
1.15	0722-161.3-1B	0.011	471.68		1.9
1.16	0722-161.4-1B	0.036	807.84		1.2
S.7	CCV	4.650	63482.34		1.2
S.8	CCB	0.010	460.20		1.4



8/5/2022 1:44:48 PM	Worksheet Saved
8/5/2022 1:44:48 PM	Sample 'CCB' measured. Conc.: 1.0100E-002 ppb [not diln, corrected]
8/5/2022 1:44:48 PM	QC Sample 'CCV' recovery was measured at 93.03 percent
8/5/2022 1:42:28 PM	Sample 'CCV' measured. Conc.: 4.650 ppb [not diln, corrected]
8/5/2022 1:42:28 PM	Sample '0722-161.4-1B' measured. Conc.: 3.5700E-002 ppb [not diln, corrected]
8/5/2022 1:40:08 PM	Sample '0722-161.3-1B' measured. Conc.: 1.1000E-002 ppb [not diln, corrected]
8/5/2022 1:37:52 PM	Sample '0722-161.2-1B DUP' measured. Conc.: 6.2500E-002 ppb [not diln, corrected]
8/5/2022 1:35:36 PM	Sample '0722-161.2-1B' measured. Conc.: 5.7400E-002 ppb [not diln, corrected]
8/5/2022 1:33:21 PM	Sample '0722-161.1-B MS' measured. Conc.: 4.860 ppb [not diln, corrected]
8/5/2022 1:31:05 PM	Sample '0722-161.1-B' measured. Conc.: 3.4600E-002 ppb [not diln, corrected]
8/5/2022 1:28:47 PM	Sample 'CCB' measured. Conc.: 2.1700E-003 ppb [not diln, corrected]
8/5/2022 1:26:28 PM	QC Sample 'CCV' recovery was measured at 108.64 percent
8/5/2022 1:24:08 PM	

Walt Jr Pg 117A 555
8/5/22

Sheet1

Sample ID	Time Stamp	Sample Type
Cal Blank - 0 ug/mL	8/5/2022 12:42:51 PM	Standard
Std. 1 - 0.1ug/mL	8/5/2022 12:45:07 PM	Standard
Std. 2 - 1.0 ug/mL	8/5/2022 12:47:24 PM	Standard
Std. 3 - 2.0 ug/mL	8/5/2022 12:49:41 PM	Standard
Std. 4 - 5.0 ug/mL	8/5/2022 12:51:59 PM	Standard
Std. 5 - 10.0 ug/mL	8/5/2022 12:54:19 PM	Standard
ICV	8/5/2022 12:56:38 PM	ICV
ICB	8/5/2022 12:58:59 PM	ICB
0722-161.LB	8/5/2022 1:01:14 PM	Unknown
0722-161.LCS	8/5/2022 1:03:30 PM	Unknown
MDL.1	8/5/2022 1:05:46 PM	Unknown
MDL.2	8/5/2022 1:08:03 PM	Unknown
MDL.3	8/5/2022 1:10:20 PM	Unknown
MDL.4	8/5/2022 1:12:37 PM	Unknown
MDL.5	8/5/2022 1:14:54 PM	Unknown
MDL.6	8/5/2022 1:17:12 PM	Unknown
MDL.7	8/5/2022 1:19:30 PM	Unknown
MDL.8	8/5/2022 1:21:48 PM	Unknown
CCV	8/5/2022 1:24:08 PM	CCV
CCB	8/5/2022 1:26:28 PM	CCB
0722-161.1-1B	8/5/2022 1:28:47 PM	Unknown
0722-161.1-1B MS	8/5/2022 1:31:05 PM	Unknown
0722-161.2-1B	8/5/2022 1:33:21 PM	Unknown
0722-161.2-1B DUP	8/5/2022 1:35:36 PM	Unknown
0722-161.3-1B	8/5/2022 1:37:52 PM	Unknown
0722-161.4-1B	8/5/2022 1:40:08 PM	Unknown
CCV	8/5/2022 1:42:28 PM	CCV
CCB	8/5/2022 1:44:48 PM	CCB

**This Is The Last Page
Of This Report.**



Appendix A.5 EPA Method 320 Data



**Sunshine Canyon Landfill
Sylmar, CA
Turbine 4 & Turbine 5
USEPA Method 320 Testing**

**February 7, 8, 14 & 15, 2023
PROJ-023392**

By

Phillip Kauppi
District Manager / Chemist

April 12, 2023



**Sunshine Canyon Landfill
Sylmar, CA
Turbine 4 & Turbine 5
USEPA Method 320 Testing
February 7, 8, 14 & 15, 2023
PROJ-023392**

Scope

Montrose Air Quality Services (MAQS, Mt. Pleasant, MI) was contracted to conduct emissions testing on Turbine 4 and Turbine 5 at Sunshine Canyon Landfill in Sylmar, CA. Testing was performed February 7, 8, 14 and 15, 2023 to determine concentrations of gaseous formaldehyde (CH_2O), hydrochloric acid (HCl), hydrofluoric acid (HF), and moisture (H_2O) from the turbines.

US EPA Method 320 was performed to quantify the concentration levels of gaseous emissions. Trevor Tilmann (MAQS) performed data collection. Phillip Kauppi (MAQS) performed data validation, and report generation.

Procedures

FTIR Method 320 Instrumental Configuration & Sample Collection

FTIR data were collected using an MKS MultiGas 2030 FTIR spectrometer. The FTIR was equipped with a temperature-controlled, 5.11-meter multipass gas cell maintained at 191°C. All data were collected at 0.5 cm⁻¹ resolution. Each FTIR spectrum was derived from the coaddition of 64 scans, with a new data point generated approximately every 60 seconds.

Sample gas continuously passed through the FTIR gas cell via heated head sampling pump. Total sample flow was approximately ten liters per minute. Gas flow and sampling system pressure were monitored using a rotameter and pressure transducer. See Table 1 below for sampling system details.

Table 1 – FTIR Sampling System

Source	MKS Serial #	Sampling Line	Probe Assembly	Particulate Filter Media	Operating Temperatures
Turbine 4	017796313	50', 3/8" dia. Teflon	3', 3/8" dia. SS + heated filter element	0.01μ borosilicate	191°C FTIR + system
Turbine 5					

FTIR diagnostics were performed on the instrument daily to ensure signal intensity and line shape were acceptable to make measurements. See these results in the FTIR Diagnostics appendix.

FTIR QA/QC Methodology

QA/QC procedures followed US EPA Method 320. See Tables 2 and 3 below for QA/QC procedure details and list of calibration gas standards. All calibration gases were introduced to the analyzer and sampling system using instrument grade stainless steel rotameters. All QA/QC procedures were within the acceptance criteria allowance of the EPA methodology. QA/QC calculations are presented in detail below.

Table 2 – FTIR QA/QC Procedures

QAQC Specification	Purpose	Calibration Gas Analyte	Delivery	Frequency	Acceptance Criteria	Result
M320: Zero	Verify that the FTIR is free of contaminants & zero the FTIR	Nitrogen (zero)	Direct to FTIR	Daily - pre/post test	< MDL or Noise	Pass
M320: Calibration Transfer Standard (CTS) Direct	Verify FTIR stability, confirm optical path length	Ethylene	Direct to FTIR	Daily - pre-test	+/- 5% cert. value	Pass
M320: Analyte Direct	Verify FTIR calibration	Formaldehyde/SF6 HCl/SF6 HF/SF6	Direct to FTIR	Daily - pre-test	Determine FTIR response to be used for analyte spike calcs	Pass
M320: CTS Response	Verify system stability, recovery, RT	Ethylene	Sampling System	Daily - pre/post test runs	+/- 5% of Direct Measurement	Pass
M320: Zero Response	Verify system is free of contaminants, system bias	Nitrogen (zero)	Sampling System	Daily - pre/post test	Bias correct data	Pass
M320: Analyte Spike	Verify system ability to deliver and quantify analyte of interest in the presence of other effluent gases	Formaldehyde/SF6 HCl/SF6 HF/SF6	Dynamic Addition to Sampling System, 1:10 effluent	Daily - pre-test	+/- 30% theoretical recovery	Pass

Table 3 – Calibration Gas Standards

Components	Concentration (ppm)	Vendor	Cylinder #	Standard Type
Formaldehyde/SF6	19.71, 4.97	Apel Reimer	CC751990	Certified Standard +/- 5%, 2%
HCl, SF6	99.9, 5.0	Airgas	CC715847	GMACS +/- 2.30%, 0.96%
HF, SF6	111.2, 4.999	Airgas	EB01146042	Certified Standard +/- 10%
Ethylene	100.2	Airgas	CC14351	Primary +/- 1%
Nitrogen	Zero gas	Praxair	CC700873	UHP Grade

FTIR QA/QC Calculations

Method 320: Analyte Spiking

Formaldehyde, HCl and HF spiking was performed daily at each source prior to testing to verify the ability of the sampling system to quantitatively deliver a sample containing formaldehyde, HCl and HF from the base of the probe to the FTIR. The spike target dilution ratio was 1:10 or

less. Analyte spiking assures the ability of the FTIR to quantify formaldehyde, HCl and HF in the presence of effluent gas.

As part of the spiking procedure, samples from the sources were measured to determine native formaldehyde, HCl and HF concentrations to be used in the spike recovery calculations. The spiking gases contained a low concentration of sulfur hexafluoride (SF_6). The determined SF_6 concentration in the spiked sample was used to calculate the dilution factor of the spike and thus used to calculate the concentration of the spiked formaldehyde, HCl and HF. The following equations illustrates the percent recovery calculation.

$$DF = \frac{SF_6(spk)}{SF_6(dir)} \quad (\text{Sec. 9.3.1 (3) USEPA Method 320})$$

$$CS = DF * Spike(dir) + Unspike(1 - DF) \quad (\text{Sec. 9.3.1 (2) USEPA Method 320})$$

DF	= Dilution factor of the spike gas
$SF_6(\text{nat})$	= SF_6 concentration measured directly in unspiked sample
$SF_6(\text{dir})$	= SF_6 concentration measured directly in undiluted spike gas
$SF_6(\text{spk})$	= Diluted SF_6 concentration measured in a spiked sample
$H_2O(\text{nat})$	= Native H_2O concentration measured in unspiked samples
$H_2O(\text{spk})$	= Diluted H_2O concentration measured in a spiked sample
$\text{Spike}_{\text{dir}}$	= Concentration of the analyte in the spike standard measure by the FTIR directly
CS	= Expected concentration of the spiked samples
Unspike	= Native concentration of analytes in unspiked samples

FTIR Post Collection Data Validation

As part of the data validation procedure, reference spectra are manually fit to that of the sample spectra and a concentration is determined. The reference spectra are scaled to match the peak amplitude of the sample, thus providing a scale factor. The scale factor multiplied by the reference spectra concentration is used to determine the concentration value for the sample spectra. Sample pressure and temperature corrections are then applied to compute the final sample concentration. The manually calculated results are then compared with the software-generated results. The data is then validated if the two concentrations are within $\pm 20\%$ agreement. If there is a difference greater than $\pm 20\%$ the spectra are reviewed for possible spectra interferences or any other potential causes leading to misquantified data.

Results and Discussion

Detection Limit

The FTIR detection limit for each analyte was calculated following Annex A2 of ASTM D6348-12 procedure using spectra that contained similar amounts of moisture. The minimum detectable concentration of the analytes was calculated as three times the standard deviation of the noise in

the FTIR system. This minimum concentration can be detected with a probability of 99.7 %. See Table 4 below for determined minimum detectable concentrations.

Table 4 - FTIR Detection Limits

Analyte	Detection Limit (ppmv wet)	Detection Limit (%v wet)
H ₂ O	-	0.1
Formaldehyde	0.2	-
HCl	0.2	-
HF	0.4	-

Turbine 4 & Turbine 5

Seven, sixty-minute test runs were performed on Turbine 4 over February 7 and 8, 2023. Seven, sixty-minute test runs were performed on Turbine 5 on February 14 and 15, 2023. All Method 320 FTIR data concentration data were determined on a wet concentration (ppmvw) volume basis. The determined moisture content was used to calculate formaldehyde, HCl and HF on a dry basis (ppmvd).

Analyte spiking was performed to confirm the ability of the measurement system to deliver and quantify formaldehyde, HCl and HF. See the FTIR QA/QC Data and Run Results Appendix for all concentration results. See Tables 5 and 6 below for a summary of test run results.

Table 5 – Turbine 4 – Test Run Averages

Test Detail	H ₂ O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)
02/07/2023 Turbine 4 - Run 1 10:50 - 11:50	5.61	0.51	1.62	< 0.2	0.54	1.72	< 0.2
02/07/2023 Turbine 4 - Run 2 12:00 - 12:56 ; 13:04 - 13:08	5.57	0.46	1.58	< 0.2	0.49	1.67	< 0.2
02/07/2023 Turbine 4 - Run 3 13:15 - 14:15	5.56	0.48	1.69	< 0.2	0.50	1.79	< 0.2
02/08/2023 Turbine 4 - Run 4 09:06 - 10:06	5.69	0.42	1.53	< 0.2	0.45	1.62	< 0.2
02/08/2023 Turbine 4 - Run 5 10:19 - 11:19	5.69	0.48	1.71	< 0.2	0.51	1.81	< 0.2
02/08/2023 Turbine 4 - Run 6 11:23 - 12:18 ; 12:27 - 12:32	5.70	0.53	1.80	< 0.2	0.56	1.90	< 0.2
02/08/2023 Turbine 4 - Run 7 13:05 - 14:05	5.65	0.56	1.89	< 0.2	0.60	2.00	< 0.2

Table 6 – Turbine 5 – Test Run Averages

Test Detail	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)
02/14/2023 Turbine 5 - Run 1 9:15 - 10:15	5.85	0.27	1.19	< 0.2	0.29	1.26	< 0.2
02/14/2023 Turbine 5 - Run 2 10:20 - 11:20	5.70	0.30	1.26	< 0.2	0.31	1.34	< 0.2
02/14/2023 Turbine 5 - Run 3 11:25 - 12:09; 12:18 - 12:34	5.68	0.33	1.32	< 0.2	0.35	1.40	< 0.2
02/14/2023 Turbine 5 - Run 4 12:40 - 13:40	5.63	0.36	1.37	< 0.2	0.38	1.45	< 0.2
02/15/2023 Turbine 5 - Run 5 9:05 - 10:05	5.46	0.27	1.14	< 0.2	0.29	1.21	< 0.2
02/15/2023 Turbine 5 - Run 6 10:10 - 11:10	5.37	0.31	1.44	< 0.2	0.33	1.52	< 0.2
02/15/2023 Turbine 5 - Run 7 11:15 - 11:45; 12:00 - 12:30	5.31	0.37	1.56	< 0.2	0.39	1.64	< 0.2

The following Appendices are included:

- FTIR QA/QC Data
- FTIR Run Data
- Certificates of Analysis



 Date: April 12th, 2023

Phillip Kauppi

District Manager / Chemist

SunshineCanyonLandfill_2023Feb_PROJ-023392_txt

APPENDIX

FTIR Test Run Data

Turbine 4 - Run 1

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T4_001183.LAB	2/7/2023	10:50:59	5.63	0.50	1.63	0.02	0.53	1.73	0.02	191.9	1.004
T4_001184.LAB	2/7/2023	10:51:59	5.60	0.54	1.66	0.03	0.58	1.76	0.03	191.8	1.004
T4_001185.LAB	2/7/2023	10:52:59	5.58	0.46	1.62	0.05	0.49	1.71	0.05	191.8	1.004
T4_001186.LAB	2/7/2023	10:53:59	5.59	0.51	1.58	0.08	0.54	1.68	0.09	191.8	1.005
T4_001187.LAB	2/7/2023	10:54:59	5.59	0.53	1.56	0.02	0.57	1.65	0.02	191.8	1.005
T4_001188.LAB	2/7/2023	10:55:59	5.59	0.49	1.56	0.05	0.52	1.66	0.05	191.7	1.005
T4_001189.LAB	2/7/2023	10:56:59	5.59	0.49	1.53	0.08	0.52	1.62	0.08	191.8	1.007
T4_001190.LAB	2/7/2023	10:57:59	5.61	0.48	1.54	-0.09	0.51	1.64	-0.10	191.8	1.006
T4_001191.LAB	2/7/2023	10:58:59	5.61	0.51	1.56	-0.02	0.54	1.66	-0.02	191.9	1.006
T4_001192.LAB	2/7/2023	10:59:59	5.62	0.49	1.55	-0.02	0.52	1.65	-0.02	191.8	1.006
T4_001193.LAB	2/7/2023	11:00:59	5.62	0.49	1.60	-0.07	0.52	1.69	-0.07	191.7	1.004
T4_001194.LAB	2/7/2023	11:01:59	5.58	0.53	1.64	0.02	0.56	1.74	0.02	191.6	1.005
T4_001195.LAB	2/7/2023	11:02:59	5.61	0.54	1.64	0.06	0.57	1.74	0.06	191.6	1.003
T4_001196.LAB	2/7/2023	11:03:58	5.60	0.57	1.63	-0.03	0.61	1.72	-0.03	191.7	1.003
T4_001197.LAB	2/7/2023	11:04:59	5.61	0.53	1.60	0.07	0.56	1.70	0.07	191.8	1.005
T4_001198.LAB	2/7/2023	11:05:59	5.62	0.46	1.61	0.01	0.48	1.71	0.01	191.8	1.004
T4_001199.LAB	2/7/2023	11:06:58	5.61	0.51	1.59	0.05	0.54	1.68	0.05	191.7	1.006
T4_001200.LAB	2/7/2023	11:07:58	5.61	0.49	1.61	-0.01	0.52	1.70	-0.01	191.7	1.005
T4_001201.LAB	2/7/2023	11:08:58	5.61	0.47	1.61	0.01	0.49	1.70	0.01	191.6	1.006
T4_001202.LAB	2/7/2023	11:09:58	5.59	0.51	1.61	0.03	0.54	1.70	0.04	191.7	1.006
T4_001203.LAB	2/7/2023	11:10:58	5.61	0.57	1.64	0.05	0.60	1.74	0.05	191.7	1.006
T4_001204.LAB	2/7/2023	11:11:58	5.62	0.53	1.70	-0.02	0.56	1.80	-0.02	191.7	1.004
T4_001205.LAB	2/7/2023	11:12:58	5.60	0.50	1.71	0.05	0.53	1.81	0.06	191.8	1.004
T4_001206.LAB	2/7/2023	11:13:58	5.61	0.55	1.66	0.08	0.59	1.76	0.08	191.7	1.003
T4_001207.LAB	2/7/2023	11:14:58	5.60	0.47	1.61	-0.06	0.49	1.71	-0.07	191.7	1.004
T4_001208.LAB	2/7/2023	11:15:58	5.62	0.56	1.61	0.09	0.60	1.70	0.10	191.7	1.004
T4_001209.LAB	2/7/2023	11:16:58	5.63	0.50	1.61	0.05	0.53	1.71	0.05	191.7	1.004
T4_001210.LAB	2/7/2023	11:17:58	5.63	0.44	1.60	0.01	0.47	1.69	0.01	191.7	1.005
T4_001211.LAB	2/7/2023	11:18:58	5.61	0.50	1.60	0.01	0.53	1.70	0.01	191.7	1.006
T4_001212.LAB	2/7/2023	11:19:58	5.61	0.47	1.60	-0.04	0.50	1.70	-0.04	191.7	1.007
T4_001213.LAB	2/7/2023	11:20:57	5.61	0.51	1.60	0.02	0.54	1.69	0.02	191.7	1.006
T4_001214.LAB	2/7/2023	11:21:57	5.63	0.48	1.66	0.08	0.51	1.76	0.09	191.7	1.004
T4_001215.LAB	2/7/2023	11:22:57	5.66	0.51	1.70	0.00	0.54	1.80	0.00	191.8	1.003
T4_001216.LAB	2/7/2023	11:23:57	5.63	0.50	1.67	0.02	0.53	1.76	0.02	191.8	1.005
T4_001217.LAB	2/7/2023	11:24:57	5.62	0.53	1.63	-0.03	0.56	1.73	-0.03	191.7	1.004
T4_001218.LAB	2/7/2023	11:25:57	5.64	0.52	1.60	0.02	0.55	1.70	0.02	191.7	1.004
T4_001219.LAB	2/7/2023	11:26:57	5.63	0.49	1.62	0.01	0.52	1.72	0.01	191.6	1.005
T4_001220.LAB	2/7/2023	11:27:57	5.61	0.51	1.63	0.12	0.54	1.73	0.12	191.6	1.005
T4_001221.LAB	2/7/2023	11:28:57	5.59	0.50	1.62	0.04	0.53	1.71	0.05	191.7	1.006
T4_001222.LAB	2/7/2023	11:29:57	5.63	0.52	1.61	-0.02	0.56	1.71	-0.02	191.7	1.005
T4_001223.LAB	2/7/2023	11:30:58	5.65	0.52	1.63	0.06	0.55	1.73	0.06	191.7	1.007
T4_001224.LAB	2/7/2023	11:31:57	5.71	0.52	1.70	0.07	0.55	1.81	0.07	193.1	1.000
T4_001225.LAB	2/7/2023	11:32:57	5.63	0.54	1.69	0.04	0.57	1.79	0.04	191.6	1.003
T4_001226.LAB	2/7/2023	11:33:57	5.60	0.52	1.70	-0.06	0.55	1.80	-0.06	191.6	1.004
T4_001227.LAB	2/7/2023	11:34:57	5.63	0.51	1.66	0.07	0.54	1.76	0.07	191.6	1.004
T4_001228.LAB	2/7/2023	11:35:56	5.60	0.49	1.64	0.05	0.52	1.74	0.05	191.6	1.003
T4_001229.LAB	2/7/2023	11:36:57	5.63	0.52	1.63	0.05	0.56	1.73	0.06	191.8	1.004
T4_001230.LAB	2/7/2023	11:37:57	5.60	0.49	1.61	-0.05	0.52	1.71	-0.05	191.7	1.006
T4_001231.LAB	2/7/2023	11:38:57	5.58	0.49	1.61	0.01	0.52	1.71	0.01	191.7	1.007
T4_001232.LAB	2/7/2023	11:39:57	5.60	0.53	1.59	-0.02	0.56	1.68	-0.02	191.6	1.005
T4_001233.LAB	2/7/2023	11:40:56	5.59	0.50	1.57	0.06	0.53	1.66	0.06	191.7	1.006
T4_001234.LAB	2/7/2023	11:41:56	5.62	0.47	1.59	0.06	0.50	1.69	0.06	191.6	1.006
T4_001235.LAB	2/7/2023	11:42:56	5.61	0.51	1.65	0.06	0.54	1.75	0.06	191.7	1.003
T4_001236.LAB	2/7/2023	11:43:56	5.61	0.54	1.66	-0.01	0.58	1.76	-0.01	191.7	1.004
T4_001237.LAB	2/7/2023	11:44:56	5.63	0.55	1.63	0.03	0.58	1.72	0.03	191.6	1.003
T4_001238.LAB	2/7/2023	11:45:56	5.63	0.53	1.61	-0.04	0.56	1.70	-0.04	191.6	1.004
T4_001239.LAB	2/7/2023	11:46:56	5.60	0.49	1.59	-0.03	0.52	1.69	-0.03	191.6	1.005
T4_001240.LAB	2/7/2023	11:47:56	5.61	0.49	1.61	-0.01	0.52	1.70	-0.01	191.6	1.004
T4_001241.LAB	2/7/2023	11:48:56	5.62	0.51	1.58	0.07	0.54	1.68	0.07	191.6	1.004
T4_001242.LAB	2/7/2023	11:49:56	5.62	0.51	1.60	0.05	0.54	1.69	0.05	191.6	1.005
T4_001243.LAB	2/7/2023	11:50:56	5.61	0.49	1.56	-0.04	0.52	1.66	-0.04	191.6	1.004
02/07/2023		Minimum	5.58	0.44	1.53	-0.09	0.47	1.62	-0.10		
Turbine 4 - Run 1		Maximum	5.71	0.57	1.71	0.12	0.61	1.81	0.12		
10:50 - 11:50		Average	5.61	0.51	1.62	0.02	0.54	1.72	0.02		

Turbine 4 - Run 2

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T4_001259.LAB	2/7/2023	12:00:59	5.61	0.41	1.49	0.02	0.43	1.58	0.02	191.7	1.006
T4_001260.LAB	2/7/2023	12:01:59	5.59	0.44	1.50	0.01	0.47	1.59	0.02	191.6	1.006
T4_001261.LAB	2/7/2023	12:02:59	5.60	0.48	1.56	-0.01	0.51	1.65	-0.01	191.6	1.005
T4_001262.LAB	2/7/2023	12:03:59	5.61	0.51	1.60	-0.09	0.54	1.70	-0.10	191.6	1.004
T4_001263.LAB	2/7/2023	12:04:59	5.60	0.47	1.58	-0.01	0.49	1.67	-0.01	191.7	1.003
T4_001264.LAB	2/7/2023	12:05:58	5.60	0.49	1.58	0.04	0.52	1.67	0.04	191.6	1.004
T4_001265.LAB	2/7/2023	12:06:58	5.59	0.47	1.55	-0.04	0.50	1.64	-0.05	191.7	1.004
T4_001266.LAB	2/7/2023	12:07:58	5.59	0.47	1.57	-0.01	0.50	1.66	-0.01	191.7	1.002
T4_001267.LAB	2/7/2023	12:08:58	5.60	0.48	1.55	-0.02	0.51	1.64	-0.02	191.7	1.004
T4_001268.LAB	2/7/2023	12:09:59	5.56	0.45	1.54	0.03	0.48	1.63	0.03	191.7	1.005
T4_001269.LAB	2/7/2023	12:10:58	5.59	0.44	1.57	0.01	0.46	1.66	0.01	191.6	1.005
T4_001270.LAB	2/7/2023	12:11:58	5.59	0.49	1.54	0.07	0.52	1.64	0.07	191.6	1.006
T4_001271.LAB	2/7/2023	12:12:58	5.57	0.48	1.57	0.10	0.50	1.66	0.10	191.6	1.006
T4_001272.LAB	2/7/2023	12:13:58	5.57	0.49	1.62	-0.01	0.52	1.71	-0.01	191.7	1.004
T4_001273.LAB	2/7/2023	12:14:58	5.56	0.48	1.61	0.02	0.50	1.70	0.03	191.7	1.004
T4_001274.LAB	2/7/2023	12:15:58	5.60	0.48	1.57	0.00	0.51	1.67	0.00	191.7	1.002
T4_001275.LAB	2/7/2023	12:16:58	5.60	0.50	1.55	0.09	0.53	1.64	0.10	191.6	1.003
T4_001276.LAB	2/7/2023	12:17:58	5.59	0.45	1.54	-0.01	0.47	1.63	-0.01	191.6	1.003
T4_001277.LAB	2/7/2023	12:18:58	5.57	0.48	1.55	-0.06	0.51	1.64	-0.06	191.6	1.005
T4_001278.LAB	2/7/2023	12:19:58	5.58	0.46	1.55	0.07	0.49	1.64	0.07	191.7	1.005
T4_001279.LAB	2/7/2023	12:20:58	5.60	0.43	1.56	0.03	0.46	1.65	0.03	191.6	1.005
T4_001280.LAB	2/7/2023	12:21:58	5.58	0.49	1.55	0.05	0.52	1.64	0.06	191.7	1.006
T4_001281.LAB	2/7/2023	12:22:58	5.58	0.45	1.59	0.03	0.48	1.68	0.03	191.7	1.004
T4_001282.LAB	2/7/2023	12:23:57	5.57	0.48	1.64	-0.02	0.50	1.74	-0.02	191.7	1.003
T4_001283.LAB	2/7/2023	12:24:57	5.56	0.51	1.63	0.01	0.54	1.73	0.02	191.7	1.004
T4_001284.LAB	2/7/2023	12:25:58	5.58	0.50	1.60	0.06	0.53	1.70	0.06	191.6	1.002
T4_001285.LAB	2/7/2023	12:26:57	5.56	0.49	1.57	0.03	0.52	1.67	0.03	191.7	1.003
T4_001286.LAB	2/7/2023	12:27:57	5.54	0.43	1.57	0.03	0.46	1.66	0.04	191.7	1.003
T4_001287.LAB	2/7/2023	12:28:57	5.57	0.43	1.54	0.05	0.46	1.63	0.05	191.7	1.003
T4_001288.LAB	2/7/2023	12:29:57	5.55	0.42	1.54	-0.04	0.44	1.63	-0.04	191.7	1.004
T4_001289.LAB	2/7/2023	12:30:57	5.53	0.43	1.52	-0.04	0.46	1.61	-0.04	191.7	1.005
T4_001290.LAB	2/7/2023	12:31:57	5.54	0.42	1.55	-0.05	0.45	1.64	-0.06	191.6	1.005
T4_001291.LAB	2/7/2023	12:32:57	5.53	0.45	1.57	0.02	0.48	1.66	0.02	191.6	1.005
T4_001292.LAB	2/7/2023	12:33:57	5.57	0.44	1.60	0.02	0.47	1.69	0.02	191.7	1.002
T4_001293.LAB	2/7/2023	12:34:57	5.54	0.49	1.62	0.04	0.52	1.71	0.04	191.8	1.002
T4_001294.LAB	2/7/2023	12:35:57	5.54	0.42	1.57	0.04	0.44	1.66	0.04	191.7	1.000
T4_001295.LAB	2/7/2023	12:36:57	5.55	0.44	1.56	0.02	0.46	1.65	0.03	191.7	1.003
T4_001296.LAB	2/7/2023	12:37:57	5.52	0.45	1.54	0.02	0.47	1.63	0.02	191.6	1.004
T4_001297.LAB	2/7/2023	12:38:57	5.57	0.44	1.56	0.04	0.47	1.65	0.05	191.6	1.003
T4_001298.LAB	2/7/2023	12:39:57	5.54	0.47	1.56	0.05	0.50	1.65	0.05	191.6	1.003
T4_001299.LAB	2/7/2023	12:40:57	5.57	0.48	1.56	0.06	0.51	1.65	0.07	191.7	1.004
T4_001300.LAB	2/7/2023	12:41:56	5.64	0.44	1.59	-0.01	0.47	1.68	-0.01	234.1	1.085
T4_001301.LAB	2/7/2023	12:42:56	5.57	0.45	1.60	-0.04	0.48	1.69	-0.04	191.7	1.003
T4_001302.LAB	2/7/2023	12:43:56	5.61	0.48	1.65	0.08	0.51	1.75	0.09	193.1	0.999
T4_001303.LAB	2/7/2023	12:44:56	5.56	0.47	1.67	0.06	0.49	1.76	0.07	191.7	1.002
T4_001304.LAB	2/7/2023	12:45:56	5.58	0.50	1.66	0.06	0.53	1.76	0.07	191.6	1.003
T4_001305.LAB	2/7/2023	12:46:56	5.55	0.48	1.61	0.03	0.50	1.70	0.03	191.6	1.001
T4_001306.LAB	2/7/2023	12:47:56	5.59	0.47	1.58	0.04	0.50	1.68	0.05	191.7	1.002
T4_001307.LAB	2/7/2023	12:48:56	5.58	0.45	1.59	0.01	0.48	1.68	0.01	191.8	1.003
T4_001308.LAB	2/7/2023	12:49:56	5.63	0.47	1.61	0.03	0.50	1.70	0.03	232.5	1.082
T4_001309.LAB	2/7/2023	12:50:56	5.56	0.45	1.59	-0.02	0.48	1.68	-0.02	191.7	1.003
T4_001310.LAB	2/7/2023	12:51:56	5.53	0.44	1.57	0.02	0.47	1.66	0.02	191.6	1.004
T4_001311.LAB	2/7/2023	12:52:56	5.52	0.45	1.56	0.05	0.48	1.65	0.05	191.7	1.004
T4_001312.LAB	2/7/2023	12:53:56	5.52	0.46	1.59	0.03	0.49	1.68	0.03	191.7	1.003
T4_001313.LAB	2/7/2023	12:54:56	5.58	0.46	1.65	0.03	0.49	1.75	0.03	191.7	1.003
T4_001314.LAB	2/7/2023	12:55:56	5.54	0.50	1.62	0.06	0.53	1.71	0.07	191.7	1.002
T4_001315.LAB	2/7/2023	12:56:56	5.55	0.48	1.59	0.08	0.51	1.68	0.09	191.7	1.001
T4_001323.LAB	2/7/2023	13:04:55	5.51	0.45	1.58	0.01	0.48	1.67	0.02	191.7	1.002
T4_001324.LAB	2/7/2023	13:05:55	5.55	0.45	1.62	0.06	0.47	1.72	0.06	191.7	1.002
T4_001325.LAB	2/7/2023	13:06:55	5.53	0.44	1.61	-0.02	0.47	1.71	-0.02	191.6	1.001
T4_001326.LAB	2/7/2023	13:07:55	5.54	0.44	1.58	0.00	0.46	1.67	0.00	191.7	1.002
T4_001327.LAB	2/7/2023	13:08:55	5.55	0.43	1.58	-0.01	0.46	1.67	-0.01	191.7	1.001
02/07/2023			Minimum	5.51	0.41	1.49	-0.09	0.43	1.58	-0.10	
Turbine 4 - Run 2			Maximum	5.64	0.51	1.67	0.10	0.54	1.76	0.10	
12:00 - 12:56 ; 13:04 -			Average	5.57	0.46	1.58	0.02	0.49	1.67	0.02	

Turbine 4 - Run 3

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T4_001340.LAB	2/7/2023	13:15:47	5.54	0.40	1.60	-0.10	0.43	1.70	-0.11	191.7	1.002
T4_001341.LAB	2/7/2023	13:16:47	5.57	0.41	1.62	0.13	0.43	1.71	0.14	191.7	1.001
T4_001342.LAB	2/7/2023	13:17:47	5.55	0.41	1.60	0.05	0.43	1.70	0.05	191.7	1.001
T4_001343.LAB	2/7/2023	13:18:47	5.51	0.41	1.58	0.01	0.43	1.67	0.01	191.7	1.001
T4_001344.LAB	2/7/2023	13:19:47	5.55	0.42	1.59	-0.06	0.45	1.68	-0.07	191.7	1.003
T4_001345.LAB	2/7/2023	13:20:47	5.54	0.46	1.58	0.05	0.49	1.67	0.05	191.6	1.003
T4_001346.LAB	2/7/2023	13:21:47	5.57	0.39	1.61	0.06	0.41	1.70	0.06	191.7	1.002
T4_001347.LAB	2/7/2023	13:22:47	5.54	0.47	1.57	-0.07	0.50	1.67	-0.07	191.7	1.002
T4_001348.LAB	2/7/2023	13:23:46	5.56	0.42	1.59	0.03	0.45	1.68	0.04	191.6	1.003
T4_001349.LAB	2/7/2023	13:24:47	5.56	0.42	1.60	0.02	0.44	1.69	0.02	191.6	1.004
T4_001350.LAB	2/7/2023	13:25:46	5.56	0.45	1.67	0.07	0.47	1.77	0.07	191.6	1.003
T4_001351.LAB	2/7/2023	13:26:46	5.58	0.50	1.70	0.03	0.53	1.81	0.04	191.7	1.002
T4_001352.LAB	2/7/2023	13:27:46	5.53	0.49	1.68	0.03	0.52	1.78	0.03	191.6	1.001
T4_001353.LAB	2/7/2023	13:28:46	5.57	0.48	1.64	-0.02	0.51	1.74	-0.02	191.7	1.002
T4_001354.LAB	2/7/2023	13:29:46	5.56	0.48	1.66	0.03	0.51	1.76	0.03	191.6	1.002
T4_001355.LAB	2/7/2023	13:30:46	5.55	0.47	1.62	-0.01	0.49	1.71	-0.01	191.6	1.003
T4_001356.LAB	2/7/2023	13:31:46	5.56	0.41	1.65	-0.01	0.44	1.75	-0.02	191.7	1.004
T4_001357.LAB	2/7/2023	13:32:46	5.56	0.46	1.64	0.00	0.49	1.74	0.00	191.7	1.005
T4_001358.LAB	2/7/2023	13:33:46	5.58	0.46	1.65	0.01	0.49	1.75	0.02	191.7	1.003
T4_001359.LAB	2/7/2023	13:34:46	5.58	0.46	1.68	-0.04	0.49	1.78	-0.04	191.8	1.003
T4_001360.LAB	2/7/2023	13:35:46	5.60	0.50	1.74	-0.04	0.53	1.84	-0.04	191.7	1.003
T4_001361.LAB	2/7/2023	13:36:46	5.58	0.46	1.79	-0.04	0.48	1.90	-0.05	191.7	1.002
T4_001362.LAB	2/7/2023	13:37:46	5.56	0.49	1.77	0.10	0.52	1.87	0.11	191.7	1.002
T4_001363.LAB	2/7/2023	13:38:46	5.56	0.50	1.72	0.06	0.53	1.82	0.06	191.7	1.002
T4_001364.LAB	2/7/2023	13:39:46	5.60	0.54	1.73	0.04	0.57	1.83	0.04	191.7	1.001
T4_001365.LAB	2/7/2023	13:40:46	5.56	0.51	1.71	0.08	0.54	1.82	0.08	191.6	1.002
T4_001366.LAB	2/7/2023	13:41:46	5.58	0.53	1.72	0.03	0.56	1.82	0.03	191.7	1.002
T4_001367.LAB	2/7/2023	13:42:45	5.58	0.47	1.72	0.07	0.49	1.83	0.07	191.7	1.002
T4_001368.LAB	2/7/2023	13:43:45	5.58	0.49	1.71	0.05	0.52	1.81	0.05	191.7	1.004
T4_001369.LAB	2/7/2023	13:44:46	5.59	0.52	1.73	-0.01	0.55	1.83	-0.01	191.7	1.004
T4_001370.LAB	2/7/2023	13:45:45	5.54	0.48	1.76	0.07	0.51	1.86	0.08	191.7	1.002
T4_001371.LAB	2/7/2023	13:46:45	5.57	0.47	1.78	0.07	0.50	1.88	0.07	191.7	1.003
T4_001372.LAB	2/7/2023	13:47:45	5.51	0.52	1.76	0.04	0.55	1.86	0.04	191.7	1.001
T4_001373.LAB	2/7/2023	13:48:45	5.53	0.48	1.72	0.02	0.50	1.82	0.02	191.7	1.003
T4_001374.LAB	2/7/2023	13:49:45	5.59	0.50	1.72	0.09	0.53	1.82	0.09	191.7	1.001
T4_001375.LAB	2/7/2023	13:50:45	5.54	0.49	1.70	0.04	0.51	1.80	0.04	191.7	1.003
T4_001376.LAB	2/7/2023	13:51:45	5.55	0.50	1.67	0.04	0.53	1.77	0.05	191.7	1.003
T4_001377.LAB	2/7/2023	13:52:45	5.55	0.50	1.68	0.07	0.53	1.78	0.07	191.7	1.003
T4_001378.LAB	2/7/2023	13:53:45	5.56	0.50	1.69	0.07	0.52	1.79	0.08	191.7	1.002
T4_001379.LAB	2/7/2023	13:54:45	5.55	0.49	1.68	0.00	0.52	1.78	0.00	191.7	1.005
T4_001380.LAB	2/7/2023	13:55:45	5.55	0.45	1.70	0.02	0.47	1.80	0.02	191.7	1.003
T4_001381.LAB	2/7/2023	13:56:45	5.59	0.54	1.74	0.04	0.57	1.84	0.04	191.7	1.002
T4_001382.LAB	2/7/2023	13:57:45	5.59	0.50	1.76	0.05	0.53	1.86	0.05	191.7	1.002
T4_001383.LAB	2/7/2023	13:58:44	5.60	0.51	1.73	0.02	0.54	1.84	0.02	191.7	1.002
T4_001384.LAB	2/7/2023	13:59:44	5.56	0.44	1.71	0.06	0.47	1.81	0.06	191.7	1.002
T4_001385.LAB	2/7/2023	14:00:44	5.58	0.48	1.69	0.01	0.51	1.80	0.01	191.7	1.002
T4_001386.LAB	2/7/2023	14:01:45	5.55	0.48	1.67	0.05	0.50	1.77	0.05	191.7	1.003
T4_001387.LAB	2/7/2023	14:02:44	5.57	0.50	1.68	0.08	0.53	1.78	0.09	191.7	1.003
T4_001388.LAB	2/7/2023	14:03:44	5.59	0.50	1.67	0.00	0.53	1.77	0.00	191.7	1.002
T4_001389.LAB	2/7/2023	14:04:44	5.58	0.47	1.67	-0.01	0.50	1.77	-0.01	191.7	1.004
T4_001390.LAB	2/7/2023	14:05:44	5.57	0.49	1.72	0.07	0.52	1.82	0.08	191.7	1.002
T4_001391.LAB	2/7/2023	14:06:44	5.60	0.52	1.77	0.03	0.55	1.87	0.03	191.7	1.001
T4_001392.LAB	2/7/2023	14:07:44	5.59	0.54	1.77	0.05	0.58	1.87	0.05	191.7	1.002
T4_001393.LAB	2/7/2023	14:08:44	5.60	0.48	1.74	-0.03	0.51	1.84	-0.03	191.7	1.000
T4_001394.LAB	2/7/2023	14:09:44	5.56	0.46	1.71	0.07	0.48	1.81	0.07	191.7	1.001
T4_001395.LAB	2/7/2023	14:10:44	5.56	0.49	1.68	0.02	0.52	1.78	0.02	191.8	1.001
T4_001396.LAB	2/7/2023	14:11:44	5.58	0.45	1.68	-0.03	0.47	1.78	-0.03	191.8	1.002
T4_001397.LAB	2/7/2023	14:12:44	5.56	0.46	1.69	0.05	0.49	1.79	0.06	191.7	1.003
T4_001398.LAB	2/7/2023	14:13:44	5.56	0.50	1.69	0.00	0.52	1.79	0.00	191.7	1.003
T4_001399.LAB	2/7/2023	14:14:44	5.56	0.47	1.66	0.02	0.49	1.76	0.02	191.7	1.004
T4_001400.LAB	2/7/2023	14:15:44	5.59	0.50	1.70	0.01	0.52	1.80	0.01	191.7	1.002
02/07/2023		Minimum	5.51	0.39	1.57	-0.10	0.41	1.67	-0.11		
Turbine 4 - Run 3		Maximum	5.60	0.54	1.79	0.13	0.58	1.90	0.14		
13:15 - 14:15		Average	5.56	0.48	1.69	0.03	0.50	1.79	0.03		

Turbine 4 - Run 4

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T4_001761.LAB	2/8/2023	9:06:02	5.66	0.36	1.52	0.11	0.39	1.61	0.12	191.8	1.002
T4_001762.LAB	2/8/2023	9:07:02	5.66	0.38	1.52	-0.01	0.40	1.61	-0.01	191.8	1.003
T4_001763.LAB	2/8/2023	9:08:02	5.68	0.40	1.50	0.00	0.43	1.59	0.00	191.8	1.004
T4_001764.LAB	2/8/2023	9:09:02	5.67	0.37	1.48	-0.09	0.39	1.57	-0.10	191.8	1.005
T4_001765.LAB	2/8/2023	9:10:02	5.65	0.35	1.47	0.09	0.37	1.56	0.09	191.7	1.004
T4_001766.LAB	2/8/2023	9:11:02	5.67	0.38	1.46	0.04	0.40	1.55	0.04	191.7	1.005
T4_001767.LAB	2/8/2023	9:12:02	5.69	0.37	1.45	0.01	0.39	1.54	0.01	191.7	1.005
T4_001768.LAB	2/8/2023	9:13:02	5.67	0.37	1.50	0.12	0.40	1.59	0.13	191.8	1.005
T4_001769.LAB	2/8/2023	9:14:02	5.68	0.36	1.53	0.08	0.39	1.62	0.09	191.8	1.003
T4_001770.LAB	2/8/2023	9:15:02	5.68	0.41	1.52	0.01	0.43	1.61	0.01	191.9	1.003
T4_001771.LAB	2/8/2023	9:16:02	5.68	0.43	1.49	0.05	0.46	1.58	0.06	191.8	1.002
T4_001772.LAB	2/8/2023	9:17:02	5.68	0.34	1.46	-0.05	0.36	1.55	-0.05	191.8	1.003
T4_001773.LAB	2/8/2023	9:18:01	5.68	0.42	1.45	-0.05	0.44	1.54	-0.06	191.8	1.003
T4_001774.LAB	2/8/2023	9:19:02	5.69	0.39	1.46	-0.03	0.42	1.55	-0.03	191.7	1.003
T4_001775.LAB	2/8/2023	9:20:01	5.68	0.40	1.47	-0.01	0.42	1.56	-0.01	191.7	1.004
T4_001776.LAB	2/8/2023	9:21:01	5.66	0.37	1.47	0.03	0.39	1.55	0.03	191.8	1.006
T4_001777.LAB	2/8/2023	9:22:01	5.65	0.37	1.44	0.01	0.40	1.53	0.01	191.8	1.005
T4_001778.LAB	2/8/2023	9:23:02	5.66	0.41	1.44	0.05	0.43	1.53	0.05	191.8	1.006
T4_001779.LAB	2/8/2023	9:24:01	5.69	0.38	1.52	0.01	0.40	1.61	0.01	191.8	1.004
T4_001780.LAB	2/8/2023	9:25:01	5.69	0.42	1.55	-0.05	0.45	1.65	-0.05	191.8	1.003
T4_001781.LAB	2/8/2023	9:26:01	5.68	0.42	1.51	0.01	0.44	1.60	0.01	191.8	1.002
T4_001782.LAB	2/8/2023	9:27:01	5.69	0.41	1.50	0.03	0.43	1.59	0.04	191.7	1.003
T4_001783.LAB	2/8/2023	9:28:01	5.67	0.38	1.46	0.13	0.41	1.54	0.13	191.7	1.003
T4_001784.LAB	2/8/2023	9:29:01	5.68	0.42	1.47	0.08	0.45	1.56	0.08	191.7	1.003
T4_001785.LAB	2/8/2023	9:30:01	5.69	0.38	1.47	0.04	0.40	1.56	0.04	191.8	1.005
T4_001786.LAB	2/8/2023	9:31:01	5.70	0.41	1.46	0.00	0.44	1.55	0.00	191.8	1.004
T4_001787.LAB	2/8/2023	9:32:01	5.70	0.42	1.46	-0.01	0.45	1.55	-0.01	191.8	1.006
T4_001788.LAB	2/8/2023	9:33:01	5.72	0.42	1.49	0.01	0.44	1.58	0.02	191.8	1.005
T4_001789.LAB	2/8/2023	9:34:01	5.69	0.43	1.50	0.02	0.46	1.59	0.02	191.7	1.006
T4_001790.LAB	2/8/2023	9:35:01	5.71	0.39	1.56	0.01	0.41	1.65	0.01	191.7	1.004
T4_001791.LAB	2/8/2023	9:36:00	5.71	0.47	1.58	0.07	0.49	1.68	0.07	191.8	1.003
T4_001792.LAB	2/8/2023	9:37:00	5.69	0.46	1.57	0.08	0.48	1.66	0.08	191.8	1.003
T4_001793.LAB	2/8/2023	9:38:01	5.67	0.45	1.53	0.02	0.48	1.62	0.02	191.8	1.003
T4_001794.LAB	2/8/2023	9:39:01	5.68	0.41	1.54	0.02	0.44	1.64	0.02	191.9	1.004
T4_001795.LAB	2/8/2023	9:40:00	5.68	0.43	1.52	0.04	0.46	1.61	0.04	191.8	1.003
T4_001796.LAB	2/8/2023	9:41:00	5.68	0.38	1.50	0.05	0.41	1.59	0.06	191.7	1.004
T4_001797.LAB	2/8/2023	9:42:00	5.69	0.41	1.50	0.04	0.44	1.59	0.05	191.7	1.005
T4_001798.LAB	2/8/2023	9:43:00	5.65	0.41	1.52	0.03	0.44	1.61	0.03	191.6	1.004
T4_001799.LAB	2/8/2023	9:44:00	5.67	0.40	1.50	0.14	0.43	1.59	0.15	191.7	1.007
T4_001800.LAB	2/8/2023	9:45:00	5.69	0.48	1.53	0.04	0.51	1.62	0.05	191.8	1.007
T4_001801.LAB	2/8/2023	9:46:00	5.71	0.44	1.58	0.01	0.46	1.67	0.01	191.9	1.004
T4_001802.LAB	2/8/2023	9:47:00	5.70	0.44	1.60	0.01	0.47	1.70	0.02	191.8	1.004
T4_001803.LAB	2/8/2023	9:48:00	5.69	0.46	1.57	0.05	0.49	1.67	0.05	191.7	1.002
T4_001804.LAB	2/8/2023	9:49:00	5.68	0.44	1.55	0.03	0.47	1.65	0.03	191.7	1.003
T4_001805.LAB	2/8/2023	9:50:00	5.71	0.46	1.57	0.06	0.48	1.67	0.06	191.7	1.004
T4_001806.LAB	2/8/2023	9:51:00	5.70	0.48	1.54	0.07	0.51	1.63	0.07	191.8	1.004
T4_001807.LAB	2/8/2023	9:51:59	5.69	0.44	1.54	0.03	0.46	1.63	0.03	191.8	1.004
T4_001808.LAB	2/8/2023	9:52:59	5.70	0.47	1.57	-0.03	0.49	1.66	-0.03	191.8	1.005
T4_001809.LAB	2/8/2023	9:53:59	5.69	0.42	1.57	0.11	0.45	1.66	0.12	191.8	1.005
T4_001810.LAB	2/8/2023	9:54:59	5.68	0.44	1.56	0.03	0.46	1.65	0.03	191.7	1.006
T4_001811.LAB	2/8/2023	9:55:59	5.69	0.46	1.60	0.02	0.49	1.70	0.03	191.6	1.005
T4_001812.LAB	2/8/2023	9:56:59	5.71	0.44	1.63	0.11	0.46	1.73	0.11	191.7	1.003
T4_001813.LAB	2/8/2023	9:57:59	5.71	0.49	1.65	0.08	0.51	1.75	0.09	191.7	1.002
T4_001814.LAB	2/8/2023	9:58:59	5.72	0.45	1.62	0.03	0.48	1.71	0.03	191.8	1.003
T4_001815.LAB	2/8/2023	9:59:59	5.71	0.46	1.59	0.08	0.49	1.69	0.09	191.8	1.005
T4_001816.LAB	2/8/2023	10:00:59	5.73	0.50	1.60	0.03	0.53	1.70	0.03	191.7	1.004
T4_001817.LAB	2/8/2023	10:01:59	5.71	0.46	1.58	-0.01	0.49	1.68	-0.01	191.7	1.004
T4_001818.LAB	2/8/2023	10:02:59	5.70	0.48	1.58	0.02	0.51	1.67	0.02	191.6	1.004
T4_001819.LAB	2/8/2023	10:03:59	5.70	0.44	1.58	0.11	0.46	1.67	0.12	191.8	1.005
T4_001820.LAB	2/8/2023	10:04:59	5.69	0.45	1.56	-0.05	0.47	1.66	-0.05	191.8	1.005
T4_001821.LAB	2/8/2023	10:05:59	5.69	0.44	1.58	0.00	0.47	1.67	0.00	191.9	1.005
T4_001822.LAB	2/8/2023	10:06:59	5.70	0.49	1.60	0.03	0.52	1.70	0.03	191.9	1.007
02/08/2023			Minimum	5.65	0.34	1.44	-0.09	0.36	1.53	-0.10	
Turbine 4 - Run 4			Maximum	5.73	0.50	1.65	0.14	0.53	1.75	0.15	
09:06 - 10:06			Average	5.69	0.42	1.53	0.03	0.45	1.62	0.03	

Turbine 4 - Run 5

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T4_001840.LAB	2/8/2023	10:19:05	5.68	0.42	1.62	-0.01	0.44	1.71	-0.01	191.9	1.003
T4_001841.LAB	2/8/2023	10:20:05	5.68	0.38	1.60	0.04	0.40	1.69	0.04	191.9	1.004
T4_001842.LAB	2/8/2023	10:21:05	5.69	0.40	1.54	0.08	0.43	1.63	0.08	191.8	1.003
T4_001843.LAB	2/8/2023	10:22:05	5.68	0.43	1.58	-0.05	0.45	1.67	-0.05	191.7	1.005
T4_001844.LAB	2/8/2023	10:23:05	5.66	0.41	1.56	0.03	0.43	1.66	0.03	191.7	1.004
T4_001845.LAB	2/8/2023	10:24:04	5.66	0.41	1.60	-0.01	0.43	1.69	-0.01	191.7	1.005
T4_001846.LAB	2/8/2023	10:25:04	5.70	0.39	1.59	0.07	0.41	1.69	0.07	191.8	1.005
T4_001847.LAB	2/8/2023	10:26:05	5.69	0.42	1.60	0.05	0.45	1.70	0.05	191.9	1.004
T4_001848.LAB	2/8/2023	10:27:04	5.70	0.43	1.63	0.04	0.46	1.73	0.05	191.8	1.005
T4_001849.LAB	2/8/2023	10:28:04	5.68	0.47	1.66	0.03	0.50	1.76	0.03	191.7	1.005
T4_001850.LAB	2/8/2023	10:29:04	5.68	0.46	1.71	0.08	0.49	1.81	0.08	191.7	1.003
T4_001851.LAB	2/8/2023	10:30:04	5.69	0.47	1.72	-0.02	0.50	1.82	-0.02	191.7	1.003
T4_001852.LAB	2/8/2023	10:31:04	5.69	0.50	1.68	0.03	0.54	1.78	0.03	191.7	1.003
T4_001853.LAB	2/8/2023	10:32:04	5.69	0.49	1.67	0.00	0.52	1.77	0.00	191.8	1.003
T4_001854.LAB	2/8/2023	10:33:04	5.68	0.41	1.66	0.01	0.44	1.76	0.01	191.8	1.005
T4_001855.LAB	2/8/2023	10:34:04	5.70	0.46	1.66	0.07	0.49	1.76	0.07	191.8	1.003
T4_001856.LAB	2/8/2023	10:35:04	5.68	0.46	1.68	-0.01	0.49	1.78	-0.01	191.7	1.005
T4_001857.LAB	2/8/2023	10:36:04	5.71	0.46	1.67	0.00	0.49	1.77	0.00	191.6	1.005
T4_001858.LAB	2/8/2023	10:37:04	5.70	0.47	1.69	0.05	0.49	1.80	0.05	191.6	1.006
T4_001859.LAB	2/8/2023	10:38:04	5.70	0.50	1.71	0.01	0.53	1.81	0.01	191.7	1.006
T4_001860.LAB	2/8/2023	10:39:04	5.69	0.48	1.75	0.08	0.51	1.86	0.09	191.8	1.005
T4_001861.LAB	2/8/2023	10:40:04	5.70	0.49	1.79	0.10	0.52	1.90	0.10	191.8	1.003
T4_001862.LAB	2/8/2023	10:41:03	5.71	0.53	1.74	0.03	0.56	1.84	0.03	191.8	1.001
T4_001863.LAB	2/8/2023	10:42:03	5.71	0.50	1.71	0.03	0.53	1.82	0.03	191.7	1.002
T4_001864.LAB	2/8/2023	10:43:03	5.69	0.51	1.72	0.01	0.54	1.82	0.01	191.7	1.005
T4_001865.LAB	2/8/2023	10:44:03	5.71	0.49	1.71	-0.07	0.52	1.82	-0.07	191.7	1.005
T4_001866.LAB	2/8/2023	10:45:03	5.70	0.46	1.72	-0.06	0.49	1.83	-0.06	191.7	1.006
T4_001867.LAB	2/8/2023	10:46:03	5.72	0.49	1.74	0.07	0.51	1.84	0.07	191.7	1.005
T4_001868.LAB	2/8/2023	10:47:03	5.70	0.48	1.73	0.04	0.51	1.83	0.04	191.8	1.005
T4_001869.LAB	2/8/2023	10:48:03	5.71	0.50	1.75	0.03	0.53	1.85	0.03	191.7	1.005
T4_001870.LAB	2/8/2023	10:49:03	5.69	0.51	1.78	-0.03	0.54	1.89	-0.03	191.6	1.005
T4_001871.LAB	2/8/2023	10:50:03	5.71	0.54	1.83	0.05	0.57	1.94	0.05	191.6	1.004
T4_001872.LAB	2/8/2023	10:51:03	5.68	0.51	1.82	0.00	0.54	1.93	0.00	191.6	1.005
T4_001873.LAB	2/8/2023	10:52:03	5.68	0.53	1.78	0.04	0.56	1.88	0.04	191.7	1.003
T4_001874.LAB	2/8/2023	10:53:03	5.69	0.52	1.76	0.04	0.55	1.86	0.04	191.7	1.002
T4_001875.LAB	2/8/2023	10:54:03	5.69	0.51	1.75	0.03	0.54	1.86	0.03	191.7	1.004
T4_001876.LAB	2/8/2023	10:55:02	5.68	0.50	1.73	0.03	0.53	1.83	0.03	191.7	1.004
T4_001877.LAB	2/8/2023	10:56:02	5.65	0.45	1.69	0.02	0.47	1.79	0.03	191.8	1.005
T4_001878.LAB	2/8/2023	10:57:02	5.66	0.45	1.70	0.03	0.47	1.80	0.03	191.7	1.005
T4_001879.LAB	2/8/2023	10:58:02	5.66	0.50	1.72	0.05	0.53	1.82	0.05	191.6	1.005
T4_001880.LAB	2/8/2023	10:59:02	5.65	0.45	1.72	0.04	0.48	1.83	0.04	191.6	1.005
T4_001881.LAB	2/8/2023	11:00:02	5.69	0.52	1.75	-0.04	0.55	1.85	-0.05	191.6	1.003
T4_001882.LAB	2/8/2023	11:01:02	5.71	0.51	1.79	0.01	0.54	1.90	0.01	191.6	1.004
T4_001883.LAB	2/8/2023	11:02:02	5.71	0.51	1.77	0.02	0.54	1.87	0.02	191.7	1.003
T4_001884.LAB	2/8/2023	11:03:02	5.70	0.52	1.76	0.02	0.55	1.87	0.02	191.7	1.001
T4_001885.LAB	2/8/2023	11:04:02	5.69	0.50	1.75	0.06	0.53	1.85	0.07	191.6	1.003
T4_001886.LAB	2/8/2023	11:05:02	5.68	0.50	1.74	0.02	0.53	1.85	0.02	191.6	1.005
T4_001887.LAB	2/8/2023	11:06:02	5.68	0.49	1.71	0.04	0.52	1.82	0.05	191.7	1.006
T4_001888.LAB	2/8/2023	11:07:02	5.69	0.46	1.73	-0.01	0.49	1.83	-0.01	191.7	1.005
T4_001889.LAB	2/8/2023	11:08:02	5.68	0.49	1.72	0.05	0.52	1.83	0.05	191.7	1.006
T4_001890.LAB	2/8/2023	11:09:02	5.67	0.50	1.73	0.03	0.53	1.83	0.03	191.7	1.006
T4_001891.LAB	2/8/2023	11:10:02	5.62	0.53	1.76	0.09	0.56	1.86	0.10	191.6	1.004
T4_001892.LAB	2/8/2023	11:11:02	5.64	0.50	1.78	-0.09	0.53	1.89	-0.09	191.6	1.003
T4_001893.LAB	2/8/2023	11:12:01	5.66	0.47	1.78	-0.01	0.49	1.89	-0.01	191.6	1.001
T4_001894.LAB	2/8/2023	11:13:02	5.66	0.46	1.75	0.12	0.49	1.86	0.13	191.7	1.003
T4_001895.LAB	2/8/2023	11:14:01	5.68	0.44	1.73	0.03	0.47	1.84	0.03	191.7	1.004
T4_001896.LAB	2/8/2023	11:15:01	5.67	0.50	1.69	0.06	0.53	1.79	0.06	191.7	1.005
T4_001897.LAB	2/8/2023	11:16:01	5.69	0.48	1.70	0.08	0.51	1.80	0.08	191.7	1.003
T4_001898.LAB	2/8/2023	11:17:01	5.67	0.47	1.70	0.03	0.50	1.80	0.03	191.6	1.005
T4_001899.LAB	2/8/2023	11:18:01	5.69	0.55	1.72	-0.05	0.59	1.82	-0.05	191.6	1.006
T4_001900.LAB	2/8/2023	11:19:01	5.69	0.50	1.72	0.02	0.53	1.82	0.02	191.6	1.006
02/08/2023		Minimum	5.62	0.38	1.54	-0.09	0.40	1.63	-0.09		
Turbine 4 - Run 5		Maximum	5.72	0.55	1.83	0.12	0.59	1.94	0.13		
10:19 - 11:19		Average	5.69	0.48	1.71	0.02	0.51	1.81	0.03		

Turbine 4 - Run 6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T4_001910.LAB	2/8/2023	11:23:04	5.69	0.46	1.73	0.07	0.49	1.84	0.08	191.6	1.002
T4_001911.LAB	2/8/2023	11:24:04	5.71	0.52	1.71	0.11	0.55	1.81	0.12	191.6	1.003
T4_001912.LAB	2/8/2023	11:25:04	5.69	0.50	1.69	-0.02	0.53	1.79	-0.02	191.6	1.002
T4_001913.LAB	2/8/2023	11:26:04	5.69	0.48	1.70	0.04	0.50	1.80	0.04	191.6	1.005
T4_001914.LAB	2/8/2023	11:27:04	5.68	0.49	1.70	0.04	0.52	1.81	0.04	191.6	1.005
T4_001915.LAB	2/8/2023	11:28:04	5.70	0.44	1.67	0.05	0.47	1.78	0.05	191.6	1.004
T4_001916.LAB	2/8/2023	11:29:04	5.68	0.47	1.72	0.00	0.50	1.82	0.00	191.6	1.006
T4_001917.LAB	2/8/2023	11:30:03	5.69	0.48	1.72	-0.01	0.51	1.83	-0.01	191.6	1.006
T4_001918.LAB	2/8/2023	11:31:04	5.68	0.53	1.76	-0.02	0.56	1.87	-0.02	191.6	1.006
T4_001919.LAB	2/8/2023	11:32:03	5.70	0.48	1.79	0.09	0.51	1.90	0.10	191.6	1.004
T4_001920.LAB	2/8/2023	11:33:03	5.70	0.49	1.80	0.02	0.52	1.91	0.02	191.7	1.002
T4_001921.LAB	2/8/2023	11:34:03	5.71	0.47	1.79	0.01	0.50	1.90	0.01	191.7	1.002
T4_001922.LAB	2/8/2023	11:35:03	5.71	0.50	1.74	-0.01	0.53	1.84	-0.01	191.7	1.004
T4_001923.LAB	2/8/2023	11:36:03	5.72	0.52	1.77	-0.01	0.55	1.88	-0.01	191.6	1.003
T4_001924.LAB	2/8/2023	11:37:03	5.72	0.53	1.74	0.02	0.57	1.85	0.02	191.6	1.004
T4_001925.LAB	2/8/2023	11:38:03	5.73	0.55	1.76	0.05	0.58	1.87	0.05	191.6	1.004
T4_001926.LAB	2/8/2023	11:39:03	5.73	0.52	1.74	-0.01	0.55	1.84	-0.01	191.6	1.005
T4_001927.LAB	2/8/2023	11:40:03	5.72	0.50	1.78	0.01	0.53	1.88	0.01	191.6	1.006
T4_001928.LAB	2/8/2023	11:41:03	5.73	0.56	1.83	0.04	0.59	1.94	0.04	191.6	1.005
T4_001929.LAB	2/8/2023	11:42:03	5.71	0.57	1.87	0.06	0.60	1.99	0.06	191.6	1.005
T4_001930.LAB	2/8/2023	11:43:03	5.73	0.55	1.89	0.03	0.59	2.00	0.03	191.6	1.002
T4_001931.LAB	2/8/2023	11:44:03	5.71	0.53	1.83	0.04	0.56	1.94	0.04	191.6	1.004
T4_001932.LAB	2/8/2023	11:45:03	5.74	0.56	1.85	0.00	0.60	1.96	0.00	191.6	1.003
T4_001933.LAB	2/8/2023	11:46:02	5.74	0.53	1.84	0.02	0.57	1.95	0.02	191.6	1.003
T4_001934.LAB	2/8/2023	11:47:02	5.74	0.55	1.83	0.09	0.58	1.95	0.09	191.6	1.003
T4_001935.LAB	2/8/2023	11:48:02	5.71	0.54	1.80	-0.01	0.57	1.91	-0.01	191.6	1.004
T4_001936.LAB	2/8/2023	11:49:02	5.70	0.55	1.81	-0.03	0.58	1.92	-0.03	191.6	1.004
T4_001937.LAB	2/8/2023	11:50:02	5.68	0.52	1.81	0.08	0.55	1.92	0.08	191.6	1.005
T4_001938.LAB	2/8/2023	11:51:02	5.70	0.57	1.84	-0.01	0.60	1.95	-0.01	191.6	1.005
T4_001939.LAB	2/8/2023	11:52:02	5.73	0.56	1.89	0.05	0.59	2.01	0.05	191.6	1.004
T4_001940.LAB	2/8/2023	11:53:02	5.72	0.55	1.89	-0.02	0.58	2.00	-0.02	191.6	1.003
T4_001941.LAB	2/8/2023	11:54:02	5.73	0.51	1.85	0.12	0.54	1.97	0.13	191.6	1.002
T4_001942.LAB	2/8/2023	11:55:02	5.69	0.53	1.82	0.05	0.57	1.93	0.06	191.5	1.004
T4_001943.LAB	2/8/2023	11:56:02	5.70	0.55	1.83	-0.01	0.58	1.94	-0.01	191.6	1.002
T4_001944.LAB	2/8/2023	11:57:02	5.73	0.53	1.80	0.05	0.56	1.91	0.05	191.6	1.003
T4_001945.LAB	2/8/2023	11:58:02	5.72	0.47	1.81	0.10	0.50	1.92	0.11	191.5	1.003
T4_001946.LAB	2/8/2023	11:59:02	5.70	0.57	1.79	0.07	0.60	1.90	0.07	191.5	1.004
T4_001947.LAB	2/8/2023	12:00:02	5.69	0.56	1.78	-0.05	0.60	1.89	-0.06	191.6	1.005
T4_001948.LAB	2/8/2023	12:01:02	5.71	0.54	1.82	0.04	0.58	1.93	0.05	191.6	1.005
T4_001949.LAB	2/8/2023	12:02:01	5.72	0.57	1.85	-0.08	0.61	1.96	-0.08	191.5	1.003
T4_001950.LAB	2/8/2023	12:03:01	5.71	0.57	1.89	0.03	0.61	2.00	0.03	191.6	1.002
T4_001951.LAB	2/8/2023	12:04:01	5.70	0.53	1.83	0.01	0.56	1.94	0.01	191.6	1.003
T4_001952.LAB	2/8/2023	12:05:01	5.71	0.57	1.83	0.11	0.60	1.94	0.12	191.6	1.002
T4_001953.LAB	2/8/2023	12:06:01	5.72	0.60	1.79	-0.01	0.64	1.90	-0.01	191.6	1.001
T4_001954.LAB	2/8/2023	12:07:01	5.71	0.56	1.80	0.02	0.59	1.91	0.03	191.6	1.003
T4_001955.LAB	2/8/2023	12:08:01	5.69	0.54	1.80	-0.01	0.57	1.90	-0.01	191.6	1.004
T4_001956.LAB	2/8/2023	12:09:01	5.68	0.58	1.80	0.00	0.62	1.90	0.00	191.6	1.005
T4_001957.LAB	2/8/2023	12:10:01	5.67	0.52	1.80	0.01	0.55	1.91	0.01	191.6	1.003
T4_001958.LAB	2/8/2023	12:11:01	5.67	0.57	1.79	0.01	0.61	1.90	0.01	191.6	1.005
T4_001959.LAB	2/8/2023	12:12:01	5.70	0.52	1.84	-0.07	0.55	1.96	-0.08	191.6	1.003
T4_001960.LAB	2/8/2023	12:13:01	5.70	0.56	1.88	0.01	0.59	1.99	0.02	191.6	1.001
T4_001961.LAB	2/8/2023	12:14:01	5.68	0.54	1.84	0.02	0.58	1.95	0.03	191.6	1.002
T4_001962.LAB	2/8/2023	12:15:01	5.68	0.55	1.81	-0.04	0.58	1.92	-0.05	191.6	1.002
T4_001963.LAB	2/8/2023	12:16:01	5.68	0.54	1.79	-0.01	0.57	1.90	-0.01	191.6	1.002
T4_001964.LAB	2/8/2023	12:17:00	5.68	0.56	1.78	0.10	0.60	1.89	0.11	191.6	1.004
T4_001965.LAB	2/8/2023	12:18:01	5.66	0.58	1.80	0.06	0.62	1.91	0.07	191.6	1.003
T4_001967.LAB	2/8/2023	12:27:00	5.65	0.53	1.76	0.08	0.56	1.87	0.09	191.6	1.003
T4_001975.LAB	2/8/2023	12:28:00	5.67	0.53	1.76	0.04	0.56	1.86	0.04	191.6	1.003
T4_001976.LAB	2/8/2023	12:29:00	5.67	0.55	1.78	0.02	0.58	1.88	0.02	191.6	1.004
T4_001977.LAB	2/8/2023	12:30:00	5.65	0.49	1.75	0.02	0.52	1.85	0.02	191.6	1.004
T4_001978.LAB	2/8/2023	12:31:00	5.65	0.53	1.77	0.13	0.56	1.88	0.14	191.6	1.005
T4_001979.LAB	2/8/2023	12:32:00	5.66	0.53	1.84	0.04	0.56	1.95	0.05	191.6	1.003
02/08/2023			Minimum	5.65	0.44	1.67	-0.08	0.47	1.78	-0.08	
Turbine 4 - Run 6			Maximum	5.74	0.60	1.89	0.13	0.64	2.01	0.14	
11:23 - 12:18 , 12:27 -			Average	5.70	0.53	1.80	0.03	0.56	1.90	0.03	

Turbine 4 - Run 7

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T4_002018.LAB	2/8/2023	13:05:20	5.66	0.56	1.85	0.00	0.60	1.96	0.00	191.6	1.000
T4_002019.LAB	2/8/2023	13:06:20	5.65	0.53	1.84	0.01	0.56	1.95	0.01	191.6	1.001
T4_002020.LAB	2/8/2023	13:07:20	5.65	0.58	1.84	0.03	0.61	1.95	0.03	191.5	1.002
T4_002021.LAB	2/8/2023	13:08:20	5.65	0.54	1.83	-0.01	0.57	1.94	-0.01	191.6	1.002
T4_002022.LAB	2/8/2023	13:09:20	5.64	0.52	1.83	0.11	0.56	1.94	0.12	191.5	1.002
T4_002023.LAB	2/8/2023	13:10:20	5.64	0.57	1.82	0.02	0.61	1.93	0.02	191.6	1.002
T4_002024.LAB	2/8/2023	13:11:20	5.62	0.50	1.85	0.06	0.53	1.96	0.06	191.6	1.004
T4_002025.LAB	2/8/2023	13:12:20	5.65	0.56	1.88	0.09	0.60	2.00	0.10	191.6	1.002
T4_002026.LAB	2/8/2023	13:13:19	5.63	0.56	1.92	0.03	0.59	2.03	0.04	191.6	1.001
T4_002027.LAB	2/8/2023	13:14:20	5.63	0.57	1.92	0.08	0.61	2.04	0.09	191.6	1.002
T4_002028.LAB	2/8/2023	13:15:19	5.60	0.50	1.87	0.04	0.53	1.98	0.05	191.6	1.001
T4_002029.LAB	2/8/2023	13:16:19	5.69	0.58	1.88	0.03	0.62	2.00	0.03	191.5	1.002
T4_002030.LAB	2/8/2023	13:17:19	5.60	0.52	1.85	0.04	0.55	1.95	0.05	191.5	1.003
T4_002031.LAB	2/8/2023	13:18:19	5.67	0.58	1.88	0.08	0.62	1.99	0.08	191.5	1.001
T4_002032.LAB	2/8/2023	13:19:19	5.66	0.56	1.87	0.03	0.59	1.98	0.03	191.6	1.001
T4_002033.LAB	2/8/2023	13:20:19	5.66	0.53	1.84	0.04	0.57	1.95	0.04	191.6	1.002
T4_002034.LAB	2/8/2023	13:21:19	5.66	0.55	1.85	0.13	0.58	1.96	0.13	191.6	1.003
T4_002035.LAB	2/8/2023	13:22:19	5.68	0.59	1.91	0.02	0.62	2.02	0.03	191.6	1.002
T4_002036.LAB	2/8/2023	13:23:19	5.65	0.56	1.96	0.11	0.59	2.07	0.12	191.6	1.002
T4_002037.LAB	2/8/2023	13:24:19	5.66	0.60	1.96	-0.07	0.64	2.08	-0.08	191.6	1.000
T4_002038.LAB	2/8/2023	13:25:19	5.67	0.54	1.90	0.07	0.57	2.02	0.07	191.6	0.999
T4_002039.LAB	2/8/2023	13:26:19	5.67	0.57	1.89	-0.02	0.61	2.00	-0.02	191.6	0.999
T4_002040.LAB	2/8/2023	13:27:19	5.67	0.58	1.86	-0.02	0.62	1.97	-0.02	191.6	1.001
T4_002041.LAB	2/8/2023	13:28:19	5.68	0.61	1.87	0.08	0.64	1.98	0.08	191.6	1.002
T4_002042.LAB	2/8/2023	13:29:18	5.65	0.56	1.86	0.06	0.59	1.97	0.06	191.6	1.002
T4_002043.LAB	2/8/2023	13:30:19	5.63	0.56	1.84	-0.04	0.59	1.95	-0.05	191.6	1.002
T4_002044.LAB	2/8/2023	13:31:18	5.63	0.56	1.83	-0.02	0.59	1.94	-0.03	191.6	1.003
T4_002045.LAB	2/8/2023	13:32:19	5.63	0.58	1.86	0.08	0.62	1.97	0.08	191.6	1.003
T4_002046.LAB	2/8/2023	13:33:18	5.64	0.54	1.92	0.05	0.57	2.04	0.05	191.6	1.001
T4_002047.LAB	2/8/2023	13:34:18	5.64	0.57	1.96	0.06	0.61	2.08	0.06	191.6	1.001
T4_002048.LAB	2/8/2023	13:35:18	5.63	0.58	1.92	0.03	0.61	2.04	0.03	191.6	1.000
T4_002049.LAB	2/8/2023	13:36:18	5.63	0.59	1.87	0.06	0.62	1.99	0.07	191.6	1.000
T4_002050.LAB	2/8/2023	13:37:18	5.64	0.58	1.89	-0.01	0.61	2.01	-0.01	191.6	1.000
T4_002051.LAB	2/8/2023	13:38:18	5.66	0.55	1.89	-0.03	0.59	2.01	-0.03	191.6	1.000
T4_002052.LAB	2/8/2023	13:39:18	5.63	0.57	1.84	0.02	0.60	1.95	0.02	191.6	1.002
T4_002053.LAB	2/8/2023	13:40:18	5.64	0.61	1.88	0.05	0.64	1.99	0.05	191.6	1.002
T4_002054.LAB	2/8/2023	13:41:18	5.64	0.58	1.85	0.02	0.61	1.96	0.02	191.6	1.001
T4_002055.LAB	2/8/2023	13:42:18	5.64	0.57	1.89	0.09	0.61	2.00	0.10	191.6	1.003
T4_002056.LAB	2/8/2023	13:43:18	5.63	0.55	1.92	0.03	0.58	2.03	0.03	191.6	1.001
T4_002057.LAB	2/8/2023	13:44:18	5.63	0.58	1.97	0.03	0.62	2.08	0.03	191.6	1.001
T4_002058.LAB	2/8/2023	13:45:17	5.65	0.61	1.98	0.02	0.65	2.10	0.02	191.6	0.998
T4_002059.LAB	2/8/2023	13:46:17	5.64	0.56	1.92	0.06	0.60	2.03	0.06	191.6	1.001
T4_002060.LAB	2/8/2023	13:47:17	5.66	0.56	1.90	0.01	0.59	2.02	0.01	191.6	1.001
T4_002061.LAB	2/8/2023	13:48:17	5.64	0.54	1.86	-0.01	0.57	1.97	-0.02	191.6	1.001
T4_002062.LAB	2/8/2023	13:49:17	5.65	0.57	1.86	-0.10	0.60	1.97	-0.10	191.5	1.001
T4_002063.LAB	2/8/2023	13:50:17	5.66	0.56	1.90	0.01	0.59	2.01	0.01	191.6	1.002
T4_002064.LAB	2/8/2023	13:51:17	5.67	0.56	1.89	0.09	0.60	2.00	0.09	191.6	1.002
T4_002065.LAB	2/8/2023	13:52:17	5.64	0.56	1.88	0.05	0.59	1.99	0.06	191.6	1.003
T4_002066.LAB	2/8/2023	13:53:17	5.64	0.57	1.88	0.03	0.60	1.99	0.03	191.6	1.002
T4_002067.LAB	2/8/2023	13:54:17	5.63	0.59	1.92	0.01	0.63	2.03	0.01	191.6	1.002
T4_002068.LAB	2/8/2023	13:55:17	5.65	0.61	1.96	0.02	0.65	2.08	0.03	191.6	1.000
T4_002069.LAB	2/8/2023	13:56:17	5.66	0.59	1.93	0.02	0.62	2.04	0.02	191.6	1.000
T4_002070.LAB	2/8/2023	13:57:17	5.65	0.53	1.89	0.03	0.56	2.00	0.03	191.5	1.000
T4_002071.LAB	2/8/2023	13:58:17	5.65	0.57	1.89	-0.02	0.61	2.00	-0.02	191.5	1.000
T4_002072.LAB	2/8/2023	13:59:17	5.64	0.56	1.87	0.10	0.59	1.98	0.11	191.5	1.000
T4_002073.LAB	2/8/2023	14:00:17	5.65	0.55	1.87	-0.08	0.59	1.98	-0.09	191.5	1.001
T4_002074.LAB	2/8/2023	14:01:17	5.66	0.55	1.89	0.01	0.58	2.01	0.01	191.5	1.000
T4_002075.LAB	2/8/2023	14:02:16	5.65	0.56	1.87	0.05	0.59	1.98	0.05	191.5	1.002
T4_002076.LAB	2/8/2023	14:03:16	5.66	0.56	1.88	0.05	0.60	1.99	0.06	191.6	1.002
T4_002077.LAB	2/8/2023	14:04:16	5.65	0.54	1.92	-0.05	0.57	2.03	-0.05	191.5	1.002
T4_002078.LAB	2/8/2023	14:05:16	5.64	0.57	1.94	0.00	0.61	2.05	0.00	191.5	1.001
02/08/2023		Minimum	5.60	0.50	1.82	-0.10	0.53	1.93	-0.10		
Turbine 4 - Run 7		Maximum	5.69	0.61	1.98	0.13	0.65	2.10	0.13		
13:05 - 14:05		Average	5.65	0.56	1.89	0.03	0.60	2.00	0.03		

Turbine 5 - Run 1

Spectrum	Date	Time	H ₂ O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T5_003226.LAB	2/14/2023	9:15:11	6.03	0.26	1.29	0.14	0.28	1.37	0.15	191.9	1.004
T5_003227.LAB	2/14/2023	9:16:11	6.02	0.28	1.24	0.09	0.29	1.32	0.09	191.9	1.004
T5_003228.LAB	2/14/2023	9:17:11	6.03	0.26	1.23	0.18	0.28	1.31	0.19	191.8	1.004
T5_003229.LAB	2/14/2023	9:18:11	6.04	0.25	1.24	0.05	0.27	1.32	0.05	191.8	1.005
T5_003230.LAB	2/14/2023	9:19:11	6.04	0.26	1.23	0.12	0.27	1.30	0.13	191.8	1.007
T5_003231.LAB	2/14/2023	9:20:11	6.03	0.28	1.23	0.06	0.30	1.30	0.07	191.8	1.007
T5_003232.LAB	2/14/2023	9:21:11	6.03	0.27	1.21	0.13	0.28	1.29	0.14	191.8	1.007
T5_003233.LAB	2/14/2023	9:22:11	6.02	0.29	1.25	0.04	0.31	1.33	0.04	191.8	1.005
T5_003234.LAB	2/14/2023	9:23:11	5.99	0.27	1.25	0.15	0.29	1.33	0.16	191.8	1.006
T5_003235.LAB	2/14/2023	9:24:10	6.02	0.27	1.26	0.04	0.29	1.34	0.04	191.8	1.003
T5_003236.LAB	2/14/2023	9:25:11	5.99	0.31	1.23	0.14	0.33	1.30	0.15	191.8	1.003
T5_003237.LAB	2/14/2023	9:26:10	5.97	0.27	1.19	0.07	0.29	1.27	0.08	191.8	1.006
T5_003238.LAB	2/14/2023	9:27:10	5.99	0.28	1.15	0.15	0.30	1.23	0.16	191.9	1.005
T5_003239.LAB	2/14/2023	9:28:10	5.97	0.26	1.17	0.11	0.28	1.25	0.12	191.9	1.006
T5_003240.LAB	2/14/2023	9:29:10	5.97	0.24	1.16	0.15	0.26	1.24	0.16	191.9	1.006
T5_003241.LAB	2/14/2023	9:30:10	5.97	0.25	1.16	0.12	0.26	1.23	0.12	191.9	1.007
T5_003242.LAB	2/14/2023	9:31:10	5.97	0.27	1.15	0.08	0.28	1.22	0.09	191.9	1.007
T5_003243.LAB	2/14/2023	9:32:10	5.97	0.26	1.20	0.15	0.28	1.28	0.16	191.8	1.005
T5_003244.LAB	2/14/2023	9:33:10	5.96	0.30	1.23	0.19	0.32	1.31	0.20	191.7	1.005
T5_003245.LAB	2/14/2023	9:34:10	5.94	0.27	1.22	0.12	0.29	1.30	0.12	191.7	1.005
T5_003246.LAB	2/14/2023	9:35:10	5.93	0.27	1.17	0.19	0.29	1.24	0.20	191.7	1.005
T5_003247.LAB	2/14/2023	9:36:10	5.95	0.25	1.18	0.12	0.26	1.25	0.12	191.8	1.005
T5_003248.LAB	2/14/2023	9:37:10	5.94	0.23	1.13	0.10	0.25	1.21	0.10	191.9	1.004
T5_003249.LAB	2/14/2023	9:38:10	5.93	0.22	1.12	0.11	0.24	1.19	0.11	191.9	1.006
T5_003250.LAB	2/14/2023	9:39:10	5.90	0.25	1.14	0.07	0.26	1.21	0.07	191.8	1.006
T5_003251.LAB	2/14/2023	9:40:09	5.90	0.25	1.13	0.06	0.26	1.20	0.06	191.8	1.007
T5_003252.LAB	2/14/2023	9:41:09	5.86	0.27	1.10	0.06	0.29	1.17	0.06	191.8	1.007
T5_003253.LAB	2/14/2023	9:42:09	5.88	0.23	1.14	0.04	0.25	1.21	0.04	191.7	1.006
T5_003254.LAB	2/14/2023	9:43:09	5.86	0.23	1.18	0.09	0.24	1.26	0.09	191.7	1.005
T5_003255.LAB	2/14/2023	9:44:09	5.85	0.31	1.22	0.06	0.33	1.30	0.06	191.7	1.003
T5_003256.LAB	2/14/2023	9:45:09	5.83	0.26	1.18	0.04	0.28	1.25	0.04	191.8	1.002
T5_003257.LAB	2/14/2023	9:46:09	5.83	0.29	1.15	0.14	0.31	1.23	0.15	191.8	1.005
T5_003258.LAB	2/14/2023	9:47:09	5.85	0.23	1.15	0.14	0.25	1.23	0.15	191.8	1.003
T5_003259.LAB	2/14/2023	9:48:09	5.82	0.24	1.14	0.05	0.25	1.21	0.05	191.8	1.007
T5_003260.LAB	2/14/2023	9:49:09	5.81	0.27	1.11	0.10	0.29	1.18	0.11	191.8	1.005
T5_003261.LAB	2/14/2023	9:50:09	5.79	0.26	1.14	0.05	0.27	1.21	0.05	191.8	1.006
T5_003262.LAB	2/14/2023	9:51:09	5.76	0.28	1.11	0.09	0.30	1.18	0.10	191.8	1.008
T5_003263.LAB	2/14/2023	9:52:09	5.76	0.26	1.15	0.07	0.28	1.22	0.08	191.8	1.007
T5_003264.LAB	2/14/2023	9:53:09	5.77	0.31	1.20	0.11	0.33	1.28	0.12	191.8	1.007
T5_003265.LAB	2/14/2023	9:54:09	5.76	0.25	1.19	0.09	0.26	1.27	0.10	191.7	1.004
T5_003266.LAB	2/14/2023	9:55:08	5.76	0.30	1.20	0.03	0.31	1.27	0.03	191.7	1.003
T5_003267.LAB	2/14/2023	9:56:09	5.74	0.31	1.19	0.12	0.33	1.27	0.13	191.7	1.004
T5_003268.LAB	2/14/2023	9:57:08	5.76	0.30	1.16	0.12	0.32	1.23	0.13	191.7	1.004
T5_003269.LAB	2/14/2023	9:58:08	5.74	0.28	1.17	0.06	0.30	1.24	0.06	191.6	1.004
T5_003270.LAB	2/14/2023	9:59:08	5.74	0.28	1.16	0.06	0.30	1.23	0.07	191.7	1.006
T5_003271.LAB	2/14/2023	10:00:08	5.74	0.23	1.15	0.07	0.25	1.22	0.08	191.7	1.005
T5_003272.LAB	2/14/2023	10:01:08	5.73	0.27	1.16	-0.02	0.28	1.23	-0.02	191.8	1.008
T5_003273.LAB	2/14/2023	10:02:08	5.73	0.23	1.19	0.11	0.25	1.26	0.12	191.9	1.006
T5_003274.LAB	2/14/2023	10:03:08	5.71	0.27	1.20	0.03	0.29	1.28	0.03	191.9	1.006
T5_003275.LAB	2/14/2023	10:04:08	5.70	0.29	1.24	0.12	0.30	1.31	0.13	191.9	1.005
T5_003276.LAB	2/14/2023	10:05:08	5.69	0.31	1.25	0.07	0.33	1.33	0.08	191.9	1.004
T5_003277.LAB	2/14/2023	10:06:08	5.73	0.31	1.21	0.12	0.33	1.28	0.12	191.8	1.004
T5_003278.LAB	2/14/2023	10:07:08	5.71	0.26	1.20	0.06	0.28	1.27	0.06	191.7	1.004
T5_003279.LAB	2/14/2023	10:08:08	5.70	0.30	1.17	0.00	0.32	1.24	0.00	191.7	1.004
T5_003280.LAB	2/14/2023	10:09:08	5.72	0.29	1.17	0.08	0.31	1.25	0.08	191.7	1.004
T5_003281.LAB	2/14/2023	10:10:07	5.72	0.30	1.15	0.03	0.32	1.22	0.03	191.7	1.005
T5_003282.LAB	2/14/2023	10:11:08	5.72	0.28	1.19	0.03	0.29	1.26	0.03	191.8	1.007
T5_003283.LAB	2/14/2023	10:12:08	5.70	0.26	1.16	0.07	0.27	1.23	0.08	191.9	1.007
T5_003284.LAB	2/14/2023	10:13:07	5.67	0.25	1.17	0.08	0.27	1.24	0.09	191.9	1.006
T5_003285.LAB	2/14/2023	10:14:07	5.69	0.30	1.23	0.16	0.32	1.30	0.16	191.9	1.005
T5_003286.LAB	2/14/2023	10:15:07	5.69	0.28	1.25	0.09	0.29	1.32	0.09	191.8	1.004
02/14/2023		Minimum	5.67	0.22	1.10	-0.02	0.24	1.17	-0.02		
Turbine 5 - Run 1		Maximum	6.04	0.31	1.29	0.19	0.33	1.37	0.20		
9:15 - 10:15		Average	5.85	0.27	1.19	0.09	0.29	1.26	0.10		

Turbine 5 - Run 2

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T5_003297.LAB	2/14/2023	10:20:08	5.68	0.28	1.14	0.12	0.30	1.21	0.13	191.9	1.007
T5_003298.LAB	2/14/2023	10:21:08	5.67	0.24	1.15	0.12	0.26	1.22	0.12	191.8	1.007
T5_003299.LAB	2/14/2023	10:22:08	5.67	0.26	1.14	0.15	0.28	1.21	0.16	191.8	1.007
T5_003300.LAB	2/14/2023	10:23:08	5.67	0.26	1.16	0.06	0.27	1.23	0.07	191.8	1.007
T5_003301.LAB	2/14/2023	10:24:08	5.68	0.25	1.19	0.09	0.27	1.27	0.09	191.8	1.004
T5_003302.LAB	2/14/2023	10:25:08	5.68	0.30	1.23	0.04	0.32	1.30	0.04	191.8	1.005
T5_003303.LAB	2/14/2023	10:26:08	5.69	0.27	1.23	0.17	0.28	1.31	0.18	191.8	1.004
T5_003304.LAB	2/14/2023	10:27:08	5.69	0.24	1.21	0.04	0.25	1.28	0.04	191.8	1.004
T5_003305.LAB	2/14/2023	10:28:08	5.69	0.27	1.21	0.04	0.28	1.29	0.04	191.8	1.004
T5_003306.LAB	2/14/2023	10:29:08	5.67	0.27	1.18	0.00	0.28	1.26	0.00	191.8	1.006
T5_003307.LAB	2/14/2023	10:30:08	5.70	0.27	1.19	-0.06	0.28	1.27	-0.07	191.8	1.006
T5_003308.LAB	2/14/2023	10:31:08	5.71	0.26	1.18	0.00	0.28	1.26	0.01	191.7	1.005
T5_003309.LAB	2/14/2023	10:32:08	5.69	0.25	1.21	0.04	0.26	1.28	0.04	191.8	1.007
T5_003310.LAB	2/14/2023	10:33:08	5.68	0.28	1.20	0.16	0.29	1.28	0.17	191.8	1.007
T5_003311.LAB	2/14/2023	10:34:07	5.70	0.25	1.25	0.01	0.26	1.32	0.01	191.9	1.007
T5_003312.LAB	2/14/2023	10:35:07	5.69	0.25	1.28	0.11	0.26	1.36	0.11	191.8	1.005
T5_003313.LAB	2/14/2023	10:36:07	5.69	0.26	1.28	0.09	0.27	1.36	0.09	191.8	1.005
T5_003314.LAB	2/14/2023	10:37:07	5.71	0.24	1.25	0.08	0.26	1.33	0.08	191.7	1.004
T5_003315.LAB	2/14/2023	10:38:07	5.72	0.32	1.24	0.13	0.34	1.31	0.14	191.7	1.003
T5_003316.LAB	2/14/2023	10:39:07	5.67	0.29	1.22	0.10	0.31	1.29	0.11	191.7	1.006
T5_003317.LAB	2/14/2023	10:40:07	5.69	0.28	1.22	0.05	0.30	1.29	0.06	191.8	1.004
T5_003318.LAB	2/14/2023	10:41:07	5.73	0.27	1.25	0.01	0.29	1.32	0.01	191.9	1.005
T5_003319.LAB	2/14/2023	10:42:07	5.70	0.29	1.21	0.03	0.31	1.28	0.03	191.9	1.008
T5_003320.LAB	2/14/2023	10:43:07	5.71	0.31	1.25	0.03	0.33	1.33	0.03	191.8	1.008
T5_003321.LAB	2/14/2023	10:44:07	5.71	0.28	1.27	0.04	0.30	1.35	0.04	191.8	1.006
T5_003322.LAB	2/14/2023	10:45:07	5.71	0.29	1.31	0.06	0.31	1.39	0.07	191.7	1.005
T5_003323.LAB	2/14/2023	10:46:07	5.68	0.29	1.33	0.13	0.31	1.41	0.14	191.7	1.003
T5_003324.LAB	2/14/2023	10:47:07	5.70	0.29	1.32	0.07	0.31	1.40	0.07	191.7	1.003
T5_003325.LAB	2/14/2023	10:48:07	5.72	0.31	1.29	0.11	0.33	1.36	0.12	191.8	1.003
T5_003326.LAB	2/14/2023	10:49:06	5.71	0.29	1.26	0.02	0.31	1.34	0.02	191.8	1.005
T5_003327.LAB	2/14/2023	10:50:06	5.69	0.29	1.28	0.07	0.31	1.35	0.08	191.8	1.006
T5_003328.LAB	2/14/2023	10:51:06	5.68	0.27	1.23	0.10	0.29	1.31	0.10	191.8	1.006
T5_003329.LAB	2/14/2023	10:52:07	5.69	0.26	1.28	0.09	0.28	1.35	0.09	191.7	1.006
T5_003330.LAB	2/14/2023	10:53:06	5.69	0.28	1.25	0.11	0.29	1.32	0.12	191.7	1.007
T5_003331.LAB	2/14/2023	10:54:06	5.72	0.28	1.28	0.01	0.30	1.35	0.02	191.7	1.007
T5_003332.LAB	2/14/2023	10:55:06	5.68	0.32	1.33	0.15	0.34	1.41	0.16	191.8	1.005
T5_003333.LAB	2/14/2023	10:56:06	5.71	0.31	1.35	0.08	0.33	1.43	0.08	191.9	1.004
T5_003334.LAB	2/14/2023	10:57:06	5.71	0.32	1.32	0.13	0.34	1.40	0.14	191.9	1.004
T5_003335.LAB	2/14/2023	10:58:06	5.74	0.33	1.31	0.02	0.35	1.39	0.02	191.8	1.004
T5_003336.LAB	2/14/2023	10:59:06	5.70	0.32	1.29	0.05	0.34	1.37	0.05	191.7	1.004
T5_003337.LAB	2/14/2023	11:00:06	5.66	0.33	1.26	0.02	0.35	1.34	0.02	191.6	1.006
T5_003338.LAB	2/14/2023	11:01:06	5.68	0.32	1.26	0.13	0.34	1.34	0.13	191.6	1.005
T5_003339.LAB	2/14/2023	11:02:06	5.70	0.36	1.27	0.05	0.38	1.35	0.06	191.7	1.005
T5_003340.LAB	2/14/2023	11:03:06	5.67	0.31	1.27	0.09	0.32	1.34	0.09	191.8	1.007
T5_003341.LAB	2/14/2023	11:04:06	5.70	0.31	1.26	0.05	0.32	1.34	0.06	191.8	1.007
T5_003342.LAB	2/14/2023	11:05:05	5.72	0.37	1.34	0.12	0.39	1.42	0.13	191.9	1.006
T5_003343.LAB	2/14/2023	11:06:05	5.70	0.29	1.37	0.02	0.31	1.45	0.02	191.8	1.004
T5_003344.LAB	2/14/2023	11:07:06	5.70	0.32	1.35	0.08	0.34	1.43	0.08	191.7	1.004
T5_003345.LAB	2/14/2023	11:08:05	5.68	0.33	1.32	0.04	0.35	1.40	0.04	191.7	1.005
T5_003346.LAB	2/14/2023	11:09:05	5.71	0.31	1.31	0.17	0.33	1.39	0.18	191.8	1.003
T5_003347.LAB	2/14/2023	11:10:05	5.72	0.35	1.28	0.10	0.37	1.35	0.11	191.9	1.005
T5_003348.LAB	2/14/2023	11:11:05	5.70	0.34	1.28	0.12	0.36	1.36	0.13	191.9	1.007
T5_003349.LAB	2/14/2023	11:12:05	5.74	0.31	1.31	0.13	0.33	1.39	0.14	191.9	1.006
T5_003350.LAB	2/14/2023	11:13:05	5.75	0.34	1.28	0.11	0.36	1.36	0.11	191.8	1.005
T5_003351.LAB	2/14/2023	11:14:05	5.70	0.30	1.29	0.09	0.31	1.37	0.10	191.6	1.006
T5_003352.LAB	2/14/2023	11:15:05	5.70	0.37	1.33	0.03	0.39	1.41	0.03	191.6	1.005
T5_003353.LAB	2/14/2023	11:16:05	5.73	0.31	1.35	0.11	0.33	1.43	0.11	191.6	1.003
T5_003354.LAB	2/14/2023	11:17:05	5.69	0.32	1.33	0.16	0.34	1.41	0.17	191.7	1.003
T5_003355.LAB	2/14/2023	11:18:05	5.71	0.31	1.29	0.06	0.33	1.37	0.06	191.8	1.003
T5_003356.LAB	2/14/2023	11:19:05	5.72	0.35	1.25	0.06	0.37	1.32	0.07	191.8	1.001
T5_003357.LAB	2/14/2023	11:20:05	5.71	0.32	1.24	0.12	0.34	1.31	0.12	191.8	1.004
02/14/2023	Minimum	5.66	0.24	1.14	-0.06	0.25	1.21	-0.07			
Turbine 5 - Run 2	Maximum	5.75	0.37	1.37	0.17	0.39	1.45	0.18			
10:20 - 11:20	Average	5.70	0.30	1.26	0.08	0.31	1.34	0.08			

Turbine 5 - Run 3

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T5_003368.LAB	2/14/2023	11:25:38	5.73	0.27	1.24	0.12	0.29	1.31	0.12	191.9	1.004
T5_003369.LAB	2/14/2023	11:26:38	5.73	0.28	1.27	0.11	0.30	1.35	0.11	191.9	1.002
T5_003370.LAB	2/14/2023	11:27:38	5.68	0.31	1.26	0.11	0.33	1.33	0.12	191.9	1.004
T5_003371.LAB	2/14/2023	11:28:38	5.69	0.29	1.23	0.07	0.31	1.30	0.08	191.8	1.003
T5_003372.LAB	2/14/2023	11:29:38	5.71	0.29	1.22	0.06	0.31	1.30	0.07	191.7	1.002
T5_003373.LAB	2/14/2023	11:30:38	5.70	0.25	1.21	0.01	0.27	1.29	0.01	191.7	1.005
T5_003374.LAB	2/14/2023	11:31:38	5.71	0.29	1.21	0.13	0.30	1.29	0.14	191.7	1.004
T5_003375.LAB	2/14/2023	11:32:38	5.71	0.25	1.23	0.10	0.26	1.30	0.11	191.7	1.003
T5_003376.LAB	2/14/2023	11:33:37	5.69	0.27	1.26	0.02	0.29	1.33	0.02	191.8	1.007
T5_003377.LAB	2/14/2023	11:34:37	5.74	0.30	1.25	0.11	0.31	1.33	0.12	191.9	1.005
T5_003378.LAB	2/14/2023	11:35:38	5.73	0.29	1.32	0.08	0.31	1.40	0.08	191.8	1.004
T5_003379.LAB	2/14/2023	11:36:37	5.64	0.28	1.33	0.09	0.29	1.41	0.09	191.7	1.003
T5_003380.LAB	2/14/2023	11:37:37	5.65	0.31	1.32	0.11	0.33	1.40	0.12	191.6	1.003
T5_003381.LAB	2/14/2023	11:38:37	5.69	0.30	1.29	0.09	0.32	1.37	0.10	191.6	1.004
T5_003382.LAB	2/14/2023	11:39:37	5.70	0.26	1.29	0.11	0.28	1.37	0.11	191.7	1.003
T5_003383.LAB	2/14/2023	11:40:37	5.71	0.28	1.27	0.20	0.29	1.35	0.22	191.8	1.004
T5_003384.LAB	2/14/2023	11:41:37	5.71	0.30	1.28	0.04	0.32	1.36	0.04	191.9	1.005
T5_003385.LAB	2/14/2023	11:42:37	5.69	0.31	1.27	0.04	0.33	1.35	0.05	191.8	1.005
T5_003386.LAB	2/14/2023	11:43:37	5.69	0.32	1.29	0.12	0.34	1.37	0.12	191.7	1.005
T5_003387.LAB	2/14/2023	11:44:37	5.69	0.32	1.29	0.05	0.34	1.37	0.05	191.6	1.006
T5_003388.LAB	2/14/2023	11:45:37	5.69	0.31	1.33	0.10	0.33	1.41	0.11	191.6	1.004
T5_003389.LAB	2/14/2023	11:46:37	5.68	0.34	1.37	0.13	0.36	1.45	0.14	191.6	1.003
T5_003390.LAB	2/14/2023	11:47:37	5.69	0.35	1.37	0.00	0.37	1.45	0.01	191.7	1.002
T5_003391.LAB	2/14/2023	11:48:37	5.70	0.30	1.35	-0.03	0.32	1.43	-0.03	191.8	1.001
T5_003392.LAB	2/14/2023	11:49:36	5.68	0.29	1.30	0.22	0.31	1.38	0.24	191.8	1.003
T5_003393.LAB	2/14/2023	11:50:36	5.71	0.31	1.34	0.08	0.32	1.42	0.09	191.8	1.003
T5_003394.LAB	2/14/2023	11:51:36	5.69	0.33	1.31	0.05	0.35	1.39	0.05	191.7	1.004
T5_003395.LAB	2/14/2023	11:52:37	5.71	0.34	1.32	0.11	0.36	1.40	0.11	191.6	1.004
T5_003396.LAB	2/14/2023	11:53:36	5.68	0.31	1.31	0.08	0.33	1.39	0.09	191.6	1.003
T5_003397.LAB	2/14/2023	11:54:36	5.67	0.34	1.30	0.10	0.36	1.38	0.10	191.7	1.005
T5_003398.LAB	2/14/2023	11:55:36	5.69	0.32	1.33	0.11	0.34	1.41	0.11	191.7	1.005
T5_003399.LAB	2/14/2023	11:56:36	5.67	0.35	1.37	0.11	0.37	1.45	0.12	191.8	1.004
T5_003400.LAB	2/14/2023	11:57:36	5.71	0.37	1.40	0.08	0.39	1.49	0.09	191.8	1.002
T5_003401.LAB	2/14/2023	11:58:36	5.70	0.35	1.36	0.04	0.37	1.44	0.04	191.7	1.003
T5_003402.LAB	2/14/2023	11:59:36	5.69	0.34	1.33	0.03	0.37	1.41	0.03	191.6	1.002
T5_003403.LAB	2/14/2023	12:00:36	5.68	0.35	1.31	0.05	0.37	1.39	0.06	191.7	1.002
T5_003404.LAB	2/14/2023	12:01:36	5.68	0.36	1.31	0.10	0.38	1.39	0.10	191.7	1.002
T5_003405.LAB	2/14/2023	12:02:36	5.66	0.35	1.28	0.05	0.37	1.35	0.06	191.8	1.003
T5_003406.LAB	2/14/2023	12:03:36	5.67	0.31	1.30	0.14	0.33	1.37	0.14	191.9	1.003
T5_003407.LAB	2/14/2023	12:04:36	5.67	0.34	1.30	0.12	0.36	1.38	0.12	191.9	1.003
T5_003408.LAB	2/14/2023	12:05:35	5.67	0.32	1.31	0.04	0.34	1.39	0.04	191.8	1.005
T5_003409.LAB	2/14/2023	12:06:35	5.67	0.34	1.38	0.14	0.36	1.47	0.15	191.7	1.005
T5_003410.LAB	2/14/2023	12:07:36	5.65	0.34	1.38	0.03	0.36	1.47	0.03	191.7	1.003
T5_003411.LAB	2/14/2023	12:08:35	5.70	0.36	1.38	0.05	0.39	1.46	0.06	191.7	1.002
T5_003412.LAB	2/14/2023	12:09:35	5.67	0.35	1.37	-0.03	0.37	1.45	-0.03	191.6	1.002
T5_003421.LAB	2/14/2023	12:18:35	5.64	0.37	1.39	0.09	0.40	1.48	0.09	191.8	1.002
T5_003422.LAB	2/14/2023	12:19:35	5.66	0.39	1.36	0.09	0.41	1.45	0.10	191.8	1.002
T5_003423.LAB	2/14/2023	12:20:34	5.67	0.37	1.36	0.03	0.39	1.44	0.03	191.8	1.001
T5_003424.LAB	2/14/2023	12:21:35	5.67	0.38	1.35	0.10	0.40	1.43	0.11	191.7	1.002
T5_003425.LAB	2/14/2023	12:22:34	5.65	0.37	1.35	0.10	0.40	1.43	0.11	191.6	1.004
T5_003426.LAB	2/14/2023	12:23:34	5.67	0.39	1.36	0.08	0.42	1.44	0.08	191.6	1.004
T5_003427.LAB	2/14/2023	12:24:34	5.66	0.38	1.34	0.11	0.40	1.42	0.11	191.6	1.004
T5_003428.LAB	2/14/2023	12:25:34	5.63	0.37	1.35	0.09	0.39	1.43	0.09	191.7	1.004
T5_003429.LAB	2/14/2023	12:26:34	5.67	0.37	1.42	0.08	0.39	1.50	0.08	191.8	1.004
T5_003430.LAB	2/14/2023	12:27:34	5.64	0.40	1.44	0.04	0.42	1.53	0.05	191.8	1.003
T5_003431.LAB	2/14/2023	12:28:34	5.67	0.38	1.44	0.08	0.40	1.52	0.09	191.7	1.001
T5_003432.LAB	2/14/2023	12:29:34	5.68	0.35	1.41	0.14	0.37	1.49	0.15	191.7	1.002
T5_003433.LAB	2/14/2023	12:30:34	5.68	0.37	1.34	0.12	0.39	1.42	0.12	191.6	1.001
T5_003434.LAB	2/14/2023	12:31:34	5.63	0.35	1.36	0.11	0.37	1.44	0.12	191.6	1.001
T5_003435.LAB	2/14/2023	12:32:34	5.61	0.39	1.31	0.12	0.42	1.39	0.13	191.7	1.002
T5_003436.LAB	2/14/2023	12:33:34	5.66	0.36	1.33	0.13	0.38	1.41	0.14	191.7	1.004
T5_003437.LAB	2/14/2023	12:34:34	5.63	0.39	1.32	0.17	0.41	1.40	0.18	191.8	1.004
02/14/2023			Minimum	5.61	0.25	1.21	-0.03	0.26	1.29	-0.03	
Turbine 5 - Run 3			Maximum	5.74	0.40	1.44	0.22	0.42	1.53	0.24	
11:25 - 12:09; 12:18 -			Average	5.68	0.33	1.32	0.09	0.35	1.40	0.09	

Turbine 5 - Run 4

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T5_003449.LAB	2/14/2023	12:40:57	5.64	0.37	1.31	-0.03	0.39	1.39	-0.03	191.7	1.001
T5_003450.LAB	2/14/2023	12:41:57	5.63	0.34	1.27	0.00	0.36	1.35	0.00	191.8	1.003
T5_003451.LAB	2/14/2023	12:42:57	5.63	0.34	1.30	0.09	0.36	1.38	0.09	191.8	1.004
T5_003452.LAB	2/14/2023	12:43:56	5.64	0.32	1.29	0.10	0.34	1.36	0.10	191.7	1.003
T5_003453.LAB	2/14/2023	12:44:56	5.64	0.35	1.32	0.05	0.37	1.40	0.05	191.6	1.002
T5_003454.LAB	2/14/2023	12:45:56	5.63	0.37	1.32	0.07	0.39	1.40	0.07	191.6	1.005
T5_003455.LAB	2/14/2023	12:46:56	5.62	0.36	1.36	0.09	0.38	1.44	0.09	191.6	1.004
T5_003456.LAB	2/14/2023	12:47:56	5.60	0.34	1.39	0.00	0.36	1.47	0.00	191.7	1.002
T5_003457.LAB	2/14/2023	12:48:56	5.62	0.34	1.41	0.06	0.36	1.49	0.06	191.8	1.001
T5_003458.LAB	2/14/2023	12:49:56	5.64	0.34	1.36	0.09	0.36	1.44	0.09	191.8	1.000
T5_003459.LAB	2/14/2023	12:50:56	5.63	0.37	1.36	0.10	0.39	1.44	0.10	191.7	1.002
T5_003460.LAB	2/14/2023	12:51:56	5.63	0.33	1.35	0.09	0.35	1.43	0.10	191.7	1.002
T5_003461.LAB	2/14/2023	12:52:56	5.60	0.30	1.33	0.09	0.32	1.41	0.09	191.6	1.003
T5_003462.LAB	2/14/2023	12:53:56	5.60	0.37	1.33	0.16	0.39	1.41	0.17	191.6	1.003
T5_003463.LAB	2/14/2023	12:54:56	5.64	0.34	1.33	0.09	0.36	1.41	0.09	191.7	1.003
T5_003464.LAB	2/14/2023	12:55:56	5.62	0.36	1.34	0.12	0.39	1.42	0.13	191.8	1.004
T5_003465.LAB	2/14/2023	12:56:56	5.64	0.37	1.35	0.04	0.39	1.44	0.04	191.8	1.004
T5_003466.LAB	2/14/2023	12:57:56	5.66	0.38	1.39	0.09	0.41	1.47	0.10	191.8	1.002
T5_003467.LAB	2/14/2023	12:58:56	5.63	0.38	1.41	0.04	0.40	1.50	0.04	191.7	1.002
T5_003468.LAB	2/14/2023	12:59:55	5.62	0.34	1.37	0.17	0.36	1.46	0.18	191.6	1.002
T5_003469.LAB	2/14/2023	13:00:55	5.61	0.35	1.35	0.11	0.38	1.44	0.11	191.6	1.001
T5_003470.LAB	2/14/2023	13:01:55	5.63	0.37	1.36	0.08	0.39	1.44	0.09	191.6	1.001
T5_003471.LAB	2/14/2023	13:02:55	5.62	0.36	1.35	0.00	0.38	1.43	0.00	191.7	1.001
T5_003472.LAB	2/14/2023	13:03:56	5.62	0.34	1.34	0.11	0.36	1.42	0.12	191.8	1.002
T5_003473.LAB	2/14/2023	13:04:55	5.63	0.40	1.34	0.05	0.42	1.42	0.05	191.8	1.004
T5_003474.LAB	2/14/2023	13:05:55	5.63	0.33	1.36	0.06	0.35	1.44	0.06	191.8	1.004
T5_003475.LAB	2/14/2023	13:06:55	5.64	0.35	1.37	0.13	0.37	1.45	0.14	191.7	1.004
T5_003476.LAB	2/14/2023	13:07:55	5.66	0.37	1.41	0.11	0.39	1.50	0.12	191.7	1.003
T5_003477.LAB	2/14/2023	13:08:55	5.63	0.38	1.43	0.13	0.40	1.52	0.14	191.6	1.001
T5_003478.LAB	2/14/2023	13:09:55	5.62	0.37	1.41	0.06	0.39	1.50	0.07	191.6	1.002
T5_003479.LAB	2/14/2023	13:10:55	5.64	0.35	1.37	0.10	0.38	1.45	0.11	191.7	1.001
T5_003480.LAB	2/14/2023	13:11:55	5.68	0.36	1.38	0.07	0.39	1.46	0.07	191.7	1.000
T5_003481.LAB	2/14/2023	13:12:55	5.68	0.37	1.37	0.07	0.40	1.45	0.08	191.7	1.001
T5_003482.LAB	2/14/2023	13:13:55	5.65	0.36	1.36	0.06	0.38	1.44	0.07	191.8	1.003
T5_003483.LAB	2/14/2023	13:14:55	5.64	0.37	1.35	0.10	0.39	1.43	0.11	191.7	1.002
T5_003484.LAB	2/14/2023	13:15:55	5.63	0.36	1.33	0.09	0.39	1.41	0.10	191.6	1.002
T5_003485.LAB	2/14/2023	13:16:54	5.65	0.36	1.36	0.00	0.38	1.44	0.00	191.6	1.004
T5_003486.LAB	2/14/2023	13:17:55	5.62	0.36	1.37	0.15	0.38	1.46	0.15	191.7	1.003
T5_003487.LAB	2/14/2023	13:18:54	5.63	0.39	1.42	0.06	0.42	1.50	0.06	191.7	1.001
T5_003488.LAB	2/14/2023	13:19:54	5.65	0.38	1.41	0.05	0.40	1.49	0.05	191.8	1.001
T5_003489.LAB	2/14/2023	13:20:54	5.68	0.40	1.40	0.13	0.42	1.49	0.14	191.7	1.000
T5_003490.LAB	2/14/2023	13:21:54	5.60	0.32	1.35	0.08	0.34	1.43	0.09	191.7	1.002
T5_003491.LAB	2/14/2023	13:22:54	5.60	0.33	1.34	0.01	0.35	1.42	0.01	191.7	1.002
T5_003492.LAB	2/14/2023	13:23:54	5.58	0.35	1.30	0.06	0.37	1.38	0.06	191.7	1.002
T5_003493.LAB	2/14/2023	13:24:54	5.67	0.37	1.34	0.00	0.39	1.42	0.00	191.7	1.002
T5_003494.LAB	2/14/2023	13:25:54	5.62	0.35	1.34	0.07	0.37	1.42	0.08	191.7	1.004
T5_003495.LAB	2/14/2023	13:26:54	5.60	0.31	1.35	0.10	0.32	1.43	0.11	191.8	1.005
T5_003496.LAB	2/14/2023	13:27:54	5.63	0.33	1.36	0.06	0.35	1.44	0.07	191.7	1.003
T5_003497.LAB	2/14/2023	13:28:54	5.65	0.41	1.41	0.01	0.44	1.50	0.01	191.7	1.002
T5_003498.LAB	2/14/2023	13:29:54	5.63	0.40	1.43	0.04	0.42	1.52	0.04	191.6	1.000
T5_003499.LAB	2/14/2023	13:30:54	5.62	0.35	1.38	0.01	0.37	1.46	0.01	191.7	0.999
T5_003500.LAB	2/14/2023	13:31:54	5.63	0.40	1.38	0.13	0.43	1.46	0.14	191.7	1.001
T5_003501.LAB	2/14/2023	13:32:54	5.64	0.41	1.38	0.08	0.43	1.46	0.08	191.7	1.000
T5_003502.LAB	2/14/2023	13:33:53	5.67	0.38	1.36	0.10	0.40	1.44	0.10	191.8	1.000
T5_003503.LAB	2/14/2023	13:34:54	5.62	0.37	1.36	0.07	0.39	1.44	0.07	191.7	1.002
T5_003504.LAB	2/14/2023	13:35:53	5.64	0.41	1.38	0.03	0.43	1.46	0.03	191.7	1.003
T5_003505.LAB	2/14/2023	13:36:53	5.63	0.38	1.37	0.04	0.41	1.45	0.05	191.6	1.003
T5_003506.LAB	2/14/2023	13:37:53	5.63	0.38	1.41	0.07	0.40	1.49	0.07	191.6	1.003
T5_003507.LAB	2/14/2023	13:38:53	5.65	0.40	1.44	0.11	0.42	1.53	0.12	191.7	1.002
T5_003508.LAB	2/14/2023	13:39:53	5.62	0.39	1.43	0.05	0.42	1.52	0.05	191.7	1.000
T5_003509.LAB	2/14/2023	13:40:53	5.63	0.38	1.41	0.06	0.40	1.50	0.06	191.8	1.000
02/14/2023		Minimum	5.58	0.30	1.27	-0.03	0.32	1.35	-0.03		
Turbine 5 - Run 4		Maximum	5.68	0.41	1.44	0.17	0.44	1.53	0.18		
12:40 - 13:40		Average	5.63	0.36	1.37	0.07	0.38	1.45	0.08		

Turbine 5 - Run 5

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T5_003872.LAB	2/15/2023	9:05:29	5.47	0.22	1.15	0.10	0.24	1.21	0.10	191.9	0.998
T5_003873.LAB	2/15/2023	9:06:29	5.47	0.27	1.11	0.05	0.28	1.18	0.06	191.9	1.000
T5_003874.LAB	2/15/2023	9:07:29	5.49	0.29	1.09	0.05	0.30	1.15	0.06	191.9	0.999
T5_003875.LAB	2/15/2023	9:08:29	5.49	0.24	1.11	0.01	0.25	1.18	0.01	191.9	1.000
T5_003876.LAB	2/15/2023	9:09:29	5.44	0.24	1.09	-0.01	0.25	1.15	-0.01	191.9	1.001
T5_003877.LAB	2/15/2023	9:10:29	5.48	0.29	1.10	0.03	0.30	1.16	0.03	191.9	0.999
T5_003878.LAB	2/15/2023	9:11:29	5.46	0.29	1.12	-0.02	0.31	1.18	-0.02	191.9	0.999
T5_003879.LAB	2/15/2023	9:12:29	5.50	0.28	1.14	0.01	0.29	1.21	0.01	191.9	0.997
T5_003880.LAB	2/15/2023	9:13:28	5.49	0.28	1.08	0.03	0.30	1.14	0.04	191.9	0.997
T5_003881.LAB	2/15/2023	9:14:28	5.48	0.25	1.07	0.09	0.27	1.13	0.10	191.9	0.998
T5_003882.LAB	2/15/2023	9:15:28	5.49	0.25	1.06	0.08	0.26	1.13	0.08	191.9	0.998
T5_003883.LAB	2/15/2023	9:16:28	5.47	0.24	1.05	0.04	0.25	1.11	0.04	191.9	0.998
T5_003884.LAB	2/15/2023	9:17:28	5.47	0.25	1.05	0.02	0.26	1.11	0.02	191.9	1.000
T5_003885.LAB	2/15/2023	9:18:28	5.48	0.25	1.03	0.07	0.26	1.09	0.07	191.9	1.001
T5_003886.LAB	2/15/2023	9:19:28	5.48	0.29	1.04	0.11	0.31	1.10	0.12	191.9	1.001
T5_003887.LAB	2/15/2023	9:20:28	5.48	0.28	1.06	0.07	0.29	1.12	0.07	191.9	1.000
T5_003888.LAB	2/15/2023	9:21:28	5.46	0.27	1.08	0.07	0.28	1.14	0.07	191.9	1.000
T5_003889.LAB	2/15/2023	9:22:28	5.46	0.28	1.10	0.04	0.29	1.16	0.04	191.8	0.999
T5_003890.LAB	2/15/2023	9:23:28	5.46	0.26	1.09	0.03	0.28	1.15	0.03	191.8	0.998
T5_003891.LAB	2/15/2023	9:24:28	5.48	0.27	1.08	0.01	0.28	1.15	0.01	191.9	0.997
T5_003892.LAB	2/15/2023	9:25:28	5.48	0.25	1.07	0.12	0.26	1.13	0.12	191.9	0.998
T5_003893.LAB	2/15/2023	9:26:28	5.47	0.25	1.05	0.03	0.27	1.12	0.03	191.8	0.999
T5_003894.LAB	2/15/2023	9:27:27	5.46	0.26	1.03	0.06	0.28	1.09	0.07	191.8	1.000
T5_003895.LAB	2/15/2023	9:28:28	5.46	0.27	1.05	0.09	0.28	1.11	0.10	191.8	1.000
T5_003896.LAB	2/15/2023	9:29:27	5.46	0.26	1.06	-0.11	0.28	1.12	-0.12	191.9	1.001
T5_003897.LAB	2/15/2023	9:30:27	5.46	0.28	1.07	0.14	0.29	1.13	0.14	191.9	1.001
T5_003898.LAB	2/15/2023	9:31:27	5.45	0.25	1.08	0.03	0.27	1.14	0.03	191.9	1.000
T5_003899.LAB	2/15/2023	9:32:27	5.46	0.28	1.11	0.11	0.30	1.18	0.12	191.9	0.999
T5_003900.LAB	2/15/2023	9:33:27	5.46	0.28	1.11	0.05	0.30	1.18	0.05	191.9	0.997
T5_003901.LAB	2/15/2023	9:34:27	5.47	0.25	1.10	0.12	0.27	1.17	0.13	191.9	0.997
T5_003902.LAB	2/15/2023	9:35:27	5.46	0.29	1.09	0.05	0.31	1.16	0.05	191.9	0.999
T5_003903.LAB	2/15/2023	9:36:27	5.45	0.29	1.10	0.08	0.30	1.16	0.08	191.9	0.998
T5_003904.LAB	2/15/2023	9:37:27	5.46	0.27	1.08	0.15	0.29	1.15	0.16	191.9	0.999
T5_003905.LAB	2/15/2023	9:38:27	5.46	0.28	1.09	-0.04	0.29	1.16	-0.04	191.9	1.000
T5_003906.LAB	2/15/2023	9:39:27	5.46	0.24	1.11	0.01	0.25	1.17	0.01	191.9	1.000
T5_003907.LAB	2/15/2023	9:40:27	5.47	0.27	1.14	0.04	0.29	1.21	0.04	191.9	1.000
T5_003908.LAB	2/15/2023	9:41:27	5.45	0.31	1.16	0.04	0.33	1.23	0.04	191.9	1.000
T5_003909.LAB	2/15/2023	9:42:27	5.44	0.28	1.20	0.03	0.29	1.27	0.04	191.8	0.999
T5_003910.LAB	2/15/2023	9:43:26	5.45	0.27	1.23	0.01	0.29	1.30	0.01	191.8	0.998
T5_003911.LAB	2/15/2023	9:44:26	5.47	0.32	1.21	-0.01	0.34	1.28	-0.01	191.9	0.998
T5_003912.LAB	2/15/2023	9:45:26	5.45	0.30	1.20	0.05	0.32	1.27	0.06	191.9	0.999
T5_003913.LAB	2/15/2023	9:46:26	5.45	0.27	1.18	0.04	0.29	1.25	0.04	191.9	0.999
T5_003914.LAB	2/15/2023	9:47:26	5.45	0.26	1.18	0.06	0.28	1.25	0.06	191.9	1.000
T5_003915.LAB	2/15/2023	9:48:26	5.42	0.24	1.19	-0.02	0.26	1.26	-0.02	191.9	1.001
T5_003916.LAB	2/15/2023	9:49:26	5.43	0.29	1.19	0.06	0.31	1.26	0.06	191.9	1.001
T5_003917.LAB	2/15/2023	9:50:26	5.45	0.32	1.20	0.11	0.30	1.27	0.12	191.9	1.001
T5_003918.LAB	2/15/2023	9:51:26	5.45	0.25	1.20	0.04	0.26	1.27	0.04	191.9	1.001
T5_003919.LAB	2/15/2023	9:52:26	5.45	0.29	1.24	0.06	0.31	1.31	0.06	191.9	1.001
T5_003920.LAB	2/15/2023	9:53:26	5.44	0.28	1.25	0.04	0.30	1.32	0.04	191.9	1.000
T5_003921.LAB	2/15/2023	9:54:26	5.45	0.28	1.25	0.05	0.30	1.33	0.06	191.9	0.998
T5_003922.LAB	2/15/2023	9:55:26	5.45	0.28	1.23	0.12	0.29	1.30	0.13	191.9	0.998
T5_003923.LAB	2/15/2023	9:56:26	5.44	0.27	1.23	0.09	0.29	1.30	0.09	191.9	0.999
T5_003924.LAB	2/15/2023	9:57:26	5.44	0.25	1.22	0.11	0.26	1.29	0.11	191.8	1.000
T5_003925.LAB	2/15/2023	9:58:26	5.43	0.28	1.22	0.02	0.29	1.29	0.02	191.8	1.000
T5_003926.LAB	2/15/2023	9:59:26	5.44	0.28	1.22	-0.02	0.29	1.29	-0.02	191.8	1.001
T5_003927.LAB	2/15/2023	10:00:25	5.45	0.26	1.22	0.04	0.27	1.29	0.04	191.9	1.001
T5_003928.LAB	2/15/2023	10:01:25	5.45	0.30	1.25	0.08	0.32	1.33	0.09	191.9	1.000
T5_003929.LAB	2/15/2023	10:02:25	5.44	0.30	1.29	0.02	0.31	1.37	0.02	191.8	1.000
T5_003930.LAB	2/15/2023	10:03:25	5.42	0.29	1.31	0.06	0.31	1.39	0.06	191.9	0.999
T5_003931.LAB	2/15/2023	10:04:25	5.43	0.31	1.32	0.06	0.32	1.40	0.06	191.9	0.997
T5_003932.LAB	2/15/2023	10:05:25	5.42	0.25	1.31	0.01	0.27	1.38	0.01	191.9	0.999
02/15/2023		Minimum	5.42	0.22	1.03	-0.11	0.24	1.09	-0.12		
Turbine 5 - Run 5		Maximum	5.50	0.32	1.32	0.15	0.34	1.40	0.16		
9:05 - 10:05		Average	5.46	0.27	1.14	0.05	0.29	1.21	0.05		

Turbine 5 - Run 6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T5_003943.LAB	2/15/2023	10:10:34	5.41	0.24	1.36	0.05	0.26	1.44	0.05	191.8	1.000
T5_003944.LAB	2/15/2023	10:11:34	5.41	0.28	1.36	0.07	0.29	1.44	0.07	191.8	1.002
T5_003945.LAB	2/15/2023	10:12:34	5.42	0.30	1.37	0.02	0.32	1.44	0.02	191.8	1.000
T5_003946.LAB	2/15/2023	10:13:34	5.43	0.34	1.40	0.06	0.36	1.48	0.06	191.8	1.000
T5_003947.LAB	2/15/2023	10:14:34	5.43	0.28	1.40	0.10	0.29	1.48	0.11	191.8	0.999
T5_003948.LAB	2/15/2023	10:15:34	5.40	0.30	1.37	0.14	0.32	1.45	0.15	191.8	0.999
T5_003949.LAB	2/15/2023	10:16:34	5.41	0.30	1.37	0.11	0.31	1.45	0.11	191.8	0.999
T5_003950.LAB	2/15/2023	10:17:34	5.39	0.28	1.36	0.04	0.30	1.43	0.04	191.7	1.000
T5_003951.LAB	2/15/2023	10:18:34	5.39	0.31	1.37	0.03	0.33	1.45	0.03	191.7	1.001
T5_003952.LAB	2/15/2023	10:19:34	5.41	0.30	1.37	0.03	0.32	1.45	0.03	191.8	1.000
T5_003953.LAB	2/15/2023	10:20:34	5.42	0.33	1.38	0.03	0.35	1.46	0.04	191.9	1.001
T5_003954.LAB	2/15/2023	10:21:34	5.40	0.27	1.38	0.04	0.28	1.46	0.04	191.9	1.002
T5_003955.LAB	2/15/2023	10:22:34	5.40	0.28	1.41	0.01	0.29	1.49	0.01	191.8	1.000
T5_003956.LAB	2/15/2023	10:23:34	5.40	0.26	1.45	0.06	0.28	1.54	0.06	191.8	1.000
T5_003957.LAB	2/15/2023	10:24:34	5.40	0.31	1.43	0.04	0.33	1.51	0.04	191.8	0.998
T5_003958.LAB	2/15/2023	10:25:34	5.39	0.30	1.42	0.03	0.32	1.50	0.04	191.7	1.000
T5_003959.LAB	2/15/2023	10:26:33	5.39	0.27	1.41	0.04	0.29	1.49	0.05	191.8	0.999
T5_003960.LAB	2/15/2023	10:27:34	5.40	0.31	1.38	0.03	0.33	1.46	0.04	191.9	1.000
T5_003961.LAB	2/15/2023	10:28:33	5.39	0.31	1.40	0.03	0.33	1.48	0.03	191.9	1.000
T5_003962.LAB	2/15/2023	10:29:33	5.39	0.33	1.38	0.12	0.35	1.46	0.13	191.9	0.999
T5_003963.LAB	2/15/2023	10:30:33	5.39	0.28	1.40	0.09	0.30	1.47	0.09	191.8	1.001
T5_003964.LAB	2/15/2023	10:31:33	5.38	0.32	1.38	0.08	0.34	1.46	0.09	191.9	1.001
T5_003965.LAB	2/15/2023	10:32:33	5.40	0.32	1.46	0.07	0.34	1.54	0.08	191.8	1.000
T5_003966.LAB	2/15/2023	10:33:33	5.37	0.32	1.47	-0.01	0.34	1.55	-0.01	191.7	1.001
T5_003967.LAB	2/15/2023	10:34:33	5.38	0.31	1.48	0.00	0.33	1.56	0.00	191.8	0.999
T5_003968.LAB	2/15/2023	10:35:33	5.39	0.32	1.48	0.05	0.34	1.57	0.05	191.8	0.999
T5_003969.LAB	2/15/2023	10:36:33	5.38	0.31	1.46	0.05	0.32	1.54	0.05	191.9	0.999
T5_003970.LAB	2/15/2023	10:37:33	5.37	0.34	1.42	0.07	0.36	1.50	0.08	191.9	1.001
T5_003971.LAB	2/15/2023	10:38:33	5.39	0.28	1.45	0.01	0.30	1.54	0.01	191.8	1.000
T5_003972.LAB	2/15/2023	10:39:33	5.37	0.31	1.40	0.06	0.32	1.48	0.06	191.8	1.001
T5_003973.LAB	2/15/2023	10:40:33	5.37	0.33	1.44	0.03	0.35	1.52	0.03	191.8	1.002
T5_003974.LAB	2/15/2023	10:41:33	5.36	0.37	1.42	0.05	0.39	1.51	0.05	191.7	1.003
T5_003975.LAB	2/15/2023	10:42:32	5.36	0.33	1.47	0.04	0.35	1.55	0.05	191.7	1.002
T5_003976.LAB	2/15/2023	10:43:32	5.35	0.31	1.47	0.06	0.33	1.56	0.06	191.8	1.001
T5_003977.LAB	2/15/2023	10:44:32	5.35	0.34	1.50	0.02	0.36	1.58	0.02	191.9	1.000
T5_003978.LAB	2/15/2023	10:45:32	5.36	0.33	1.45	0.09	0.35	1.53	0.10	191.9	0.998
T5_003979.LAB	2/15/2023	10:46:32	5.36	0.36	1.46	0.02	0.38	1.54	0.02	191.8	0.998
T5_003980.LAB	2/15/2023	10:47:32	5.37	0.30	1.46	0.04	0.31	1.54	0.04	191.8	0.999
T5_003981.LAB	2/15/2023	10:48:32	5.36	0.30	1.42	0.02	0.32	1.50	0.02	191.8	1.000
T5_003982.LAB	2/15/2023	10:49:32	5.35	0.30	1.41	0.11	0.31	1.49	0.11	191.7	1.000
T5_003983.LAB	2/15/2023	10:50:32	5.35	0.29	1.45	0.09	0.31	1.53	0.09	191.7	1.002
T5_003984.LAB	2/15/2023	10:51:32	5.37	0.29	1.45	0.04	0.31	1.53	0.04	191.8	1.002
T5_003985.LAB	2/15/2023	10:52:32	5.37	0.33	1.45	0.06	0.35	1.54	0.06	191.9	1.002
T5_003986.LAB	2/15/2023	10:53:32	5.35	0.34	1.49	0.10	0.36	1.58	0.10	191.9	1.000
T5_003987.LAB	2/15/2023	10:54:32	5.34	0.33	1.53	0.00	0.34	1.61	0.00	191.8	1.000
T5_003988.LAB	2/15/2023	10:55:32	5.34	0.35	1.52	0.00	0.37	1.61	0.00	191.7	0.998
T5_003989.LAB	2/15/2023	10:56:32	5.36	0.34	1.48	0.05	0.36	1.57	0.05	191.7	0.999
T5_003990.LAB	2/15/2023	10:57:32	5.34	0.33	1.46	0.12	0.35	1.54	0.12	191.7	0.999
T5_003991.LAB	2/15/2023	10:58:31	5.34	0.30	1.45	-0.02	0.32	1.54	-0.02	191.8	1.000
T5_003992.LAB	2/15/2023	10:59:31	5.35	0.30	1.47	0.13	0.32	1.55	0.14	191.8	1.001
T5_003993.LAB	2/15/2023	11:00:31	5.33	0.26	1.45	-0.02	0.28	1.53	-0.02	191.8	1.001
T5_003994.LAB	2/15/2023	11:01:31	5.33	0.28	1.45	0.10	0.30	1.54	0.11	191.8	1.002
T5_003995.LAB	2/15/2023	11:02:31	5.33	0.36	1.47	0.05	0.38	1.56	0.05	191.7	1.000
T5_003996.LAB	2/15/2023	11:03:31	5.33	0.36	1.52	0.07	0.38	1.60	0.08	191.7	0.999
T5_003997.LAB	2/15/2023	11:04:31	5.32	0.39	1.52	0.03	0.41	1.60	0.03	191.7	1.000
T5_003998.LAB	2/15/2023	11:05:31	5.33	0.36	1.53	-0.02	0.38	1.62	-0.02	191.8	0.998
T5_003999.LAB	2/15/2023	11:06:31	5.35	0.32	1.46	0.05	0.34	1.54	0.05	191.8	0.998
T5_004000.LAB	2/15/2023	11:07:31	5.32	0.37	1.47	0.07	0.39	1.56	0.07	191.8	0.999
T5_004001.LAB	2/15/2023	11:08:31	5.30	0.33	1.46	0.15	0.35	1.54	0.16	191.7	1.002
T5_004002.LAB	2/15/2023	11:09:31	5.33	0.35	1.47	0.02	0.37	1.55	0.02	191.7	1.001
T5_004003.LAB	2/15/2023	11:10:31	5.35	0.33	1.48	0.02	0.35	1.57	0.02	191.8	1.000
02/15/2023		Minimum	5.30	0.24	1.36	-0.02	0.26	1.43	-0.02		
Turbine 5 - Run 6		Maximum	5.43	0.39	1.53	0.15	0.41	1.62	0.16		
10:10 - 11:10		Average	5.37	0.31	1.44	0.05	0.33	1.52	0.05		

Turbine 5 - Run 7

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	HCl (ppmv dry)	HF (ppmv dry)	Formaldehyde (ppmv dry)	FTIR Gas Cell Temperature (°C)	FTIR Gas Cell Pressure (atm)
T5_004014.LAB	2/15/2023	11:15:31	5.31	0.32	1.50	-0.01	0.33	1.58	-0.01	191.8	0.999
T5_004015.LAB	2/15/2023	11:16:31	5.32	0.35	1.48	0.10	0.37	1.57	0.11	191.7	0.999
T5_004016.LAB	2/15/2023	11:17:31	5.34	0.31	1.47	0.13	0.33	1.55	0.14	191.8	0.999
T5_004017.LAB	2/15/2023	11:18:31	5.32	0.32	1.45	0.03	0.34	1.53	0.04	191.8	1.001
T5_004018.LAB	2/15/2023	11:19:31	5.32	0.31	1.44	0.02	0.33	1.52	0.03	191.9	1.001
T5_004019.LAB	2/15/2023	11:20:31	5.32	0.29	1.44	0.03	0.31	1.53	0.03	191.8	1.000
T5_004020.LAB	2/15/2023	11:21:31	5.32	0.33	1.48	0.03	0.35	1.56	0.03	191.8	1.000
T5_004021.LAB	2/15/2023	11:22:31	5.31	0.32	1.48	0.07	0.34	1.56	0.08	191.8	1.001
T5_004022.LAB	2/15/2023	11:23:31	5.32	0.36	1.50	0.06	0.38	1.59	0.06	191.7	1.000
T5_004023.LAB	2/15/2023	11:24:31	5.32	0.34	1.52	0.03	0.36	1.60	0.03	191.8	0.999
T5_004024.LAB	2/15/2023	11:25:31	5.32	0.35	1.53	0.07	0.36	1.62	0.07	191.9	0.999
T5_004025.LAB	2/15/2023	11:26:31	5.33	0.37	1.52	0.09	0.39	1.61	0.09	191.9	0.999
T5_004026.LAB	2/15/2023	11:27:31	5.31	0.34	1.49	0.04	0.36	1.57	0.04	191.8	0.998
T5_004027.LAB	2/15/2023	11:28:31	5.30	0.36	1.50	0.11	0.38	1.58	0.12	191.6	1.000
T5_004028.LAB	2/15/2023	11:29:30	5.32	0.35	1.51	0.06	0.37	1.59	0.06	191.6	1.000
T5_004029.LAB	2/15/2023	11:30:30	5.32	0.36	1.50	0.14	0.38	1.59	0.15	191.7	1.000
T5_004030.LAB	2/15/2023	11:31:30	5.34	0.32	1.48	0.06	0.34	1.57	0.06	191.8	1.001
T5_004031.LAB	2/15/2023	11:32:30	5.32	0.35	1.51	0.05	0.36	1.59	0.06	191.8	1.002
T5_004032.LAB	2/15/2023	11:33:30	5.33	0.33	1.54	0.02	0.35	1.63	0.02	191.8	1.001
T5_004033.LAB	2/15/2023	11:34:30	5.31	0.36	1.59	0.05	0.38	1.68	0.05	191.7	1.000
T5_004034.LAB	2/15/2023	11:35:30	5.31	0.37	1.57	0.04	0.39	1.66	0.04	191.6	0.998
T5_004035.LAB	2/15/2023	11:36:30	5.30	0.36	1.54	0.03	0.38	1.63	0.03	191.7	0.998
T5_004036.LAB	2/15/2023	11:37:30	5.31	0.38	1.54	0.06	0.40	1.63	0.06	191.8	1.000
T5_004037.LAB	2/15/2023	11:38:30	5.32	0.37	1.53	0.04	0.39	1.62	0.04	191.9	1.000
T5_004038.LAB	2/15/2023	11:39:30	5.31	0.36	1.51	0.04	0.38	1.60	0.04	191.9	1.000
T5_004039.LAB	2/15/2023	11:40:30	5.31	0.34	1.52	0.03	0.35	1.60	0.03	191.8	1.000
T5_004040.LAB	2/15/2023	11:41:30	5.30	0.33	1.52	0.05	0.35	1.60	0.05	191.7	1.001
T5_004041.LAB	2/15/2023	11:42:30	5.30	0.36	1.52	0.03	0.38	1.60	0.03	191.7	1.001
T5_004042.LAB	2/15/2023	11:43:30	5.30	0.38	1.54	0.02	0.40	1.63	0.02	191.8	1.002
T5_004043.LAB	2/15/2023	11:44:29	5.31	0.37	1.60	0.11	0.39	1.69	0.12	191.8	1.000
T5_004044.LAB	2/15/2023	11:45:29	5.30	0.38	1.58	0.03	0.41	1.67	0.03	191.9	0.999
T5_004059.LAB	2/15/2023	12:00:29	5.34	0.41	1.58	0.02	0.43	1.67	0.02	191.7	0.999
T5_004060.LAB	2/15/2023	12:01:28	5.32	0.39	1.59	0.02	0.41	1.67	0.02	191.8	1.000
T5_004061.LAB	2/15/2023	12:02:28	5.30	0.38	1.58	-0.04	0.41	1.67	-0.04	191.8	1.001
T5_004062.LAB	2/15/2023	12:03:28	5.31	0.42	1.59	-0.01	0.44	1.68	-0.01	191.8	1.001
T5_004063.LAB	2/15/2023	12:04:28	5.31	0.40	1.62	-0.03	0.42	1.71	-0.03	191.7	1.000
T5_004064.LAB	2/15/2023	12:05:28	5.30	0.42	1.64	0.05	0.44	1.73	0.06	191.7	0.998
T5_004065.LAB	2/15/2023	12:06:28	5.29	0.43	1.62	0.10	0.46	1.71	0.11	191.7	0.999
T5_004066.LAB	2/15/2023	12:07:28	5.31	0.40	1.61	0.03	0.42	1.71	0.03	191.8	0.998
T5_004067.LAB	2/15/2023	12:08:28	5.29	0.38	1.58	0.03	0.40	1.67	0.03	191.8	0.999
T5_004068.LAB	2/15/2023	12:09:28	5.30	0.37	1.57	-0.02	0.39	1.66	-0.02	191.8	1.000
T5_004069.LAB	2/15/2023	12:10:28	5.29	0.39	1.57	0.06	0.42	1.66	0.06	191.7	1.000
T5_004070.LAB	2/15/2023	12:11:28	5.29	0.38	1.58	-0.04	0.40	1.67	-0.04	191.6	1.001
T5_004071.LAB	2/15/2023	12:12:28	5.28	0.41	1.57	-0.01	0.44	1.66	-0.01	191.6	1.001
T5_004072.LAB	2/15/2023	12:13:28	5.29	0.40	1.61	-0.04	0.42	1.70	-0.04	191.7	1.001
T5_004073.LAB	2/15/2023	12:14:28	5.30	0.41	1.66	0.11	0.43	1.75	0.12	191.8	1.001
T5_004074.LAB	2/15/2023	12:15:27	5.30	0.40	1.66	-0.05	0.43	1.75	-0.05	191.8	0.999
T5_004075.LAB	2/15/2023	12:16:28	5.29	0.41	1.62	0.09	0.43	1.72	0.09	191.6	0.998
T5_004076.LAB	2/15/2023	12:17:27	5.29	0.39	1.60	-0.05	0.41	1.69	-0.05	191.6	0.997
T5_004077.LAB	2/15/2023	12:18:27	5.29	0.38	1.57	0.01	0.41	1.66	0.01	191.6	1.000
T5_004078.LAB	2/15/2023	12:19:27	5.29	0.42	1.59	0.04	0.44	1.68	0.04	191.8	0.999
T5_004079.LAB	2/15/2023	12:20:27	5.30	0.38	1.58	0.01	0.40	1.66	0.01	191.9	1.000
T5_004080.LAB	2/15/2023	12:21:27	5.29	0.40	1.56	0.08	0.42	1.65	0.09	191.9	1.002
T5_004081.LAB	2/15/2023	12:22:27	5.29	0.40	1.55	0.03	0.42	1.63	0.04	191.7	1.002
T5_004082.LAB	2/15/2023	12:23:27	5.32	0.39	1.61	-0.03	0.41	1.70	-0.03	191.7	1.000
T5_004083.LAB	2/15/2023	12:24:27	5.31	0.42	1.65	-0.02	0.44	1.74	-0.02	191.6	0.999
T5_004084.LAB	2/15/2023	12:25:27	5.31	0.46	1.66	-0.01	0.49	1.75	-0.01	191.7	0.999
T5_004085.LAB	2/15/2023	12:26:27	5.32	0.40	1.62	0.09	0.42	1.71	0.09	191.7	0.999
T5_004086.LAB	2/15/2023	12:27:27	5.34	0.37	1.60	0.04	0.39	1.69	0.04	191.9	0.999
T5_004087.LAB	2/15/2023	12:28:27	5.34	0.36	1.58	0.01	0.38	1.67	0.02	191.8	0.998
T5_004088.LAB	2/15/2023	12:29:27	5.32	0.43	1.58	'0.13	0.45	1.67	0.14	191.7	0.998
T5_004089.LAB	2/15/2023	12:30:27	5.30	0.42	1.55	0.03	0.44	1.64	0.03	191.7	1.001
02/15/2023			Minimum	5.28	0.29	1.44	-0.05	0.31	1.52	-0.05	
Turbine 5 - Run 7			Maximum	5.34	0.46	1.66	0.14	0.49	1.75	0.15	
11:15 - 11:45; 12:00 -			Average	5.31	0.37	1.56	0.04	0.39	1.64	0.04	

APPENDIX

FTIR QA/QC Data

Nitrogen (Zero) Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_N2_DIR_000629BKG.LAB	2/7/2023	7:39:14	0.00	0.00	0.00	0.00	0.00	0.00
T4_N2_DIR_000630.LAB	2/7/2023	7:39:27	0.00	-0.02	0.00	-0.14	-0.02	0.00
T4_N2_DIR_000631.LAB	2/7/2023	7:39:34	0.00	0.01	0.01	0.31	0.20	0.00
T4_N2_DIR_000632.LAB	2/7/2023	7:39:42	0.00	-0.02	0.01	0.17	0.14	0.00
T4_N2_DIR_000633.LAB	2/7/2023	7:39:49	0.00	-0.01	0.00	-0.08	-0.15	0.00
T4_N2_DIR_000634.LAB	2/7/2023	7:39:57	0.01	-0.03	0.01	-0.08	0.11	0.01
T4_N2_DIR_000635.LAB	2/7/2023	7:40:04	0.00	0.01	0.03	0.06	0.08	0.00
T4_N2_DIR_000636.LAB	2/7/2023	7:40:12	0.02	-0.01	-0.04	0.10	0.04	0.00
T4_N2_DIR_000637.LAB	2/7/2023	7:40:19	0.00	0.03	-0.02	-0.21	0.06	0.00

CTS, 100.2 ppm Ethylene/5.000 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_DIR_000640.LAB	2/7/2023	7:41:15	0.00	-0.12	0.05	0.10	100.27	5.08	100.1%
T4_CTS_DIR_000641.LAB	2/7/2023	7:41:22	0.01	-0.04	-0.04	0.14	100.85	5.11	100.6%
T4_CTS_DIR_000642.LAB	2/7/2023	7:41:29	0.01	-0.02	0.07	0.10	100.90	5.11	100.7%
T4_CTS_DIR_000643.LAB	2/7/2023	7:41:37	0.01	-0.03	-0.03	0.02	101.22	5.11	101.0%
T4_CTS_DIR_000644.LAB	2/7/2023	7:41:44	0.01	-0.03	0.03	0.26	101.06	5.11	100.9%
T4_CTS_DIR_000645.LAB	2/7/2023	7:41:52	0.01	-0.10	-0.01	0.11	100.48	5.11	100.3%
T4_CTS_DIR_000646.LAB	2/7/2023	7:41:59	0.00	0.08	0.01	-0.05	100.72	5.10	100.5%
T4_CTS_DIR_000647.LAB	2/7/2023	7:42:07	0.00	-0.01	0.00	-0.08	101.20	5.11	101.0%
Average							100.84		

19.71 ppm Formaldehyde/4.97 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_HCHO_DIR_000659.LAB	2/7/2023	7:50:57	0.00	-0.08	0.00	16.20	-0.36	5.02
T4_HCHO_DIR_000660.LAB	2/7/2023	7:51:04	0.01	-0.18	0.01	16.30	-0.36	5.02
T4_HCHO_DIR_000661.LAB	2/7/2023	7:51:11	0.01	-0.12	0.00	16.09	-0.31	5.01
T4_HCHO_DIR_000662.LAB	2/7/2023	7:51:19	0.00	-0.04	-0.04	16.22	-0.30	5.01
T4_HCHO_DIR_000663.LAB	2/7/2023	7:51:27	0.00	-0.12	-0.08	16.16	-0.66	5.02
T4_HCHO_DIR_000664.LAB	2/7/2023	7:51:34	0.01	-0.19	-0.06	16.10	-0.19	5.03
T4_HCHO_DIR_000665.LAB	2/7/2023	7:51:41	0.00	-0.15	-0.04	16.47	-0.26	5.02
T4_HCHO_DIR_000666.LAB	2/7/2023	7:51:49	0.00	-0.12	0.03	16.15	-0.38	5.03
Average						16.21		5.02

99.9 ppm HCl/5.00 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_HCL_DIR_000668.LAB	2/7/2023	7:59:05	-0.01	95.74	0.18	-0.14	-0.31	4.98
T4_HCL_DIR_000669.LAB	2/7/2023	7:59:12	0.01	97.66	0.14	0.18	-0.30	4.97
T4_HCL_DIR_000670.LAB	2/7/2023	7:59:20	0.01	97.71	0.22	0.20	-0.29	4.97
T4_HCL_DIR_000671.LAB	2/7/2023	7:59:27	0.00	97.63	0.18	0.11	-0.16	4.99
T4_HCL_DIR_000672.LAB	2/7/2023	7:59:35	0.01	97.84	0.22	0.40	-0.43	4.98
T4_HCL_DIR_000673.LAB	2/7/2023	7:59:42	0.00	96.11	0.15	0.10	-0.34	4.99
T4_HCL_DIR_000674.LAB	2/7/2023	7:59:50	-0.01	96.13	0.16	0.09	-0.26	4.97
T4_HCL_DIR_000675.LAB	2/7/2023	7:59:57	0.00	95.98	0.15	-0.02	-0.21	4.99
Average				96.85				4.98

111.2 ppm HF/4.999 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_HF_DIR_000709.LAB	2/7/2023	8:18:47	0.00	1.20	103.19	-0.17	-0.48	4.97
T4_HF_DIR_000710.LAB	2/7/2023	8:18:55	0.00	1.29	103.09	0.09	-0.06	4.96
T4_HF_DIR_000711.LAB	2/7/2023	8:19:02	0.01	1.22	102.59	-0.04	-0.08	4.98
T4_HF_DIR_000712.LAB	2/7/2023	8:19:10	0.00	1.13	102.54	0.04	-0.02	4.98
T4_HF_DIR_000713.LAB	2/7/2023	8:19:17	0.00	1.17	102.87	-0.22	-0.37	4.98
T4_HF_DIR_000714.LAB	2/7/2023	8:19:25	0.01	1.13	102.71	0.21	-0.20	4.97
T4_HF_DIR_000715.LAB	2/7/2023	8:19:32	0.00	1.03	102.61	-0.01	-0.17	4.97
T4_HF_DIR_000716.LAB	2/7/2023	8:19:40	0.00	1.05	102.88	0.13	-0.14	4.97
Average					102.81			4.97

100.2 ppm Ethylene/5.000 ppm SF6 System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T4_CTS_RT_000717.LAB	2/7/2023	8:23:08	5.61	1.07	2.52	-0.08	0.07	0.04	0.1%	-
T4_CTS_RT_000718.LAB	2/7/2023	8:23:15	4.89	1.17	2.30	0.23	1.54	0.16	1.5%	8
T4_CTS_RT_000719.LAB	2/7/2023	8:23:22	0.21	0.24	0.20	0.46	89.38	4.77	88.6%	16
T4_CTS_RT_000720.LAB	2/7/2023	8:23:30	0.04	0.18	0.03	0.24	101.58	5.14	100.7%	23
T4_CTS_RT_000721.LAB	2/7/2023	8:23:37	0.02	0.28	0.06	-0.07	101.73	5.14	100.9%	
T4_CTS_RT_000722.LAB	2/7/2023	8:23:45	0.03	0.23	0.06	0.12	101.80	5.15	101.0%	
T4_CTS_RT_000723.LAB	2/7/2023	8:23:52	0.02	0.09	-0.01	-0.20	101.92	5.17	101.1%	
T4_CTS_RT_000724.LAB	2/7/2023	8:24:00	0.00	0.09	-0.01	0.15	101.81	5.17	101.0%	
T4_CTS_RT_000725.LAB	2/7/2023	8:24:07	0.02	0.12	0.00	0.02	100.23	5.11	99.4%	
T4_CTS_RT_000726.LAB	2/7/2023	8:24:15	0.01	0.13	-0.01	0.21	101.47	5.15	100.6%	
T4_CTS_RT_000727.LAB	2/7/2023	8:24:22	0.02	0.18	0.00	0.00	100.83	5.14	100.0%	

Nitrogen (Zero) System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T4_N2_RT_000728.LAB	2/7/2023	8:24:49	0.01	0.10	0.01	0.17	101.40	5.13	100.6%	-
T4_N2_RT_000729.LAB	2/7/2023	8:24:57	0.52	0.25	0.44	-0.10	81.41	4.17	80.7%	8
T4_N2_RT_000730.LAB	2/7/2023	8:25:04	0.10	0.33	0.18	0.02	2.64	0.13	2.6%	15
T4_N2_RT_000731.LAB	2/7/2023	8:25:12	0.02	0.16	-0.02	-0.11	0.24	0.01	0.2%	23
T4_N2_RT_000732.LAB	2/7/2023	8:25:19	0.02	0.15	0.02	-0.01	0.15	0.01	0.1%	
T4_N2_RT_000733.LAB	2/7/2023	8:25:27	0.01	0.09	0.01	-0.08	0.08	0.00	0.1%	
T4_N2_RT_000734.LAB	2/7/2023	8:25:34	0.02	0.08	-0.06	-0.04	-0.03	0.00	0.0%	
T4_N2_RT_000735.LAB	2/7/2023	8:25:42	0.01	0.14	-0.07	0.04	-0.01	0.00	0.0%	
T4_N2_RT_000736.LAB	2/7/2023	8:25:49	0.01	0.13	-0.03	0.01	-0.05	0.00	0.0%	
T4_N2_RT_000737.LAB	2/7/2023	8:25:56	0.01	0.06	-0.01	0.04	-0.33	0.01	-0.3%	
T4_N2_RT_000738.LAB	2/7/2023	8:26:04	0.01	0.01	-0.01	-0.08	0.13	-0.01	0.1%	
Average			0.01	0.10	-0.02	-0.03	0.02	0.00		

Turbine 4 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_000739.LAB	2/7/2023	8:27:33	5.63	1.08	2.46	0.09	0.24	0.00
T4_000740.LAB	2/7/2023	8:28:33	5.63	1.02	2.21	-0.05	0.25	0.00
T4_000741.LAB	2/7/2023	8:29:33	5.63	1.03	2.13	0.08	0.17	0.00
Average			1.04			0.04		0.00

Turbine 4 Analyte Spike, Using 19.71 ppm Formaldehyde/4.97 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	Formaldehyde Recovery %
T4_HCHO_SPK_000766.LAB	2/7/2023	8:33:22	5.18	0.86	1.95	1.30	0.15	0.39	0.077	100.6%
T4_HCHO_SPK_000767.LAB	2/7/2023	8:33:29	5.18	0.84	1.97	1.21	0.21	0.39	0.078	93.3%
T4_HCHO_SPK_000768.LAB	2/7/2023	8:33:37	5.17	1.00	1.88	1.10	0.11	0.39	0.078	84.6%
T4_HCHO_SPK_000769.LAB	2/7/2023	8:33:44	5.17	0.83	1.91	1.10	0.10	0.39	0.077	85.6%
T4_HCHO_SPK_000770.LAB	2/7/2023	8:33:51	5.18	0.78	1.96	1.36	0.19	0.39	0.077	106.0%
T4_HCHO_SPK_000771.LAB	2/7/2023	8:33:59	5.20	0.78	1.91	1.14	0.02	0.38	0.076	89.5%
T4_HCHO_SPK_000772.LAB	2/7/2023	8:34:06	5.19	0.94	1.95	1.40	0.23	0.38	0.077	109.2%
T4_HCHO_SPK_000773.LAB	2/7/2023	8:34:14	5.17	0.94	1.89	1.16	0.11	0.39	0.078	88.6%
Spike Average										94.7%

Turbine 4 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_000775.LAB	2/7/2023	8:36:51	5.61	0.92	1.93	0.01	0.17	0.00
T4_000776.LAB	2/7/2023	8:37:51	5.63	0.86	1.95	-0.07	0.14	0.00
T4_000777.LAB	2/7/2023	8:38:51	5.61	0.90	1.91	-0.08	0.16	0.00
Average			0.89			-0.04		0.00

Turbine 4 Analyte Spike, Using 99.9 ppm HCl/5.00 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HCl Recovery %
T4_HCL_SPK_000831.LAB	2/7/2023	8:46:31	5.17	8.19	1.99	0.29	0.10	0.42	0.084	91.2%
T4_HCL_SPK_000832.LAB	2/7/2023	8:46:38	5.13	8.30	2.05	0.04	0.15	0.40	0.081	96.1%
T4_HCL_SPK_000833.LAB	2/7/2023	8:46:46	5.17	8.20	2.04	0.04	0.01	0.41	0.083	92.6%
T4_HCL_SPK_000834.LAB	2/7/2023	8:46:53	5.16	8.39	2.05	0.14	0.20	0.42	0.084	93.9%
T4_HCL_SPK_000835.LAB	2/7/2023	8:47:01	5.15	8.16	2.00	0.05	0.06	0.42	0.084	91.0%
T4_HCL_SPK_000836.LAB	2/7/2023	8:47:08	5.12	8.19	2.00	0.04	0.07	0.41	0.082	94.0%
T4_HCL_SPK_000837.LAB	2/7/2023	8:47:16	5.15	8.25	1.99	0.07	0.01	0.42	0.084	92.0%
T4_HCL_SPK_000838.LAB	2/7/2023	8:47:23	5.19	8.32	2.03	0.31	-0.03	0.42	0.085	92.3%
Spike Average										92.9%

Turbine 4 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_000839.LAB	2/7/2023	8:49:41	5.63	1.72	1.69	0.03	0.16	0.00
T4_000840.LAB	2/7/2023	8:50:41	5.62	1.42	1.67	-0.01	0.18	0.00
T4_000841.LAB	2/7/2023	8:51:41	5.63	1.27	1.68	0.03	0.17	0.00
Average					1.68			0.00

Turbine 4 Analyte Spike, Using 111.2 ppm HF/4.999 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HF Recovery %
T4_HF_SPK_001083.LAB	2/7/2023	9:22:22	5.16	0.71	9.03	0.06	0.11	0.41	0.082	90.3%
T4_HF_SPK_001084.LAB	2/7/2023	9:22:30	5.11	0.63	9.09	-0.14	-0.01	0.41	0.081	91.7%
T4_HF_SPK_001085.LAB	2/7/2023	9:22:37	5.17	0.56	9.07	0.10	0.05	0.42	0.084	89.2%
T4_HF_SPK_001086.LAB	2/7/2023	9:22:44	5.14	0.59	9.07	-0.10	0.36	0.41	0.081	91.5%
T4_HF_SPK_001087.LAB	2/7/2023	9:22:52	5.12	0.63	9.01	0.09	0.11	0.40	0.080	92.5%
T4_HF_SPK_001088.LAB	2/7/2023	9:23:00	5.16	0.63	9.10	-0.03	0.12	0.41	0.082	91.2%
T4_HF_SPK_001089.LAB	2/7/2023	9:23:07	5.11	0.66	9.08	-0.01	0.18	0.41	0.082	90.6%
T4_HF_SPK_001090.LAB	2/7/2023	9:23:14	5.16	0.69	9.04	0.12	0.15	0.41	0.081	91.6%
Spike Average										91.1%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001091.LAB	2/7/2023	9:24:48	0.02	0.10	0.04	-0.06	100.20	5.09	99.4%
T4_CTS_SYS_001092.LAB	2/7/2023	9:24:55	0.02	0.13	0.08	-0.02	100.64	5.11	99.8%
T4_CTS_SYS_001093.LAB	2/7/2023	9:25:03	0.03	0.02	0.03	0.17	101.30	5.12	100.5%
T4_CTS_SYS_001094.LAB	2/7/2023	9:25:10	0.01	-0.03	0.04	-0.06	101.28	5.11	100.4%
T4_CTS_SYS_001095.LAB	2/7/2023	9:25:18	0.01	0.06	0.00	0.15	100.27	5.10	99.4%
T4_CTS_SYS_001096.LAB	2/7/2023	9:25:25	0.00	0.01	-0.05	0.06	100.87	5.09	100.0%
T4_CTS_SYS_001097.LAB	2/7/2023	9:25:33	0.01	-0.02	0.03	-0.03	100.88	5.12	100.0%
T4_CTS_SYS_001098.LAB	2/7/2023	9:25:40	0.00	-0.09	0.00	-0.12	100.85	5.11	100.0%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001247.LAB	2/7/2023	11:54:44	0.05	0.04	-0.05	-0.03	100.68	5.11	99.8%
T4_CTS_SYS_001248.LAB	2/7/2023	11:54:51	0.04	0.09	0.00	-0.13	100.74	5.10	99.9%
T4_CTS_SYS_001249.LAB	2/7/2023	11:54:59	0.03	0.06	-0.05	0.01	100.47	5.11	99.6%
T4_CTS_SYS_001250.LAB	2/7/2023	11:55:06	0.03	0.10	-0.07	-0.15	101.13	5.12	100.3%
T4_CTS_SYS_001251.LAB	2/7/2023	11:55:14	0.02	-0.03	-0.12	-0.09	100.88	5.13	100.0%
T4_CTS_SYS_001252.LAB	2/7/2023	11:55:21	0.02	0.00	-0.08	-0.24	101.15	5.13	100.3%
T4_CTS_SYS_001253.LAB	2/7/2023	11:55:29	0.02	0.14	-0.05	-0.04	101.66	5.15	100.8%
T4_CTS_SYS_001254.LAB	2/7/2023	11:55:36	0.02	0.02	-0.06	-0.05	101.32	5.13	100.5%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001329.LAB	2/7/2023	13:10:33	0.02	-0.02	-0.08	-0.02	100.80	5.11	100.0%
T4_CTS_SYS_001330.LAB	2/7/2023	13:10:41	0.02	0.01	-0.06	0.09	101.19	5.13	100.3%
T4_CTS_SYS_001331.LAB	2/7/2023	13:10:48	0.02	0.03	-0.03	-0.17	101.37	5.12	100.5%
T4_CTS_SYS_001332.LAB	2/7/2023	13:10:56	0.01	0.05	-0.04	-0.12	101.04	5.12	100.2%
T4_CTS_SYS_001333.LAB	2/7/2023	13:11:03	0.01	0.03	-0.10	-0.24	101.23	5.14	100.4%
T4_CTS_SYS_001334.LAB	2/7/2023	13:11:11	0.01	-0.07	-0.07	0.03	101.01	5.12	100.2%
T4_CTS_SYS_001335.LAB	2/7/2023	13:11:18	0.02	-0.08	-0.09	-0.07	101.55	5.13	100.7%
T4_CTS_SYS_001336.LAB	2/7/2023	13:11:26	0.01	0.00	-0.08	0.11	101.40	5.12	100.6%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001401.LAB	2/7/2023	14:16:23	0.02	0.07	-0.05	0.15	100.71	5.12	99.9%
T4_CTS_SYS_001402.LAB	2/7/2023	14:16:31	0.02	-0.12	-0.09	0.08	100.76	5.12	99.9%
T4_CTS_SYS_001403.LAB	2/7/2023	14:16:38	0.02	0.08	-0.08	-0.11	101.64	5.13	100.8%
T4_CTS_SYS_001404.LAB	2/7/2023	14:16:46	0.02	0.01	-0.07	0.22	100.70	5.11	99.9%
T4_CTS_SYS_001405.LAB	2/7/2023	14:16:53	0.01	-0.01	-0.06	-0.02	100.82	5.11	100.0%
T4_CTS_SYS_001406.LAB	2/7/2023	14:17:01	0.02	-0.09	-0.12	-0.07	101.52	5.13	100.7%
T4_CTS_SYS_001407.LAB	2/7/2023	14:17:08	0.00	-0.07	-0.12	0.07	100.99	5.12	100.2%
T4_CTS_SYS_001408.LAB	2/7/2023	14:17:16	0.00	0.07	-0.08	-0.13	101.06	5.12	100.2%

Nitrogen (Zero) System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_N2_SYS_001409.LAB	2/7/2023	14:17:53	0.01	0.03	-0.10	0.13	-0.01	0.00
T4_N2_SYS_001410.LAB	2/7/2023	14:18:00	0.01	-0.09	-0.05	-0.03	-0.08	0.00
T4_N2_SYS_001411.LAB	2/7/2023	14:18:07	0.00	-0.05	-0.09	0.02	-0.10	0.01
T4_N2_SYS_001412.LAB	2/7/2023	14:18:15	0.01	-0.08	-0.10	0.16	0.16	0.00
T4_N2_SYS_001413.LAB	2/7/2023	14:18:22	0.00	0.03	-0.10	0.11	0.19	0.00
T4_N2_SYS_001414.LAB	2/7/2023	14:18:30	0.01	-0.04	-0.12	0.09	-0.03	0.00
T4_N2_SYS_001415.LAB	2/7/2023	14:18:38	0.00	0.00	-0.06	0.03	0.05	0.00
T4_N2_SYS_001416.LAB	2/7/2023	14:18:45	0.02	0.00	-0.04	-0.09	-0.03	0.00
Average			0.01	-0.03	-0.08	0.05	0.02	0.00

Nitrogen Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_N2_DIR_001417.LAB	2/7/2023	14:23:09	0.00	-0.04	-0.09	0.00	-0.11	0.00
T4_N2_DIR_001418.LAB	2/7/2023	14:25:10	0.00	-0.05	-0.09	0.07	-0.08	0.00
T4_N2_DIR_001419.LAB	2/7/2023	14:27:09	0.00	-0.03	-0.09	-0.08	-0.05	0.00

Nitrogen (Zero) Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_N2_DIR_001422.LAB	2/8/2023	7:18:11	0.00	-0.02	-0.06	0.01	-0.01	0.00
T4_N2_DIR_001423BKG.LAB	2/8/2023	7:20:17	0.00	0.00	0.00	0.00	0.00	0.00
T4_N2_DIR_001424.LAB	2/8/2023	7:20:30	0.00	-0.13	-0.02	0.19	0.11	-0.01
T4_N2_DIR_001425.LAB	2/8/2023	7:20:38	0.00	0.01	0.04	-0.15	0.03	-0.01
T4_N2_DIR_001426.LAB	2/8/2023	7:20:45	0.01	0.10	-0.01	0.26	-0.22	0.00
T4_N2_DIR_001427.LAB	2/8/2023	7:20:53	0.01	0.00	0.03	0.28	0.04	0.00
T4_N2_DIR_001428.LAB	2/8/2023	7:21:00	-0.01	-0.04	-0.03	0.01	-0.01	0.00
T4_N2_DIR_001429.LAB	2/8/2023	7:21:08	0.00	-0.03	-0.02	-0.24	0.02	-0.01
T4_N2_DIR_001430.LAB	2/8/2023	7:21:15	0.00	-0.05	-0.04	-0.09	-0.02	0.00
T4_N2_DIR_001431.LAB	2/8/2023	7:21:23	-0.01	-0.01	0.00	-0.06	0.05	0.00

CTS, 100.2 ppm Ethylene/5.000 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_DIR_001434.LAB	2/8/2023	7:22:24	0.00	0.01	0.04	-0.19	100.92	5.12	100.7%
T4_CTS_DIR_001435.LAB	2/8/2023	7:22:32	0.01	0.06	0.08	0.35	100.94	5.12	100.7%
T4_CTS_DIR_001436.LAB	2/8/2023	7:22:39	0.01	0.03	0.08	0.05	101.33	5.16	101.1%
T4_CTS_DIR_001437.LAB	2/8/2023	7:22:47	0.00	0.02	0.04	-0.05	100.80	5.12	100.6%
T4_CTS_DIR_001438.LAB	2/8/2023	7:22:54	0.01	0.06	-0.01	-0.21	100.67	5.12	100.5%
T4_CTS_DIR_001439.LAB	2/8/2023	7:23:02	0.01	-0.01	0.04	-0.01	100.75	5.11	100.5%
T4_CTS_DIR_001440.LAB	2/8/2023	7:23:09	0.01	-0.07	0.00	0.12	100.85	5.12	100.6%
T4_CTS_DIR_001441.LAB	2/8/2023	7:23:16	0.01	0.14	-0.01	0.15	100.74	5.12	100.5%
Average							100.87		

19.71 ppm Formaldehyde/4.97 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_HCHO_DIR_001472.LAB	2/8/2023	7:27:44	0.00	-0.06	0.01	16.15	-0.29	5.04
T4_HCHO_DIR_001473.LAB	2/8/2023	7:27:52	0.00	0.03	-0.05	16.26	-0.23	5.04
T4_HCHO_DIR_001474.LAB	2/8/2023	7:27:59	-0.01	-0.11	-0.01	16.16	-0.06	5.04
T4_HCHO_DIR_001475.LAB	2/8/2023	7:28:07	-0.01	-0.05	-0.02	16.27	-0.13	5.03
T4_HCHO_DIR_001476.LAB	2/8/2023	7:28:14	0.00	-0.10	0.03	16.21	-0.36	5.05
T4_HCHO_DIR_001477.LAB	2/8/2023	7:28:22	0.00	-0.05	0.01	16.22	0.02	5.05
T4_HCHO_DIR_001478.LAB	2/8/2023	7:28:29	0.00	-0.13	0.03	16.24	-0.27	5.05
T4_HCHO_DIR_001479.LAB	2/8/2023	7:28:37	0.00	-0.18	0.00	15.97	0.09	5.03
Average						16.19		5.04

99.9 ppm HCl/5.00 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_HCL_DIR_001486.LAB	2/8/2023	7:33:31	0.00	101.76	0.24	0.39	0.07	5.00
T4_HCL_DIR_001487.LAB	2/8/2023	7:33:38	0.00	101.86	0.21	0.29	-0.10	4.99
T4_HCL_DIR_001488.LAB	2/8/2023	7:33:46	0.00	99.41	0.17	0.46	0.15	5.00
T4_HCL_DIR_001489.LAB	2/8/2023	7:33:53	0.00	99.46	0.22	0.13	-0.29	5.00
T4_HCL_DIR_001490.LAB	2/8/2023	7:34:01	0.00	101.72	0.14	0.22	-0.17	5.00
T4_HCL_DIR_001491.LAB	2/8/2023	7:34:08	-0.01	99.81	0.20	0.11	-0.27	5.01
T4_HCL_DIR_001492.LAB	2/8/2023	7:34:16	0.00	99.60	0.21	0.32	-0.12	5.00
T4_HCL_DIR_001493.LAB	2/8/2023	7:34:23	0.00	101.85	0.24	0.17	-0.01	5.01
Average				100.68				5.00

111.2 ppm HF/4.999 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_HF_DIR_001508.LAB	2/8/2023	7:47:13	0.00	0.61	106.77	0.07	-0.08	4.95
T4_HF_DIR_001509.LAB	2/8/2023	7:47:20	0.00	0.59	106.09	-0.38	-0.06	4.97
T4_HF_DIR_001510.LAB	2/8/2023	7:47:28	0.00	0.60	105.96	-0.06	0.00	4.97
T4_HF_DIR_001511.LAB	2/8/2023	7:47:35	0.00	0.58	106.22	0.05	-0.32	4.97
T4_HF_DIR_001512.LAB	2/8/2023	7:47:43	-0.01	0.62	106.37	0.04	-0.27	4.97
T4_HF_DIR_001513.LAB	2/8/2023	7:47:50	0.00	0.56	105.99	0.00	-0.14	4.97
T4_HF_DIR_001514.LAB	2/8/2023	7:47:58	-0.01	0.57	105.93	-0.06	-0.12	4.95
T4_HF_DIR_001515.LAB	2/8/2023	7:48:05	0.01	0.56	106.14	0.02	-0.33	4.97
Average					106.18			4.97

100.2 ppm Ethylene/5.000 ppm SF6 System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T4_CTS_RT_001516.LAB	2/8/2023	7:51:31	5.58	0.52	2.19	0.12	0.32	0.03	0.3%	-
T4_CTS_RT_001517.LAB	2/8/2023	7:51:39	4.91	0.46	1.94	-0.09	2.29	0.13	2.3%	8
T4_CTS_RT_001518.LAB	2/8/2023	7:51:46	0.20	0.19	0.23	0.23	92.50	4.69	91.7%	15
T4_CTS_RT_001519.LAB	2/8/2023	7:51:54	0.03	0.01	0.08	-0.22	101.16	5.19	100.3%	23
T4_CTS_RT_001520.LAB	2/8/2023	7:52:01	0.02	0.10	0.08	0.07	101.17	5.16	100.3%	
T4_CTS_RT_001521.LAB	2/8/2023	7:52:09	0.01	-0.02	0.06	0.18	101.15	5.14	100.3%	
T4_CTS_RT_001522.LAB	2/8/2023	7:52:16	0.01	0.17	-0.01	0.00	101.44	5.16	100.6%	
T4_CTS_RT_001523.LAB	2/8/2023	7:52:24	0.01	0.18	0.02	-0.03	102.28	5.18	101.4%	
T4_CTS_RT_001524.LAB	2/8/2023	7:52:31	-0.01	0.13	0.08	-0.17	101.70	5.19	100.8%	
T4_CTS_RT_001525.LAB	2/8/2023	7:52:39	-0.01	0.10	0.00	-0.13	101.74	5.15	100.9%	
T4_CTS_RT_001526.LAB	2/8/2023	7:52:46	0.02	0.12	0.00	-0.20	101.30	5.15	100.4%	

Nitrogen (Zero) System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T4_N2_RT_001527.LAB	2/8/2023	7:53:14	0.01	0.11	-0.02	-0.06	101.87	5.15	101.0%	-
T4_N2_RT_001528.LAB	2/8/2023	7:53:21	1.00	0.09	0.78	-0.17	66.95	3.48	66.4%	8
T4_N2_RT_001529.LAB	2/8/2023	7:53:28	0.09	0.08	0.19	-0.12	2.68	0.13	2.7%	15
T4_N2_RT_001530.LAB	2/8/2023	7:53:36	0.02	0.02	0.04	0.12	0.45	0.01	0.4%	23
T4_N2_RT_001531.LAB	2/8/2023	7:53:43	0.00	0.04	0.05	0.15	0.24	0.00	0.2%	
T4_N2_RT_001532.LAB	2/8/2023	7:53:51	0.00	0.09	0.01	-0.05	0.17	-0.01	0.2%	
T4_N2_RT_001533.LAB	2/8/2023	7:53:58	0.01	0.03	0.06	-0.30	0.11	0.00	0.1%	
T4_N2_RT_001534.LAB	2/8/2023	7:54:06	-0.01	0.03	-0.01	-0.26	0.18	0.01	0.2%	
T4_N2_RT_001535.LAB	2/8/2023	7:54:13	0.00	-0.06	0.03	-0.36	0.10	0.00	0.1%	
T4_N2_RT_001536.LAB	2/8/2023	7:54:21	0.00	0.02	0.02	0.07	0.18	-0.01	0.2%	
T4_N2_RT_001537.LAB	2/8/2023	7:54:28	0.01	0.00	-0.01	0.05	0.17	0.00	0.2%	
Average			0.00	0.02	0.02	-0.07	0.20	0.00		

Turbine 4 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_001538.LAB	2/8/2023	7:55:49	5.58	0.44	1.94	0.02	0.28	0.00
T4_001539.LAB	2/8/2023	7:56:49	5.62	0.44	1.74	0.07	0.35	0.00
T4_001540.LAB	2/8/2023	7:57:50	5.65	0.41	1.64	-0.01	0.25	0.00
Average			0.43		0.03		0.00	

Turbine 4 Analyte Spike, Using 19.71 ppm Formaldehyde/4.97 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	Formaldehyde Recovery %
T4_HCHO_SPK_001556.LAB	2/8/2023	8:00:40	5.14	0.26	1.44	1.56	0.35	0.44	0.088	107.8%
T4_HCHO_SPK_001557.LAB	2/8/2023	8:00:47	5.17	0.30	1.32	1.52	0.13	0.44	0.088	105.0%
T4_HCHO_SPK_001558.LAB	2/8/2023	8:00:55	5.13	0.30	1.41	1.24	0.24	0.44	0.086	87.4%
T4_HCHO_SPK_001559.LAB	2/8/2023	8:01:02	5.15	0.21	1.40	1.47	0.29	0.44	0.088	101.9%
T4_HCHO_SPK_001560.LAB	2/8/2023	8:01:10	5.14	0.27	1.39	1.61	0.33	0.44	0.087	112.6%
T4_HCHO_SPK_001561.LAB	2/8/2023	8:01:17	5.17	0.34	1.43	1.59	0.23	0.43	0.086	112.2%
T4_HCHO_SPK_001562.LAB	2/8/2023	8:01:25	5.15	0.24	1.43	1.75	0.22	0.44	0.087	122.0%
T4_HCHO_SPK_001563.LAB	2/8/2023	8:01:32	5.17	0.35	1.37	1.54	0.37	0.44	0.088	105.9%
Spike Average										106.8%

Turbine 4 Analyte Spike, Using 99.9 ppm HCl/5.00 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HCl Recovery %
T4_HCL_SPK_001609.LAB	2/8/2023	8:08:22	5.14	8.15	1.78	-0.05	0.07	0.42	0.084	92.0%
T4_HCL_SPK_001610.LAB	2/8/2023	8:08:30	5.16	8.08	1.74	0.15	0.14	0.42	0.084	91.8%
T4_HCL_SPK_001611.LAB	2/8/2023	8:08:38	5.17	8.07	1.74	0.19	0.06	0.41	0.082	93.0%
T4_HCL_SPK_001612.LAB	2/8/2023	8:08:45	5.15	8.14	1.77	0.13	0.01	0.41	0.082	94.2%
T4_HCL_SPK_001613.LAB	2/8/2023	8:08:53	5.18	8.17	1.72	-0.03	0.07	0.42	0.084	92.7%
T4_HCL_SPK_001614.LAB	2/8/2023	8:09:00	5.18	8.15	1.81	-0.06	0.21	0.42	0.084	92.0%
T4_HCL_SPK_001615.LAB	2/8/2023	8:09:07	5.15	8.22	1.79	0.17	0.20	0.42	0.083	93.5%
T4_HCL_SPK_001616.LAB	2/8/2023	8:09:15	5.15	8.37	1.78	0.01	0.26	0.43	0.085	93.4%
Spike Average										92.8%

Turbine 4 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_HCL_SPK_001618.LAB	2/8/2023	8:11:58	5.65	0.97	1.55	-0.02	0.35	0.00
T4_HCL_SPK_001619.LAB	2/8/2023	8:12:58	5.65	0.77	1.53	-0.05	0.25	0.00
T4_HCL_SPK_001620.LAB	2/8/2023	8:13:58	5.64	0.68	1.55	-0.03	0.26	0.00
Average					1.54		0.00	

Turbine 4 Analyte Spike, Using 111.2 ppm HF/4.999 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HF Recovery %
T4_HF_SPK_001710.LAB	2/8/2023	8:25:41	5.20	0.60	8.91	0.01	0.20	0.40	0.080	89.5%
T4_HF_SPK_001711.LAB	2/8/2023	8:25:48	5.15	0.69	8.96	-0.06	0.28	0.40	0.081	89.3%
T4_HF_SPK_001712.LAB	2/8/2023	8:25:56	5.20	0.68	9.00	-0.05	0.04	0.41	0.082	89.1%
T4_HF_SPK_001713.LAB	2/8/2023	8:26:03	5.23	0.63	9.07	0.13	0.07	0.41	0.082	89.4%
T4_HF_SPK_001714.LAB	2/8/2023	8:26:11	5.18	0.59	9.02	-0.03	0.05	0.40	0.081	90.4%
T4_HF_SPK_001715.LAB	2/8/2023	8:26:18	5.13	0.63	9.05	-0.01	0.28	0.40	0.080	91.3%
T4_HF_SPK_001716.LAB	2/8/2023	8:26:26	5.16	0.54	9.00	0.03	0.14	0.40	0.081	90.2%
T4_HF_SPK_001717.LAB	2/8/2023	8:26:33	5.27	0.64	9.13	0.08	0.05	0.40	0.081	91.3%
Spike Average										
90.0%										

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001718.LAB	2/8/2023	8:28:47	0.02	0.09	0.08	-0.01	100.75	5.09	99.9%
T4_CTS_SYS_001719.LAB	2/8/2023	8:28:55	0.01	0.19	0.07	-0.05	100.39	5.10	99.5%
T4_CTS_SYS_001720.LAB	2/8/2023	8:29:02	0.02	0.16	0.07	0.13	100.96	5.11	100.1%
T4_CTS_SYS_001721.LAB	2/8/2023	8:29:09	0.01	0.21	0.05	0.08	100.83	5.11	100.0%
T4_CTS_SYS_001722.LAB	2/8/2023	8:29:17	0.00	0.12	0.03	-0.12	100.95	5.11	100.1%
T4_CTS_SYS_001723.LAB	2/8/2023	8:29:24	0.01	0.03	0.08	0.20	101.47	5.12	100.6%
T4_CTS_SYS_001724.LAB	2/8/2023	8:29:32	0.01	0.08	0.01	-0.02	100.60	5.09	99.7%
T4_CTS_SYS_001725.LAB	2/8/2023	8:29:39	0.01	0.09	0.11	0.05	101.07	5.10	100.2%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001823.LAB	2/8/2023	10:07:48	0.08	0.07	0.00	0.05	101.15	5.11	100.3%
T4_CTS_SYS_001824.LAB	2/8/2023	10:07:56	0.06	0.11	0.03	0.13	100.71	5.10	99.8%
T4_CTS_SYS_001825.LAB	2/8/2023	10:08:03	0.03	0.10	-0.04	0.07	101.02	5.11	100.1%
T4_CTS_SYS_001826.LAB	2/8/2023	10:08:11	0.02	0.03	-0.01	0.04	100.59	5.12	99.7%
T4_CTS_SYS_001827.LAB	2/8/2023	10:08:18	0.04	0.08	-0.02	0.05	100.87	5.13	100.0%
T4_CTS_SYS_001828.LAB	2/8/2023	10:08:26	0.03	0.10	0.00	-0.03	100.57	5.10	99.7%
T4_CTS_SYS_001829.LAB	2/8/2023	10:08:33	0.02	0.00	0.04	0.11	100.85	5.07	100.0%
T4_CTS_SYS_001830.LAB	2/8/2023	10:08:41	0.01	-0.07	-0.04	0.14	101.68	5.13	100.8%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001901.LAB	2/8/2023	11:19:49	0.04	0.12	-0.03	-0.08	101.09	5.13	100.2%
T4_CTS_SYS_001902.LAB	2/8/2023	11:19:57	0.03	-0.01	-0.03	-0.13	100.64	5.15	99.8%
T4_CTS_SYS_001903.LAB	2/8/2023	11:20:04	0.01	-0.04	-0.03	0.05	100.91	5.12	100.0%
T4_CTS_SYS_001904.LAB	2/8/2023	11:20:12	0.01	0.08	-0.07	0.00	101.02	5.10	100.1%
T4_CTS_SYS_001905.LAB	2/8/2023	11:20:19	0.01	0.06	-0.03	-0.17	101.66	5.14	100.8%
T4_CTS_SYS_001906.LAB	2/8/2023	11:20:27	0.02	-0.01	-0.07	0.00	101.78	5.13	100.9%
T4_CTS_SYS_001907.LAB	2/8/2023	11:20:34	0.01	0.13	-0.04	0.13	100.66	5.11	99.8%
T4_CTS_SYS_001908.LAB	2/8/2023	11:20:42	0.01	0.04	-0.05	-0.07	100.67	5.10	99.8%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_001981.LAB	2/8/2023	12:34:01	0.02	0.00	0.00	0.11	100.70	5.10	99.8%
T4_CTS_SYS_001982.LAB	2/8/2023	12:34:08	0.01	0.09	-0.03	0.14	100.79	5.11	99.9%
T4_CTS_SYS_001983.LAB	2/8/2023	12:34:16	0.01	0.04	-0.03	0.02	102.03	5.16	101.1%
T4_CTS_SYS_001984.LAB	2/8/2023	12:34:23	0.01	0.10	-0.04	-0.11	101.43	5.14	100.6%
T4_CTS_SYS_001985.LAB	2/8/2023	12:34:31	0.01	0.04	-0.01	-0.06	101.81	5.15	100.9%
T4_CTS_SYS_001986.LAB	2/8/2023	12:34:38	-0.01	0.01	-0.01	0.05	101.13	5.10	100.3%
T4_CTS_SYS_001987.LAB	2/8/2023	12:34:46	0.01	0.05	-0.02	-0.02	101.19	5.14	100.3%
T4_CTS_SYS_001988.LAB	2/8/2023	12:34:53	0.01	0.00	-0.01	0.05	101.49	5.14	100.6%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T4_CTS_SYS_002079.LAB	2/8/2023	14:06:17	0.02	0.04	0.00	0.17	101.23	5.11	100.3%
T4_CTS_SYS_002080.LAB	2/8/2023	14:06:25	0.01	0.16	-0.01	-0.10	101.18	5.12	100.3%
T4_CTS_SYS_002081.LAB	2/8/2023	14:06:32	0.02	0.12	0.02	0.06	100.88	5.13	100.0%
T4_CTS_SYS_002082.LAB	2/8/2023	14:06:39	0.00	0.11	0.00	0.13	101.38	5.12	100.5%
T4_CTS_SYS_002083.LAB	2/8/2023	14:06:47	0.00	0.00	-0.04	-0.31	100.91	5.12	100.0%
T4_CTS_SYS_002084.LAB	2/8/2023	14:06:54	0.00	0.12	0.00	0.06	101.20	5.13	100.3%
T4_CTS_SYS_002085.LAB	2/8/2023	14:07:02	0.01	0.14	0.01	0.31	101.29	5.12	100.4%
T4_CTS_SYS_002086.LAB	2/8/2023	14:07:10	0.01	0.10	-0.06	-0.13	101.74	5.12	100.9%

Nitrogen (Zero) System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_N2_SYS_002087.LAB	2/8/2023	14:07:50	0.00	0.09	-0.05	-0.13	-0.07	-0.01
T4_N2_SYS_002088.LAB	2/8/2023	14:07:58	0.00	0.05	-0.04	-0.12	0.21	0.00
T4_N2_SYS_002089.LAB	2/8/2023	14:08:05	0.00	0.11	-0.05	-0.28	0.14	0.00
T4_N2_SYS_002090.LAB	2/8/2023	14:08:13	0.01	0.02	0.04	0.13	-0.08	0.01
T4_N2_SYS_002091.LAB	2/8/2023	14:08:20	0.00	-0.11	-0.06	0.24	-0.04	0.01
T4_N2_SYS_002092.LAB	2/8/2023	14:08:28	0.00	0.00	-0.07	-0.01	0.17	0.00
T4_N2_SYS_002093.LAB	2/8/2023	14:08:35	0.01	0.14	-0.02	-0.08	-0.07	0.00
T4_N2_SYS_002094.LAB	2/8/2023	14:08:43	0.01	0.02	-0.05	0.10	0.02	-0.01
Average			0.01	0.04	-0.04	-0.02	0.04	0.00

Nitrogen Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T4_N2_DIR_002095.LAB	2/8/2023	14:13:38	0.00	0.02	-0.04	0.01	0.04	0.00
T4_N2_DIR_002096.LAB	2/8/2023	14:15:38	0.00	-0.02	-0.02	-0.02	0.11	0.00
T4_N2_DIR_002097.LAB	2/8/2023	14:17:38	0.00	-0.01	-0.04	0.05	0.05	0.00

Nitrogen (Zero) Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_N2_DIR_002881BKG.LAB	2/14/2023	7:29:09	0.00	0.00	0.00	0.00	0.00	0.00
T5_N2_DIR_002882.LAB	2/14/2023	7:29:22	0.00	0.04	-0.02	-0.07	0.05	-0.01
T5_N2_DIR_002883.LAB	2/14/2023	7:29:29	0.00	-0.02	-0.04	-0.04	0.13	0.00
T5_N2_DIR_002884.LAB	2/14/2023	7:29:37	0.00	0.04	-0.04	0.06	0.06	0.00
T5_N2_DIR_002885.LAB	2/14/2023	7:29:44	0.00	0.07	-0.06	0.11	0.01	0.00
T5_N2_DIR_002886.LAB	2/14/2023	7:29:52	0.01	-0.03	-0.06	-0.15	-0.02	-0.01
T5_N2_DIR_002887.LAB	2/14/2023	7:29:59	0.01	0.06	-0.07	0.16	0.12	0.00
T5_N2_DIR_002888.LAB	2/14/2023	7:30:07	0.00	0.04	-0.04	-0.23	-0.06	0.00
T5_N2_DIR_002889.LAB	2/14/2023	7:30:14	0.00	-0.05	-0.02	0.12	-0.08	0.00

CTS, 100.2 ppm Ethylene/5.000 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_DIR_002898.LAB	2/14/2023	7:31:56	0.01	-0.02	0.04	0.21	100.32	5.09	100.1%
T5_CTS_DIR_002899.LAB	2/14/2023	7:32:03	0.00	0.09	-0.01	-0.03	100.76	5.11	100.6%
T5_CTS_DIR_002900.LAB	2/14/2023	7:32:11	0.00	-0.04	-0.04	-0.02	100.45	5.13	100.3%
T5_CTS_DIR_002901.LAB	2/14/2023	7:32:18	0.01	0.01	-0.06	0.17	101.23	5.13	101.0%
T5_CTS_DIR_002902.LAB	2/14/2023	7:32:26	-0.01	0.03	-0.09	0.08	100.24	5.08	100.0%
T5_CTS_DIR_002903.LAB	2/14/2023	7:32:33	0.00	0.05	-0.08	0.17	100.99	5.11	100.8%
T5_CTS_DIR_002904.LAB	2/14/2023	7:32:41	0.00	0.01	-0.12	0.06	100.32	5.10	100.1%
T5_CTS_DIR_002905.LAB	2/14/2023	7:32:48	0.01	-0.08	-0.11	-0.02	100.62	5.11	100.4%
Average							100.62	5.11	

99.9 ppm HCl/5.00 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_HCL_DIR_002912.LAB	2/14/2023	7:37:09	0.00	99.18	0.17	0.19	-0.27	4.98
T5_HCL_DIR_002913.LAB	2/14/2023	7:37:16	0.01	101.33	0.15	0.16	-0.31	4.99
T5_HCL_DIR_002914.LAB	2/14/2023	7:37:24	0.00	101.35	0.17	0.14	-0.21	5.00
T5_HCL_DIR_002915.LAB	2/14/2023	7:37:31	0.00	101.25	0.14	0.16	-0.17	4.99
T5_HCL_DIR_002916.LAB	2/14/2023	7:37:39	0.00	101.70	0.17	-0.01	-0.11	4.98
T5_HCL_DIR_002917.LAB	2/14/2023	7:37:46	0.01	101.39	0.12	-0.05	-0.27	4.99
T5_HCL_DIR_002918.LAB	2/14/2023	7:37:54	0.00	101.86	0.11	0.12	-0.12	4.99
T5_HCL_DIR_002919.LAB	2/14/2023	7:38:01	0.00	99.76	0.13	0.19	-0.22	4.97
Average							100.98	4.99

19.71 ppm Formaldehyde/4.97 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_HCHO_DIR_002937.LAB	2/14/2023	7:40:50	0.00	0.10	-0.14	16.23	-0.24	5.01
T5_HCHO_DIR_002938.LAB	2/14/2023	7:40:57	-0.01	0.20	-0.17	16.27	-0.21	5.02
T5_HCHO_DIR_002939.LAB	2/14/2023	7:41:05	0.01	0.14	-0.22	16.10	-0.36	5.02
T5_HCHO_DIR_002940.LAB	2/14/2023	7:41:12	0.00	0.23	-0.11	16.29	-0.33	5.00
T5_HCHO_DIR_002941.LAB	2/14/2023	7:41:20	0.00	0.12	-0.15	16.10	-0.29	5.01
T5_HCHO_DIR_002942.LAB	2/14/2023	7:41:27	0.00	0.07	-0.15	16.45	-0.33	5.01
T5_HCHO_DIR_002943.LAB	2/14/2023	7:41:35	0.00	0.17	-0.18	16.22	-0.20	5.03
T5_HCHO_DIR_002944.LAB	2/14/2023	7:41:42	0.00	0.06	-0.19	16.20	-0.28	5.01
Average							16.23	5.01

111.2 ppm HF/4.999 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_HF_DIR_002963.LAB	2/14/2023	7:49:15	-0.01	0.41	105.60	0.11	-0.19	4.96
T5_HF_DIR_002964.LAB	2/14/2023	7:49:23	0.00	0.47	105.80	-0.07	-0.33	4.96
T5_HF_DIR_002965.LAB	2/14/2023	7:49:30	-0.01	0.42	105.77	0.02	0.13	4.96
T5_HF_DIR_002966.LAB	2/14/2023	7:49:38	-0.01	0.45	105.95	-0.06	-0.16	4.96
T5_HF_DIR_002967.LAB	2/14/2023	7:49:45	0.00	0.41	105.94	-0.03	-0.02	4.97
T5_HF_DIR_002968.LAB	2/14/2023	7:49:53	-0.01	0.37	106.25	-0.06	-0.23	4.96
T5_HF_DIR_002969.LAB	2/14/2023	7:50:00	0.00	0.42	105.74	-0.02	-0.37	4.98
T5_HF_DIR_002970.LAB	2/14/2023	7:50:08	0.00	0.45	106.19	0.10	-0.25	4.97
Average							105.90	4.97

100.2 ppm Ethylene/5.000 ppm SF6 System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T5_CTS_RT_002971.LAB	2/14/2023	7:55:19	5.98	0.90	2.05	0.19	0.26	0.03	0.3%	-
T5_CTS_RT_002972.LAB	2/14/2023	7:55:26	5.46	0.82	1.94	0.56	3.01	0.25	3.0%	8
T5_CTS_RT_002973.LAB	2/14/2023	7:55:33	0.97	0.46	0.37	0.58	93.25	4.87	92.7%	15
T5_CTS_RT_002974.LAB	2/14/2023	7:55:41	0.19	0.24	-0.07	0.15	101.26	5.12	100.6%	23
T5_CTS_RT_002975.LAB	2/14/2023	7:55:48	0.12	0.21	-0.09	0.15	101.10	5.13	100.5%	
T5_CTS_RT_002976.LAB	2/14/2023	7:55:56	0.09	0.21	-0.13	0.19	101.42	5.15	100.8%	
T5_CTS_RT_002977.LAB	2/14/2023	7:56:03	0.07	0.27	-0.13	-0.01	101.28	5.14	100.7%	
T5_CTS_RT_002978.LAB	2/14/2023	7:56:11	0.05	0.15	-0.11	0.33	101.34	5.14	100.7%	
T5_CTS_RT_002979.LAB	2/14/2023	7:56:18	0.04	0.11	-0.16	0.14	101.44	5.15	100.8%	
T5_CTS_RT_002980.LAB	2/14/2023	7:56:26	0.03	0.15	-0.16	0.05	101.30	5.15	100.7%	
T5_CTS_RT_002981.LAB	2/14/2023	7:56:33	0.03	0.09	-0.17	0.17	101.61	5.14	101.0%	

Nitrogen (Zero) System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T5_N2_RT_002982.LAB	2/14/2023	7:56:59	0.02	0.05	-0.21	0.06	101.02	5.14	100.4%	-
T5_N2_RT_002983.LAB	2/14/2023	7:57:06	0.70	0.10	0.13	-0.01	80.80	4.16	80.3%	8
T5_N2_RT_002984.LAB	2/14/2023	7:57:14	0.51	0.30	0.17	0.12	9.16	0.47	9.1%	16
T5_N2_RT_002985.LAB	2/14/2023	7:57:21	0.03	0.19	-0.20	0.11	0.25	0.00	0.2%	23
T5_N2_RT_002986.LAB	2/14/2023	7:57:28	0.02	0.11	-0.22	0.04	0.09	-0.01	0.1%	
T5_N2_RT_002987.LAB	2/14/2023	7:57:36	0.01	0.13	-0.11	0.02	0.10	0.01	0.1%	
T5_N2_RT_002988.LAB	2/14/2023	7:57:44	0.03	0.02	-0.21	0.00	-0.06	0.00	-0.1%	
T5_N2_RT_002989.LAB	2/14/2023	7:57:51	-0.01	-0.01	-0.23	0.09	0.15	0.00	0.2%	
T5_N2_RT_002990.LAB	2/14/2023	7:57:59	0.02	0.15	-0.21	0.04	0.33	0.01	0.3%	
T5_N2_RT_002991.LAB	2/14/2023	7:58:06	0.00	0.12	-0.19	0.16	0.05	0.00	0.0%	
T5_N2_RT_002992.LAB	2/14/2023	7:58:13	0.01	0.08	-0.22	0.01	0.04	0.00	0.0%	
Average			0.01	0.10	-0.20	0.06	0.12	0.00		

Turbine 5 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_002994.LAB	2/14/2023	8:00:19	6.01	0.62	1.86	0.10	0.26	0.00
T5_002995.LAB	2/14/2023	8:01:19	6.01	0.50	1.68	0.06	0.33	0.00
T5_002996.LAB	2/14/2023	8:02:19	6.01	0.48	1.60	0.11	0.26	0.00
Average			0.53			0.09		0.00

Turbine 5 Analyte Spike, Using 19.71 ppm Formaldehyde/4.97 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	Formaldehyde Recovery %
T5_HCHO_SPK_003007.LAB	2/14/2023	8:04:37	5.49	0.38	1.35	1.47	0.10	0.45	0.089	95.9%
T5_HCHO_SPK_003008.LAB	2/14/2023	8:04:44	5.48	0.41	1.34	1.55	0.22	0.45	0.090	100.4%
T5_HCHO_SPK_003009.LAB	2/14/2023	8:04:51	5.47	0.34	1.39	1.73	0.14	0.46	0.091	110.5%
T5_HCHO_SPK_003010.LAB	2/14/2023	8:04:59	5.46	0.40	1.37	1.63	0.12	0.45	0.091	105.1%
T5_HCHO_SPK_003011.LAB	2/14/2023	8:05:06	5.48	0.45	1.40	1.53	0.00	0.45	0.089	100.0%
T5_HCHO_SPK_003012.LAB	2/14/2023	8:05:14	5.48	0.34	1.30	1.46	0.09	0.44	0.089	95.8%
T5_HCHO_SPK_003013.LAB	2/14/2023	8:05:22	5.49	0.38	1.36	1.35	0.12	0.45	0.090	87.2%
T5_HCHO_SPK_003014.LAB	2/14/2023	8:05:29	5.46	0.46	1.40	1.36	0.16	0.44	0.089	89.0%
Spike Average										98.0%

Turbine 5 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_003020.LAB	2/14/2023	8:12:01	6.02	0.42	1.55	0.08	0.21	0.00
T5_003021.LAB	2/14/2023	8:13:01	6.02	0.42	1.54	0.06	0.15	0.00
T5_003022.LAB	2/14/2023	8:14:01	6.03	0.40	1.52	0.13	0.22	0.00
Average			0.41			0.09		0.00

Turbine 5 Analyte Spike, Using 99.9 ppm HCl/5.00 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HCl Recovery %
T5_HCL_SPK_003065.LAB	2/14/2023	8:19:47	5.56	7.76	1.70	0.21	0.20	0.40	0.080	92.2%
T5_HCL_SPK_003066.LAB	2/14/2023	8:19:54	5.53	7.74	1.72	0.22	0.08	0.40	0.080	91.3%
T5_HCL_SPK_003067.LAB	2/14/2023	8:20:02	5.54	7.79	1.73	-0.03	0.17	0.40	0.080	92.6%
T5_HCL_SPK_003068.LAB	2/14/2023	8:20:09	5.54	7.76	1.68	0.33	0.23	0.39	0.078	93.5%
T5_HCL_SPK_003069.LAB	2/14/2023	8:20:17	5.55	7.78	1.72	0.17	0.01	0.39	0.079	93.3%
T5_HCL_SPK_003070.LAB	2/14/2023	8:20:24	5.53	7.83	1.68	-0.05	0.26	0.40	0.081	91.8%
T5_HCL_SPK_003071.LAB	2/14/2023	8:20:32	5.57	7.87	1.70	-0.02	0.16	0.39	0.079	94.6%
T5_HCL_SPK_003072.LAB	2/14/2023	8:20:40	5.55	7.80	1.67	0.08	0.12	0.39	0.078	94.2%
Spike Average										92.9%

Turbine 5 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_003076.LAB	2/14/2023	8:25:11	6.04	0.63	1.42	0.06	0.23	0.00
T5_003077.LAB	2/14/2023	8:26:11	6.05	0.56	1.39	0.10	0.15	0.00
T5_003078.LAB	2/14/2023	8:27:11	6.05	0.53	1.39	0.02	0.24	0.00
Average					1.40			0.00

Turbine 5 Analyte Spike, Using 111.2 ppm HF/4.999 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HF Recovery %
T5_HF_SPK_003180.LAB	2/14/2023	8:40:18	5.49	0.47	9.58	0.05	0.03	0.43	0.086	91.8%
T5_HF_SPK_003181.LAB	2/14/2023	8:40:26	5.49	0.47	9.52	0.10	0.16	0.42	0.085	92.2%
T5_HF_SPK_003182.LAB	2/14/2023	8:40:33	5.51	0.53	9.54	-0.06	0.12	0.43	0.086	91.7%
T5_HF_SPK_003183.LAB	2/14/2023	8:40:40	5.50	0.46	9.55	-0.04	0.06	0.43	0.087	90.9%
T5_HF_SPK_003184.LAB	2/14/2023	8:40:48	5.49	0.51	9.57	-0.03	0.17	0.44	0.088	90.4%
T5_HF_SPK_003185.LAB	2/14/2023	8:40:55	5.50	0.48	9.66	0.03	0.15	0.44	0.089	90.6%
T5_HF_SPK_003186.LAB	2/14/2023	8:41:03	5.48	0.49	9.64	0.01	0.09	0.43	0.087	91.9%
T5_HF_SPK_003187.LAB	2/14/2023	8:41:10	5.47	0.51	9.53	-0.10	0.19	0.44	0.089	88.9%
Spike Average										91.1%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_SYS_003287.LAB	2/14/2023	10:15:49	0.05	-0.08	-0.20	-0.04	101.10	5.10	100.5%
T5_CTS_SYS_003288.LAB	2/14/2023	10:15:57	0.03	0.02	-0.28	0.10	101.05	5.12	100.4%
T5_CTS_SYS_003289.LAB	2/14/2023	10:16:04	0.01	0.06	-0.24	0.06	101.64	5.12	101.0%
T5_CTS_SYS_003290.LAB	2/14/2023	10:16:11	0.01	0.04	-0.27	-0.01	101.51	5.13	100.9%
T5_CTS_SYS_003291.LAB	2/14/2023	10:16:19	0.00	0.02	-0.24	0.00	101.40	5.12	100.8%
T5_CTS_SYS_003292.LAB	2/14/2023	10:16:26	0.01	0.16	-0.25	-0.08	100.40	5.11	99.8%
T5_CTS_SYS_003293.LAB	2/14/2023	10:16:34	0.00	0.06	-0.23	-0.13	100.63	5.10	100.0%
T5_CTS_SYS_003294.LAB	2/14/2023	10:16:41	-0.01	0.07	-0.27	-0.12	100.85	5.12	100.2%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_SYS_003358.LAB	2/14/2023	11:21:17	0.01	0.11	-0.23	0.19	101.17	5.11	100.6%
T5_CTS_SYS_003359.LAB	2/14/2023	11:21:24	0.02	-0.01	-0.31	-0.04	100.58	5.11	100.0%
T5_CTS_SYS_003360.LAB	2/14/2023	11:21:32	0.02	0.05	-0.25	-0.07	100.52	5.12	99.9%
T5_CTS_SYS_003361.LAB	2/14/2023	11:21:39	0.01	0.06	-0.22	0.12	100.70	5.12	100.1%
T5_CTS_SYS_003362.LAB	2/14/2023	11:21:47	0.01	-0.02	-0.23	0.15	100.84	5.10	100.2%
T5_CTS_SYS_003363.LAB	2/14/2023	11:21:54	0.01	0.12	-0.24	-0.24	100.98	5.10	100.4%
T5_CTS_SYS_003364.LAB	2/14/2023	11:22:02	0.01	0.08	-0.26	0.15	101.38	5.11	100.8%
T5_CTS_SYS_003365.LAB	2/14/2023	11:22:09	0.01	0.10	-0.25	0.07	101.03	5.11	100.4%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_SYS_003438.LAB	2/14/2023	12:35:37	0.03	0.22	-0.24	0.17	101.21	5.10	100.6%
T5_CTS_SYS_003439.LAB	2/14/2023	12:35:44	0.02	-0.04	-0.25	-0.02	101.11	5.11	100.5%
T5_CTS_SYS_003440.LAB	2/14/2023	12:35:52	0.01	0.01	-0.26	0.04	100.72	5.11	100.1%
T5_CTS_SYS_003441.LAB	2/14/2023	12:35:59	0.01	0.03	-0.24	0.10	100.75	5.12	100.1%
T5_CTS_SYS_003442.LAB	2/14/2023	12:36:07	0.01	0.02	-0.24	0.29	100.22	5.12	99.6%
T5_CTS_SYS_003443.LAB	2/14/2023	12:36:14	0.02	0.05	-0.24	0.01	101.03	5.11	100.4%
T5_CTS_SYS_003444.LAB	2/14/2023	12:36:22	0.00	0.11	-0.29	-0.07	101.22	5.12	100.6%
T5_CTS_SYS_003445.LAB	2/14/2023	12:36:29	0.00	0.09	-0.26	0.02	101.17	5.12	100.5%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_SYS_003510.LAB	2/14/2023	13:41:42	0.03	0.08	-0.21	-0.09	100.67	5.10	100.1%
T5_CTS_SYS_003511.LAB	2/14/2023	13:41:50	0.03	0.04	-0.20	-0.03	101.36	5.13	100.7%
T5_CTS_SYS_003512.LAB	2/14/2023	13:41:57	0.02	0.03	-0.26	0.14	101.37	5.12	100.8%
T5_CTS_SYS_003513.LAB	2/14/2023	13:42:05	0.02	0.05	-0.21	0.01	100.79	5.10	100.2%
T5_CTS_SYS_003514.LAB	2/14/2023	13:42:12	0.01	-0.06	-0.28	-0.29	100.53	5.12	99.9%
T5_CTS_SYS_003515.LAB	2/14/2023	13:42:20	0.02	0.02	-0.25	0.00	100.89	5.11	100.3%
T5_CTS_SYS_003516.LAB	2/14/2023	13:42:27	0.01	-0.03	-0.22	0.04	100.88	5.12	100.3%
T5_CTS_SYS_003517.LAB	2/14/2023	13:42:35	0.01	0.00	-0.23	0.10	100.90	5.10	100.3%

Nitrogen (Zero) System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_N2_SYS_003518.LAB	2/14/2023	13:43:12	0.01	-0.09	-0.27	-0.04	0.21	0.00
T5_N2_SYS_003519.LAB	2/14/2023	13:43:20	0.01	0.04	-0.27	0.01	0.08	0.00
T5_N2_SYS_003520.LAB	2/14/2023	13:43:27	0.00	0.01	-0.20	0.07	0.08	0.00
T5_N2_SYS_003521.LAB	2/14/2023	13:43:35	0.01	0.02	-0.26	0.02	-0.10	0.00
T5_N2_SYS_003522.LAB	2/14/2023	13:43:42	0.01	0.01	-0.26	0.00	0.12	0.00
T5_N2_SYS_003523.LAB	2/14/2023	13:43:49	0.00	0.07	-0.21	0.11	0.05	0.00
T5_N2_SYS_003524.LAB	2/14/2023	13:43:57	0.01	0.01	-0.27	0.20	0.18	0.00
T5_N2_SYS_003525.LAB	2/14/2023	13:44:04	0.02	-0.01	-0.24	0.22	0.05	0.00
Average			0.01	0.01	-0.25	0.08	0.08	0.00

Nitrogen (Zero) Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_N2_DIR_003526.LAB	2/14/2023	13:49:05	0.00	-0.01	-0.25	0.04	0.04	0.00
T5_N2_DIR_003527.LAB	2/14/2023	13:51:05	0.00	0.00	-0.27	-0.01	0.05	0.00
T5_N2_DIR_003528.LAB	2/14/2023	13:53:05	0.00	0.00	-0.28	-0.03	0.01	0.00

Nitrogen (Zero) Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_N2_DIR_003532BKG.LAB	2/15/2023	7:21:22	0.00	0.00	0.00	0.00	0.00	0.00
T5_N2_DIR_003533.LAB	2/15/2023	7:21:35	0.00	-0.03	-0.07	0.16	0.19	0.00
T5_N2_DIR_003534.LAB	2/15/2023	7:21:43	0.00	-0.02	-0.04	0.00	0.08	0.00
T5_N2_DIR_003535.LAB	2/15/2023	7:21:50	0.00	-0.08	-0.03	0.04	0.07	0.00
T5_N2_DIR_003536.LAB	2/15/2023	7:21:58	0.01	0.01	-0.02	-0.01	0.06	0.00
T5_N2_DIR_003537.LAB	2/15/2023	7:22:05	0.00	0.04	-0.03	0.03	0.04	0.00
T5_N2_DIR_003538.LAB	2/15/2023	7:22:13	-0.01	0.01	-0.01	-0.11	0.09	0.00
T5_N2_DIR_003539.LAB	2/15/2023	7:22:20	-0.01	-0.02	-0.02	-0.14	-0.06	0.00
T5_N2_DIR_003540.LAB	2/15/2023	7:22:28	0.00	-0.01	-0.04	0.11	0.17	0.00
Average								

CTS, 100.2 ppm Ethylene/5.000 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_DIR_003541.LAB	2/15/2023	7:23:08	0.00	-0.05	-0.01	0.03	100.26	5.09	100.1%
T5_CTS_DIR_003542.LAB	2/15/2023	7:23:16	0.01	0.06	0.00	0.07	100.78	5.11	100.6%
T5_CTS_DIR_003543.LAB	2/15/2023	7:23:23	0.01	0.03	0.09	0.06	100.55	5.10	100.4%
T5_CTS_DIR_003544.LAB	2/15/2023	7:23:30	0.01	-0.11	-0.02	0.30	100.47	5.09	100.3%
T5_CTS_DIR_003545.LAB	2/15/2023	7:23:38	0.01	0.05	0.01	0.15	100.44	5.10	100.2%
T5_CTS_DIR_003546.LAB	2/15/2023	7:23:46	0.00	0.01	0.01	-0.06	100.60	5.11	100.4%
T5_CTS_DIR_003547.LAB	2/15/2023	7:23:53	0.00	-0.02	0.00	-0.10	100.07	5.10	99.9%
T5_CTS_DIR_003548.LAB	2/15/2023	7:24:01	0.01	0.02	0.00	-0.07	100.26	5.10	100.1%
Average							100.43	* 5.10	

19.71 ppm Formaldehyde/4.97 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_HCHO_DIR_003560.LAB	2/15/2023	7:26:03	0.00	-0.10	-0.07	16.19	-0.19	5.02
T5_HCHO_DIR_003561.LAB	2/15/2023	7:26:11	0.00	-0.13	-0.04	15.98	-0.39	5.02
T5_HCHO_DIR_003562.LAB	2/15/2023	7:26:18	0.00	-0.18	-0.04	16.16	-0.24	5.03
T5_HCHO_DIR_003563.LAB	2/15/2023	7:26:26	0.00	-0.09	-0.07	16.10	-0.14	5.01
T5_HCHO_DIR_003564.LAB	2/15/2023	7:26:33	-0.01	-0.03	-0.06	16.02	-0.25	5.00
T5_HCHO_DIR_003565.LAB	2/15/2023	7:26:41	0.00	-0.14	-0.01	15.88	-0.19	5.02
T5_HCHO_DIR_003566.LAB	2/15/2023	7:26:48	0.00	-0.04	-0.02	16.18	-0.46	5.02
T5_HCHO_DIR_003567.LAB	2/15/2023	7:26:56	0.00	-0.21	-0.05	15.87	-0.19	5.01
Average						16.05	5.02	

99.9 ppm HCl/5.00 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_HCL_DIR_003579.LAB	2/15/2023	7:30:56	0.00	104.49	0.18	0.09	-0.27	4.99
T5_HCL_DIR_003580.LAB	2/15/2023	7:31:04	0.00	104.57	0.14	0.06	-0.28	5.00
T5_HCL_DIR_003581.LAB	2/15/2023	7:31:11	0.00	102.33	0.14	0.03	-0.16	4.97
T5_HCL_DIR_003582.LAB	2/15/2023	7:31:18	0.00	104.42	0.16	0.03	-0.18	4.97
T5_HCL_DIR_003583.LAB	2/15/2023	7:31:26	0.00	104.70	0.18	0.09	-0.23	4.98
T5_HCL_DIR_003584.LAB	2/15/2023	7:31:33	-0.01	102.75	0.17	0.22	-0.22	4.98
T5_HCL_DIR_003585.LAB	2/15/2023	7:31:41	-0.01	102.68	0.15	0.15	-0.25	4.98
T5_HCL_DIR_003586.LAB	2/15/2023	7:31:48	0.01	104.71	0.17	0.23	-0.32	4.96
Average			103.83			0.23	-0.32	4.98

111.2 ppm HF/4.999 ppm SF6 Direct Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_HF_DIR_003607.LAB	2/15/2023	7:44:23	0.00	0.28	102.13	-0.03	-0.10	4.96
T5_HF_DIR_003608.LAB	2/15/2023	7:44:31	-0.01	0.33	102.34	-0.01	-0.33	4.96
T5_HF_DIR_003609.LAB	2/15/2023	7:44:38	-0.01	0.48	102.55	-0.07	0.00	4.95
T5_HF_DIR_003610.LAB	2/15/2023	7:44:45	-0.01	0.38	102.38	-0.29	-0.01	4.95
T5_HF_DIR_003611.LAB	2/15/2023	7:44:53	0.01	0.37	102.41	-0.22	-0.08	4.95
T5_HF_DIR_003612.LAB	2/15/2023	7:45:00	0.00	0.21	102.66	-0.20	-0.04	4.95
T5_HF_DIR_003613.LAB	2/15/2023	7:45:08	0.01	0.36	102.68	-0.06	-0.16	4.96
T5_HF_DIR_003614.LAB	2/15/2023	7:45:15	0.00	0.32	102.31	0.04	-0.14	4.96
Average					102.43			4.95

100.2 ppm Ethylene/5.000 ppm SF6 System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T5_CTS_RT_003615.LAB	2/15/2023	7:48:51	5.43	0.43	2.38	0.09	0.27	0.04	0.3%	-
T5_CTS_RT_003616.LAB	2/15/2023	7:48:59	4.29	0.27	2.01	0.35	6.41	0.33	6.4%	8
T5_CTS_RT_003617.LAB	2/15/2023	7:49:06	0.12	0.14	0.20	0.06	97.58	5.00	97.2%	15
T5_CTS_RT_003618.LAB	2/15/2023	7:49:14	0.03	0.11	0.05	-0.04	102.27	5.18	101.8%	
T5_CTS_RT_003619.LAB	2/15/2023	7:49:21	0.02	0.00	0.05	-0.09	101.97	5.17	101.5%	
T5_CTS_RT_003620.LAB	2/15/2023	7:49:29	0.00	0.10	0.02	-0.22	102.27	5.17	101.8%	
T5_CTS_RT_003621.LAB	2/15/2023	7:49:36	0.01	-0.05	0.05	-0.06	101.72	5.18	101.3%	
T5_CTS_RT_003622.LAB	2/15/2023	7:49:44	0.01	0.09	-0.01	-0.05	101.29	5.16	100.9%	
T5_CTS_RT_003623.LAB	2/15/2023	7:49:51	0.01	0.12	0.01	-0.04	101.42	5.15	101.0%	
T5_CTS_RT_003624.LAB	2/15/2023	7:49:59	0.01	0.00	0.00	0.06	101.92	5.17	101.5%	
T5_CTS_RT_003625.LAB	2/15/2023	7:50:06	0.00	0.01	-0.01	0.07	101.22	5.15	100.8%	

Nitrogen (Zero) System Purge and Response Time Test

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %	Response Time (sec)
T5_N2_RT_003626.LAB	2/15/2023	7:50:31	0.01	-0.05	0.01	0.29	101.32	5.15	100.9%	-
T5_N2_RT_003627.LAB	2/15/2023	7:50:38	0.78	0.03	0.65	0.06	70.19	3.64	69.9%	8
T5_N2_RT_003628.LAB	2/15/2023	7:50:46	0.07	0.01	0.20	0.23	1.87	0.10	1.9%	15
T5_N2_RT_003629.LAB	2/15/2023	7:50:53	0.01	0.11	0.01	-0.03	0.37	-0.01	0.4%	
T5_N2_RT_003630.LAB	2/15/2023	7:51:01	-0.01	-0.06	-0.04	-0.19	0.18	0.00	0.2%	
T5_N2_RT_003631.LAB	2/15/2023	7:51:08	0.00	0.05	-0.02	-0.11	0.03	0.01	0.0%	
T5_N2_RT_003632.LAB	2/15/2023	7:51:16	0.00	0.04	-0.01	0.13	-0.02	0.01	0.0%	
T5_N2_RT_003633.LAB	2/15/2023	7:51:23	-0.01	0.07	-0.02	0.18	-0.06	0.00	-0.1%	
T5_N2_RT_003634.LAB	2/15/2023	7:51:31	0.01	0.02	-0.02	-0.02	0.16	-0.01	0.2%	
T5_N2_RT_003635.LAB	2/15/2023	7:51:38	0.00	-0.04	-0.04	0.11	-0.08	0.00	-0.1%	
T5_N2_RT_003636.LAB	2/15/2023	7:51:46	0.01	-0.02	-0.03	0.10	0.02	0.00	0.0%	
Average			0.00	0.02	-0.02	0.02	0.07	0.00		

Turbine 5 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_003638.LAB	2/15/2023	7:53:24	5.46	0.41	1.77	0.07	0.15	0.00
T5_003639.LAB	2/15/2023	7:54:24	5.46	0.42	1.60	0.06	0.16	0.00
T5_003640.LAB	2/15/2023	7:55:24	5.46	0.40	1.53	0.10	0.23	0.00
Average			0.41			0.07		0.00

Turbine 5 Analyte Spike, Using 19.71 ppm Formaldehyde/4.97 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	Formaldehyde Recovery %
T5_HCHO_SPK_003659.LAB	2/15/2023	7:58:13	5.04	0.33	1.45	1.11	0.23	0.39	0.077	85.1%
T5_HCHO_SPK_003660.LAB	2/15/2023	7:58:21	5.05	0.26	1.44	1.37	0.02	0.38	0.076	106.5%
T5_HCHO_SPK_003661.LAB	2/15/2023	7:58:28	5.05	0.30	1.52	1.00	0.00	0.38	0.075	78.7%
T5_HCHO_SPK_003662.LAB	2/15/2023	7:58:36	5.04	0.26	1.46	1.06	0.12	0.39	0.077	80.7%
T5_HCHO_SPK_003663.LAB	2/15/2023	7:58:43	5.05	0.26	1.46	1.10	0.25	0.39	0.078	83.4%
T5_HCHO_SPK_003664.LAB	2/15/2023	7:58:51	5.06	0.35	1.40	1.05	-0.01	0.38	0.076	81.3%
T5_HCHO_SPK_003665.LAB	2/15/2023	7:58:58	5.07	0.31	1.37	1.35	0.11	0.39	0.077	103.7%
T5_HCHO_SPK_003666.LAB	2/15/2023	7:59:06	5.09	0.22	1.41	1.24	0.16	0.39	0.078	94.4%
Spike Average										89.2%

Turbine 5 Analyte Spike, Using 99.9 ppm HCl/5.00 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HCl Recovery %
T5_HCL_SPK_003721.LAB	2/15/2023	8:06:22	5.13	7.68	1.26	-0.02	0.18	0.38	0.076	92.7%
T5_HCL_SPK_003722.LAB	2/15/2023	8:06:29	5.12	7.85	1.30	-0.02	0.17	0.39	0.078	92.7%
T5_HCL_SPK_003723.LAB	2/15/2023	8:06:37	5.09	7.74	1.27	0.08	0.07	0.37	0.075	94.9%
T5_HCL_SPK_003724.LAB	2/15/2023	8:06:44	5.08	7.69	1.32	0.12	0.08	0.37	0.074	94.8%
T5_HCL_SPK_003725.LAB	2/15/2023	8:06:52	5.10	7.75	1.31	-0.13	0.23	0.37	0.075	95.1%
T5_HCL_SPK_003726.LAB	2/15/2023	8:06:59	5.10	7.57	1.25	0.06	0.18	0.38	0.076	91.0%
T5_HCL_SPK_003727.LAB	2/15/2023	8:07:07	5.11	7.74	1.29	-0.01	0.17	0.37	0.075	95.1%
T5_HCL_SPK_003728.LAB	2/15/2023	8:07:14	5.07	7.68	1.24	0.03	-0.04	0.37	0.074	95.1%
Spike Average										93.9%

Turbine 5 Prior to Analyte Spike

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_003730.LAB	2/15/2023	8:09:46	5.48	0.73	1.30	0.05	0.17	0.00
T5_003731.LAB	2/15/2023	8:10:45	5.49	0.57	1.30	0.00	0.20	0.00
T5_003732.LAB	2/15/2023	8:11:45	5.48	0.53	1.27	0.02	0.19	0.00
Average					1.29			0.00

Turbine 5 Analyte Spike, Using 111.2 ppm HF/4.999 ppm SF6

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Dilution Factor	HF Recovery %
T5_HF_SPK_003825.LAB	2/15/2023	8:23:45	5.15	0.39	6.99	0.03	-0.06	0.31	0.063	91.6%
T5_HF_SPK_003826.LAB	2/15/2023	8:23:53	5.17	0.45	6.99	0.08	0.31	0.32	0.064	90.3%
T5_HF_SPK_003827.LAB	2/15/2023	8:24:00	5.18	0.46	6.94	-0.22	0.04	0.31	0.063	91.0%
T5_HF_SPK_003828.LAB	2/15/2023	8:24:08	5.18	0.48	7.07	0.06	0.17	0.31	0.063	91.9%
T5_HF_SPK_003829.LAB	2/15/2023	8:24:15	5.17	0.34	6.99	0.03	0.15	0.32	0.064	89.5%
T5_HF_SPK_003830.LAB	2/15/2023	8:24:23	5.20	0.42	7.09	-0.08	0.29	0.32	0.065	89.8%
T5_HF_SPK_003831.LAB	2/15/2023	8:24:30	5.20	0.33	7.01	0.18	-0.14	0.31	0.063	91.2%
T5_HF_SPK_003832.LAB	2/15/2023	8:24:38	5.15	0.47	6.98	-0.29	0.16	0.31	0.063	91.3%
Spike Average										90.8%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_SYS_003933.LAB	2/15/2023	10:06:14	0.03	0.13	-0.03	-0.27	100.95	5.11	100.5%
T5_CTS_SYS_003934.LAB	2/15/2023	10:06:22	0.03	0.18	-0.04	-0.18	100.72	5.10	100.3%
T5_CTS_SYS_003935.LAB	2/15/2023	10:06:29	0.01	0.05	-0.04	-0.18	100.78	5.13	100.3%
T5_CTS_SYS_003936.LAB	2/15/2023	10:06:37	0.01	0.04	-0.07	-0.20	100.75	5.11	100.3%
T5_CTS_SYS_003937.LAB	2/15/2023	10:06:44	0.01	0.06	-0.02	0.03	101.11	5.11	100.7%
T5_CTS_SYS_003938.LAB	2/15/2023	10:06:52	0.00	0.00	-0.09	-0.12	100.30	5.08	99.9%
T5_CTS_SYS_003939.LAB	2/15/2023	10:06:59	0.00	-0.12	-0.04	0.05	101.36	5.11	100.9%
T5_CTS_SYS_003940.LAB	2/15/2023	10:07:07	0.02	-0.01	-0.07	-0.26	101.30	5.12	100.9%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_SYS_004004.LAB	2/15/2023	11:11:04	0.03	0.01	-0.03	-0.03	100.44	5.11	100.0%
T5_CTS_SYS_004005.LAB	2/15/2023	11:11:12	0.02	0.01	-0.05	-0.09	100.68	5.10	100.2%
T5_CTS_SYS_004006.LAB	2/15/2023	11:11:19	0.01	0.10	-0.03	0.12	101.10	5.11	100.7%
T5_CTS_SYS_004007.LAB	2/15/2023	11:11:27	0.00	0.11	-0.06	-0.04	101.45	5.11	101.0%
T5_CTS_SYS_004008.LAB	2/15/2023	11:11:34	0.00	0.01	-0.04	0.06	101.20	5.12	100.8%
T5_CTS_SYS_004009.LAB	2/15/2023	11:11:42	0.01	0.14	-0.09	0.02	100.92	5.10	100.5%
T5_CTS_SYS_004010.LAB	2/15/2023	11:11:49	0.02	0.01	-0.09	-0.19	101.41	5.11	101.0%
T5_CTS_SYS_004011.LAB	2/15/2023	11:11:57	0.02	0.10	-0.04	-0.04	101.24	5.12	100.8%

100.2 ppm Ethylene/5.000 ppm SF6 System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)	Ethylene Recovery %
T5_CTS_SYS_004091.LAB	2/15/2023	12:32:44	0.02	0.16	-0.07	-0.03	101.27	5.12	100.8%
T5_CTS_SYS_004092.LAB	2/15/2023	12:32:52	0.02	0.02	-0.02	0.08	101.09	5.12	100.7%
T5_CTS_SYS_004093.LAB	2/15/2023	12:32:59	0.01	0.11	-0.04	-0.12	100.55	5.10	100.1%
T5_CTS_SYS_004094.LAB	2/15/2023	12:33:07	0.00	0.19	-0.07	-0.26	100.96	5.10	100.5%
T5_CTS_SYS_004095.LAB	2/15/2023	12:33:14	0.01	0.10	-0.07	0.07	101.68	5.14	101.2%
T5_CTS_SYS_004096.LAB	2/15/2023	12:33:22	0.00	0.17	-0.05	0.19	101.28	5.12	100.8%
T5_CTS_SYS_004097.LAB	2/15/2023	12:33:29	0.01	0.16	-0.05	-0.16	101.41	5.13	101.0%
T5_CTS_SYS_004098.LAB	2/15/2023	12:33:37	0.01	0.03	-0.08	-0.17	101.16	5.10	100.7%

Nitrogen (Zero) System Purge

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_N2_SYS_004099.LAB	2/15/2023	12:34:13	0.01	-0.02	-0.05	0.20	0.10	0.00
T5_N2_SYS_004100.LAB	2/15/2023	12:34:21	0.01	0.03	-0.05	-0.16	-0.04	0.00
T5_N2_SYS_004101.LAB	2/15/2023	12:34:28	0.00	0.13	-0.05	0.11	0.08	0.00
T5_N2_SYS_004102.LAB	2/15/2023	12:34:36	0.01	0.10	-0.03	-0.01	-0.04	0.00
T5_N2_SYS_004103.LAB	2/15/2023	12:34:43	0.01	0.12	-0.06	0.11	-0.10	-0.01
T5_N2_SYS_004104.LAB	2/15/2023	12:34:50	0.00	0.06	-0.09	-0.21	0.26	0.00
T5_N2_SYS_004105.LAB	2/15/2023	12:34:58	0.00	0.09	-0.08	-0.38	0.02	0.00
T5_N2_SYS_004106.LAB	2/15/2023	12:35:06	0.01	0.02	-0.09	-0.24	0.07	-0.01
Average	0.01		0.07		-0.06	-0.07	0.04	0.00

Nitrogen (Zero) Direct Purge to FTIR

Spectrum	Date	Time	H2O (%v)	HCl (ppmv wet)	HF (ppmv wet)	Formaldehyde (ppmv wet)	Ethylene (ppmv wet)	SF6 (ppmv wet)
T5_N2_DIR_004107.LAB	2/15/2023	12:39:31	0.00	0.01	-0.05	0.06	0.03	0.00
T5_N2_DIR_004108.LAB	2/15/2023	12:41:31	0.00	0.03	-0.06	0.03	0.03	0.00
T5_N2_DIR_004109.LAB	2/15/2023	12:43:31	0.00	0.01	-0.06	-0.02	0.01	0.00

APPENDIX

Certificates of Analysis

APEL-RIEMER ENVIRONMENTAL, INC

REFERENCE GASES AND ATMOSPHERIC CHEMISTRY

Certificate of Analysis

Gas-phase Calibration Standard

This gas-phase standard is intended to be used as a reference material for the calibration of instruments.

Statement about preparation and traceability:

Standards are gravimetrically prepared in high-pressure aluminum cylinders (Luxfer, Inc., Riverside, California). Cylinders are cleaned and treated to eliminate contamination and ensure inertness. Standards are prepared in N150 cylinders (~4000 Liters calibration gas), N033 cylinders (~800 Liters calibration gas), or N006 cylinders (~125 Liters calibration gas at a pressure of 2000 psia UHP nitrogen. Valves are high purity stainless steel (Ceodeux, Lintgen, Luxembourg) with a CGA-350 fitting. Pure compounds as liquids and gases are obtained from a number of sources. All lot numbers are cataloged. The gravimetric preparation is performed using calibrated microbalances (Mettler-Toledo, Columbus, Ohio) and microsyringes (Hamilton, Reno, Nevada and SGE, Austin, Texas) for measuring the compounds and cylinder balances (Mettler-Toledo, Columbus, Ohio) for the balance gas. Balances are calibrated with NIST traceable weights.

We prepare each cylinder individually. Accuracy is better than +/- 5%. Analysis confirms the accuracy of the gravimetric preparation. We use a series of NIST, NIST-traceable, NPL, and in-house gravimetric standards to perform the instrument calibrations.

Stability varies depending on the compound, concentration, and cylinder size. Many compounds are stable for several years.

The calibration gas mixture in cylinder CC751990 is certified from the analysis date for 12 months.



Daniel D. Riemer, Ph.D.

May 15, 2022

Date

Cylinder: CC751990

Cylinder Date: 10/21

Valve: CGA350 SS 21/153406

Lot No.: 22117.3

Cylinder Pressure: 2000 psia

Analysis Date: May 15, 2022

Multi-component calibration mixture in ultra-pure nitrogen

Compound	CAS#	Concentration (ppm)	Uncertainty
Formaldehyde	50-0-0	19.71	±5%
Sulfur Hexafluoride	2551-62-4	4.97	±2%

Uncertainty is a conservative estimate of the combination of the uncertainties of the gravimetric preparation and analysis.

Formaldehyde Raw Material Lot No. - AA 10136752

Sulfur Hexafluoride Raw Material Lot No. - SQ Q9B-79

CERTIFICATE OF ANALYSIS

Grade of Product: PRIMARY STANDARD

Part Number: X03NI99P15AC267 Reference Number: 54-401485086-1
Cylinder Number: CC14351 Cylinder Volume: 144.4 CF
Laboratory: 124 - Chicago (SAP) - IL Cylinder Pressure: 2015 PSIG
Analysis Date: May 03, 2019 Valve Outlet: 350
Lot Number: 54-401485086-1
Expiration Date: May 03, 2027

Primary Standard Gas Mixtures are traceable to N.I.S.T. weights and/or N.I.S.T. Gas Mixture reference materials.

ANALYTICAL RESULTS

Component	Req Conc	Actual Concentration (Mole %)	Analytical Uncertainty
SULFUR HEXAFLUORIDE	5.000 PPM	5.000 PPM	+/- 1%
ETHYLENE	100.0 PPM	100.2 PPM	+/- 1%
NITROGEN	Balance		



Signature on file

Approved for Release

W002AS-023392-RT-4542

433 of 688

Page 1 of 1

CERTIFICATE OF ANALYSIS**Grade of Product: CERTIFIED STANDARD-SPEC**

Customer: MONTROSE AIR QUALITY SERVICES LLC
Part Number: X03NI99C15A05C5 Reference Number: 160-402627146-1
Cylinder Number: EB0116042 Cylinder Volume: 144.0 CF
Laboratory: 124 - Plumsteadville - PA Cylinder Pressure: 2016 PSIG
Analysis Date: Jan 25, 2023 Valve Outlet: 330
Lot Number: 160-402627146-1


Expiration Date: Jan 25, 2024

Product composition verified by direct comparison to calibration standards traceable to N.I.S.T. weights and/or N.I.S.T.
Gas Mixture reference materials.

ANALYTICAL RESULTS

Component	Req Conc	Actual Concentration (Mole %)	Analytical Uncertainty
SULFUR HEXAFLUORIDE	5.000 PPM	4.999 PPM	+/- 10%
HYDROGEN FLUORIDE	100.0 PPM	111.2 PPM	+/- 10%
NITROGEN	Balance		

Permanent Notes:-NA-



Approved for Release

Airgas

an Air Liquide company

CERTIFICATE OF ACCURACY: HCl GMACS (Gas Manufacturer Alternative Certified Standard)

ASSAY LABORATORY

AIRGAS SPECIALTY GASES
 Exploratory Products Group
 6141 Easton Road
 Plumsteadville, PA 18949

Lot No.: 160-402456622-1
 P.O. No.: 28292

CUSTOMER INFORMATION

Montrose Air Quality Services, LLC
 951 N. Old Rand Rd., STE 106
 Wauconda, IL 60084
 USA

PRODUCT INFORMATION

<u>COMPOSITION</u>	<u>CERTIFIED CONCENTRATION</u>		<u>UNCERTAINTY (Abs)</u>		<u>UNCERTAINTY (Rel)</u>	
Hydrogen Chloride	99.9	PPM	2.87	PPM	2.30	%
Sulfur Hexafluoride	5.0	PPM	0.05	PPM	0.96	%
Nitrogen	Bal					
Cylinder Number:	CC715847		Certification Date:	26-Jul-2022		
Cylinder Type:	30L Aluminum		Prior Certification Date:	None		
Cylinder Pressure:	1900 PSIG		Expiration Date:	26-Jul-2024		
Mixture Dew Point:	N / A		Part No.:	EO2NI99T15EC013		

CERTIFICATION DATA

GravStat™ Blending Process

<u>COMPOSITION</u>	<u>MEASURED CONCENTRATION</u>		<u>UNCERTAINTY (Abs)</u>		<u>UNCERTAINTY (Rel)</u>	
Hydrogen Chloride	100.1	PPM	0.867	PPM	0.87	%
Sulfur Hexafluoride	5.03	PPM	0.049	PPM	0.96	%

Confirming Analysis

<u>COMPOSITION</u>	<u>MEASURED CONCENTRATION</u>		<u>UNCERTAINTY (Abs)</u>		<u>UNCERTAINTY (Rel)</u>	
Hydrogen Chloride	99.7	PPM	2.12	PPM	2.13	%
<u>INSTRUMENT MODEL / ANALYTICAL PRINCIPLE</u>						
CAI Model 700 FTIR						

Reference Standard(s)

Cylinder Number:	GMPS ND65251				
<u>COMPOSITION</u>	<u>CERTIFIED CONCENTRATION</u>		<u>UNCERTAINTY (Abs)</u>	<u>UNCERTAINTY (Rel)</u>	<u>EXPIRES:</u>
Hydrogen Chloride	103.0	PPM	2.11	PPM	2.05 % 11-Feb-2023

Calibration Curve Data:

Curve Order	Correlation	Slope	Intercept
1st Order -	0.9998875	0.996220	0.654920
6 points, with zero			

INTERLOCK STATISTICS

	<u>MEASURED CONCENTRATION</u>		<u>UNCERTAINTY (Abs)</u>		<u>UNCERTAINTY (Rel)</u>	
GravStat Result	100.1	PPM	0.867	PPM	0.87	%
Analysis Result	99.7	PPM	2.12	PPM	2.13	%
Interlock Result	99.9	PPM	2.87	PPM	2.30	%

COMMENTS / SPECIAL INSTRUCTIONS

1. This GMACS was certified according to the EPA approved alternative (Alt-114) found at:

https://cfpub.epa.gov/si/si_public_record_report.cfm?Lab=NRMRL&dirEntryId=336073

2. Do not use this standard if pressure is less than 200 psig.
3. Do not use or store this product at or below the stated dew point.
4. Replace valve plug when not in use.

APPROVED BY:

W002AS-023392 RT 4542

Bob Griswold


Appendix A.6 Fuel Analysis Report

CLIENT: Montrose
 CLIENT PROJ NO: DTE Sunshine
 LABORATORY NO: 23-147
 SAMPLING DATE: 02/10/23
 RECEIVING DATE: 02/10/23
 ANALYSIS DATE: 02/10/23
 REPORT DATE: 02/15/23

Laboratory Analysis Report

Analysis Methods: ASTM 1945-03 ; HHV Calculations: ASTM 3588-98

Analyte, Units	Sample ID	Sunshine LFG Inlet Eng 4
	Sampling Date	02/10/23
	Lab ID	04123-17
	Units	Mole %
Methane, %		45.24
Ethane, %		<0.01
Ethylene, %		<0.01
Propane, %		<0.01
Propylene, %		<0.01
i-Butane, %		<0.01
n-Butane, %		<0.01
1-Butene, %		<0.01
i-Butylene, %		<0.01
trans-2-Butene, %		<0.01
cis-2-Butene, %		<0.01
i-Pentane, %		<0.01
n-Pentane, %		<0.01
2,2-Dimethyl Butane, %		<0.01
2,3-Dimethyl Butane, %		<0.01
2-Methyl Pentane, %		<0.01
3-Methyl Pentane, %		<0.01
n-Hexane, %		<0.01
C6+, %		<0.01
CO2, %		34.62
CO, %		<0.01
O2, %		2.69
N2, %		17.41
H2, %		<0.01
H2S, %		<0.01
NH3, %		<0.01
Average Molecular Weight		28.265
Total Wt.% Adjusted Sp. Gravity		0.9759
Compressibility Factor (14.696 Psi, 60 F)		0.9978
NET BTU/Cub. Ft		413
GROSS BTU/Cub. Ft		459
CHONS	%	
Carbon		34.04
Hydrogen		6.47
Oxygen		42.23
Nitrogen		17.26
Sulfur		<0.01
Dry F Factor (60 F, 1 Atm); SDCF/MMBTU, ASTM 3588		9476


 Dr. Andrew Kitto
 President



1210 E. 223rd Street, Suite #314 • Carson, California 90745 • 310/830-2226 • Fax 310/830-2227

www.quantumairlab.com

CLIENT Montrose
CLIENT PROJ NO: DTE Sunshine
LABORATORY NO: 23-147
SAMPLING DATE: 02/10/23
RECEIVING DATE: 02/10/23
ANALYSIS DATE: 02/10/23
REPORT DATE: 02/15/23

Laboratory Results

Analysis Method	EPA 3C				
Detection Limits	0.10%				
		CH4	CO2	CO	O2
Sample ID	Lab ID No.	%	%	%	%
Sunshine LFG Inlet Eng 4	04123-17	45.24	34.62	<0.01	2.7
					17.4

A handwritten signature in black ink, appearing to read "Andrew Kitto".

Dr. Andrew Kitto
President



www.quantumairlab.com

1210 E. 223rd Street, Suite #314 • Carson, California 90745 • 310/830-2226 • Fax 310/830-2227

CLIENT Montrose

CLIENT PROJ NO: DTE Sunshine
LABORATORY NO: 23-147
SAMPLING DATE: 02/10/23
RECEIVING DATE: 02/10/23
ANALYSIS DATE: 02/10/23
REPORT DATE: 02/15/23

Standard Verification

EPA 3C - Fixed Gases

Lab ID	Analyte	Theoretical Value Mole %	Tested Value Mole %	% Recovery*
SCOTT STD	CO2	15.00	15.30	102%
SCOTT STD	O2	4.00	3.98	100%
SCOTT STD	N2	69.50	69.86	101%
SCOTT STD	CH4	4.50	4.52	100%
SCOTT STD	CO	7.00	6.93	99%

* Must be $\pm 10\%$

Dr. Andrew Kitto
President



W002AS-02639-RT-4542

CHAIN OF CUSTODY

Email: andrewkitto.quantum@gmail.com

310/830-2226 • www.quantumairlab.com
1210 E. 223rd Street, Suite #314 • Carson, California 90745

23-147

No 10305


Client: <u>MONTMORÉ AQ'S</u>	Project No.: <u>Proj - 003392</u>	Analysis	Turnaround Time:		
Contact Person: <u>Pete Saws USA</u>	Project Name: <u>THE SUNSHINE</u>	<input type="checkbox"/> Same Day			
tel: <u>626-617-16313</u>	Project Manager: <u>PSAN JUAN</u>	<input type="checkbox"/> 24 Hours			
fax: _____	P.O. Number: _____	<input type="checkbox"/> 48 Hours			
<input checked="" type="checkbox"/> Normal					
Client Sample ID	Tag #	Date	Time	Lab ID Number	Remarks
440 of 688	<u>INSULINE UFG INT/35</u> <u>ENCL 4</u>	<u>210/23</u>	<u>04/23-17</u>	X	
Relinquished by: (signature) <u>Jesse Mancuso</u>	Date/Time 2-10-23 14:00	Received by: (signature) <u>John V. Sauer</u>	Date/time 2/10/23 1400		
Relinquished by: (signature)	Date/Time	Received by: (signature)	Date/time		
Relinquished by: (signature)	Date/Time	Received by: (signature)	Date/time		

CLIENT: Montrose
CLIENT PROJ NO: DTE Sunshine
LABORATORY NO: 23-171
SAMPLING DATE: 02/16/23
RECEIVING DATE: 02/16/23
ANALYSIS DATE: 02/17/23
REPORT DATE: 02/20/23

Laboratory Analysis Report

Analysis Methods: ASTM 1945-03 ; HHV Calculations: ASTM 3588-98

Analyte, Units	Sample ID	Sunshine LFG Inlet Eng 5
	Sampling Date	02/16/23
	Lab ID	04723-8
	Units	Mole %
Methane, %		44.50
Ethane, %		<0.01
Ethylene, %		<0.01
Propane, %		<0.01
Propylene, %		<0.01
i-Butane, %		<0.01
n-Butane, %		<0.01
1-Butene, %		<0.01
i-Butylene, %		<0.01
trans-2-Butene, %		<0.01
cis-2-Butene, %		<0.01
i-Pentane, %		<0.01
n-Pentane, %		<0.01
2,2-Dimethyl Butane, %		<0.01
2,3-Dimethyl Butane, %		<0.01
2-Methyl Pentane, %		<0.01
3-Methyl Pentane, %		<0.01
n-Hexane, %		<0.01
C6+, %		<0.01
CO2, %		36.06
CO, %		<0.01
O2, %		3.28
N2, %		16.17
H2, %		<0.01
H2S, %		<0.01
NH3, %		<0.01
Average Molecular Weight		28.585
Total Wt.% Adjusted Sp. Gravity		0.9869
Compressibility Factor (14.696 Psi, 60 F)		0.9977
NET BTU/Cub. Ft		405
GROSS BTU/Cub. Ft		449
CHONS		%
Carbon		33.85
Hydrogen		6.28
Oxygen		44.03
Nitrogen		15.85
Sulfur		<0.01
Dry F Factor (60 F, 1 Atm); SDCF/MMBTU, ASTM 3588		9444


 Dr. Andrew Kitto
 President



www.quantumairlab.com

1210 E. 223rd Street, Suite #314 • Carson, California 90745 • 310/830-2226 • Fax 310/830-2227

CLIENT Montrose
CLIENT PROJ NO: DTE Sunshine
LABORATORY NO: 23-171
SAMPLING DATE: 02/16/23
RECEIVING DATE: 02/16/23
ANALYSIS DATE: 02/17/23
REPORT DATE: 02/20/23

Laboratory Results

Analysis Method	EPA 3C				
Detection Limits	0.10%				
		CH4	CO2	CO	O2
Sample ID	Lab ID No.	%	%	%	%
Sunshine LFG Inlet Eng 5	04723-8	44.50	36.06	<0.01	3.3
					16.2

A handwritten signature in black ink, appearing to read "Andrew Kitto".

Dr. Andrew Kitto
President



www.quantumairlab.com

1210 E. 223rd Street, Suite #314 • Carson, California 90745 • 310/830-2226 • Fax 310/830-2227

CLIENT Montrose

CLIENT PROJ NO: DTE Sunshine
LABORATORY NO: 23-171
SAMPLING DATE: 02/16/23
RECEIVING DATE: 02/16/23
ANALYSIS DATE: 02/17/23
REPORT DATE: 02/20/23

Standard Verification

EPA 3C - Fixed Gases

Lab ID	Analyte	Theoretical Value	Tested Value	% Recovery*
Mole %	Mole %			
SCOTT STD	CO2	15.00	15.30	102%
SCOTT STD	O2	4.00	3.98	100%
SCOTT STD	N2	69.50	69.86	101%
SCOTT STD	CH4	4.50	4.52	100%
SCOTT STD	CO	7.00	6.93	99%

* Must be $\pm 10\%$

Dr. Andrew Kitto
President



No. 10305

Analytical Services Inc.

W002AS-023392-RT-4542

23 - 171

CHAIN OF CUSTODY

Montrose No. 5

92-RT-4542


1210 E. 223rd Street, Suite #314 • Carson, California 90745
310/830-2226 • www.squartufairlab.com

Email: andrewkitto@gmail.com

Turnaround Time:

Turnaround Time:

Appendix A.7 Quality Assurance Data



SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 4 DATE: 2/7/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022 50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022 96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022 49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022 96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022 46.8%
CO	High	CC181175	9.650	5/6/30	F22022 96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	-0.02	-0.10	--
Error (% of scale)	-0.1%	-0.2%	-1.0%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.29	9.64	9.64	--
Error (% of scale)	-0.1%	-0.3%	-0.1%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.12	4.90	4.66	--
Error (% of scale)	0.0%	-0.2%	-0.2%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.01	-0.02	-0.04	--
Error (% of scale)	-0.1%	-0.2%	-0.4%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.33	9.71	9.57	--
Error (% of scale)	0.1%	0.5%	-0.9%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.14	4.98	4.64	--
Error (% of scale)	0.1%	0.6%	-0.4%	PASS



SPAN GAS RECORD AND EPA CALIBRATION ERROR

CLIENT/LOCATION: Sunshine Gas CT 4 DATE: 2/7/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	-0.03	-0.02	-0.10	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	-0.1%	-0.2%	-2.1%	
Status⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.29	9.64	9.64	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.1%	-0.3%	-0.3%	
Status⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.12	4.90	4.66	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	0.0%	-0.2%	-0.3%	
Status⁽¹⁾	PASS	PASS	PASS	

1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.



SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 4 DATE: 2/8/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022 50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022 96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022 49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022 96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022 46.8%
CO	High	CC181175	9.650	5/6/30	F22022 96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.01	-0.02	-0.02	--
Error (% of scale)	-0.1%	-0.2%	-0.2%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.63	9.66	--
Error (% of scale)	-0.1%	-0.3%	0.1%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.22	4.90	4.72	--
Error (% of scale)	0.4%	-0.2%	0.4%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.01	-0.02	-0.08	--
Error (% of scale)	0.0%	-0.2%	-0.8%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.62	9.58	--
Error (% of scale)	-0.1%	-0.4%	-0.7%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.13	4.89	4.65	--
Error (% of scale)	0.0%	-0.3%	-0.3%	PASS



SPAN GAS RECORD AND EPA CALIBRATION ERROR


CLIENT/LOCATION: Sunshine Gas CT 4 DATE: 2/8/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	-0.01	-0.02	-0.02	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.1%	-0.2%	-0.5%	
Status ⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.28	9.63	9.66	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.1%	-0.3%	0.3%	
Status ⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.22	4.90	4.72	
Difference (% or ppm)	0.1	0.0	0.0	
Error (% of Cal. Span)	0.5%	-0.2%	0.7%	
Status ⁽¹⁾	PASS	PASS	PASS	

1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.



SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 4 DATE: 2/9/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

	Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0			
O ₂	Mid	CC106542	10.13	5/19/30	F22022	50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022	96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022	49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022	96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022	46.8%
CO	High	CC181175	9.650	5/6/30	F22022	96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	0.00	-0.07	-0.08	--
Error (% of scale)	0.0%	-0.7%	-0.8%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.31	9.69	9.62	--
Error (% of scale)	0.0%	0.3%	-0.3%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.13	4.93	4.63	--
Error (% of scale)	0.0%	0.1%	-0.5%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.04	-0.01	-0.04	--
Error (% of scale)	-0.2%	-0.1%	-0.4%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.30	9.63	9.64	--
Error (% of scale)	0.0%	-0.3%	-0.1%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.10	4.92	4.70	--
Error (% of scale)	-0.2%	0.0%	0.2%	PASS

SPAN GAS RECORD AND EPA CALIBRATION ERROR


CLIENT/LOCATION: Sunshine Gas CT 4 DATE: 2/9/23
 TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	0.00	-0.07	-0.08	
Difference (% or ppm)	0.0	-0.1	-0.1	
Error (% of Cal. Span)	0.0%	-0.7%	-1.8%	
Status ⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.31	9.69	9.62	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	0.0%	0.3%	-0.7%	
Status ⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.13	4.93	4.63	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	0.0%	0.1%	-1.2%	
Status ⁽¹⁾	PASS	PASS	PASS	

1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.



SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 4 DATE: 2/10/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022 50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022 96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022 49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022 96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022 46.8%
CO	High	CC181175	9.650	5/6/30	F22022 96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	-0.04	-0.07	--
Error (% of scale)	-0.2%	-0.4%	-0.7%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.29	9.63	9.67	--
Error (% of scale)	-0.1%	-0.3%	0.1%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.11	4.91	4.62	--
Error (% of scale)	-0.1%	-0.1%	-0.6%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.01	-0.07	0.00	--
Error (% of scale)	0.0%	-0.7%	0.0%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.32	9.66	9.64	--
Error (% of scale)	0.1%	0.0%	-0.1%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.15	5.00	4.68	--
Error (% of scale)	0.1%	0.8%	0.0%	PASS



SPAN GAS RECORD AND EPA CALIBRATION ERROR

CLIENT/LOCATION: Sunshine Gas CT 4
TRUCK/CEM I.D.: Trailer 2

DATE: 2/10/23


BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	-0.03	-0.04	-0.07	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	-0.2%	-0.4%	-1.4%	
Status ⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.29	9.63	9.67	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.1%	-0.3%	0.3%	
Status ⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.11	4.91	4.62	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	-0.1%	-0.1%	-1.2%	
Status ⁽¹⁾	PASS	PASS	PASS	

- 1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.



SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 5
TRUCK/CEM I.D.: Trailer 2

DATE: 2/14/23
BY: PSJ

	Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0			
O ₂	Mid	CC106542	10.13	5/19/30	F22022	50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022	96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022	49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022	96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022	46.8%
CO	High	CC181175	9.650	5/6/30	F22022	96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	-0.03	0.04	--
Error (% of scale)	-0.1%	-0.3%	0.4%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.63	9.65	--
Error (% of scale)	-0.1%	-0.3%	0.0%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.08	4.90	4.63	--
Error (% of scale)	-0.3%	-0.2%	-0.5%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.04	-0.01	0.01	--
Error (% of scale)	-0.2%	-0.1%	0.1%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.27	9.66	9.65	--
Error (% of scale)	-0.2%	0.0%	0.0%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.11	4.90	4.61	--
Error (% of scale)	-0.1%	-0.2%	-0.7%	PASS



SPAN GAS RECORD AND EPA CALIBRATION ERROR


CLIENT/LOCATION: Sunshine Gas CT 5 DATE: 2/14/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	-0.03	-0.03	0.04	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.1%	-0.3%	0.9%	
Status⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.28	9.63	9.65	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.2%	-0.3%	0.0%	
Status⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.08	4.90	4.63	
Difference (% or ppm)	-0.1	0.0	-0.1	
Error (% of Cal. Span)	-0.3%	-0.2%	-1.1%	
Status⁽¹⁾	PASS	PASS	PASS	

1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.



SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 5 DATE: 2/15/23
TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022 50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022 96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022 49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022 96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022 46.8%
CO	High	CC181175	9.650	5/6/30	F22022 96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	-0.04	-0.06	--
Error (% of scale)	-0.1%	-0.4%	-0.6%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.62	9.62	--
Error (% of scale)	-0.1%	-0.4%	-0.3%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.10	4.97	4.66	--
Error (% of scale)	-0.1%	0.5%	-0.2%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	0.07	-0.01	--
Error (% of scale)	-0.1%	0.7%	-0.1%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.65	9.66	--
Error (% of scale)	-0.1%	-0.1%	0.0%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.10	4.98	4.58	--
Error (% of scale)	-0.2%	0.6%	-1.0%	PASS

SPAN GAS RECORD AND EPA CALIBRATION ERROR

CLIENT/LOCATION: Sunshine Gas CT 5 DATE: 2/15/23
 TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	-0.03	-0.04	-0.06	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	-0.1%	-0.4%	-1.3%	
Status ⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.28	9.62	9.62	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.1%	-0.5%	-0.6%	
Status ⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.10	4.97	4.66	
Difference (% or ppm)	0.0	0.1	0.0	
Error (% of Cal. Span)	-0.1%	0.5%	-0.5%	
Status ⁽¹⁾	PASS	PASS	PASS	

1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.

SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 5 DATE: 2/16/23
 TRUCK/CEM I.D.: Trailer 2 BY: PSJ

	Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0			
O ₂	Mid	CC106542	10.13	5/19/30	F22022	50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022	96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022	49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022	96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022	46.8%
CO	High	CC181175	9.650	5/6/30	F22022	96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	-0.04	-0.03	--
Error (% of scale)	-0.2%	-0.4%	-0.3%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.29	9.63	9.60	--
Error (% of scale)	-0.1%	-0.3%	-0.5%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.10	4.91	4.61	--
Error (% of scale)	-0.1%	-0.1%	-0.7%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.04	-0.04	0.07	--
Error (% of scale)	-0.2%	-0.4%	0.7%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.64	9.62	--
Error (% of scale)	-0.1%	-0.2%	-0.3%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.11	4.90	4.69	--
Error (% of scale)	-0.1%	-0.3%	0.1%	PASS



SPAN GAS RECORD AND EPA CALIBRATION ERROR

CLIENT/LOCATION: Sunshine Gas CT 5
TRUCK/CEM I.D.: Trailer 2

DATE: 2/16/23
BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	-0.03	-0.04	-0.03	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.2%	-0.4%	-0.7%	
Status ⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.29	9.63	9.60	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	-0.1%	-0.3%	-1.1%	
Status ⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.10	4.91	4.61	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	-0.1%	-0.1%	-1.5%	
Status ⁽¹⁾	PASS	PASS	PASS	

1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.

SPAN GAS RECORD AND SCAQMD CALIBRATION ERROR/LINEARITY

CLIENT/LOCATION: Sunshine Gas CT 5 DATE: 2/17/23
 TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder #	Value	Exp. Date	Vendor ID	% of Range
ZERO	Low	CC241060	0.0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022 50.7%
O ₂	High	CC258464	19.31	4/5/30	F22022 96.6%
CO ₂	Mid	CC106542	4.92	5/19/30	F22022 49.2%
CO ₂	High	CC258464	9.66	4/5/30	F22022 96.6%
CO	Mid	CC205667	4.680	6/2/30	F22022 46.8%
CO	High	CC181175	9.650	5/6/30	F22022 96.5%

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	-0.02	-0.03	--
Error (% of scale)	-0.2%	-0.2%	-0.3%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.63	9.60	--
Error (% of scale)	-0.2%	-0.3%	-0.5%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.10	4.91	4.59	--
Error (% of scale)	-0.1%	-0.1%	-0.9%	PASS

POST-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			STATUS
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Zero Gas Value	0.0	0.0	0.0	--
Analyzer Reads	-0.03	-0.02	-0.03	--
Error (% of scale)	-0.2%	-0.2%	-0.3%	PASS
High Gas Value	19.31	9.66	9.65	--
Analyzer Reads	19.28	9.63	9.65	--
Error (% of scale)	-0.2%	-0.3%	0.0%	PASS
Mid Gas Value	10.13	4.92	4.68	--
Analyzer Reads	10.10	4.90	4.63	--
Error (% of scale)	-0.2%	-0.2%	-0.5%	PASS

SPAN GAS RECORD AND EPA CALIBRATION ERROR

CLIENT/LOCATION: Sunshine Gas CT 5 DATE: 2/17/23
 TRUCK/CEM I.D.: Trailer 2 BY: PSJ

Gas	Cylinder Number	Value	Exp. Date	Vendor ID	% of Cal Span
ZERO	Low	CC241060	0		
O ₂	Mid	CC106542	10.13	5/19/30	F22022
O ₂	High	CC258464	19.31	4/5/30	F22022
CO ₂	Mid	CC106542	4.92	5/19/30	F22022
CO ₂	High	CC258464	9.66	4/5/30	F22022
CO	Mid	CC205667	4.68	6/2/30	F22022
CO	High	CC181175	9.65	5/6/30	F22022

PRE-TEST INSTRUMENT CALIBRATION ERROR

	ANALYZER			
	O ₂	CO ₂	CO	
Analyzer Range	20	10	10	
Calibration Span	19.31	9.66	4.68	
Zero Gas Value	0.0	0.0	0.0	
Analyzer Reads	-0.03	-0.02	-0.03	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.2%	-0.2%	-0.7%	
Status⁽¹⁾	PASS	PASS	PASS	
High Gas Value	19.31	9.66	9.650	
Analyzer Reads	19.28	9.63	9.60	
Difference (% or ppm)	0.0	0.0	0.0	
Error (% of Cal. Span)	-0.2%	-0.3%	-1.0%	
Status⁽¹⁾	PASS	PASS	PASS	
Mid Gas Value	10.13	4.92	4.68	
Analyzer Reads	10.10	4.91	4.59	
Difference (% or ppm)	0.0	0.0	-0.1	
Error (% of Cal. Span)	-0.1%	-0.1%	-1.9%	
Status⁽¹⁾	PASS	PASS	PASS	

1) Calibration Error must be within +/- 2.0% of the Calibration Span; alternatively the results are acceptable if the difference is less than or equal to 0.5 ppm.



making our world
more productive



Montrose Air Quality Services, LLC

1631 E. St. Andrew Pl.
Santa Ana, CA 92705

Linde Order Number: 72116641
Customer PO Number: 80120587



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles, CA 90058
Tel: 323-585-2154
Fax: 714-542-6689

Certificate Issuance Date: 7/12/2022

Certification Date: 7/12/2022
Lot Number: N70086217204
Part Number: NI 5.5CE-AS
DocNumber: 559820

CERTIFICATE OF ANALYSIS

Nitrogen, 5.5 Continuous Emission Monitoring Zero

Analytes	N₂ <i>CC241060 A.D. 7/5/22</i>	Specification	Analytical Results	Analytical Reference	Analytical Uncertainty
Nitrogen		≥ 99.9995 %	≥ 99.9995 %	5	N/A
Carbon Dioxide		≤ 1 ppm	≤ 0.5 ppm	3	± 10%
Carbon Monoxide		≤ 0.5 ppm	≤ 0.5 ppm	3	± 15%
Total Hydrocarbons		≤ 0.1 ppm	≤ 0.1 ppm	6	± 15%
Oxides of Nitrogen		≤ 0.1 ppm	≤ 0.1 ppm	7	± 15%
Oxygen		≤ 0.5 ppm	≤ 0.5 ppm	2	± 15%
Sulfur Dioxide		≤ 0.1 ppm	≤ 0.1 ppm	1	± 15%
Water		≤ 2 ppm	≤ 1.0 ppm	4	± 10%

Cylinder Style: AS

Fill Date: 6/21/2022

Filling Method: Pressure/Temperature

Cylinder Pressure @ 70 F: 2000 psig

Analysis Date: 7/5/2022

Cylinder Volume: 142 ft³

Valve Outlet Connection: CGA 580

Cylinder Number(s): CC79327, CC243496, CC320298, CC39253, DT0025644, CC241060,
DT0036679, CC165749, SA3614, CC332474, CC323960CC113610,
DT0040987CC78171, CC198351, DT0028851, CC265793, DT0025628

Analyzed Cylinder Number(s): CC79327

[Signature]
Analyst: **Amalia Real**

[Signature]
Approved Signer: **Ving Yu**

Key to Analytical Techniques:

Reference Analytical Instrument - Analytical Principle

- | | |
|---|--|
| 1 | Ametek 921CE S/N AW-921-S321 - UV Spectrometry |
| 2 | Delta F DF-550 Nanotrace - Electrolytic Cell/Electrochemical |
| 3 | Horiba Instruments Inc. GA-360E - NDIR |
| 4 | Meeco Aquavolt PLUS - Specific Water Analyzer |
| 5 | N/A - By Difference of Typical Impurities |
| 6 | Rosemount/Beckman 400A - FID Total Hydrocarbon Analyzer |
| 7 | Thermo Electron 42i-LS S/N 1030645077 - Chemiluminescence |

lu 7-20-22

This analysis of the product described herein was prepared by Linde Gas & Equipment Inc. using instruments whose calibration is certified using Linde Gas & Equipment Inc. Reference Materials which are traceable to the International System of Units (SI) through either weights traceable to the National Institute of Standards and Technology (NIST) or Measurement Canada, or through NIST Standard Reference Materials or equivalent where available.

Note: All expressions for concentration (e.g. % or ppm) are for gas phase, by mole unless otherwise noted. Analytical uncertainty is expressed as a Relative % unless otherwise noted.

IMPORTANT

The information contained herein has been prepared at your request by personnel within Linde Gas & Equipment Inc. While we believe the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any particular purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall liability of Linde Gas & Equipment Inc. arising out of the use of the information contained herein exceed the fee established for providing such information.



DocNumber: 475059



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

MONTROSE AIR QUALITY SERVICES
1531 E ST ANDREWS PLACE
SANTA ANA CA92705

Certificate Issuance Date: 05/23/2022

Linde Order Number: 68405833

Part Number: EV NICDOXE78-AS

Customer PO Number: LUIS OLIVARES

Fill Date: 05/10/2022

Lot Number: 70088213002

Cylinder Style & Outlet: AS

CGA 580

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration		
Expiration Date:	05/19/2030	NIST Traceable
Cylinder Number:	CC106542	Expanded Uncertainty
4.92 %	Carbon dioxide	± 0.02 %
10.13 %	Oxygen	± 0.05 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 05/19/2022

Term: 96 Months

Expiration Date: 05/19/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

CO₂ responses have been corrected for Oxygen IR Broadening effect. O₂ responses have been corrected for CO₂ interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon dioxide

Requested Concentration: 5 %
Certified Concentration: 4.92 %
Instrument Used: Horiba VIA-510 S/N 20C194WK
Analytical Method: NDIR
Last Multipoint Calibration: 04/21/2022

First Analysis Data:	Date	05/19/2022
Z: 0 R: 6.99 C: 4.92 Conc: 4.92		
R: 6.99 Z: 0 C: 4.92 Conc: 4.92		
Z: 0 C: 4.92 R: 6.99 Conc: 4.92		
UOM: % Mean Test Assay: 4.92 %		

Reference Standard: Type / Cylinder #: GMIS / CC256638

Concentration / Uncertainty: 6.99 % ± 0.02 %

Expiration Date: 05/24/2027

Traceable to: SRM # / Sample # / Cylinder #: SRM 1674b / 7-H-07 / FF10831

SRM Concentration / Uncertainty: 6.944 % ± 0.013 %

SRM Expiration Date: 06/17/2019

Second Analysis Data:	Date
Z: 0 R: 0 C: 0 Conc: 0	
R: 0 Z: 0 C: 0 Conc: 0	
Z: 0 C: 0 R: 0 Conc: 0	
UOM: % Mean Test Assay: %	

Reference Standard: Type / Cylinder #: NTRM / DT0010262

Concentration / Uncertainty: 9.875 % ± 0.040 %

Expiration Date: 11/18/2022

Traceable to: SRM # / Sample # / Cylinder #: NTRM / 170701 / DT0010262

SRM Concentration / Uncertainty: 9.875 % ± 0.040 %

SRM Expiration Date: 11/16/2022

2. Component: Oxygen

Requested Concentration: 10 %
Certified Concentration: 10.13 %
Instrument Used: Siemens Oxymat 6E S/N 7MB20211AA000CA1
Analytical Method: Paramagnetic
Last Multipoint Calibration: 05/09/2022

First Analysis Data:	Date	05/19/2022
Z: 0 R: 9.875 C: 10.14 Conc: 10.14		
R: 0.879 Z: 0 C: 10.12 Conc: 10.12		
Z: 0 C: 10.12 R: 9.869 Conc: 10.12		
UOM: % Mean Test Assay: 10.13 %		

Second Analysis Data:	Date
Z: 0 R: 0 C: 0 Conc: 0	
R: 0 Z: 0 C: 0 Conc: 0	
Z: 0 C: 0 R: 0 Conc: 0	
UOM: % Mean Test Assay: %	

Analyzed By

Courtney Zielke

Certified By

Ying Yu (nm)

02% 10-13
CO₂ 4.92
CC106542
EXP 5-19-30
F2022

AS 63-22

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



DocNumber: 451723



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

C#:



Montrose Air Quality Services, LLC
1631 E. St. Andrew Pl.
Santa Ana, CA 92705

Certificate Issuance Date: 04/06/2022

Linde Order Number: 59924698

Part Number: NI CD9.5O3E-AS

Customer PO Number: LUIS OLIVARES

Fill Date: 04/01/2022

Lot Number: 70086209103

Cylinder Style & Outlet: AS

CGA 590

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	04/05/2030	NIST Traceable
Cylinder Number:	CC258464	Expanded Uncertainty
9.66 %	Carbon dioxide	± 0.05 %
19.31 %	Oxygen	± 0.03 %
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 04/05/2022

Term: 96 Months

Expiration Date: 04/05/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

CO2 responses have been corrected for Oxygen IR Broadening effect. O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:	Carbon dioxide	Reference Standard:	Type / Cylinder #: GMIS / CC176580
Requested Concentration:	9.5 %	Concentration / Uncertainty:	14.26 % ±0.03 %
Certified Concentration:	9.66 %	Expiration Date:	01/21/2030
Instrument Used:	Horiba VIA-510 S/N 20C194WK	Traceable to:	SRM # / Sample # / Cylinder #: NTRM / NIA / CC726055
Analytical Method:	NDIR	SRM Concentration / Uncertainty:	19.34% ±0.03%
Last Multipoint Calibration:	05/21/2022	SRM Expiration Date:	01/12/2027
First Analysis Data:	Date 04/05/2022	Second Analysis Data:	Date
Z: 0 R: 14.26 C: 9.66 Conc: 9.66	Z: 0 R: 0 C: 0 Conc: 0	Z: 0 R: 0 C: 0 Conc: 0	
R: 14.26 Z: 0 C: 9.66 Conc: 9.66	R: 0 Z: 0 C: 0 Conc: 0	Z: 0 C: 0 R: 0 Conc: 0	
Z: 0 C: 9.67 R: 14.27 Conc: 9.67	UOM: % Mean Test Assay: 9.66 %	Mean Test Assay: %	
2. Component:	Oxygen	Reference Standard:	Type / Cylinder #: GMIS / ND29287
Requested Concentration:	19 %	Concentration / Uncertainty:	20.90 % ±0.02 %
Certified Concentration:	19.31 %	Expiration Date:	09/01/2028
Instrument Used:	Siemens Oxymat 6E S/N 7M320211AA000CA1	Traceable to:	SRM # / Sample # / Cylinder #: SRM 2659a / 71-E-19 / FF22331
Analytical Method:	Paramagnetic	SRM Concentration / Uncertainty:	20.863% ±0.021%
Last Multipoint Calibration:	03/11/2022	SRM Expiration Date:	08/23/2021
First Analysis Data:	Date 04/05/2022	Second Analysis Data:	Date
Z: 0 R: 20.9 C: 19.31 Conc: 19.31	Z: 0 R: 0 C: 0 Conc: 0	Z: 0 R: 0 C: 0 Conc: 0	
R: 20.9 Z: 0 C: 19.32 Conc: 19.32	R: 0 Z: 0 C: 0 Conc: 0	Z: 0 C: 0 R: 0 Conc: 0	
Z: 0 C: 19.32 R: 20.91 Conc: 19.32	UOM: % Mean Test Assay: 19.31 %	Mean Test Assay: %	

Analyzed By

Jose Vasquez

Certified By

Amalia Real

O₂ 19.31
 CO₂ 9.66
 CC258464
 EXP 4-5-30
 FQ2022 AS4-2222

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty, representation or guarantee as to the accuracy of the data or the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In the event of any claim for damages arising out of the use of the information contained herein exceed the fee established for providing such information.



Making our world
more productive.

DocNumber: 476135



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

MONTROSE AIR QUALITY SERVICES
1631 E ST ANDREWS PLACE
SANTA ANA CA92705

Certificate Issuance Date: 06/03/2022

Linde Order Number: 69438296

Part Number: NI CO4.7ME-AS

Customer PO Number: LUIS OLIVARES

Fill Date: 05/09/2022

Lot Number: 70086212908

Cylinder Style & Outlet: AS CGA 350

Cylinder Pressure and Volume: 2000 psig 140 ft³

Certified Concentration

Expiration Date:	06/02/2030	NIST Traceable
Cylinder Number:	CC205667	Expanded Uncertainty
4.68 ppm	Carbon monoxide	± 0.08 ppm
Balance	Nitrogen	

ProSpec EZ Cert



Certification Information:

Certification Date: 06/02/2022

Term: 96 Months

Expiration Date: 06/02/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon monoxide

Requested Concentration: 4.7 ppm

Certified Concentration: 4.68 ppm

Instrument Used: Horiba VIA-510 S/N 43627990042

Analytical Method: NDIR

Last Multipoint Calibration: 05/27/2022

Reference Standard: Type / Cylinder #: GMIS / CC707397

Concentration / Uncertainty: 9.897 ppm ± 0.048 ppm

Expiration Date: 09/05/2026

Traceable to: SRM # / Sample # / Cylinder #: SRM 1677c / 5-J-42 / CAL015337

SRM Concentration / Uncertainty: 9.825 PPM / ±0.047 PPM

SRM Expiration Date: 06/24/2024

First Analysis Data:				Date
Z:	1.1	R:	99.8	06/02/2022
R:	99.1	Z:	2.4	C: 47.6 Conc: 4.62
Z:	1.5	C:	48.5	R: 101 Conc: 4.71
UOM:	mV	Mean Test Assay: 4.68 ppm		

Second Analysis Data:				Date
Z:	0	R:	0	C: 0 Conc: 0
R:	0	Z:	0	C: 0 Conc: 0
Z:	0	C:	0	R: 0 Conc: 0
UOM:	mV	Mean Test Assay: ppm		

Analyzed By

Courtney Zielke

Certified By

Nelson Ma

CO 4.68
CC205667
EXP 6-2-30
F22022

AS 6-15-23

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.



Making our world
more productive

DocNumber: 464049



Linde Gas & Equipment Inc.
5700 S. Alameda Street
Los Angeles CA 90058
Tel: 323-585-2154
Fax: 714-542-6689
PGVP ID: F22022

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

MONROSE AIR QUALITY SERVICES
1631 E ST ANDREWS PLACE
SANTA ANA CA 97705

Certificate Issuance Date: 05/06/2022

Linde Order Number: 71995830

Fill Date: 04/15/2022

Lot Number: 70086210505

Part Number: NI CO9.5ME-AS

CGA 350

Customer PO Number: 79988098

Cylinder Style & Outlet: AS
Cylinder Pressure and Volume: 2000 psig 140 ft³

ProSpec EZ Cert



Certified Concentration

Expiration Date:	05/06/2030	NIST Traceable
Cylinder Number:	CC181175	Expanded Uncertainty
9.65 ppm	Carbon monoxide	± 0.07 ppm
Balance	Nitrogen	

Certification Information:

Certification Date: 05/06/2022

Term: 96 Months

Expiration Date: 05/06/2030

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1. Uncertainty above is expressed as absolute expanded uncertainty at a level of confidence of approximately 95% with a coverage factor k = 2. Do Not Use this Standard if Pressure is less than 100 PSIG.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:	Carbon monoxide	Reference Standard:	Type / Cylinder #: GMIS / CC707397
Requested Concentration:	9.5 ppm	Concentration / Uncertainty:	9.897 ppm ± 0.048 ppm
Certified Concentration:	9.65 ppm	Expiration Date:	09/05/2026
Instrument Used:	Horiba VIA-510 S/N 43627990042	Traceable to:	SRM # / Sample # / Cylinder #: SRM 1677c / 5-J-42 / CAL015337
Analytical Method:	NDIR	SRM Concentration / Uncertainty:	9.825 PPM / ± 0.047 PPM
Last Multipoint Calibration:	04/26/2022	SRM Expiration Date:	06/24/2024

First Analysis Data:				Date
Z: 8	R: 104.1	C: 101	Conc: 9.63	05/06/2022
R: 103.2	Z: 6.2	C: 101.2	Conc: 9.65	
Z: 5.9	C: 101.4	R: 103.5	Conc: 9.67	
UOM: ppm		Mean Test Assay:	9.65 ppm	

Second Analysis Data:				Date
Z: 0	R: 0	C: 0	Conc: 0	
R: 0	Z: 0	C: 0	Conc: 0	
Z: 0	C: 0	R: 0	Conc: 0	
UOM: ppm		Mean Test Assay:	ppm	

Analyzed By

Courtney Zieba

CO 9.65
CC181175
EXP 5-6-30
F22022

Certified By

Jose Vasquez

AT Salas

Information contained herein has been prepared at your request by qualified experts within Linde Gas & Equipment Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Linde Gas & Equipment Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

SEMI-ANNUAL DRY GAS METER/ORIFICE CALIBRATION

Orifice Method - Triplicate Runs/Four Calibration Points
 English Meter Box Units, English K' Factor
 Filename: M\Santa Ana\Equipment\Test Equipment\Calibrations\Dry Gas Meters\42-WCS\2022\42\WCS Semi Annual Cal 9-23-2022.xls\WCS
 File Modified From: APEX 522 Series Meter box Calibration
 Revised: 4/8/2005

Model #: 522-D Source Sampler
 ID #: 42-WCS
 Date: 9/23/2022
 Bar. Pressure: 29.84 (in. Hg)
 Performed By: L.Olivares
 Reviewed By: M.Chowsanitphon

DRY GAS METER READINGS										CRITICAL ORIFICE READINGS					
dH (in H ₂ O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps. (deg F)	Outlet (deg F)	Final Temps. (deg F)	Inlet (deg F)	Outlet (deg F)	Orifice Serial#	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Initial (deg F)	Ambient Temperature (deg F)	
0.14	26.00	50.000	55.985	55.985	74.0	74.0	14742.33	14735	14742.33	14735	14742.33	15.0	73.0	73.0	
0.14	26.00	55.585	61.160	55.775	74.0	74.0	14742.33	14735	14742.33	14735	14742.33	19.0	73.0	73.0	
0.14	26.00	61.160	66.740	55.880	74.0	74.0	14742.33	14735	14742.33	14735	14742.33	19.0	73.0	73.5	
0.63	12.00	33.000	38.520	5.520	74.0	74.0	74.0	75.0	PK-48	0.3491	18.0	73.0	73.0	73.0	
0.63	12.00	38.520	44.050	5.530	74.0	74.0	74.0	75.0	PK-48	0.3491	18.0	73.0	72.0	72.5	
0.63	12.00	44.050	49.580	5.530	75.0	76.0	76.0	PK-48	0.3491	18.0	72.0	73.0	72.0	72.5	
1.90	7.00	16.000	21.325	5.325	73.0	74.0	74.0	75.0	PK-63	0.5729	17.0	72.0	73.0	72.5	
1.90	7.00	21.325	26.655	5.330	74.0	75.0	75.0	76.0	PK-63	0.5729	17.0	73.0	72.0	72.5	
1.90	7.00	26.655	31.985	5.330	75.0	76.0	76.0	75.0	PK-63	0.5729	17.0	72.0	72.0	72.0	
3.40	5.00	0.000	5.245	5.245	71.0	72.0	72.0	75.0	PK-73	0.7978	16.0	72.0	72.0	72.0	
3.40	5.00	5.245	10.485	5.240	72.0	75.0	75.0	75.0	PK-73	0.7978	16.0	72.0	72.0	72.0	
3.40	5.00	10.485	15.720	5.235	75.0	75.0	75.0	75.0	PK-73	0.7978	16.0	72.0	72.0	72.0	

DRY GAS METER			ORIFICE			DRY GAS METER			ORIFICE			CALIBRATION FACTOR			ORIFICE		
VOLUME CORRECTED Vm(sid) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vm(Std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vm(Std) (cu ft)	VOLUME NOMINAL V _c (cu ft)	VOLUME NOMINAL V _c (cu ft)	VOLUME NOMINAL V _c (cu ft)	VOLUME NOMINAL V _c (cu ft)	Y Value (number)	Y Value (number)	Y Value (number)	dh@ Value (in H ₂ O)					
5.507	156.0	5.494	155.6	5.564	0.998	1.739	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	Pass	Pass	Pass	Pass	Pass	
5.497	155.7	5.494	155.6	5.564	0.999	1.739	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	Pass	Pass	Pass	Pass	Pass	
5.497	155.7	5.492	155.5	5.566	0.999	1.739	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	Pass	Pass	Pass	Pass	Pass	
5.450	154.3	5.415	153.3	5.483	0.994	1.716	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	Pass	Pass	Pass	Pass	Pass	
5.554	154.5	5.417	153.4	5.480	0.993	1.713	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	Pass	Pass	Pass	Pass	Pass	
5.444	154.2	5.417	153.4	5.480	0.995	1.710	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	0.95 < Y < 1.05?	Pass	Pass	Pass	Pass	Pass	
5.279	149.5	5.186	146.9	5.246	0.982	1.922	1.716 < Y < 1.913	1.716 < Y < 1.913	1.716 < Y < 1.913	1.716 < Y < 1.913	1.716 < Y < 1.913	Pass	Pass	Pass	Pass	Pass	
5.274	149.3	5.186	146.9	5.246	0.983	1.918	1.716 < Y < 1.913	1.716 < Y < 1.913	1.716 < Y < 1.913	1.716 < Y < 1.913	1.716 < Y < 1.913	Pass	Pass	Pass	Pass	Pass	
5.264	149.1	5.188	146.9	5.244	0.986	1.913	1.716 < Y < 1.912	1.716 < Y < 1.912	1.716 < Y < 1.912	1.716 < Y < 1.912	1.716 < Y < 1.912	Pass	Pass	Pass	Pass	Pass	
5.238	148.3	5.161	146.2	5.216	0.985	1.779	1.716 < Y < 1.772	1.716 < Y < 1.772	1.716 < Y < 1.772	1.716 < Y < 1.772	1.716 < Y < 1.772	Pass	Pass	Pass	Pass	Pass	
5.213	147.6	5.161	146.2	5.216	0.990	1.772	1.716 < Y < 1.771	1.716 < Y < 1.771	1.716 < Y < 1.771	1.716 < Y < 1.771	1.716 < Y < 1.771	Pass	Pass	Pass	Pass	Pass	
5.194	147.1	5.161	146.2	5.216	0.994	1.767	1.716 < Y < 1.767	1.716 < Y < 1.767	1.716 < Y < 1.767	1.716 < Y < 1.767	1.716 < Y < 1.767	Pass	Pass	Pass	Pass	Pass	
						Average Yd:			0.992			dh@:			1.786		
						Q @ dh =:			0.561								

SIGNED: _____

Signature on File

Note: Control box not equipped with meter inlet temperature reading.

Date: 9/23/2022

Orifice Method - Triplicate Runs/Four Calibration Points
 English Meter Box Units, English K Factor
 Filename:
 File Modified From: APEX 522 Series Meter box Calibration
 Revised: 4/8/2005

Model #: C-5000 (SN 2578)
 ID #: 45-WCS
 Date: 12/6/2022
 Bar. Pressure: 29.90 (in. Hg)
 Performed By: L.Olivares
 Reviewed By: M.Chowsanitphon

DRY GAS METER READINGS

ΔH (in H ₂ O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps. (deg F)	Outlet (deg F)	Inlet (deg F)	Final Temps. Outlet (deg F)
0.14	26.00	386.200	401.655	5.455	69.0	69.0	147.42-33	0.1635
0.14	26.00	401.655	407.110	5.455	69.0	70.0	147.42-33	0.1635
0.14	26.00	407.110	412.565	5.455	70.0	71.0	147.42-33	0.1635
0.65	12.00	376.400	381.780	5.380	67.0	68.0	PK-48	0.3491
0.65	12.00	381.780	387.155	5.385	68.0	68.0	PK-48	0.3491
0.65	12.00	387.155	392.540	5.385	68.0	68.0	PK-48	0.3491
1.80	7.00	360.100	365.250	5.150	67.0	67.0	PK-63	0.5729
1.80	7.00	365.250	370.400	5.150	67.0	67.0	PK-63	0.5729
1.80	7.00	370.400	375.550	5.150	67.0	67.0	PK-63	0.5729
3.60	5.00	343.300	348.410	5.110	67.0	67.0	PK-73	0.7978
3.60	5.00	348.410	353.525	5.115	67.0	67.0	PK-73	0.7978
3.60	5.00	353.525	358.625	5.100	67.0	67.0	PK-73	0.7978

DRY GAS METER

VOLUME CORRECTED V_m (std) (cu ft)	VOLUME CORRECTED V_m (std) (liters)	ORIFICE	VOLUME CORRECTED V_{cr} (std) (cu ft)	VOLUME NOMINAL V_{cr} (cu ft)	Y Value (number)	dH@ Value (in H ₂ O)	CALIBRATION FACTOR	ORIFICE CALIBRATION FACTOR	CALIBRATION FACTOR	Individual Run	Individual Orifice	Orifice Average	Orifice Average	
5.441	154.1		5.550	157.2	5.519	1.020	1.724			0.95 < Y < 1.05?				
5.436	153.9		5.539	156.9	5.530	1.019	1.729				Pass			
5.425	153.6		5.537	156.8	5.532	1.021	1.727				Pass			
5.388	152.6		5.474	155.0	5.434	1.016	1.757				Pass			
5.378	152.3		5.469	154.9	5.439	1.017	1.759				Pass			
5.368	152.6		5.467	154.8	5.441	1.015	1.761				Pass			
5.177	146.6		5.236	148.3	5.207	1.011	1.812				Pass			
5.177	146.6		5.236	148.3	5.207	1.011	1.812				Pass			
5.177	146.6		5.233	148.2	5.209	1.011	1.814				Pass			
5.160	146.1		5.210	147.6	5.176	1.010	1.867				Pass			
5.165	146.3		5.215	147.7	5.171	1.010	1.863				Pass			
5.149	145.8		5.213	147.6	5.174	1.012	1.865				Pass			
				Average	5.174	1.011	1.813				Pass			
					Average	1.014	dH@:	1.791						
							Q @ dH = 1:	0.560						

SIGNED: _____ Signature on File

Note: Control box not equipped with meter inlet temperature reading.

Date: 12/6/2022

Alternative Method 5 Post-Test Calibration (ALT-009)

Client name								DTE Sunshine
Source Name								CT4
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	
Y (dry gas meter calibration value), dimensionless	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992
Y _{qa} (dry gas meter calibration check value), dimensionless	0.988	0.986	1.002	0.981	0.998	1.008	1.028	0.999
Reference temperature, °F	68.0	68.0	68.0	68.0	68.0	68.0	68.0	68.0
• (total run time), min	240.00	240.00	240.00	240.00	240.00	240.00	240.00	240.00
V _m (meter box volume), acf	199.991	198.273	196.276	201.295	199.297	194.565	192.868	197.51
T _m (average dry gas meter temperature), °F	84.5	76.6	91.5	84.8	91.5	74.4	86.3	84.2
P _b (barometric pressure), in. Hg	28.36	28.34	28.34	28.32	28.32	28.26	28.26	28.31
0.0319 = (29.92/(460+Tref))*(0.75*0.75), in. Hg/R * cfm ²	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319
• ΔH _{avg} (average orifice meter differential), in. H ₂ O	2.013	2.000	1.967	2.004	2.008	2.013	2.013	2.002
• H@ (orifice meter calibration coefficient), in. H ₂ O	1.786	1.786	1.786	1.786	1.786	1.786	1.786	1.786
M _d (dry molecular weight of stack gas), lb/lb-mole	29.35	29.36	29.36	29.34	29.33	29.36	29.37	29.35
29 (dry molecular weight of air), lb/lb-mole	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00
13.6 (specific gravity of mercury)	13.60	13.60	13.60	13.60	13.60	13.60	13.60	13.60
Calibration check, % difference:							Criteria	Result
							< 5	0.7

Alternative Method 29 Post-Test Calibration (ALT-009)

Client name								DTE Sunshine
Source Name								CT4
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	
Y (dry gas meter calibration value), dimensionless	1.014	1.014	1.014	1.014	1.014	1.014	1.014	1.014
Y _{qa} (dry gas meter calibration check value), dimensionless	1.028	1.026	1.015	1.010	1.029	1.062	1.060	1.033
Reference temperature, °F	68.0	68.0	68.0	68.0	68.0	68.0	68.0	68.0
• (total run time), min	240.00	240.00	240.00	240.00	240.00	240.00	240.00	240.00
V _m (meter box volume), acf	189.103	189.463	193.355	193.079	191.724	183.187	184.559	189.21
T _m (average dry gas meter temperature), °F	80.4	76.9	90.8	82.4	90.0	77.3	86.6	83.5
P _b (barometric pressure), in. Hg	28.36	28.34	28.34	28.32	28.32	28.26	28.26	28.31
0.0319 = (29.92/(460+Tref))*(0.75*0.75), in. Hg°R * cfm ²	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319
• ΔH _{avg} (average orifice meter differential), in. H ₂ O	1.967	1.979	1.967	1.971	1.988	1.975	1.967	1.973
• H@ (orifice meter calibration coefficient), in. H ₂ O	1.791	1.791	1.791	1.791	1.791	1.791	1.791	1.791
M _d (dry molecular weight of stack gas), lb/lb-mole	29.35	29.36	29.36	29.34	29.33	29.36	29.37	29.35
29 (dry molecular weight of air), lb/lb-mole	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00
13.6 (specific gravity of mercury)	13.60	13.60	13.60	13.60	13.60	13.60	13.60	13.60
Calibration check, % difference:							<u>Criteria</u>	<u>Result</u>
							< 5	1.9

Alternative Method 5 Post-Test Calibration (ALT-009)

								DTE Sunshine
								CT5
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023	
Y (dry gas meter calibration value), dimensionless	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992
Y _{qa} (dry gas meter calibration check value), dimensionless	1.029	1.016	1.004	1.013	1.011	1.016	1.007	1.014
Reference temperature, °F	68.0	68.0	68.0	68.0	68.0	68.0	68.0	68.0
• (total run time), min	240.00	240.00	240.00	240.00	240.00	240.00	240.00	240.00
V _m (meter box volume), acf	189.534	192.261	190.825	191.308	189.553	190.937	191.228	190.81
T _m (average dry gas meter temperature), °F	68.6	76.1	57.9	72.7	61.7	76.0	68.3	68.8
P _b (barometric pressure), in. Hg	27.98	27.98	28.15	28.15	28.33	28.33	28.14	28.15
0.0319 = (29.92/(460+Tref))*(0.75*0.75), in. Hg°R * cfm ²	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319
• ΔH _{avg} (average orifice meter differential), in. H ₂ O	1.992	1.971	1.971	1.963	1.971	1.967	1.954	1.970
• H@ (orifice meter calibration coefficient), in. H ₂ O	1.786	1.786	1.786	1.786	1.786	1.786	1.786	1.786
M _d (dry molecular weight of stack gas), lb/lb-mole	29.33	29.32	29.32	29.31	29.32	29.31	29.33	29.32
29 (dry molecular weight of air), lb/lb-mole	29.00	29.00	29.00	29.00	29.00	29.00	29.00	29.00
13.6 (specific gravity of mercury)	13.60	13.60	13.60	13.60	13.60	13.60	13.60	13.60
Calibration check, % difference:							<u>Criteria</u>	<u>Result</u>
							< 5	2.2

Alternative Method 29 Post-Test Calibration (ALT-009)

Client name	DTE Sunshine						
Source Name	CT5						
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023
Y (dry gas meter calibration value), dimensionless	1.014	1.014	1.014	1.014	1.014	1.014	1.014
Y _{qa} (dry gas meter calibration check value), dimensionless	1.059	1.081	1.057	1.064	1.045	1.069	1.059
Reference temperature, °F	68.0	68.0	68.0	68.0	68.0	68.0	68.0
• (total run time), min	240.00	240.00	240.00	240.00	240.00	240.00	240.00
V _m (meter box volume), acf	182.643	181.832	183.055	183.156	183.107	182.271	183.135
T _m (average dry gas meter temperature), °F	63.2	73.4	58.8	70.5	60.8	76.8	70.7
P _b (barometric pressure), in. Hg	27.98	27.98	28.15	28.15	28.33	28.33	28.14
0.0319 = (29.92/(460+Tref))*(0.75*0.75), in. Hg°R * cfm ²	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319	0.0319
• ΔH _{avg} (average orifice meter differential), in. H ₂ O	1.983	2.008	2.013	1.996	1.975	1.988	1.979
• H@ (orifice meter calibration coefficient), in. H ₂ O	1.791	1.791	1.791	1.791	1.791	1.791	1.791
M _d (dry molecular weight of stack gas), lb/lb-mole	29.33	29.32	29.32	29.31	29.32	29.31	29.33
29 (dry molecular weight of air), lb/lb-mole	29.00	29.00	29.00	29.00	29.00	29.00	29.00
13.6 (specific gravity of mercury)	13.60	13.60	13.60	13.60	13.60	13.60	13.60
Calibration check, % difference:						<u>Criteria</u>	<u>Result</u>
						< 5	4.7



DIGITAL TEMPERATURE READOUT CALIBRATION

Digital Temperature Readout ID: 42-WCS
Readout Description: Control Box
Date: 1/3/2023
Performed By: LO, RMo, DA

Calibrated Thermocouple ID: TC-CAL
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D. TC-CAL	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	42-WCS	363	363	364	363	361	361	361	361	2.3	0.3%
T2 (Boiling H ₂ O)	42-WCS	213	213	212	213	212	212	212	212	0.7	0.1%
T1 (Ice/Water)	42-WCS	35	34	34	34	32	32	32	32	2.3	0.5%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

Thermocouple Source Readings

T/C Source S/N	T/C - Readout °F				T/C Source °F				Difference		
	Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T4 (~650 F)	129103	651	651	651	651	650	650	650	650	1.0	0.1%
T3 (~370 F)	129103	363	363	363	363	370	370	370	370	7.0	0.8%
T2 (~212 F)	129103	213	213	213	213	212	212	212	212	1.0	0.1%
T1 (~32 F)	129103	34	34	34	34	32	32	32	32	2.0	0.4%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



DIGITAL TEMPERATURE READOUT CALIBRATION

Digital Temperature Readout ID: 45-WCS
 Readout Description: Control box
 Date: 1/3/2023
 Performed By: LO, RMo, DA

Calibrated Thermocouple ID: TC-CAL
 T1 Reference Thermometer ID: 313010
 T2 Reference Thermometer ID: 242196
 T3 Reference Thermometer ID: 805002770

T/C I.D. TC-CAL	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	45-WCS	362	362	362	362	361	361	361	361	1.0	0.1%
T2 (Boiling H ₂ O)	45-WCS	217	217	217	217	212	212	212	212	5.0	0.7%
T1 (Ice/Water)	45-WCS	38	38	38	38	32	32	32	32	6.0	1.2%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

Thermocouple Source Readings

T/C Source S/N	T/C - Readout °F				T/C Source °F				Difference		
	Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T4 (~650 F)	129103	655	655	655	655	650	650	650	650	5.0	0.5%
T3 (~370 F)	129103	373	373	373	373	370	370	370	370	3.0	0.4%
T2 (~212 F)	129103	215	215	215	215	212	212	212	212	3.0	0.4%
T1 (~32 F)	129103	34	34	34	34	32	32	32	32	2.0	0.4%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 6

Date: 1/4/2023

Performed By: LO, RMo, DA

Calibrated Digital Temperature Readout ID: PTC-80

T1 Reference Thermometer ID: 313010

T2 Reference Thermometer ID: 242196

T3 Reference Thermometer ID: 805002770

T/C I.D. 6	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	360	363	366	363	365	365	365	365	2.0	0.2%
T2 (Boiling H ₂ O)	PTC-80	207	210	211	209	212	212	212	212	2.7	0.4%
T1 (Ice/Water)	PTC-80	37	37	37	37	32	32	32	32	5.0	1.0%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 7

Date: 1/4/2023

Performed By: LO, RMo, DA

Calibrated Digital Temperature Readout ID: PTC-80

T1 Reference Thermometer ID: 313010

T2 Reference Thermometer ID: 242196

T3 Reference Thermometer ID: 805002770

T/C I.D.	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	362	361	361	361	365	365	365	365	3.7	0.4%
T2 (Boiling H ₂ O)	PTC-80	214	214	214	214	212	212	212	212	2.0	0.3%
T1 (Ice/Water)	PTC-80	34	34	34	34	32	32	32	32	2.0	0.4%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 170

Date: 1/5/2023

Performed By: LO, RMo, DA

Calibrated Digital Temperature Readout ID: PTC-80

T1 Reference Thermometer ID: 313010

T2 Reference Thermometer ID: 242196

T3 Reference Thermometer ID: 805002770

T/C I.D.	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	366	366	366	366	365	365	365	365	1.0	0.1%
T2 (Boiling H ₂ O)	PTC-80	212	212	211	212	212	212	212	212	0.3	0.0%
T1 (Ice/Water)	PTC-80	36	35	35	35	32	32	32	32	3.3	0.7%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 172

Date: 1/5/2023

Performed By: LO, RMo, DA

Calibrated Digital Temperature Readout ID: PTC-80

T1 Reference Thermometer ID: 313010

T2 Reference Thermometer ID: 242196

T3 Reference Thermometer ID: 805002770

T/C I.D.	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	364	365	366	365	365	365	365	365	0.0	0.0%
T2 (Boiling H ₂ O)	PTC-80	210	211	211	211	212	212	212	212	1.3	0.2%
T1 (Ice/Water)	PTC-80	35	35	34	35	32	32	32	32	2.7	0.5%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 75

Date: 1/4/2023

Performed By: LO, RMo, DA

Calibrated Digital Temperature Readout ID: PTC-80

T1 Reference Thermometer ID: 313010

T2 Reference Thermometer ID: 242196

T3 Reference Thermometer ID: 805002770

T/C I.D.	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	366	368	368	367	365	365	365	365	2.3	0.3%
T2 (Boiling H ₂ O)	PTC-80	216	216	216	216	212	212	212	212	4.0	0.6%
T1 (Ice/Water)	PTC-80	35	33	32	33	32	32	32	32	1.3	0.3%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 6
Date: 3/23/2023
Performed By: LO

Calibrated Digital Temperature Readout ID: PTC-80
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D. 6	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	356	356	356	356	360	360	360	360	4.0	0.5%
T2 (Boiling H ₂ O)	PTC-80	210	210	209	210	212	212	212	212	2.3	0.3%
T1 (Ice/Water)	PTC-80	31	31	31	31	32	32	32	32	1.0	0.2%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 7
Date: 3/23/2023
Performed By: LO

Calibrated Digital Temperature Readout ID: PTC-80
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D. 7	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	357	357	357	357	360	360	360	360	3.0	0.4%
T2 (Boiling H ₂ O)	PTC-80	211	211	210	211	212	212	212	212	1.3	0.2%
T1 (Ice/Water)	PTC-80	31	31	31	31	32	32	32	32	1.0	0.2%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 75
Date: 3/23/2023
Performed By: LO

Calibrated Digital Temperature Readout ID: PTC-80
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D.	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	PTC-80	357	357	358	357	360	360	360	360	2.7	0.3%
T2 (Boiling H ₂ O)	PTC-80	209	209	210	209	212	212	212	212	2.7	0.4%
T1 (Ice/Water)	PTC-80	32	32	32	32	32	32	32	32	0.0	0.0%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 170
Date: 3/23/2023
Performed By: LO

Calibrated Digital Temperature Readout ID: PTC-80
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D. 170	Readout I.D.	T/C - Readout °F					Reference Thermometer °F					Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)		
T3 (OIL)	PTC-80	362	362	362	362	360	360	360	360	2.0	0.2%	Pass	
T2 (Boiling H ₂ O)	PTC-80	213	213	213	213	212	212	212	212	1.0	0.1%	Pass	
T1 (Ice/Water)	PTC-80	33	33	32	33	32	32	32	32	0.7	0.1%	Pass	

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



THERMOCOUPLE CALIBRATION

Thermocouple ID: 172
Date: 3/23/2023
Performed By: LO

Calibrated Digital Temperature Readout ID: PTC-80
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D.	Readout I.D.	T/C - Readout °F					Reference Thermometer °F					Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)		
T3 (OIL)	PTC-80	364	364	364	364	360	360	360	360	4.0	0.5%	Pass	
T2 (Boiling H ₂ O)	PTC-80	214	214	214	214	212	212	212	212	2.0	0.3%	Pass	
T1 (Ice/Water)	PTC-80	34	33	33	33	32	32	32	32	1.3	0.3%	Pass	

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



DIGITAL TEMPERATURE READOUT CALIBRATION

Digital Temperature Readout ID: 42-WCS
Readout Description: Control Box
Date: 3/23/2023
Performed By: LO

Calibrated Thermocouple ID: 7
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D. 7	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	42-WCS	358	358	358	358	360	360	360	360	2.0	0.2%
T2 (Boiling H ₂ O)	42-WCS	210	211	211	211	212	212	212	212	1.3	0.2%
T1 (Ice/Water)	42-WCS	32	32	32	32	32	32	32	32	0.0	0.0%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

Thermocouple Source Readings

T/C Source S/N	T/C - Readout °F				T/C Source °F				Difference		
	Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T4 (~650 F)	129103	649	649	649	649	650	650	650	650	1.0	0.1%
T3 (~370 F)	129103	368	369	369	369	370	370	370	370	1.3	0.2%
T2 (~212 F)	129103	212	212	212	212	212	212	212	212	0.0	0.0%
T1 (~32 F)	129103	32	32	32	32	32	32	32	32	0.0	0.0%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



DIGITAL TEMPERATURE READOUT CALIBRATION

Digital Temperature Readout ID: 45-WCS
Readout Description: Control Box
Date: 3/23/2023
Performed By: LO

Calibrated Thermocouple ID: 7
T1 Reference Thermometer ID: 313010
T2 Reference Thermometer ID: 242196
T3 Reference Thermometer ID: 805002770

T/C I.D. 7	Readout I.D.	T/C - Readout °F				Reference Thermometer °F				Difference	
		Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)
T3 (OIL)	45-WCS	360	360	360	360	360	360	360	360	0.0	0.0%
T2 (Boiling H ₂ O)	45-WCS	211	211	211	211	212	212	212	212	1.0	0.1%
T1 (Ice/Water)	45-WCS	32	32	31	32	32	32	32	32	0.3	0.1%

1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)

Thermocouple Source Readings

T/C Source S/N	T/C - Readout °F				T/C Source °F				Difference		
	Reading 1	Reading 2	Reading 3	Average	Reading 1	Reading 2	Reading 3	Average	°F	%, (°R)	
T4 (~650 F)	129103	648	648	648	648	650	650	650	650	2.0	0.2%
T3 (~370 F)	129103	367	367	367	367	370	370	370	370	3.0	0.4%
T2 (~212 F)	129103	210	210	210	210	212	212	212	212	2.0	0.3%
T1 (~32 F)	129103	31	31	31	31	32	32	32	32	1.0	0.2%


1) Difference % (°R) = Difference (°F) / (Average Tref + 460)

2) Pass if all Differences are less than 1.5% (°R)



MONTROSE

S Type Pitot Tube Dimensional Calibration Record



Acceptability Criteria																									
Pitot ID	Date	Calibrated By	Calibrated By	"3/16" < Dt < 3/8"	w < 1/32"	Side View, Impact openings Properly aligned, z < 1/8"	Pa = Pb	Tubing Diameter, dt	M1	M2	M3	M4	M5	M6	n/a	n/a	n/a	n/a	n/a	5 degrees	10 degrees	Average Face Opening Plane Angle, offset from parallel to transverse axis	Average Face Opening Plane Frontal Angle from parallel to Longitudinal Axis	Ratio of P/Pt	Status
075	1/3/23	N.G.	Y	Y	Y	Y	Y	0.375	0.933	0.933	0.945	0.937	0.411	0.400	0.0	0.6	0.0	0.6	1.2	Pass					


Notes:

Reference "A Type-S Pitot Tube Calibration Study": Robert F. Vollaro, October 15, 1975

Reference is made to U.S. Pat. No. 3,700,157, issued Oct. 15, 1973, entitled "Piston Type Seal for a Piston Rod", which is assigned to the assignee of the present invention.



S Type Pitot Tube Dimensional Calibration Record



Acceptability Criteria		$z < 1/8"$	$w < 1/32"$	$"3/16" < D_t < 3/8"$	Yes	n/a	n/a	n/a	n/a	n/a	10 degrees	5 degrees	$1.05 D_t < P < 1.5 D_t$		
Pitot ID	Date	Calibrated By	Side View, Impact openings Properly aligned, $z < 1/8"$	Tubing Diameter, d_t	$P_a = P_b$	M1	M2	M3	M4	M5	M6	Average Face Opening Plane Angle, offset from parallel to perpendicular to transverse axis	Average Face Frontal Angle from longitudinal Axis	Ratio of P/d_t	Status
006	1/3/23	N.G.	Y	0.375	0.944	0.947	0.949	0.946	0.946	0.355	-0.2	0.2	1.3	Pass	
007	1/3/23	N.G.	Y	0.375	0.929	0.930	0.936	0.936	0.369	0.370	-0.1	0.0	1.2	Pass	


Notes:

Reference "A Type-S Pitot Tube Calibration Study", Robert F. Vollaro, October 15, 1975
If tube is not visibly deformed it is assumed that $P_a = P_b = .5 \times \text{avg. of } M_1 \text{ & } M_2$, and that average face opening plane angles represent individual angles to tube axis



MONROE

S Type Pitot Tube Dimensional Calibration Record




Acceptability Criteria		w < 1/32"	"3/16" < Dt < 3/8"	n/a	n/a	n/a	n/a	n/a	n/a	10 degrees	5 degrees	1.05 Dt < P < 1.5 Dt	Status		
Pivot ID	Date	Calibrated By	Side View, Impact openings Properly aligned, w < 1/32"	Side View, Impact openings Properly aligned, w < 1/32"	Tubing Diameter, dt Pw = Pb	M1	M2	M3	M4	M5	M6	Average Face Opening Plane Frontal Angle, offset from parallel to longitudinal axis	Ratio of P/Dt	Status	
170	1/3/23	N.G.	Y	Y	0.370	0.880	0.881	0.880	0.888	0.419	0.409	-0.6	1.2	Pass	
172	1/3/23	N.G.	Y	Y	0.375	0.816	0.809	0.812	0.806	0.434	0.426	0.5	0.4	1.1	Pass

Notes:

Reference "A Type-S Pitot Tube Calibration Study", Robert F. Vollaro, October 15, 1975

Reference A-type S-100 tube calibration study; Robert F. Vanderschueren, October 15, 1975
 Reference A-type S-100 tube is not visibly deformed if it is assumed that $P_A = P_B$.
 $P_A = 100 \text{ kPa}$ and $P_B = 100 \text{ kPa}$. M2, and that a average face opening plane angles represent individual angles to tube axis

FACILITY: SUNSHINE
SOURCE TESTED: TURBIN COOLER 4 to 5
CALIBRATED BY: BO
DATE: 2/6/23




NOZZLE ID	READING (INCHES)			AVG DIA.
	A	B	C	
NG-15	0.251	0.254	0.254	0.254

Calibrated by:



Measuring Device Used : Mitutoyo Digital Calipers
Serial Number : 0247955
Model Number : CD-6" CS
Resolution : 0.01mm or 0.0005"/0.01mm
Accuracy : $\pm 0.02\text{mm}$ or $\pm 0.001"/\pm 0.02\text{mm}$

FACILITY: SUNSHINE
SOURCE TESTED: TURBINE/COGON 4k5
CALIBRATED BY: JAN
DATE: 2/16/23




NOZZLE ID	READING (INCHES)			AVG DIA.
	A	B	C	
296	0.254	0.255	0.254	0.254

Calibrated by:

Measuring Device Used : Mitutoyo Digital Calipers
Serial Number : 0247955
Model Number : CD-6" CS
Resolution : 0.01mm or 0.0005"/0.01mm
Accuracy : $\pm 0.02\text{mm}$ or $\pm 0.001"/\pm 0.02\text{mm}$

FACILITY: SUNSHINE
SOURCE TESTED: TURBINE COGEN 4E5
CALIBRATED BY: SPW
DATE: 2/16/22




NOZZLE ID	READING (INCHES)			AVG DIA.
	A	B	C	
N62-2	0.258	0.257	0.257	0.257

Calibrated by:

Measuring Device Used : Mitutoyo Digital Calipers
Serial Number : 0247955
Model Number : CD-6" CS
Resolution : 0.01mm or 0.0005"/0.01mm
Accuracy : $\pm 0.02\text{mm}$ or $\pm 0.001"/\pm 0.02\text{mm}$

FACILITY: SUNSHINE
SOURCE TESTED: TURBINE COOLER 4 E5
CALIBRATED BY: Sunshine
DATE: 2/6/23



NOZZLE ID	READING (INCHES)			AVG DIA.
	A	B	C	
266	0.257	0.257	0.257	0.257

Calibrated by:

Measuring Device Used : Mitutoyo Digital Calipers
Serial Number : 0247955
Model Number : CD-6" CS
Resolution : 0.01mm or 0.0005"/0.01mm
Accuracy : $\pm 0.02\text{mm}$ or $\pm 0.001"/\pm 0.02\text{mm}$

APPENDIX B PLANT DATA

Appendix B.1 CT-4 Data

CeDAR 1-Minute Data
Sunshine Gas Producers, LLC
Data for 2/7/2023 8:00 AM thru 2/7/2023 6:00 PM

Timestamp	Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F - Min
2/7 8:00	104388.0	47.90	4.2	1199.8
2/7 8:01	105141.0	48.23	4.2	1200.0
2/7 8:02	103899.0	47.65	4.2	1200.0
2/7 8:03	104771.0	48.05	4.2	1200.0
2/7 8:04	106331.0	48.79	4.2	1200.2
2/7 8:05	105420.0	48.36	4.2	1200.0
2/7 8:06	105163.0	48.26	4.2	1199.8
2/7 8:07	107116.0	49.16	4.2	1199.8
2/7 8:08	105750.0	48.53	4.2	1200.0
2/7 8:09	105054.0	48.21	4.2	1200.2
2/7 8:10	103899.0	47.71	4.2	1200.2
2/7 8:11	107030.0	49.23	4.2	1200.0
2/7 8:12	104601.0	48.12	4.2	1199.8
2/7 8:13	105332.0	48.42	4.2	1200.0
2/7 8:14	105054.0	48.21	4.2	1200.0
2/7 8:15	103763.0	47.62	4.2	1200.0
2/7 8:16	105705.0	48.54	4.2	1200.3
2/7 8:17	103628.0	47.67	4.2	1200.0
2/7 8:18	103893.0	47.79	4.2	1200.2
2/7 8:19	103278.0	47.51	4.2	1199.8
2/7 8:20	104625.0	48.11	4.2	1199.8
2/7 8:21	105395.0	48.34	4.2	1199.8
2/7 8:22	104058.0	47.73	4.2	1199.7
2/7 8:23	103690.0	47.56	4.2	1200.2
2/7 8:24	104748.0	48.07	4.2	1200.2
2/7 8:25	103324.0	47.41	4.2	1200.2
2/7 8:26	103857.0	47.66	4.2	1200.0
2/7 8:27	105607.0	48.32	4.2	1199.8
2/7 8:28	105191.0	48.10	4.2	1199.8
2/7 8:29	105320.0	48.13	4.2	1200.0
2/7 8:30	105654.0	48.37	4.2	1199.8
2/7 8:31	105412.0	48.26	4.2	1199.8
2/7 8:32	106026.0	48.54	4.2	1199.8
2/7 8:33	104610.0	47.89	4.2	1199.8
2/7 8:34	103401.0	47.25	4.2	1200.0
2/7 8:35	104984.0	47.98	4.2	1200.0
2/7 8:36	105221.0	48.20	4.2	1200.0
2/7 8:37	104839.0	48.11	4.2	1200.0
2/7 8:38	103374.0	47.52	4.2	1200.3
2/7 8:39	103532.0	47.62	4.2	1200.2
2/7 8:40	104200.0	47.93	4.2	1200.0
2/7 8:41	104455.0	48.05	4.2	1200.0
2/7 8:42	104905.0	48.26	4.2	1199.8
2/7 8:43	104406.0	48.03	4.2	1199.8
2/7 8:44	102909.0	47.34	4.2	1200.0

Timestamp	(TG-741) Landfill Gas Flow scf/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
2/7 8:45	104582.0	48.09	4.2	1200.0	
2/7 8:46	104259.0	47.96	4.2	1200.0	
2/7 8:47	103847.0	47.77	4.2	1200.2	
2/7 8:48	104681.0	48.13	4.2	1200.0	
2/7 8:49	104404.0	47.91	4.2	1200.0	
2/7 8:50	103910.0	47.68	4.2	1200.0	
2/7 8:51	102602.0	47.10	4.2	1199.8	
2/7 8:52	102731.0	47.17	4.2	1199.7	
2/7 8:53	105686.0	48.42	4.2	1200.0	
2/7 8:54	104075.0	47.65	4.2	1200.0	
2/7 8:55	105171.0	48.18	4.2	1200.0	
2/7 8:56	104945.0	48.16	4.2	1200.2	
2/7 8:57	104485.0	47.93	4.2	1199.8	
2/7 8:58	103987.0	47.61	4.2	1200.2	
2/7 8:59	104301.0	47.86	4.2	1200.0	
2/7 9:00	104856.0	48.04	4.2	1199.7	
2/7 9:01	104476.0	47.78	4.2	1199.8	
2/7 9:02	104375.0	47.67	4.2	1200.3	
2/7 9:03	102777.0	46.94	4.2	1200.2	
2/7 9:04	104675.0	47.87	4.2	1200.2	
2/7 9:05	106145.0	48.60	4.2	1200.0	
2/7 9:06	104662.0	47.91	4.2	1199.8	
2/7 9:07	104374.0	47.78	4.2	1199.8	
2/7 9:08	103985.0	47.38	4.2	1199.2	
2/7 9:09	103242.0	46.67	4.2	1200.2	
2/7 9:10	103636.0	47.22	4.2	1200.2	
2/7 9:11	105428.0	48.10	4.2	1200.2	
2/7 9:12	105074.0	47.99	4.2	1200.0	
2/7 9:13	103554.0	47.29	4.2	1200.2	
2/7 9:14	103498.0	47.27	4.2	1199.7	
2/7 9:15	104027.0	47.49	4.2	1199.7	
2/7 9:16	104603.0	47.72	4.2	1200.0	
2/7 9:17	103493.0	47.26	4.2	1200.0	
2/7 9:18	104000.0	47.44	4.2	1200.0	
2/7 9:19	105338.0	47.99	4.2	1200.0	
2/7 9:20	105114.0	47.81	4.2	1200.2	
2/7 9:21	104651.0	47.56	4.2	1199.8	
2/7 9:22	104123.0	47.32	4.2	1200.0	
2/7 9:23	103476.0	47.03	4.2	1200.0	
2/7 9:24	104951.0	47.79	4.2	1200.0	
2/7 9:25	104222.0	47.48	4.2	1200.3	
2/7 9:26	103601.0	47.20	4.2	1200.0	
2/7 9:27	106218.0	48.46	4.2	1199.8	
2/7 9:28	104898.0	47.79	4.2	1200.2	
2/7 9:29	104315.0	47.53	4.2	1200.0	
2/7 9:30	105539.0	48.06	4.2	1200.2	
2/7 9:31	104958.0	47.70	4.2	1199.5	
2/7 9:32	105547.0	47.80	4.2	1199.8	
2/7 9:33	104251.0	47.02	4.2	1199.8	

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat Input mmBtuhr	(TG-741) Megawatts 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/7 9:34	104561.0	47.01	4.2	1199.7	
2/7 9:35	104527.0	47.09	4.2	1200.2	
2/7 9:36	104663.0	47.32	4.2	1200.0	
2/7 9:37	104295.0	47.19	4.2	1199.8	
2/7 9:38	104666.0	47.24	4.2	1199.8	
2/7 9:39	105418.0	47.44	4.2	1200.0	
2/7 9:40	107856.0	48.42	4.2	1200.0	
2/7 9:41	106300.0	47.72	4.2	1200.3	
2/7 9:42	108417.0	48.83	4.2	1198.8	
2/7 9:43	106916.0	47.35	4.2	1199.8	
2/7 9:44	106449.0	46.97	4.2	1201.0	
2/7 9:45	104114.0	46.83	4.2	1200.7	
2/7 9:46	107450.0	48.12	4.2	1198.5	
2/7 9:47	108892.0	47.72	4.2	1200.5	
2/7 9:48	107915.0	47.44	4.2	1199.7	
2/7 9:49	107319.0	47.84	4.2	1201.2	
2/7 9:50	104191.0	46.98	4.2	1200.0	
2/7 9:51	107625.0	48.27	4.2	1199.7	
2/7 9:52	105917.0	47.34	4.2	1200.0	
2/7 9:53	105339.0	47.08	4.2	1199.7	
2/7 9:54	103696.0	46.72	4.2	1201.0	
2/7 9:55	104349.0	47.47	4.2	1200.2	
2/7 9:56	105664.0	48.17	4.2	1199.7	
2/7 9:57	104297.0	47.45	4.2	1199.8	
2/7 9:58	103546.0	46.99	4.2	1200.2	
2/7 9:59	104105.0	47.10	4.2	1199.3	
2/7 10:00	106914.0	47.64	4.2	1199.7	
2/7 10:01	105637.0	47.35	4.2	1200.7	
2/7 10:02	102815.0	46.65	4.2	1200.7	
2/7 10:03	103872.0	47.32	4.2	1199.8	
2/7 10:04	103850.0	47.26	4.2	1200.0	
2/7 10:05	105064.0	47.72	4.2	1199.5	
2/7 10:06	104790.0	47.41	4.2	1199.7	
2/7 10:07	104438.0	47.25	4.2	1200.0	
2/7 10:08	106364.0	48.22	4.2	1200.5	
2/7 10:09	102714.0	46.77	4.2	1200.0	
2/7 10:10	103144.0	47.01	4.2	1200.2	
2/7 10:11	104244.0	47.61	4.2	1198.7	
2/7 10:12	104711.0	47.10	4.2	1200.7	
2/7 10:13	103832.0	47.00	4.2	1200.8	
2/7 10:14	102719.0	46.88	4.2	1200.0	
2/7 10:15	103564.0	47.30	4.2	1199.7	
2/7 10:16	103049.0	46.95	4.2	1199.7	
2/7 10:17	104094.0	47.28	4.2	1200.2	
2/7 10:18	105537.0	48.05	4.2	1200.0	
2/7 10:19	103409.0	47.13	4.2	1200.5	
2/7 10:20	101673.0	46.43	4.2	1199.8	
2/7 10:21	103552.0	47.20	4.2	1199.7	
2/7 10:22	104189.0	47.30	4.2	1200.0	

	(TG-741) Landfill Gas Flow scfh 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
2/7 10:23	103734.0	47.21	4.2	1200.7
2/7 10:24	104496.0	47.67	4.2	1200.0
2/7 10:25	104046.0	47.52	4.2	1199.8
2/7 10:26	102253.0	46.70	4.2	1200.2
2/7 10:27	103279.0	47.17	4.2	1199.7
2/7 10:28	104394.0	47.58	4.2	1200.0
2/7 10:29	104177.0	47.33	4.2	1199.2
2/7 10:30	106506.0	48.10	4.2	1200.5
2/7 10:31	104283.0	47.13	4.2	1200.2
2/7 10:32	101786.0	46.13	4.2	1200.0
2/7 10:33	102677.0	46.56	4.2	1200.2
2/7 10:34	104379.0	47.31	4.2	1200.3
2/7 10:35	104772.0	47.48	4.2	1200.2
2/7 10:36	101688.0	46.11	4.2	1200.5
2/7 10:37	101887.0	46.35	4.2	1200.2
2/7 10:38	102510.0	46.70	4.2	1200.0
2/7 10:39	103352.0	47.09	4.2	1200.0
2/7 10:40	104771.0	47.73	4.2	1200.0
2/7 10:41	103220.0	47.03	4.2	1199.8
2/7 10:42	103610.0	47.13	4.2	1200.2
2/7 10:43	101481.0	46.23	4.2	1199.7
2/7 10:44	102936.0	46.96	4.2	1200.0
2/7 10:45	100899.0	46.08	4.2	1199.8
2/7 10:46	103233.0	47.09	4.2	1200.2
2/7 10:47	104955.0	47.94	4.2	1199.7
2/7 10:48	103273.0	46.94	4.2	1200.0
2/7 10:49	104835.0	47.67	4.2	1200.3
2/7 10:50	105670.0	48.14	4.2	1200.0
2/7 10:51	102467.0	46.72	4.2	1200.0
2/7 10:52	104267.0	47.57	4.2	1199.5
2/7 10:53	103641.0	47.17	4.2	1200.3
2/7 10:54	102167.0	46.64	4.2	1200.0
2/7 10:55	103342.0	47.23	4.2	1200.2
2/7 10:56	103907.0	47.59	4.2	1199.8
2/7 10:57	102899.0	47.11	4.2	1200.0
2/7 10:58	101856.0	46.62	4.2	1199.8
2/7 10:59	103772.0	47.39	4.2	1200.2
2/7 11:00	103921.0	47.54	4.2	1200.0
2/7 11:01	103324.0	47.30	4.2	1200.0
2/7 11:02	103760.0	47.50	4.2	1200.2
2/7 11:03	101793.0	46.62	4.2	1199.7
2/7 11:04	105043.0	48.09	4.2	1200.3
2/7 11:05	103123.0	47.21	4.2	1200.2
2/7 11:06	102476.0	46.94	4.2	1199.8
2/7 11:07	104310.0	47.75	4.2	1200.0
2/7 11:08	103609.0	47.45	4.2	1200.2
2/7 11:09	99523.0	45.64	4.2	1200.0
2/7 11:10	102697.0	47.07	4.2	1200.0
2/7 11:11	103728.0	47.54	4.2	1200.0

Page 4 of 13

Cedar 5 Reports 3/6/2023 6:39 AM, CeDAR 1-Minute Data

	(TG-741) Landfill Gas Flow scfh/r 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) ITT °F 1-Min
27/11:12	104177.0	47.69	4.2	1200.3	
27/11:13	103218.0	47.31	4.2	1200.0	
27/11:14	101910.0	46.77	4.2	1200.0	
27/11:15	100967.0	46.34	4.2	1199.7	
27/11:16	103052.0	47.29	4.2	1200.0	
27/11:17	103368.0	47.44	4.2	1200.0	
27/11:18	101725.0	46.86	4.2	1200.0	
27/11:19	102194.0	46.87	4.2	1199.8	
27/11:20	105316.0	48.33	4.2	1200.0	
27/11:21	103833.0	47.63	4.2	1200.2	
27/11:22	101863.0	46.77	4.2	1200.0	
27/11:23	103563.0	47.53	4.2	1200.0	
27/11:24	102952.0	47.24	4.2	1200.0	
27/11:25	101651.0	46.65	4.2	1200.3	
27/11:26	102637.0	47.12	4.2	1200.3	
27/11:27	103445.0	47.47	4.2	1198.2	
27/11:28	105075.0	47.38	4.2	1199.0	
27/11:29	108341.0	47.67	4.2	1200.0	
27/11:30	108133.0	47.06	4.2	1199.3	
27/11:31	107944.0	47.50	4.2	1202.8	
27/11:32	102878.0	46.63	4.2	1200.8	
27/11:33	104262.0	47.41	4.1	1197.5	
27/11:34	106389.0	47.23	4.2	1202.7	
27/11:35	102566.0	46.64	4.2	1199.8	
27/11:36	105489.0	48.04	4.2	1200.8	
27/11:37	102894.0	47.24	4.2	1199.2	
27/11:38	104240.0	47.59	4.2	1200.2	
27/11:39	102480.0	47.01	4.2	1199.8	
27/11:40	103511.0	47.36	4.2	1200.3	
27/11:41	102507.0	47.02	4.2	1200.5	
27/11:42	101007.0	46.52	4.2	1200.2	
27/11:43	101696.0	46.89	4.2	1200.2	
27/11:44	103969.0	47.89	4.2	1199.8	
27/11:45	100137.0	46.06	4.2	1200.0	
27/11:46	103370.0	47.55	4.2	1200.5	
27/11:47	102455.0	47.16	4.2	1200.2	
27/11:48	101309.0	46.71	4.2	1200.0	
27/11:49	101345.0	46.78	4.2	1200.0	
27/11:50	101078.0	46.68	4.2	1200.0	
27/11:51	101491.0	46.80	4.2	1200.0	
27/11:52	101023.0	46.58	4.2	1199.8	
27/11:53	100647.0	46.41	4.2	1199.8	
27/11:54	101985.0	47.03	4.2	1200.2	
27/11:55	102737.0	47.37	4.2	1200.0	
27/11:56	101627.0	46.86	4.2	1199.7	
27/11:57	101270.0	46.70	4.2	1200.2	
27/11:58	102940.0	47.47	4.2	1200.2	
27/11:59	101891.0	46.98	4.2	1200.2	
27/12:00	103767.0	47.87	4.2	1200.3	

	(TG-741) Landfill Gas Flow soft/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
2/7 12:01	101436.0	46.91	4.2	1199.8
2/7 12:02	101959.0	47.13	4.2	1200.0
2/7 12:03	100440.0	46.42	4.2	1200.2
2/7 12:04	100178.0	46.30	4.2	1200.0
2/7 12:05	100840.0	46.61	4.2	1199.8
2/7 12:06	100340.0	46.32	4.2	1199.8
2/7 12:07	101730.0	47.02	4.2	1200.0
2/7 12:08	101933.0	47.11	4.2	1200.0
2/7 12:09	102387.0	47.32	4.2	1200.3
2/7 12:10	100241.0	46.40	4.2	1200.0
2/7 12:11	99675.0	46.14	4.2	1200.0
2/7 12:12	102770.0	47.50	4.1	1199.8
2/7 12:13	103397.0	47.79	4.1	1200.2
2/7 12:14	99475.0	45.98	4.1	1200.0
2/7 12:15	99669.0	46.09	4.1	1200.2
2/7 12:16	100756.0	46.62	4.1	1199.8
2/7 12:17	100283.0	46.42	4.1	1200.2
2/7 12:18	100023.0	46.34	4.2	1200.0
2/7 12:19	100566.0	46.55	4.2	1199.8
2/7 12:20	100296.0	46.39	4.2	1200.0
2/7 12:21	100872.0	46.73	4.2	1199.7
2/7 12:22	102993.0	47.68	4.2	1200.2
2/7 12:23	101728.0	47.16	4.2	1200.0
2/7 12:24	100663.0	46.64	4.2	1199.8
2/7 12:25	100240.0	46.47	4.2	1200.2
2/7 12:26	100171.0	46.48	4.2	1199.8
2/7 12:27	103282.0	47.90	4.2	1199.8
2/7 12:28	100122.0	46.39	4.2	1200.0
2/7 12:29	101740.0	47.14	4.1	1200.0
2/7 12:30	100375.0	46.40	4.2	1200.2
2/7 12:31	101012.0	46.77	4.1	1199.7
2/7 12:32	102820.0	47.43	4.1	1200.0
2/7 12:33	100621.0	46.42	4.2	1200.3
2/7 12:34	102027.0	47.24	4.1	1200.5
2/7 12:35	101223.0	46.90	4.1	1199.8
2/7 12:36	100864.0	46.73	4.2	1200.0
2/7 12:37	100697.0	46.65	4.2	1200.0
2/7 12:38	102038.0	47.31	4.2	1200.0
2/7 12:39	100870.0	46.83	4.2	1200.0
2/7 12:40	100468.0	46.65	4.2	1200.0
2/7 12:41	100961.0	46.81	4.2	1199.7
2/7 12:42	102354.0	47.42	4.2	1199.8
2/7 12:43	103820.0	47.87	4.2	1199.8
2/7 12:44	101348.0	46.64	4.1	1200.0
2/7 12:45	101111.0	46.49	4.1	1200.2
2/7 12:46	102465.0	47.12	4.1	1199.7
2/7 12:47	101771.0	46.70	4.1	1199.8
2/7 12:48	101327.0	46.53	4.2	1200.2
2/7 12:49	101774.0	46.78	4.2	1199.8

Page 6 of 13

Cedar 5 Reports 3/8/2023 6:39 AM, CeDAR 1-Minute Data

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/7 12:50	102275.0	47.03	4.2	1199.8
2/7 12:51	100798.0	46.35	4.2	1199.8
2/7 12:52	102373.0	47.01	4.2	1200.0
2/7 12:53	101592.0	46.73	4.2	1200.7
2/7 12:54	103447.0	47.81	4.1	1199.8
2/7 12:55	101306.0	46.73	4.1	1199.8
2/7 12:56	102247.0	47.07	4.2	1200.2
2/7 12:57	102539.0	47.22	4.2	1200.0
2/7 12:58	102237.0	47.40	4.2	1200.0
2/7 12:59	100388.0	46.42	4.2	1200.2
2/7 13:00	102898.0	47.63	4.2	1200.0
2/7 13:01	100704.0	46.62	4.2	1200.0
2/7 13:02	101280.0	47.02	4.2	1200.0
2/7 13:03	100849.0	46.82	4.2	1200.2
2/7 13:04	100482.0	46.65	4.1	1200.0
2/7 13:05	100345.0	46.65	4.1	1199.7
2/7 13:06	100239.0	46.54	4.2	1199.8
2/7 13:07	100333.0	46.56	4.2	1200.0
2/7 13:08	100863.0	46.81	4.2	1200.3
2/7 13:09	102262.0	47.65	4.2	1200.0
2/7 13:10	103567.0	48.09	4.2	1200.2
2/7 13:11	101337.0	47.05	4.1	1200.2
2/7 13:12	100304.0	46.57	4.1	1199.8
2/7 13:13	101634.0	47.22	4.2	1200.0
2/7 13:14	101090.0	46.97	4.1	1200.0
2/7 13:15	101661.0	47.23	4.2	1199.7
2/7 13:16	101813.0	47.27	4.2	1200.0
2/7 13:17	101571.0	47.16	4.1	1200.0
2/7 13:18	100605.0	46.69	4.1	1199.7
2/7 13:19	100334.0	46.58	4.2	1199.8
2/7 13:20	101333.0	47.09	4.2	1199.8
2/7 13:21	100902.0	46.96	4.2	1200.0
2/7 13:22	100433.0	46.74	4.2	1200.0
2/7 13:23	101871.0	47.39	4.1	1200.2
2/7 13:24	100217.0	46.64	4.1	1199.7
2/7 13:25	100685.0	46.86	4.2	1200.3
2/7 13:26	100805.0	46.90	4.2	1200.5
2/7 13:27	100080.0	46.58	4.2	1199.8
2/7 13:28	99949.0	46.49	4.1	1200.0
2/7 13:29	100620.0	46.83	4.2	1200.0
2/7 13:30	102513.0	47.71	4.2	1200.0
2/7 13:31	102003.0	47.45	4.2	1200.0
2/7 13:32	101815.0	47.28	4.2	1199.8
2/7 13:33	100695.0	46.76	4.2	1199.8
2/7 13:34	100590.0	46.89	4.2	1199.7
2/7 13:35	101419.0	47.09	4.2	1199.8
2/7 13:36	103179.0	47.77	4.2	1200.2
2/7 13:37	101965.0	47.21	4.2	1200.2
2/7 13:38	101183.0	46.85	4.2	1200.0

	(TG-741) Landfill Gas Flow scf/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts·Min	(TG-741) T7 °F 1-Min
2/7 13:39	101954.0	47.14	4.1	1200.2
2/7 13:40	102777.0	47.54	4.2	1199.8
2/7 13:41	102047.0	47.19	4.2	1200.3
2/7 13:42	102112.0	47.28	4.2	1199.7
2/7 13:43	101807.0	47.06	4.2	1199.8
2/7 13:44	101201.0	46.77	4.2	1199.7
2/7 13:45	103307.0	47.75	4.2	1200.2
2/7 13:46	100099.0	46.29	4.2	1200.3
2/7 13:47	102448.0	47.47	4.2	1200.3
2/7 13:48	101366.0	46.96	4.1	1200.3
2/7 13:49	101093.0	46.84	4.1	1199.8
2/7 13:50	101488.0	47.07	4.2	1200.0
2/7 13:51	100992.0	46.79	4.1	1200.0
2/7 13:52	101301.0	46.93	4.2	1199.7
2/7 13:53	100393.0	46.48	4.1	1200.2
2/7 13:54	100302.0	46.43	4.1	1200.0
2/7 13:55	100674.0	46.60	4.1	1200.0
2/7 13:56	101131.0	46.79	4.2	1199.8
2/7 13:57	100656.0	46.61	4.2	1199.8
2/7 13:58	101876.0	47.17	4.2	1200.3
2/7 13:59	102077.0	47.23	4.2	1199.7
2/7 14:00	100940.0	46.65	4.2	1200.0
2/7 14:01	99958.0	46.08	4.2	1200.2
2/7 14:02	101573.0	47.06	4.2	1199.8
2/7 14:03	100711.0	46.57	4.2	1200.2
2/7 14:04	101049.0	46.82	4.2	1200.2
2/7 14:05	104967.0	48.25	4.2	1198.7
2/7 14:06	102936.0	46.82	4.2	1201.3
2/7 14:07	101702.0	46.85	4.2	1200.2
2/7 14:08	100288.0	46.24	4.2	1200.3
2/7 14:09	101653.0	46.95	4.1	1199.7
2/7 14:10	101353.0	46.73	4.2	1200.0
2/7 14:11	100929.0	46.47	4.1	1199.8
2/7 14:12	100084.0	46.06	4.2	1200.2
2/7 14:13	103388.0	47.67	4.2	1200.2
2/7 14:14	102221.0	47.13	4.2	1200.5
2/7 14:15	102196.0	47.14	4.2	1199.7
2/7 14:16	101002.0	46.59	4.2	1199.8
2/7 14:17	100677.0	46.42	4.2	1200.0
2/7 14:18	102305.0	47.18	4.2	1200.3
2/7 14:19	100331.0	46.34	4.2	1200.0
2/7 14:20	100761.0	46.53	4.2	1200.0
2/7 14:21	101961.0	46.93	4.2	1199.2
2/7 14:22	106233.0	47.82	4.2	1200.5
2/7 14:23	103213.0	46.22	4.2	1201.7
2/7 14:24	100241.0	46.33	4.2	1201.2
2/7 14:25	101044.0	46.97	4.2	1200.0
2/7 14:26	100257.0	46.74	4.2	1199.7
2/7 14:27	100809.0	46.84	4.2	1199.0

	(TG-741) Landfill Gas Flow siffr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
Timestamp				
2/7 14:28	102102.0	47.10	4.2	1200.3
2/7 14:29	100559.0	46.59	4.2	1200.2
2/7 14:30	100507.0	46.57	4.2	1200.2
2/7 14:31	101459.0	47.01	4.2	1199.8
2/7 14:32	100536.0	46.54	4.2	1200.0
2/7 14:33	100678.0	46.60	4.2	1200.0
2/7 14:34	101104.0	46.84	4.2	1200.0
2/7 14:35	101368.0	46.96	4.2	1200.2
2/7 14:36	101556.0	47.10	4.2	1199.8
2/7 14:37	102880.0	47.68	4.2	1199.8
2/7 14:38	103790.0	47.99	4.2	1200.0
2/7 14:39	103358.0	47.68	4.1	1198.2
2/7 14:40	103422.0	46.63	4.2	1200.7
2/7 14:41	100452.0	45.99	4.2	1201.8
2/7 14:42	100782.0	46.76	4.2	1200.0
2/7 14:43	102377.0	47.54	4.2	1199.3
2/7 14:44	100177.0	46.35	4.2	1199.3
2/7 14:45	101043.0	46.59	4.2	1200.3
2/7 14:46	101170.0	46.81	4.2	1199.8
2/7 14:47	102203.0	47.24	4.2	1200.2
2/7 14:48	102053.0	47.28	4.2	1200.0
2/7 14:49	101680.0	47.14	4.1	1200.2
2/7 14:50	102300.0	47.36	4.2	1200.0
2/7 14:51	101106.0	46.84	4.2	1200.0
2/7 14:52	101588.0	47.07	4.2	1200.0
2/7 14:53	102759.0	47.66	4.2	1199.8
2/7 14:54	102130.0	47.35	4.2	1199.5
2/7 14:55	103048.0	47.42	4.2	1198.8
2/7 14:56	103828.0	47.37	4.2	1201.2
2/7 14:57	102410.0	47.33	4.2	1201.0
2/7 14:58	102507.0	47.66	4.2	1200.2
2/7 14:59	102072.0	47.48	4.2	1199.7
2/7 15:00	102246.0	47.42	4.2	1199.3
2/7 15:01	100450.0	46.34	4.2	1200.5
2/7 15:02	101391.0	46.94	4.2	1200.0
2/7 15:03	101755.0	47.17	4.2	1200.2
2/7 15:04	101776.0	47.24	4.2	1200.0
2/7 15:05	100440.0	46.60	4.2	1199.7
2/7 15:06	101229.0	46.98	4.2	1200.0
2/7 15:07	101610.0	47.15	4.2	1199.8
2/7 15:08	102599.0	47.56	4.2	1199.8
2/7 15:09	100139.0	46.39	4.2	1200.3
2/7 15:10	101757.0	47.25	4.2	1199.3
2/7 15:11	103521.0	47.39	4.2	1199.8
2/7 15:12	102201.0	46.93	4.2	1200.3
2/7 15:13	101294.0	46.74	4.2	1200.2
2/7 15:14	102540.0	47.17	4.2	1199.5
2/7 15:15	100213.0	46.17	4.2	1200.5
2/7 15:16	102410.0	47.36	4.2	1199.7
Run 1 Average	101924.9	47.0	4.2	1200.0

Cedar 5 Reports 3/8/2023 6:33 AM, CeDAR 1-Minute Data

Page 9 of 13

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat Input mmBtuhr 1-Min	(TG-741) Heat Input mmBtuhr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min	(TG-741) T7 °F 1-Min
Timestamp							
2/7 15:17	104457.0	48.17	4.2	1200.2			
2/7 15:18	100333.0	46.39	4.2	1200.2			
2/7 15:19	103803.0	48.06	4.2	1200.2			
2/7 15:20	99931.0	46.27	4.2	1200.2			
2/7 15:21	101791.0	47.13	4.1	1200.2			
2/7 15:22	102156.0	47.33	4.2	1200.0			
2/7 15:23	103751.0	48.07	4.1	1200.2			
2/7 15:24	102988.0	47.63	4.2	1200.0			
2/7 15:25	100948.0	46.68	4.2	1200.2			
2/7 15:26	101154.0	46.82	4.2	1200.2			
2/7 15:27	101793.0	47.16	4.2	1200.2			
2/7 15:28	101276.0	47.02	4.2	1200.0			
2/7 15:29	102338.0	47.49	4.2	1200.0			
2/7 15:30	102332.0	47.44	4.2	1199.7			
2/7 15:31	103294.0	47.81	4.2	1200.0			
2/7 15:32	102469.0	47.39	4.2	1200.0			
2/7 15:33	101561.0	46.96	4.2	1200.2			
2/7 15:34	100390.0	46.48	4.2	1199.8			
2/7 15:35	102503.0	47.09	4.2	1199.8			
2/7 15:36	101065.0	46.51	4.2	1200.5			
2/7 15:37	101104.0	46.73	4.1	1200.0			
2/7 15:38	101270.0	46.92	4.1	1200.0			
2/7 15:39	99704.0	48.19	4.2	1199.8			
2/7 15:40	100857.0	46.73	4.2	1200.0			
2/7 15:41	101896.0	47.21	4.2	1199.8			
2/7 15:42	100267.0	46.43	4.2	1200.0			
2/7 15:43	101101.0	46.73	4.1	1200.0			
2/7 15:44	101641.0	47.05	4.1	1200.2			
2/7 15:45	101337.0	46.91	4.1	1200.5			
2/7 15:46	101120.0	46.95	4.1	1200.0			
2/7 15:47	100575.0	46.70	4.1	1200.0			
2/7 15:48	100889.0	46.82	4.1	1199.8			
2/7 15:49	100836.0	46.68	4.1	1199.5			
2/7 15:50	102193.0	47.31	4.2	1200.3			
2/7 15:51	100528.0	46.58	4.2	1199.7			
2/7 15:52	101825.0	47.28	4.2	1200.2			
2/7 15:53	99253.0	46.11	4.2	1199.8			
2/7 15:54	101249.0	47.04	4.2	1200.0			
2/7 15:55	102659.0	47.67	4.2	1200.2			
2/7 15:56	100201.0	46.42	4.2	1200.0			
2/7 15:57	101195.0	46.89	4.2	1200.0			
2/7 15:58	102118.0	47.31	4.2	1200.2			
2/7 15:59	100975.0	46.80	4.2	1200.0			
2/7 16:00	101213.0	46.99	4.2	1200.2			
2/7 16:01	102306.0	47.50	4.2	1199.7			
2/7 16:02	102145.0	47.35	4.2	1200.0			
2/7 16:03	102310.0	47.40	4.2	1200.0			
2/7 16:04	102098.0	47.30	4.2	1199.8			
2/7 16:05	102983.0	47.76	4.2	1200.0			

(TG-741) Landfill Gas Flow soft/hr 1-Min		(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
2/7 16:06	10269.0	47.64	4.2	1199.8
2/7 16:07	101691.0	47.19	4.2	1200.2
2/7 16:08	100974.0	46.88	4.2	1199.7
2/7 16:09	101284.0	47.00	4.2	1200.2
2/7 16:10	102596.0	47.64	4.2	1200.0
2/7 16:11	101235.0	46.90	4.2	1200.5
2/7 16:12	103164.0	47.87	4.2	1200.0
2/7 16:13	101843.0	47.28	4.2	1200.2
2/7 16:14	102223.0	47.46	4.2	1200.2
2/7 16:15	102046.0	47.42	4.1	1200.0
2/7 16:16	100099.0	46.51	4.1	1199.8
2/7 16:17	99640.0	46.30	4.2	1199.5
2/7 16:18	101582.0	47.20	4.2	1200.0
2/7 16:19	99796.0	46.42	4.2	1199.5
2/7 16:20	100375.0	46.61	4.2	1200.2
2/7 16:21	100496.0	46.69	4.2	1200.0
2/7 16:22	98985.0	45.96	4.2	1200.0
2/7 16:23	101261.0	47.08	4.2	1199.8
2/7 16:24	100979.0	46.89	4.2	1200.0
2/7 16:25	99963.0	46.34	4.2	1199.8
2/7 16:26	100629.0	46.62	4.2	1199.8
2/7 16:27	99832.0	46.27	4.2	1200.2
2/7 16:28	102607.0	47.64	4.2	1199.8
2/7 16:29	100715.0	46.80	4.2	1200.0
2/7 16:30	102243.0	47.51	4.2	1200.0
2/7 16:31	100429.0	46.63	4.2	1200.0
2/7 16:32	99036.0	45.96	4.2	1200.0
2/7 16:33	101191.0	46.98	4.2	1199.7
2/7 16:34	102462.0	47.47	4.2	1199.8
2/7 16:35	100510.0	46.57	4.2	1200.2
2/7 16:36	101390.0	46.97	4.2	1199.8
2/7 16:37	101917.0	47.22	4.2	1199.8
2/7 16:38	102498.0	47.49	4.2	1200.0
2/7 16:39	103051.0	47.74	4.2	1200.0
2/7 16:40	102035.0	47.33	4.2	1200.5
2/7 16:41	99523.0	46.21	4.2	1199.8
2/7 16:42	102193.0	47.43	4.2	1200.2
2/7 16:43	100742.0	46.74	4.2	1200.2
2/7 16:44	99796.0	46.34	4.2	1199.7
2/7 16:45	102034.0	47.30	4.2	1199.7
2/7 16:46	100748.0	46.68	4.2	1200.0
2/7 16:47	104000.0	48.12	4.2	1200.2
2/7 16:48	101633.0	47.09	4.2	1199.7
2/7 16:49	101091.0	46.86	4.2	1200.3
2/7 16:50	102107.0	47.39	4.2	1200.2
2/7 16:51	100790.0	46.80	4.2	1200.2
2/7 16:52	101644.0	47.17	4.2	1199.7
2/7 16:53	101713.0	47.12	4.2	1199.8
2/7 16:54	101908.0	47.18	4.2	1200.0

	(TG-741) Landfill Gas Flow scfhhr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T °F 1-Min	(TG-741) T °F 1-Min
2/7 16:55	101943.0	47.12	4.2	1200.2	
2/7 16:56	100956.0	46.71	4.2	1200.2	
2/7 16:57	103244.0	47.83	4.2	1200.3	
2/7 16:58	102537.0	47.53	4.2	1199.5	
2/7 16:59	101983.0	47.27	4.2	1199.5	
2/7 17:00	101187.0	46.90	4.2	1200.0	
2/7 17:01	103101.0	47.68	4.2	1199.8	
2/7 17:02	102305.0	47.29	4.2	1200.0	
2/7 17:03	102664.0	47.47	4.2	1200.0	
2/7 17:04	101840.0	47.07	4.2	1199.8	
2/7 17:05	101941.0	47.23	4.2	1200.5	
2/7 17:06	102369.0	47.43	4.2	1199.8	
2/7 17:07	101633.0	47.09	4.2	1200.0	
2/7 17:08	102553.0	47.51	4.2	1199.3	
2/7 17:09	103769.0	48.05	4.2	1200.0	
2/7 17:10	101110.0	46.80	4.2	1200.0	
2/7 17:11	102448.0	47.35	4.2	1199.8	
2/7 17:12	102436.0	47.35	4.2	1200.0	
2/7 17:13	102841.0	47.55	4.2	1200.3	
2/7 17:14	101279.0	46.84	4.2	1200.0	
2/7 17:15	101293.0	46.89	4.2	1200.0	
2/7 17:16	104264.0	48.26	4.2	1199.8	
2/7 17:17	101994.0	47.17	4.2	1200.2	
2/7 17:18	101655.0	46.99	4.2	1200.0	
2/7 17:19	101348.0	46.84	4.2	1200.0	
2/7 17:20	101960.0	47.13	4.2	1199.8	
2/7 17:21	101074.0	46.67	4.2	1199.8	
2/7 17:22	100717.0	46.44	4.2	1200.3	
2/7 17:23	101139.0	46.72	4.2	1200.2	
2/7 17:24	102913.0	47.57	4.2	1200.2	
2/7 17:25	100070.0	46.25	4.2	1200.0	
2/7 17:26	102512.0	47.34	4.2	1200.3	
2/7 17:27	102844.0	47.53	4.2	1199.7	
2/7 17:28	101766.0	47.04	4.2	1200.2	
2/7 17:29	102430.0	47.34	4.2	1200.0	
2/7 17:30	101768.0	47.04	4.2	1200.0	
2/7 17:31	101423.0	46.85	4.2	1200.0	
2/7 17:32	101801.0	47.05	4.2	1199.8	
2/7 17:33	102873.0	47.55	4.2	1200.2	
2/7 17:34	101510.0	46.81	4.2	1199.7	
2/7 17:35	103335.0	47.57	4.2	1200.2	
2/7 17:36	102876.0	47.42	4.2	1199.8	
2/7 17:37	102128.0	47.07	4.2	1200.0	
2/7 17:38	102632.0	47.39	4.2	1200.2	
2/7 17:39	103550.0	47.74	4.2	1200.2	
2/7 17:40	102832.0	47.50	4.2	1200.0	
2/7 17:41	102985.0	47.57	4.2	1200.2	
2/7 17:42	100997.0	46.55	4.2	1200.0	
2/7 17:43	103044.0	47.49	4.2	1200.0	

	(TG-741) Landfill Gas	(TG-741) Heat		(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	Flow scf/hr 1- Min	Input mmBtu/hr 1- Min	(TG-741) Heat Megawatts 1-Min	
2/7 17:44	102729.0	47.37	4.2	1200.0
2/7 17:45	103626.0	47.70	4.2	1200.2
2/7 17:46	101241.0	46.57	4.2	1200.3
2/7 17:47	100723.0	46.38	4.2	1200.2
2/7 17:48	103638.0	47.73	4.2	1199.8
2/7 17:49	103060.0	47.52	4.2	1200.0
2/7 17:50	100694.0	46.43	4.2	1199.8
2/7 17:51	102767.0	47.39	4.2	1200.2
2/7 17:52	101649.0	46.87	4.2	1200.0
2/7 17:53	100898.0	46.52	4.2	1200.3
2/7 17:54	102346.0	47.19	4.2	1200.2
2/7 17:55	101048.0	46.59	4.2	1200.0
2/7 17:56	103661.0	47.70	4.2	1199.8
2/7 17:57	102555.0	47.20	4.2	1200.0
2/7 17:58	102620.0	47.21	4.2	1200.0
2/7 17:59	101839.0	46.92	4.2	1200.0
2/7 18:00	102387.0	47.19	4.2	1200.2
Average (all)	102590.5	47.19	4.2	1200.0
Total (all)	--	--	--	--
Minimum (all)	98885.0	45.64	4.1	1197.5
Maximum (all)	108892.0	49.23	4.2	1202.8
Average (valid values only) Total (valid values only)	102590.5	47.19	4.2	1200.0
Count (valid values only)	601	601	601	601

CeDAR 1-Minute Data
Sunshine Gas Producers, LLC
Data for 2/8/2023 6:00 AM thru 2/8/2023 7:00 PM

Timestamp	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
2/8 6:00	104195.0	47.82	4.2	1199.8		
2/8 6:01	103059.0	47.29	4.2	1200.0		
2/8 6:02	104084.0	47.88	4.2	1200.0		
2/8 6:03	104517.0	48.08	4.2	1200.2		
2/8 6:04	103568.0	47.61	4.2	1199.7		
2/8 6:05	104013.0	47.78	4.2	1200.2		
2/8 6:06	104613.0	48.09	4.2	1200.0		
2/8 6:07	103100.0	47.33	4.2	1199.8		
2/8 6:08	102756.0	47.16	4.2	1200.0		
2/8 6:09	104065.0	47.78	4.2	1200.0		
2/8 6:10	103553.0	47.52	4.2	1200.2		
2/8 6:11	104905.0	48.26	4.2	1200.2		
2/8 6:12	104532.0	48.08	4.2	1200.0		
2/8 6:13	102576.0	47.26	4.2	1199.8		
2/8 6:14	102974.0	47.39	4.2	1199.8		
2/8 6:15	103513.0	47.59	4.2	1199.8		
2/8 6:16	104246.0	47.93	4.2	1199.7		
2/8 6:17	102815.0	47.18	4.2	1200.0		
2/8 6:18	105610.0	48.52	4.2	1199.8		
2/8 6:19	103910.0	47.71	4.2	1200.2		
2/8 6:20	102457.0	47.04	4.2	1200.2		
2/8 6:21	103748.0	47.04	4.2	1200.0		
2/8 6:22	102079.0	46.84	4.2	1200.0		
2/8 6:23	103125.0	47.44	4.2	1200.0		
2/8 6:24	105578.0	48.54	4.2	1200.2		
2/8 6:25	103194.0	47.47	4.2	1200.0		
2/8 6:26	103240.0	47.41	4.2	1200.2		
2/8 6:27	102623.0	47.12	4.2	1199.8		
2/8 6:28	103514.0	47.50	4.2	1199.8		
2/8 6:29	102984.0	47.23	4.2	1200.0		
2/8 6:30	103270.0	47.39	4.2	1200.0		
2/8 6:31	103634.0	47.59	4.2	1199.8		
2/8 6:32	103492.0	47.61	4.2	1200.2		
2/8 6:33	101431.0	46.75	4.2	1200.0		
2/8 6:34	104403.0	48.08	4.2	1200.0		
2/8 6:35	104362.0	48.08	4.2	1200.0		
2/8 6:36	103698.0	47.70	4.2	1199.7		
2/8 6:37	103807.0	47.67	4.2	1200.0		
2/8 6:38	104448.0	47.87	4.2	1200.0		
2/8 6:39	104347.0	47.85	4.2	1200.2		
2/8 6:40	105671.0	48.54	4.2	1200.0		
2/8 6:41	102322.0	47.05	4.2	1200.2		
2/8 6:42	104209.0	47.94	4.2	1199.8		
2/8 6:43	103496.0	47.61	4.2	1199.7		
2/8 6:44	101580.0	46.77	4.2	1200.0		

Timestamp	(TG-741) Landfill Gas Flow scfhhr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
2/8 6:45	104746.0	48.04	4.2	1200.0
2/8 6:46	104987.0	48.10	4.2	1200.2
2/8 6:47	105030.0	48.10	4.2	1200.3
2/8 6:48	104160.0	47.78	4.2	1200.0
2/8 6:49	103705.0	47.59	4.2	1199.8
2/8 6:50	103578.0	47.62	4.2	1199.8
2/8 6:51	105104.0	48.23	4.2	1200.0
2/8 6:52	104531.0	47.99	4.2	1200.0
2/8 6:53	103829.0	47.65	4.2	1200.0
2/8 6:54	103569.0	47.54	4.2	1200.0
2/8 6:55	104693.0	48.04	4.2	1200.0
2/8 6:56	105698.0	48.41	4.2	1199.7
2/8 6:57	105561.0	48.33	4.2	1199.7
2/8 6:58	102431.0	46.97	4.2	1199.8
2/8 6:59	104735.0	47.97	4.2	1200.0
2/8 7:00	103786.0	47.63	4.2	1200.0
2/8 7:01	105138.0	48.25	4.2	1199.8
2/8 7:02	103944.0	47.70	4.2	1199.8
2/8 7:03	104217.0	47.80	4.2	1199.8
2/8 7:04	104346.0	47.79	4.2	1199.8
2/8 7:05	104296.0	47.73	4.2	1199.8
2/8 7:06	103478.0	47.34	4.2	1200.0
2/8 7:07	104705.0	47.90	4.2	1200.2
2/8 7:08	103902.0	47.20	4.2	1199.8
2/8 7:09	105251.0	48.15	4.2	1200.2
2/8 7:10	105243.0	48.20	4.2	1200.0
2/8 7:11	106001.0	48.61	4.2	1200.2
2/8 7:12	103056.0	47.29	4.2	1200.0
2/8 7:13	103826.0	47.65	4.2	1199.7
2/8 7:14	103965.0	47.69	4.2	1200.2
2/8 7:15	103895.0	47.57	4.2	1199.8
2/8 7:16	106757.0	48.87	4.2	1200.0
2/8 7:17	104535.0	47.86	4.2	1199.7
2/8 7:18	105027.0	48.08	4.2	1200.0
2/8 7:19	105048.0	48.01	4.2	1200.2
2/8 7:20	105298.0	48.29	4.2	1200.2
2/8 7:21	106048.0	48.75	4.2	1200.2
2/8 7:22	104158.0	47.91	4.2	1200.3
2/8 7:23	104376.0	48.08	4.2	1200.0
2/8 7:24	105694.0	48.55	4.2	1200.0
2/8 7:25	102462.0	47.04	4.2	1200.0
2/8 7:26	104385.0	47.90	4.2	1200.2
2/8 7:27	104401.0	47.91	4.2	1200.0
2/8 7:28	105096.0	48.23	4.2	1199.8
2/8 7:29	103694.0	47.58	4.2	1200.0
2/8 7:30	105074.0	48.27	4.2	1200.0
2/8 7:31	105141.0	48.36	4.2	1199.8
2/8 7:32	101324.0	46.84	4.2	1200.2
2/8 7:33	103990.0	47.84	4.2	1199.7

Cedar 5 Reports 3/8/2023 6:40 AM, CeDAR 1-Minute Data

Page

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts-1Min	(TG-741) T °F. 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/8/7:34	1.036263.0	47.59	4.2	1200.0
2/8/7:35	1.02593.0	47.19	4.2	1199.8
2/8/7:36	1.04048.0	47.77	4.2	1199.7
2/8/7:37	1.05230.0	48.29	4.2	1199.8
2/8/7:38	1.04217.0	47.83	4.2	1200.2
2/8/7:39	1.03816.0	47.67	4.2	1200.0
2/8/7:40	1.04425.0	48.01	4.2	1200.0
2/8/7:41	1.03669.0	47.66	4.2	1200.0
2/8/7:42	1.02433.0	47.04	4.2	1200.0
2/8/7:43	1.03551.0	47.57	4.2	1200.0
2/8/7:44	1.04701.0	48.07	4.2	1199.8
2/8/7:45	1.05220.0	48.26	4.2	1199.7
2/8/7:46	1.04613.0	48.01	4.2	1200.0
2/8/7:47	1.02934.0	47.23	4.2	1200.0
2/8/7:48	1.06321.0	48.77	4.2	1199.8
2/8/7:49	1.04933.0	48.07	4.2	1200.3
2/8/7:50	1.04323.0	47.87	4.2	1200.3
2/8/7:51	1.03843.0	47.65	4.2	1200.0
2/8/7:52	1.04355.0	47.80	4.2	1200.3
2/8/7:53	1.03743.0	47.69	4.2	1199.8
2/8/7:54	1.05433.0	48.40	4.2	1200.2
2/8/7:55	1.04194.0	47.84	4.2	1199.8
2/8/7:56	1.05810.0	48.67	4.2	1200.3
2/8/7:57	1.03647.0	47.59	4.2	1199.8
2/8/7:58	1.06231.0	48.75	4.2	1200.0
2/8/7:59	1.03804.0	47.63	4.2	1200.0
2/8:8:00	1.03077.0	47.30	4.2	1200.0
2/8:8:01	1.02782.0	47.15	4.2	1200.0
2/8:8:02	1.04149.0	47.73	4.2	1200.2
2/8:8:03	1.05004.0	48.18	4.2	1200.0
2/8:8:04	1.04121.0	47.78	4.2	1200.2
2/8:8:05	1.03171.0	47.34	4.2	1200.0
2/8:8:06	1.05250.0	48.30	4.2	1200.2
2/8:8:07	1.03745.0	47.59	4.2	1200.0
2/8:8:08	1.04723.0	47.96	4.2	1200.3
2/8:8:09	1.02052.0	46.83	4.2	1200.2
2/8:8:10	1.02968.0	47.25	4.2	1199.7
2/8:8:11	1.03625.0	47.56	4.2	1200.2
2/8:8:12	1.05497.0	48.41	4.2	1200.0
2/8:8:13	1.04532.0	47.97	4.2	1200.7
2/8:8:14	1.04712.0	48.03	4.2	1199.7
2/8:8:15	1.03255.0	47.37	4.2	1200.2
2/8:8:16	1.03135.0	47.33	4.2	1200.0
2/8:8:17	1.05650.0	48.50	4.2	1200.0
2/8:8:18	1.02589.0	47.16	4.2	1200.0
2/8:8:19	1.04143.0	47.90	4.2	1200.2
2/8:8:20	1.03155.0	47.45	4.2	1200.0
2/8:8:21	1.01967.0	46.91	4.2	1200.0
2/8:8:22	1.03675.0	47.69	4.2	1200.2

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts -Min	(TG-741) T7 Exhaust Temp °F -Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/8 8:23	104522.0	47.85	4.2	1200.0	
2/8 8:24	105920.0	48.61	4.2	1199.8	
2/8 8:25	104912.0	48.14	4.2	1200.0	
2/8 8:26	104038.0	47.86	4.2	1200.0	
2/8 8:27	103029.0	47.41	4.2	1200.0	
2/8 8:28	102946.0	47.36	4.2	1200.2	
2/8 8:29	103204.0	47.47	4.2	1200.0	
2/8 8:30	102247.0	47.04	4.2	1200.0	
2/8 8:31	104067.0	47.87	4.2	1200.0	
2/8 8:32	104598.0	48.11	4.2	1200.0	
2/8 8:33	103867.0	47.72	4.2	1199.8	
2/8 8:34	103532.0	47.59	4.2	1199.8	
2/8 8:35	103818.0	47.85	4.2	1200.0	
2/8 8:36	102638.0	47.31	4.2	1199.8	
2/8 8:37	104398.0	47.99	4.2	1200.0	
2/8 8:38	103831.0	47.65	4.2	1199.8	
2/8 8:39	103218.0	47.37	4.2	1200.0	
2/8 8:40	103920.0	47.69	4.2	1200.2	
2/8 8:41	103322.0	47.50	4.2	1200.0	
2/8 8:42	104331.0	47.99	4.2	1200.0	
2/8 8:43	102224.0	46.98	4.2	1200.2	
2/8 8:44	103717.0	47.73	4.2	1199.8	
2/8 8:45	104302.0	47.96	4.2	1200.0	
2/8 8:46	101683.0	46.68	4.2	1200.0	
2/8 8:47	102741.0	47.15	4.2	1200.0	
2/8 8:48	103626.0	47.58	4.2	1200.0	
2/8 8:49	102853.0	47.25	4.2	1200.0	
2/8 8:50	104733.0	48.21	4.2	1200.2	
2/8 8:51	101322.0	46.70	4.2	1200.0	
2/8 8:52	103751.0	47.82	4.2	1200.0	
2/8 8:53	104846.0	48.28	4.2	1199.7	
2/8 8:54	102553.0	47.17	4.2	1199.7	
2/8 8:55	104447.0	48.05	4.2	1200.0	
2/8 8:56	103403.0	47.54	4.2	1200.2	
2/8 8:57	103539.0	47.63	4.2	1200.3	
2/8 8:58	104848.0	47.68	4.2	1200.0	
2/8 8:59	102395.0	47.10	4.2	1200.2	
2/8 9:00	103819.0	47.73	4.2	1200.0	
2/8 9:01	102813.0	47.29	4.2	1200.0	
2/8 9:02	101665.0	46.77	4.2	1199.8	
2/8 9:03	103419.0	47.55	4.2	1200.0	
2/8 9:04	102233.0	47.03	4.2	1200.2	
2/8 9:05	103096.0	47.43	4.2	1200.2	
2/8 9:06	102936.0	47.35	4.2	1200.0	
2/8 9:07	103516.0	47.54	4.2	1200.0	
2/8 9:08	102349.0	46.97	4.2	1200.0	
2/8 9:09	104247.0	47.84	4.2	1199.8	
2/8 9:10	104225.0	47.75	4.2	1200.2	
2/8 9:11	102246.0	46.94	4.2	1200.0	

Page

Cedar 5 Reports 3/8/2023 6:40 AM, Cedar 1-Minute Data

	(TG-741) Landfill Gas Flow scfh/r	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts -Min	(TG-741) T °F -Min
Timestamp					
2/8 9:12	102740.0		47.23	4.2	1200.2
2/8 9:13	103513.0		47.61	4.2	1199.8
2/8 9:14	104775.0		48.20	4.2	1200.0
2/8 9:15	101557.0		46.63	4.2	1199.8
2/8 9:16	104119.0		47.78	4.2	1200.0
2/8 9:17	103595.0		47.54	4.2	1200.0
2/8 9:18	103273.0		47.37	4.2	1200.0
2/8 9:19	104317.0		47.81	4.2	1199.8
2/8 9:20	104397.0		47.88	4.2	1200.2
2/8 9:21	100906.0		46.29	4.2	1200.2
2/8 9:22	100941.0		46.32	4.2	1199.8
2/8 9:23	102567.0		47.05	4.2	1200.0
2/8 9:24	102783.0		47.09	4.2	1200.0
2/8 9:25	103198.0		47.24	4.2	1199.8
2/8 9:26	102771.0		47.05	4.2	1200.0
2/8 9:27	103741.0		47.49	4.2	1200.0
2/8 9:28	103202.0		47.36	4.2	1200.0
2/8 9:29	101943.0		46.78	4.2	1200.0
2/8 9:30	104224.0		47.83	4.2	1200.0
2/8 9:31	103951.0		47.68	4.2	1199.7
2/8 9:32	105383.0		48.24	4.2	1200.2
2/8 9:33	104824.0		47.89	4.2	1200.0
2/8 9:34	105141.0		48.02	4.2	1200.0
2/8 9:35	103993.0		47.58	4.2	1200.2
2/8 9:36	103450.0		47.44	4.2	1199.7
2/8 9:37	102028.0		46.82	4.2	1200.0
2/8 9:38	103771.0		47.53	4.2	1200.2
2/8 9:39	103531.0		47.40	4.2	1200.3
2/8 9:40	101055.0		46.27	4.2	1200.0
2/8 9:41	102914.0		47.09	4.2	1200.0
2/8 9:42	102104.0		46.66	4.1	1200.0
2/8 9:43	102782.0		46.94	4.1	1200.0
2/8 9:44	102538.0		46.83	4.1	1200.2
2/8 9:45	101414.0		46.45	4.1	1200.0
2/8 9:46	102748.0		47.06	4.1	1200.0
2/8 9:47	100722.0		46.19	4.1	1199.8
2/8 9:48	103458.0		47.45	4.1	1199.8
2/8 9:49	104070.0		47.64	4.2	1200.0
2/8 9:50	103224.0		47.25	4.1	1200.2
2/8 9:51	104176.0		46.46	4.1	1200.2
2/8 9:52	103458.0		47.40	4.2	1200.0
2/8 9:53	103800.0		47.55	4.1	1199.7
2/8 9:54	103044.0		47.09	4.2	1200.0
2/8 9:55	103341.0		47.23	4.2	1200.0
2/8 9:56	103123.0		47.19	4.2	1200.0
2/8 9:57	102692.0		46.98	4.2	1199.7
2/8 9:58	102656.0		46.88	4.2	1199.8
2/8 9:59	103407.0		47.23	4.2	1199.7
2/8 10:00	102372.0		46.59	4.2	1200.3

Cedar 5 Reports 3/8/2023 6:40 AM, CeDAR 1-Minute Data

Page

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/8 10:01	103400.0	47.17	4.2	1200.3	
2/8 10:02	103331.0	47.33	4.2	1200.2	
2/8 10:03	103899.0	47.66	4.2	1199.8	
2/8 10:04	100204.0	45.95	4.2	1200.3	
2/8 10:05	103539.0	47.48	4.2	1199.8	
2/8 10:06	101604.0	46.51	4.2	1200.0	
2/8 10:07	102056.0	46.74	4.2	1200.2	
2/8 10:08	103397.0	47.45	4.2	1200.2	
2/8 10:09	103319.0	47.44	4.2	1200.0	
2/8 10:10	102598.0	47.16	4.2	1200.2	
2/8 10:11	101421.0	46.52	4.2	1200.0	
2/8 10:12	100554.0	46.14	4.1	1200.0	
2/8 10:13	102311.0	46.98	4.2	1199.8	
2/8 10:14	102938.0	47.33	4.2	1200.0	
2/8 10:15	101387.0	46.51	4.2	1199.7	
2/8 10:16	103125.0	47.24	4.2	1200.2	
2/8 10:17	104125.0	47.76	4.2	1200.2	
2/8 10:18	102191.0	46.86	4.2	1200.0	
2/8 10:19	100095.0	46.02	4.2	1199.8	
2/8 10:20	101459.0	46.67	4.2	1200.2	
2/8 10:21	103276.0	47.45	4.2	1200.2	
2/8 10:22	100986.0	46.37	4.2	1200.0	
2/8 10:23	103562.0	47.52	4.2	1199.7	
2/8 10:24	102374.0	47.03	4.2	1200.0	
2/8 10:25	102487.0	47.11	4.2	1199.8	
2/8 10:26	101820.0	46.75	4.2	1200.0	
2/8 10:27	103224.0	47.46	4.2	1199.5	
2/8 10:28	103145.0	47.30	4.2	1199.2	
2/8 10:29	102023.0	46.57	4.2	1200.2	
2/8 10:30	100986.0	46.05	4.2	1199.8	
2/8 10:31	102109.0	46.66	4.2	1200.2	
2/8 10:32	102568.0	46.96	4.2	1200.0	
2/8 10:33	103700.0	47.47	4.2	1200.0	
2/8 10:34	102248.0	46.81	4.2	1199.7	
2/8 10:35	104391.0	47.74	4.2	1199.8	
2/8 10:36	104193.0	47.55	4.2	1199.7	
2/8 10:37	104986.0	47.85	4.2	1200.3	
2/8 10:38	102710.0	46.89	4.2	1200.0	
2/8 10:39	102498.0	46.89	4.2	1200.3	
2/8 10:40	103439.0	47.32	4.2	1200.2	
2/8 10:41	102850.0	47.05	4.2	1200.3	
2/8 10:42	104022.0	47.71	4.2	1199.8	
2/8 10:43	102359.0	47.20	4.2	1200.2	
2/8 10:44	103580.0	47.62	4.2	1200.0	
2/8 10:45	101242.0	46.49	4.2	1199.8	
2/8 10:46	103321.0	47.41	4.2	1199.8	
2/8 10:47	103786.0	47.61	4.2	1199.8	
2/8 10:48	101132.0	46.39	4.2	1200.0	
2/8 10:49	102211.0	46.92	4.2	1200.0	

Cedar 5 Reports 3/8/2023 6:40 AM; CeDAR 1-Minute Data

Page

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Heat Megawatts -Min	(TG-741) T7 Exhaust Temp °F -Min
Timestamp					
2/8 10:50	102225.0	46.91	4.2	1200.3	
2/8 10:51	102448.0	47.13	4.2	1200.2	
2/8 10:52	100598.0	46.30	4.2	1200.2	
2/8 10:53	101864.0	46.91	4.2	1199.8	
2/8 10:54	102192.0	47.01	4.1	1200.0	
2/8 10:55	102571.0	47.18	4.1	1200.0	
2/8 10:56	102196.0	47.01	4.1	1200.2	
2/8 10:57	101236.0	46.57	4.1	1200.2	
2/8 10:58	101807.0	46.83	4.1	1200.0	
2/8 10:59	101499.0	46.69	4.1	1200.0	
2/8 11:00	102028.0	47.03	4.2	1200.0	
2/8 11:01	102445.0	47.15	4.2	1200.2	
2/8 11:02	101505.0	46.75	4.2	1200.3	
2/8 11:03	100471.0	46.38	4.2	1200.2	
2/8 11:04	99861.0	46.19	4.1	1199.8	
2/8 11:05	102741.0	47.46	4.2	1200.0	
2/8 11:06	102704.0	47.38	4.2	1199.8	
2/8 11:07	103421.0	47.72	4.2	1200.0	
2/8 11:08	100763.0	46.46	4.1	1200.5	
2/8 11:09	101644.0	46.89	4.1	1200.3	
2/8 11:10	103790.0	47.97	4.1	1200.0	
2/8 11:11	101878.0	47.06	4.1	1200.0	
2/8 11:12	100792.0	46.67	4.1	1200.0	
2/8 11:13	100833.0	46.67	4.1	1200.0	
2/8 11:14	100489.0	46.53	4.1	1200.0	
2/8 11:15	102347.0	47.42	4.1	1200.0	
2/8 11:16	102546.0	47.48	4.1	1199.8	
2/8 11:17	104080.0	48.11	4.2	1199.7	
2/8 11:18	100629.0	46.45	4.2	1199.8	
2/8 11:19	100704.0	46.45	4.2	1200.0	
2/8 11:20	101261.0	46.76	4.2	1200.0	
2/8 11:21	100561.0	46.48	4.2	1200.3	
2/8 11:22	102626.0	47.44	4.2	1199.5	
2/8 11:23	103515.0	47.82	4.2	1200.2	
2/8 11:24	99555.0	46.24	4.2	1200.0	
2/8 11:25	99513.0	46.01	4.2	1200.5	
2/8 11:26	102637.0	47.51	4.1	1200.0	
2/8 11:27	101809.0	47.14	4.1	1200.5	
2/8 11:28	99886.0	46.24	4.1	1199.7	
2/8 11:29	103189.0	47.73	4.1	1200.2	
2/8 11:30	101284.0	46.83	4.2	1199.7	
2/8 11:31	99392.0	45.94	4.2	1200.2	
2/8 11:32	101809.0	47.06	4.2	1200.0	
2/8 11:33	100883.0	46.74	4.1	1200.3	
2/8 11:34	100614.0	46.61	4.1	1200.0	
2/8 11:35	99752.0	46.21	4.1	1199.8	
2/8 11:36	101523.0	47.03	4.1	1199.8	
2/8 11:37	99880.0	46.32	4.1	1200.2	
2/8 11:38	99674.0	46.18	4.1	1199.8	

Cedar 5 Reports 3/8/2023 6:40 AM, CeDAR 1-Minute Data

Page

	(TG-741) Landfill Gas Flow scfhhr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp				
2/8/11:39	100386.0	46.72	4.1	1199.8
2/8/11:40	101715.0	47.05	4.1	1199.7
2/8/11:41	101884.0	47.12	4.2	1200.2
2/8/11:42	101112.0	46.84	4.2	1200.0
2/8/11:43	100815.0	46.71	4.2	1200.2
2/8/11:44	101758.0	47.18	4.2	1200.0
2/8/11:45	100254.0	46.48	4.2	1199.8
2/8/11:46	99595.0	46.14	4.1	1200.0
2/8/11:47	100319.0	46.40	4.1	1200.0
2/8/11:48	100309.0	46.44	4.1	1199.8
2/8/11:49	101447.0	47.00	4.1	1200.3
2/8/11:50	102233.0	47.43	4.1	1200.8
2/8/11:51	100789.0	46.86	4.1	1200.0
2/8/11:52	101568.0	47.27	4.1	1199.7
2/8/11:53	101165.0	47.00	4.1	1199.5
2/8/11:54	101836.0	47.28	4.1	1200.3
2/8/11:55	99519.0	46.19	4.1	1199.8
2/8/11:56	102572.0	47.54	4.1	1199.8
2/8/11:57	101239.0	46.99	4.1	1200.2
2/8/11:58	100078.0	46.47	4.1	1199.8
2/8/11:59	103371.0	47.97	4.1	1200.0
2/8/12:00	100443.0	46.63	4.1	1200.0
2/8/12:01	101371.0	47.07	4.1	1199.8
2/8/12:02	101829.0	47.28	4.1	1200.0
2/8/12:03	101014.0	46.99	4.1	1199.8
2/8/12:04	100484.0	46.69	4.1	1200.3
2/8/12:05	101030.0	47.02	4.1	1200.5
2/8/12:06	99897.0	46.49	4.1	1200.0
2/8/12:07	98844.0	45.88	4.1	1200.0
2/8/12:08	100358.0	46.71	4.1	1200.0
2/8/12:09	101131.0	47.07	4.1	1199.8
2/8/12:10	100469.0	46.78	4.1	1199.8
2/8/12:11	102079.0	47.53	4.1	1199.8
2/8/12:12	102116.0	47.50	4.1	1200.0
2/8/12:13	101968.0	47.48	4.1	1200.2
2/8/12:14	101342.0	47.28	4.1	1200.3
2/8/12:15	102477.0	47.78	4.1	1199.5
2/8/12:16	100527.0	46.79	4.1	1200.2
2/8/12:17	102202.0	47.56	4.1	1200.3
2/8/12:18	99649.0	46.38	4.1	1199.8
2/8/12:19	101961.0	47.37	4.1	1200.3
2/8/12:20	100300.0	46.72	4.1	1200.3
2/8/12:21	101150.0	47.12	4.1	1199.8
2/8/12:22	100520.0	46.82	4.1	1200.2
2/8/12:23	100534.0	46.83	4.1	1199.8
2/8/12:24	101238.0	47.12	4.1	1200.0
2/8/12:25	100103.0	46.59	4.1	1200.0
2/8/12:26	100668.0	46.85	4.1	1200.0
2/8/12:27	101220.0	47.17	4.1	1200.0
Average	10264.1	47.2	4.2	1200.0

Cedar 5 Reports 3/8/2023 6:46 AM, CeDAR 1-Minute Data

Page

	(TG-741) Landfill Gas Flow scfh/r 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp				
2/8 12:28	101114.0	47.10	4.1	1199.8
2/8 12:29	99942.0	46.51	4.1	1199.7
2/8 12:30	100884.0	46.88	4.1	1199.8
2/8 12:31	99442.0	46.23	4.1	1200.8
2/8 12:32	101638.0	47.36	4.1	1199.8
2/8 12:33	100378.0	46.83	4.1	1199.8
2/8 12:34	99621.0	46.40	4.1	1199.7
2/8 12:35	99731.0	46.41	4.1	1200.0
2/8 12:36	100682.0	46.86	4.1	1200.3
2/8 12:37	100120.0	46.60	4.1	1200.3
2/8 12:38	101201.0	47.19	4.1	1200.2
2/8 12:39	101239.0	47.23	4.1	1200.3
2/8 12:40	99790.0	46.55	4.1	1200.0
2/8 12:41	100232.0	46.76	4.1	1200.0
2/8 12:42	100279.0	46.78	4.1	1199.8
2/8 12:43	101859.0	47.52	4.1	1199.8
2/8 12:44	99548.0	46.44	4.1	1200.0
2/8 12:45	99108.0	46.23	4.1	1199.8
2/8 12:46	102405.0	47.77	4.1	1200.0
2/8 12:47	100296.0	46.79	4.1	1199.8
2/8 12:48	100572.0	46.92	4.1	1199.8
2/8 12:49	99753.0	46.55	4.1	1200.0
2/8 12:50	99949.0	46.63	4.1	1199.8
2/8 12:51	100848.0	47.11	4.1	1200.0
2/8 12:52	105541.0	48.05	4.2	1199.0
2/8 12:53	100213.0	45.53	4.2	1202.5
2/8 12:54	999862.0	46.54	4.1	1200.5
2/8 12:55	101349.0	47.31	4.1	1199.7
2/8 12:56	99263.0	46.30	4.1	1198.0
2/8 12:57	100936.0	46.57	4.1	1199.0
2/8 12:58	984438.0	46.28	4.1	1200.2
2/8 12:59	100299.0	46.74	4.1	1200.3
2/8 13:00	99143.0	46.25	4.1	1200.0
2/8 13:01	99038.0	46.30	4.1	1200.2
2/8 13:02	100617.0	47.00	4.1	1200.3
2/8 13:03	98904.0	46.14	4.1	1199.8
2/8 13:04	99218.0	45.72	4.1	1199.8
2/8 13:05	100381.0	46.83	4.1	1200.2
2/8 13:06	99086.0	46.30	4.1	1200.0
2/8 13:07	99325.0	46.43	4.1	1199.8
2/8 13:08	100228.0	46.87	4.1	1200.0
2/8 13:09	99218.0	46.35	4.1	1199.5
2/8 13:10	99638.0	46.48	4.1	1200.0
2/8 13:11	100181.0	46.73	4.1	1200.2
2/8 13:12	100131.0	46.64	4.1	1199.8
2/8 13:13	98590.0	46.39	4.1	1200.5
2/8 13:14	100162.0	46.61	4.1	1196.8
2/8 13:15	105722.0	47.50	4.1	1201.0
2/8 13:16	100557.0	45.82	4.1	1200.2

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) T °F 1-Min	(TG-741) T °F 1-Min	(TG-741) T °F 1-Min
Timestamp	1-Min	1-Min	Megawatts 1-Min	Megawatts 1-Min	Exhaust Temp °F 1-Min
2/8 13:17	103314.0	47.02	4.1	4.1	1200.2
2/8 13:18	101505.0	46.23	4.1	4.1	1200.0
2/8 13:19	102020.0	46.46	4.1	4.1	1200.0
2/8 13:20	104229.0	47.47	4.1	4.1	1199.8
2/8 13:21	102155.0	46.54	4.1	4.1	1200.2
2/8 13:22	101785.0	46.58	4.1	4.1	1201.0
2/8 13:23	101993.0	46.99	4.1	4.1	1199.7
2/8 13:24	103255.0	47.27	4.1	4.1	1199.7
2/8 13:25	102804.0	46.95	4.1	4.1	1200.0
2/8 13:26	102762.0	46.93	4.1	4.1	1200.0
2/8 13:27	102695.0	46.92	4.1	4.1	1201.0
2/8 13:28	101636.0	46.98	4.1	4.1	1201.2
2/8 13:29	101065.0	47.12	4.1	4.1	1199.8
2/8 13:30	100889.0	47.05	4.1	4.1	1199.3
2/8 13:31	100942.0	46.84	4.1	4.1	1199.7
2/8 13:32	100531.0	46.60	4.1	4.1	1200.2
2/8 13:33	101625.0	47.28	4.1	4.1	1200.3
2/8 13:34	100684.0	47.00	4.1	4.1	1200.2
2/8 13:35	100157.0	46.83	4.1	4.1	1200.2
2/8 13:36	100771.0	47.12	4.1	4.1	1199.8
2/8 13:37	100845.0	47.07	4.1	4.1	1200.0
2/8 13:38	100198.0	46.74	4.1	4.1	1200.0
2/8 13:39	101883.0	47.53	4.1	4.1	1200.5
2/8 13:40	99229.0	46.37	4.1	4.1	1200.5
2/8 13:41	99671.0	46.59	4.1	4.1	1200.0
2/8 13:42	100352.0	46.94	4.1	4.1	1199.8
2/8 13:43	100312.0	46.87	4.1	4.1	1200.0
2/8 13:44	100714.0	46.98	4.1	4.1	1199.5
2/8 13:45	99722.0	46.54	4.1	4.1	1200.0
2/8 13:46	99720.0	46.58	4.1	4.1	1200.0
2/8 13:47	99805.0	46.61	4.1	4.1	1199.8
2/8 13:48	98867.0	46.12	4.1	4.1	1200.0
2/8 13:49	99991.0	46.58	4.1	4.1	1200.2
2/8 13:50	100611.0	46.79	4.1	4.1	1199.8
2/8 13:51	101895.0	47.31	4.1	4.1	1200.7
2/8 13:52	100244.0	46.65	4.1	4.1	1200.5
2/8 13:53	99825.0	46.55	4.1	4.1	1200.0
2/8 13:54	99433.0	46.35	4.1	4.1	1200.0
2/8 13:55	99337.0	46.25	4.1	4.1	1199.8
2/8 14:00	100428.0	46.85	4.1	4.1	1200.2
2/8 14:01	97648.0	46.40	4.1	4.1	1199.8
2/8 14:02	101476.0	45.79	4.1	4.1	1200.2
2/8 14:03	100041.0	46.33	4.1	4.1	1199.3
2/8 14:04	101835.0	46.68	4.1	4.1	1200.0
2/8 14:05	102113.0	47.54	4.1	4.1	1199.8
		47.70	4.1	4.1	

Cedar 5 Reports 3/8/2023 6:46 AM, CEDAR 1-Minute Data

Page 1

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Input min-Btu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts	(TG-741) T ₇ °F. 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts	°F. 1-Min
2/8 14:06	100919.0	47.08	4.1	1200.0	
2/8 14:07	100579.0	46.94	4.1	1200.0	
2/8 14:08	99981.0	46.64	4.1	1199.8	
2/8 14:09	101030.0	47.13	4.1	1200.0	
2/8 14:10	100542.0	46.90	4.1	1199.7	
2/8 14:11	99964.0	46.61	4.1	1200.0	
2/8 14:12	100653.0	46.88	4.1	1200.0	
2/8 14:13	99806.0	46.47	4.1	1200.3	
2/8 14:14	101131.0	47.07	4.1	1200.2	
2/8 14:15	100506.0	46.73	4.1	1199.5	
2/8 14:16	102184.0	47.37	4.1	1200.0	
2/8 14:17	99681.0	46.28	4.1	1200.2	
2/8 14:18	99524.0	46.21	4.1	1200.2	
2/8 14:19	101276.0	47.02	4.1	1200.2	
2/8 14:20	100438.0	46.60	4.1	1199.8	
2/8 14:21	99816.0	46.33	4.1	1199.8	
2/8 14:22	100509.0	46.67	4.1	1200.3	
2/8 14:23	102095.0	47.41	4.1	1199.8	
2/8 14:24	98989.0	46.00	4.1	1199.8	
2/8 14:25	100623.0	46.76	4.1	1200.2	
2/8 14:26	101222.0	47.00	4.1	1199.8	
2/8 14:27	101824.0	47.24	4.1	1199.7	
2/8 14:28	101610.0	47.11	4.1	1200.3	
2/8 14:29	101494.0	47.04	4.1	1199.8	
2/8 14:30	100841.0	46.79	4.1	1200.2	
2/8 14:31	101441.0	47.10	4.1	1199.8	
2/8 14:32	99904.0	46.46	4.1	1200.3	
2/8 14:33	101682.0	47.32	4.1	1199.8	
2/8 14:34	100357.0	46.80	4.1	1200.0	
2/8 14:35	99774.0	46.47	4.1	1200.3	
2/8 14:36	99446.0	46.39	4.1	1199.8	
2/8 14:37	101252.0	47.21	4.1	1200.2	
2/8 14:38	100264.0	46.75	4.1	1199.7	
2/8 14:39	100804.0	46.99	4.1	1199.2	
2/8 14:40	101458.0	47.15	4.1	1200.5	
2/8 14:41	99174.0	46.26	4.1	1200.3	
2/8 14:42	101296.0	47.26	4.1	1199.8	
2/8 14:43	100274.0	46.75	4.1	1200.0	
2/8 14:44	99420.0	46.38	4.1	1200.0	
2/8 14:45	101894.0	47.31	4.1	1199.7	
2/8 14:46	102355.0	46.68	4.1	1199.8	
2/8 14:47	101043.0	46.84	4.1	1198.8	
2/8 14:48	102119.0	47.17	4.1	1200.5	
2/8 14:49	99785.0	46.36	4.1	1200.0	
2/8 14:50	101894.0	47.31	4.1	1200.2	
2/8 14:51	101188.0	46.97	4.1	1199.7	
2/8 14:52	100698.0	46.76	4.1	1200.2	
2/8 14:53	100236.0	46.58	4.1	1199.7	
2/8 14:54	103090.0	47.81	4.1	1199.5	

Cedar 5 Reports 3/8/2023 6:40 AM, CGDAR -Minute Data

Page 1

	(TG-741) Landfill Gas Flow scfh	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts-hr	(TG-741) T °F 1-Min
Timestamp	1-Min	1-Min	Megawatts-hr	1-Min
2/8 14:55	102437.0	47.24	4.1	1200.0
2/8 14:56	101797.0	46.82	4.1	1199.8
2/8 14:57	101784.0	46.93	4.1	1200.7
2/8 14:58	100192.0	46.28	4.1	1200.2
2/8 14:59	101523.0	46.97	4.1	1200.7
2/8 15:00	100740.0	46.86	4.1	1200.0
2/8 15:01	100193.0	46.65	4.1	1200.2
2/8 15:02	101715.0	47.38	4.1	1199.8
2/8 15:03	98768.0	45.97	4.1	1200.2
2/8 15:04	99438.0	46.25	4.1	1199.8
2/8 15:05	98927.0	46.02	4.1	1200.0
2/8 15:06	99743.0	46.35	4.1	1200.0
2/8 15:07	101816.0	47.31	4.1	1199.8
2/8 15:08	99659.0	46.35	4.1	1199.7
2/8 15:09	100481.0	46.65	4.1	1200.3
2/8 15:10	100210.0	46.56	4.1	1200.2
2/8 15:11	101355.0	47.07	4.1	1200.0
2/8 15:12	99608.0	46.33	4.1	1200.0
2/8 15:13	102049.0	47.42	4.1	1199.5
2/8 15:14	99217.0	46.15	4.1	1199.8
2/8 15:15	101116.0	47.04	4.1	1200.2
2/8 15:16	99823.0	46.35	4.1	1199.7
2/8 15:17	100842.0	46.82	4.1	1200.3
2/8 15:18	103311.0	48.03	4.1	1199.8
2/8 15:19	102009.0	47.46	4.1	1200.0
2/8 15:20	98920.0	46.04	4.1	1200.2
2/8 15:21	102011.0	47.48	4.1	1200.2
2/8 15:22	102452.0	47.66	4.1	1200.3
2/8 15:23	99939.0	46.60	4.1	1199.7
2/8 15:24	102418.0	47.18	4.1	1199.8
2/8 15:25	102568.0	46.14	4.2	1202.5
2/8 15:26	99657.0	46.06	4.1	1201.5
2/8 15:27	100485.0	46.83	4.1	1200.2
2/8 15:28	99908.0	46.59	4.1	1199.5
2/8 15:29	98876.0	46.02	4.1	1199.8
2/8 15:30	100028.0	46.47	4.1	1199.8
2/8 15:31	98776.0	45.86	4.1	1200.0
2/8 15:32	100870.0	46.87	4.1	1200.2
2/8 15:33	100223.0	46.70	4.1	1200.0
2/8 15:34	100307.0	46.79	4.1	1200.0
2/8 15:35	101054.0	47.11	4.1	1199.8
2/8 15:36	99729.0	46.41	4.1	1199.8
2/8 15:37	99922.0	46.50	4.1	1200.2
2/8 15:38	99263.0	46.20	4.1	1200.0
2/8 15:39	100370.0	46.73	4.1	1200.2
2/8 15:40	99781.0	46.55	4.1	1200.2
2/8 15:41	100122.0	46.71	4.1	1200.0
2/8 15:42	100196.0	46.65	4.1	1199.8
2/8 15:43	101074.0	47.04	4.1	1200.3

Cedar 5 Reports 3/8/2023 6:40 AM, CeDAR 1-Minute Data

Page 1

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T _T °F 1-Min
Timestamp					
2/8 15:44	100449.0	46.75	4.1	1199.8	
2/8 15:45	100944.0	46.98	4.1	1200.2	
2/8 15:46	100768.0	46.98	4.1	1199.7	
2/8 15:47	96098.0	46.20	4.1	1200.2	
2/8 15:48	100610.0	46.77	4.1	1199.2	
2/8 15:49	101643.0	47.01	4.1	1200.5	
2/8 15:50	101019.0	46.90	4.1	1200.2	
2/8 15:51	101245.0	47.05	4.1	1198.5	
2/8 15:52	103773.0	47.36	4.2	1199.2	
2/8 15:53	100377.0	45.87	4.1	1202.2	
2/8 15:54	99755.0	46.36	4.1	1200.3	
2/8 15:55	99249.0	46.25	4.1	1199.5	
2/8 15:56	101162.0	47.10	4.1	1199.3	
2/8 15:57	98416.0	46.11	4.1	1199.7	
2/8 15:58	101450.0	47.10	4.1	1200.0	
2/8 15:59	100058.0	46.46	4.1	1200.2	
2/8 16:00	100324.0	46.62	4.1	1200.2	
2/8 16:01	99956.0	46.56	4.1	1200.0	
2/8 16:02	101610.0	47.40	4.1	1200.0	
2/8 16:03	100758.0	46.97	4.1	1199.7	
2/8 16:04	101298.0	47.15	4.1	1200.0	
2/8 16:05	100361.0	46.71	4.1	1200.2	
2/8 16:06	100648.0	46.88	4.1	1200.7	
2/8 16:07	99102.0	46.10	4.1	1198.7	
2/8 16:08	102304.0	47.08	4.1	1198.3	
2/8 16:09	100519.0	46.07	4.2	1202.2	
2/8 16:10	100138.0	46.63	4.1	1201.2	
2/8 16:11	101798.0	47.57	4.1	1197.3	
2/8 16:12	103472.0	46.84	4.2	1200.2	
2/8 16:13	100542.0	45.92	4.1	1202.0	
2/8 16:14	98981.0	46.09	4.1	1200.5	
2/8 16:15	101691.0	47.52	4.1	1200.3	
2/8 16:16	101075.0	47.15	4.1	1199.5	
2/8 16:17	100540.0	46.88	4.1	1199.8	
2/8 16:18	99540.0	46.37	4.1	1200.0	
2/8 16:19	99339.0	46.32	4.1	1200.7	
2/8 16:20	99860.0	46.69	4.1	1200.0	
2/8 16:21	99396.0	46.46	4.1	1199.3	
2/8 16:22	101885.0	47.45	4.1	1197.8	
2/8 16:23	100847.0	46.87	4.2	1198.2	
2/8 16:24	110741.0	49.27	4.2	1196.2	
2/8 16:25	111585.0	46.59	4.2	1196.7	
2/8 16:26	113285.0	47.03	4.2	1203.2	
2/8 16:27	113018.0	47.10	4.2	1197.8	
2/8 16:28	113940.0	47.60	4.2	1198.7	
2/8 16:29	114191.0	47.55	4.2	1200.5	
2/8 16:30	116174.0	47.80	4.2	1201.2	
2/8 16:31	113964.0	46.70	4.2	1200.2	
2/8 16:32	115826.0	47.47	4.2	1199.8	

Cedar 5 Reports 3/8/2023 6:40 AM, CEDAR 1-Minute Data

Page 7

	(TG-741) Landfill Gas Flow scf/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T °F 1-Min
Timestamp				
28 16:33	113961.0	46.70	4.2	1199.0
28 16:34	113357.0	46.38	4.2	1200.0
28 16:35	113660.0	46.46	4.2	1199.5
28 16:36	114517.0	46.82	4.2	1199.8
28 16:37	114265.0	46.87	4.2	1200.8
28 16:38	113691.0	46.86	4.2	1200.0
28 16:39	110848.0	45.91	4.2	1198.5
28 16:40	110469.0	46.64	4.2	1201.0
28 16:41	108446.0	46.02	4.2	1203.2
28 16:42	101568.0	45.73	4.2	1203.2
28 16:43	101939.0	47.00	4.1	1199.7
28 16:44	101459.0	46.81	4.1	1199.3
28 16:45	101330.0	46.74	4.1	1200.5
28 16:46	98722.0	45.65	4.1	1200.3
28 16:47	100721.0	46.77	4.1	1200.2
28 16:48	100336.0	46.71	4.1	1199.8
28 16:49	99964.0	46.52	4.1	1199.8
28 16:50	101490.0	47.29	4.1	1199.8
28 16:51	100282.0	46.75	4.1	1200.0
28 16:52	98012.0	45.72	4.1	1199.7
28 16:53	100510.0	46.89	4.1	1200.0
28 16:54	100218.0	46.75	4.1	1200.0
28 16:55	100441.0	46.84	4.1	1200.0
28 16:56	982220.0	45.82	4.1	1200.0
28 16:57	101093.0	47.15	4.2	1200.0
28 16:58	98251.0	45.83	4.1	1190.7
28 16:59	100999.0	47.12	4.2	1199.3
28 17:00	100516.0	46.89	4.2	1200.3
28 17:01	99553.0	46.34	4.2	1200.0
28 17:02	100833.0	46.93	4.2	1200.7
28 17:03	100151.0	46.70	4.2	1199.8
28 17:04	101353.0	47.34	4.1	1199.5
28 17:05	100399.0	46.82	4.2	1199.5
28 17:06	100171.0	46.54	4.2	1200.0
28 17:07	100398.0	46.65	4.2	1200.3
28 17:08	101117.0	47.06	4.2	1199.5
28 17:09	103698.0	47.64	4.2	1199.5
28 17:10	100296.0	46.27	4.2	1201.2
28 17:11	101810.0	47.46	4.2	1200.2
28 17:12	100212.0	46.75	4.2	1199.8
28 17:13	101462.0	47.24	4.2	1199.3
28 17:14	101312.0	46.97	4.2	1200.5
28 17:15	101321.0	47.08	4.2	1200.7
28 17:16	101263.0	47.24	4.2	1200.5
28 17:17	99076.0	46.33	4.2	1199.8
28 17:18	102497.0	47.88	4.2	1199.7
28 17:19	101171.0	47.15	4.2	1199.8
28 17:20	101839.0	47.33	4.2	1199.8
28 17:21	100759.0	46.87	4.2	1200.7
Average	101541.9	46.8	4.1	1199.9

Run 1

Cedar 5 Reports 3/8/2023 6:40 AM, CeDAR 1-Minute Data

Page 1

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat Input 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T _E °F 1-Min
Timestamp	1-Min				
2/8 17:22	101060.0	47.14	4.2	1199.8	
2/8 17:23	101533.0	47.36	4.2	1200.0	
2/8 17:24	100996.0	46.70	4.2	1199.7	
2/8 17:25	102986.0	47.95	4.2	1199.8	
2/8 17:26	100444.0	46.72	4.2	1200.2	
2/8 17:27	101493.0	47.16	4.2	1200.2	
2/8 17:28	101355.0	47.09	4.2	1200.2	
2/8 17:29	99114.0	46.08	4.2	1200.2	
2/8 17:30	101388.0	47.19	4.2	1200.0	
2/8 17:31	100937.0	46.98	4.2	1199.8	
2/8 17:32	101493.0	47.23	4.2	1200.0	
2/8 17:33	101555.0	47.27	4.2	1199.5	
2/8 17:34	101224.0	47.11	4.2	1200.3	
2/8 17:35	102296.0	47.61	4.2	1200.0	
2/8 17:36	101133.0	47.07	4.2	1199.8	
2/8 17:37	101585.0	47.17	4.2	1199.7	
2/8 17:38	101081.0	46.93	4.2	1200.0	
2/8 17:39	99365.0	46.14	4.2	1199.8	
2/8 17:40	103181.0	47.91	4.2	1200.2	
2/8 17:41	99791.0	46.33	4.2	1199.8	
2/8 17:42	100529.0	46.68	4.2	1200.2	
2/8 17:43	101986.0	47.36	4.2	1199.8	
2/8 17:44	101828.0	47.28	4.2	1200.0	
2/8 17:45	102243.0	47.47	4.2	1200.0	
2/8 17:46	101636.0	47.19	4.2	1199.8	
2/8 17:47	101196.0	47.07	4.2	1199.8	
2/8 17:48	101197.0	46.99	4.2	1200.2	
2/8 17:49	102112.0	47.38	4.2	1200.0	
2/8 17:50	100850.0	46.72	4.2	1199.8	
2/8 17:51	102078.0	47.32	4.2	1200.2	
2/8 17:52	101548.0	47.15	4.2	1200.0	
2/8 17:53	100147.0	46.53	4.2	1200.2	
2/8 17:54	101929.0	47.33	4.2	1199.8	
2/8 17:55	103463.0	48.07	4.2	1200.0	
2/8 17:56	102266.0	47.48	4.2	1200.2	
2/8 17:57	98548.0	45.73	4.2	1199.3	
2/8 17:58	101128.0	46.85	4.2	1200.2	
2/8 17:59	101325.0	46.97	4.2	1200.0	
2/8 18:00	99792.0	46.28	4.2	1200.2	
2/8 18:01	101396.0	47.08	4.2	1199.8	
2/8 18:02	101744.0	47.22	4.2	1199.8	
2/8 18:03	101261.0	46.99	4.2	1199.7	
2/8 18:04	101754.0	47.17	4.2	1200.0	
2/8 18:05	101604.0	47.07	4.2	1199.8	
2/8 18:06	100561.0	46.56	4.2	1199.7	
2/8 18:07	101699.0	47.12	4.2	1200.0	
2/8 18:08	102324.0	47.40	4.2	1200.0	
2/8 18:09	102681.0	47.57	4.2	1200.0	
2/8 18:10	101394.0	46.97	4.2	1200.0	

Cedarr 5 Reports 3/8/2023 8:40 AM, CEDAR 1-Minute Data

Page 1

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts /Min	(TG-741) T7 °F. 1-Min
Timestamp	1-Min	1-Min	Megawatts /Min	Exhaust Temp °F. 1-Min
2/8 18:11	101334.0	46.95	4.2	1200.2
2/8 18:12	101355.0	47.01	4.2	1199.8
2/8 18:13	101957.0	47.21	4.2	1199.7
2/8 18:14	101950.0	47.09	4.2	1200.2
2/8 18:15	100581.0	46.43	4.2	1200.0
2/8 18:16	102999.0	47.61	4.2	1200.2
2/8 18:17	101635.0	46.98	4.2	1200.2
2/8 18:18	102092.0	47.19	4.2	1199.8
2/8 18:19	102361.0	47.20	4.2	1200.2
2/8 18:20	101821.0	47.03	4.2	1199.8
2/8 18:21	101497.0	46.82	4.2	1200.2
2/8 18:22	101561.0	46.88	4.2	1200.3
2/8 18:23	101414.0	46.83	4.2	1200.2
2/8 18:24	101632.0	46.87	4.2	1200.0
2/8 18:25	100640.0	46.44	4.2	1200.0
2/8 18:26	100814.0	46.59	4.2	1199.8
2/8 18:27	101619.0	46.97	4.2	1199.8
2/8 18:28	102073.0	47.10	4.2	1199.7
2/8 18:29	101254.0	46.69	4.2	1200.0
2/8 18:30	102439.0	47.17	4.2	1200.0
2/8 18:31	101238.0	46.57	4.2	1199.8
2/8 18:32	101149.0	46.60	4.2	1200.0
2/8 18:33	102462.0	47.18	4.2	1200.2
2/8 18:34	101882.0	46.98	4.2	1199.8
2/8 18:35	102305.0	47.20	4.2	1200.3
2/8 18:36	102437.0	47.31	4.2	1200.0
2/8 18:37	101666.0	46.88	4.2	1200.0
2/8 18:38	102790.0	47.40	4.2	1199.8
2/8 18:39	100881.0	46.52	4.2	1200.0
2/8 18:40	100112.0	46.16	4.2	1199.8
2/8 18:41	103478.0	47.69	4.2	1199.8
2/8 18:42	100091.0	46.15	4.2	1200.0
2/8 18:43	102189.0	47.12	4.2	1200.2
2/8 18:44	100552.0	46.34	4.2	1199.7
2/8 18:45	103869.0	47.87	4.2	1200.0
2/8 18:46	102526.0	47.19	4.2	1200.3
2/8 18:47	102411.0	47.22	4.2	1200.0
2/8 18:48	102187.0	47.12	4.2	1200.2
2/8 18:49	100275.0	46.18	4.2	1200.5
2/8 18:50	102296.0	47.13	4.2	1199.8
2/8 18:51	101619.0	46.88	4.2	1200.0
2/8 18:52	101814.0	47.02	4.2	1199.8
2/8 18:53	101986.0	47.06	4.2	1200.0
2/8 18:54	102609.0	47.43	4.2	1199.8
2/8 18:55	102233.0	47.14	4.2	1199.8
2/8 18:56	103085.0	47.56	4.2	1199.8
2/8 18:57	102447.0	47.24	4.2	1199.5
2/8 18:58	102427.0	47.25	4.2	1200.0
2/8 18:59	102090.0	46.98	4.2	1199.8

Cedar 5 Reports 3/8/2023 6:40 AM, CeDAR 1-Minute Data

Page 1

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts · Min	(TG-741) T ₇ Exhaust Temp °F · Min
Timestamp	1-Min	1-Min	1-Min	
2/8 19:00	100965.0	46.45	4.2	1200.0
Average (all)	102194.1	47.09	4.2	1200.0
Total (all)	--	--	--	--
Minimum (all)	97648.0	45.53	4.1	1190.7
Maximum (all)	118114.0	49.27	4.2	1203.2
Average (valid values only)	102194.1	47.09	4.2	1200.0
Total (valid values only)	--	--	--	--
Count (valid values only)	781	781	781	781

CeDAR 1-Minute Data
Sunshine Gas Producers, LLC
Data for 2/9/2023 6:00 AM thru 2/9/2023 7:00 PM

Timestamp	(TG-741) Landfill Gas Flow scf/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
2/9 6:00	101278.0	46.42	4.2	1200.2
2/9 6:01	105057.0	48.21	4.2	1200.0
2/9 6:02	103513.0	47.50	4.2	1200.0
2/9 6:03	102432.0	47.01	4.2	1199.7
2/9 6:04	103617.0	47.52	4.2	1200.0
2/9 6:05	103327.0	47.30	4.2	1200.0
2/9 6:06	103804.0	47.61	4.2	1200.0
2/9 6:07	102593.0	47.06	4.2	1200.3
2/9 6:08	103497.0	47.43	4.2	1200.3
2/9 6:09	103355.0	47.40	4.2	1199.8
2/9 6:10	101568.0	46.53	4.2	1200.0
2/9 6:11	104950.0	48.05	4.2	1200.2
2/9 6:12	102971.0	47.14	4.2	1200.2
2/9 6:13	102634.0	46.99	4.2	1200.0
2/9 6:14	101104.0	46.28	4.2	1200.0
2/9 6:15	103258.0	47.27	4.2	1199.8
2/9 6:16	103981.0	47.60	4.2	1200.2
2/9 6:17	103235.0	47.29	4.2	1200.0
2/9 6:18	103957.0	47.64	4.2	1199.7
2/9 6:19	103294.0	47.37	4.2	1199.8
2/9 6:20	102150.0	46.78	4.2	1200.0
2/9 6:21	104467.0	47.81	4.2	1200.0
2/9 6:22	104739.0	47.86	4.2	1200.2
2/9 6:23	103084.0	47.11	4.2	1200.2
2/9 6:24	102567.0	46.97	4.2	1199.8
2/9 6:25	103291.0	47.32	4.2	1199.8
2/9 6:26	102360.0	46.97	4.2	1200.0
2/9 6:27	104139.0	47.79	4.2	1200.0
2/9 6:28	101213.0	46.41	4.2	1200.2
2/9 6:29	102977.0	47.14	4.2	1200.0
2/9 6:30	103729.0	47.49	4.2	1200.3
2/9 6:31	101876.0	46.66	4.2	1199.8
2/9 6:32	102636.0	46.96	4.2	1200.0
2/9 6:33	103909.0	47.57	4.2	1200.0
2/9 6:34	103847.0	47.54	4.2	1199.8
2/9 6:35	102495.0	46.92	4.2	1199.8
2/9 6:36	101806.0	46.63	4.2	1200.0
2/9 6:37	103421.0	47.37	4.2	1200.0
2/9 6:38	103369.0	47.35	4.2	1200.2
2/9 6:39	102521.0	46.91	4.2	1199.7
2/9 6:40	103877.0	47.47	4.2	1200.2
2/9 6:41	102469.0	46.83	4.2	1199.8
2/9 6:42	103405.0	47.32	4.2	1200.0
2/9 6:43	104064.0	47.52	4.2	1199.7
2/9 6:44	104752.0	47.84	4.2	1200.0

	(TG-741) Landfill Gas Flow scfh/r 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
2/9/6:45	1.03727.0	47.37	4.2	1200.0
2/9/6:46	1.03639.0	47.33	4.2	1200.0
2/9/6:47	1.02268.0	46.71	4.2	1200.2
2/9/6:48	1.02843.0	46.97	4.2	1199.5
2/9/6:49	1.02133.0	46.62	4.2	1200.0
2/9/6:50	1.02527.0	46.86	4.2	1200.2
2/9/6:51	1.01449.0	46.36	4.2	1200.0
2/9/6:52	1.03954.0	47.54	4.2	1200.0
2/9/6:53	1.03239.0	47.17	4.2	1200.0
2/9/6:54	1.03389.0	47.22	4.2	1200.0
2/9/6:55	1.04211.0	47.54	4.2	1200.2
2/9/6:56	1.03817.0	47.30	4.2	1200.0
2/9/6:57	1.02865.0	46.89	4.2	1200.5
2/9/6:58	1.03213.0	47.16	4.2	1200.2
2/9/6:59	1.02603.0	46.95	4.2	1199.8
2/9/7:00	1.03926.0	47.46	4.2	1200.0
2/9/7:01	1.04557.0	47.70	4.2	1199.7
2/9/7:02	1.03138.0	46.99	4.2	1200.2
2/9/7:03	1.02208.0	46.59	4.2	1200.2
2/9/7:04	1.04538.0	47.77	4.2	1200.0
2/9/7:05	1.02967.0	47.03	4.2	1200.2
2/9/7:06	1.03036.0	47.15	4.2	1199.8
2/9/7:07	1.03623.0	47.32	4.2	1200.0
2/9/7:08	1.02117.0	46.64	4.2	1200.2
2/9/7:09	1.03915.0	47.57	4.2	1200.0
2/9/7:10	1.01460.0	46.59	4.2	1200.2
2/9/7:11	1.02934.0	47.32	4.2	1199.3
2/9/7:12	1.05156.0	48.12	4.2	1199.5
2/9/7:13	1.05307.0	48.01	4.2	1199.8
2/9/7:14	1.06217.0	48.34	4.2	1200.0
2/9/7:15	1.03108.0	47.07	4.2	1200.5
2/9/7:16	1.02430.0	46.97	4.2	1200.3
2/9/7:17	1.02096.0	47.04	4.2	1199.8
2/9/7:18	1.03464.0	47.50	4.2	1200.2
2/9/7:19	1.01742.0	46.72	4.2	1200.0
2/9/7:20	1.03605.0	47.68	4.2	1202.0
2/9/7:21	1.01737.0	47.67	4.2	1201.2
2/9/7:22	99986.0	47.18	4.2	1200.2
2/9/7:23	98734.0	47.15	4.2	1199.3
2/9/7:24	99496.0	46.96	4.2	1199.7
2/9/7:25	1.02555.0	48.21	4.2	1199.3
2/9/7:26	1.00852.0	47.19	4.2	1199.7
2/9/7:27	1.02962.0	48.00	4.2	1199.3
2/9/7:28	1.02369.0	47.50	4.2	1199.5
2/9/7:29	1.02265.0	47.27	4.2	1199.8
2/9/7:30	1.02895.0	47.36	4.2	1199.8
2/9/7:31	1.04243.0	47.89	4.2	1200.0
2/9/7:32	1.05581.0	48.45	4.2	1200.2
2/9/7:33	1.03576.0	47.53	4.2	1200.0

	(TG-741) Landfill Gas Flow scfh/r 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T °F 1-Min
Timestamp				
2/9 7:34	102739.0	47.15	4.2	1199.8
2/9 7:35	102382.0	46.95	4.2	1199.8
2/9 7:36	102349.0	46.88	4.2	1199.8
2/9 7:37	105121.0	48.12	4.2	1200.0
2/9 7:38	104394.0	47.82	4.2	1200.2
2/9 7:39	101638.0	46.66	4.2	1200.2
2/9 7:40	103463.0	47.71	4.2	1200.3
2/9 7:41	101114.0	46.80	4.2	1200.2
2/9 7:42	101469.0	47.06	4.2	1200.2
2/9 7:43	101776.0	47.26	4.2	1200.0
2/9 7:44	101369.0	47.13	4.2	1200.0
2/9 7:45	101012.0	47.03	4.2	1200.0
2/9 7:46	100944.0	47.07	4.2	1200.0
2/9 7:47	100949.0	47.00	4.2	1200.2
2/9 7:48	100519.0	46.89	4.2	1200.0
2/9 7:49	101297.0	47.35	4.2	1200.2
2/9 7:50	99986.0	46.79	4.2	1200.0
2/9 7:51	102000.0	47.70	4.2	1200.0
2/9 7:52	100727.0	47.10	4.2	1200.0
2/9 7:53	100666.0	47.13	4.2	1199.8
2/9 7:54	99631.0	46.59	4.2	1200.0
2/9 7:55	100707.0	47.09	4.2	1200.0
2/9 7:56	100730.0	47.16	4.2	1200.0
2/9 7:57	100315.0	46.94	4.2	1200.0
2/9 7:58	101684.0	47.61	4.2	1199.8
2/9 7:59	100233.0	46.89	4.2	1200.0
2/9 8:00	103103.0	48.23	4.2	1200.2
2/9 8:01	99943.0	46.75	4.2	1200.0
2/9 8:02	100321.0	46.91	4.2	1200.0
2/9 8:03	100440.0	47.00	4.2	1200.0
2/9 8:04	100666.0	47.16	4.2	1200.0
2/9 8:05	101266.0	47.37	4.2	1199.8
2/9 8:06	100490.0	47.07	4.2	1200.2
2/9 8:07	101126.0	47.29	4.2	1199.8
2/9 8:08	99979.0	46.75	4.2	1200.2
2/9 8:09	101875.0	47.64	4.2	1200.0
2/9 8:10	102192.0	47.78	4.2	1200.0
2/9 8:11	102026.0	47.71	4.2	1200.0
2/9 8:12	100074.0	46.79	4.2	1200.0
2/9 8:13	101290.0	47.36	4.2	1200.0
2/9 8:14	100906.0	47.19	4.2	1200.0
2/9 8:15	100874.0	47.17	4.2	1199.8
2/9 8:16	100283.0	46.89	4.2	1200.2
2/9 8:17	102397.0	47.96	4.2	1200.3
2/9 8:18	101162.0	47.30	4.2	1199.7
2/9 8:19	101573.0	47.51	4.2	1200.0
2/9 8:20	100475.0	47.00	4.2	1200.0
2/9 8:21	98482.0	46.08	4.2	1200.0
2/9 8:22	99603.0	46.68	4.2	1199.8

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/9 8:23	101557.0	47.60	4.2	1200.0	
2/9 8:24	100986.0	47.33	4.2	1200.0	
2/9 8:25	100197.0	46.94	4.2	1199.8	
2/9 8:26	101009.0	47.34	4.2	1200.0	
2/9 8:27	100531.0	47.12	4.2	1200.0	
2/9 8:28	101300.0	47.40	4.2	1200.0	
2/9 8:29	100402.0	46.95	4.2	1200.0	
2/9 8:30	99869.0	46.78	4.2	1200.2	
2/9 8:31	100199.0	46.94	4.2	1200.2	
2/9 8:32	100821.0	47.17	4.2	1200.0	
2/9 8:33	100736.0	47.13	4.2	1200.0	
2/9 8:34	98716.0	46.22	4.2	1200.0	
2/9 8:35	100076.0	46.89	4.2	1200.0	
2/9 8:36	100484.0	47.09	4.2	1200.2	
2/9 8:37	101231.0	47.47	4.2	1200.0	
2/9 8:38	101344.0	47.42	4.2	1199.8	
2/9 8:39	101977.0	47.63	4.2	1199.8	
2/9 8:40	998601.0	46.54	4.2	1200.2	
2/9 8:41	101563.0	47.46	4.2	1200.0	
2/9 8:42	101575.0	47.50	4.2	1200.0	
2/9 8:43	100252.0	46.90	4.2	1200.2	
2/9 8:44	101038.0	47.33	4.2	1200.3	
2/9 8:45	101530.0	47.67	4.2	1199.8	
2/9 8:46	101527.0	47.57	4.2	1200.2	
2/9 8:47	101105.0	47.39	4.2	1200.0	
2/9 8:48	99424.0	46.58	4.2	1200.3	
2/9 8:49	998696.0	46.73	4.2	1199.8	
2/9 8:50	100993.0	47.33	4.2	1200.0	
2/9 8:51	100365.0	47.04	4.2	1200.0	
2/9 8:52	99825.0	46.77	4.1	1198.8	
2/9 8:53	100726.0	46.85	4.2	1199.3	
2/9 8:54	101352.0	46.96	4.2	1200.2	
2/9 8:55	101548.0	47.15	4.2	1200.7	
2/9 8:56	100601.0	46.96	4.2	1200.5	
2/9 8:57	101475.0	47.53	4.2	1200.0	
2/9 8:58	99082.0	46.30	4.1	1198.5	
2/9 8:59	101570.0	47.09	4.2	1199.8	
2/9 9:00	101555.0	46.96	4.2	1200.0	
2/9 9:01	101218.0	47.19	4.2	1200.5	
2/9 9:02	100170.0	47.03	4.2	1199.8	
2/9 9:03	101131.0	46.74	4.2	1200.2	
2/9 9:04	100644.0	47.15	4.2	1200.2	
2/9 9:05	100246.0	46.97	4.2	1200.2	
2/9 9:06	100960.0	47.32	4.1	1200.2	
2/9 9:11	100335.0	47.05	4.2	1200.0	

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp					
29 9:12	100251.0	46.98	4.2	1199.8	
29 9:13	100972.0	47.32	4.2	1200.2	
29 9:14	100719.0	47.16	4.2	1199.8	
29 9:15	101121.0	47.28	4.1	1199.5	
29 9:16	101165.0	47.20	4.2	1199.8	
29 9:17	101007.0	47.01	4.1	1198.8	
29 9:18	102124.0	47.22	4.2	1199.5	
29 9:19	102022.0	46.85	4.2	1199.8	
29 9:20	102441.0	46.90	4.2	1199.8	
29 9:21	102097.0	46.63	4.2	1200.2	
29 9:22	101796.0	46.55	4.1	1198.3	
29 9:23	107623.0	48.10	4.2	1199.8	
29 9:24	109254.0	47.61	4.2	1199.3	
29 9:25	105497.0	46.49	4.2	1199.5	
29 9:26	104059.0	46.24	4.2	1200.7	
29 9:27	104399.0	46.87	4.2	1201.3	
29 9:28	104483.0	47.43	4.1	1199.2	
29 9:29	103209.0	46.66	4.2	1200.3	
29 9:30	103532.0	46.97	4.2	1200.2	
29 9:31	102012.0	46.40	4.2	1200.3	
29 9:32	104554.0	47.75	4.2	1200.2	
29 9:33	103476.0	47.23	4.2	1199.8	
29 9:34	103124.0	46.95	4.2	1200.2	
29 9:35	103120.0	46.89	4.2	1199.7	
29 9:36	104442.0	47.47	4.2	1200.2	
29 9:37	103163.0	46.93	4.2	1200.3	
29 9:38	103449.0	47.13	4.2	1200.2	
29 9:39	103217.0	47.03	4.2	1199.8	
29 9:40	103440.0	47.13	4.2	1200.0	
29 9:41	103608.0	47.27	4.2	1199.8	
29 9:42	101690.0	46.44	4.2	1200.2	
29 9:43	103596.0	47.41	4.2	1200.3	
29 9:44	102163.0	46.77	4.2	1200.2	
29 9:45	100997.0	46.26	4.2	1200.0	
29 9:46	104412.0	47.89	4.2	1200.0	
29 9:47	102961.0	47.14	4.2	1200.0	
29 9:48	101343.0	46.39	4.2	1200.3	
29 9:49	103977.0	47.69	4.2	1200.5	
29 9:50	103465.0	47.57	4.2	1199.8	
29 9:51	101555.0	46.70	4.2	1200.2	
29 9:52	102888.0	47.33	4.2	1200.2	
29 9:53	102035.0	46.94	4.2	1199.8	
29 9:54	100785.0	46.36	4.1	1200.0	
29 9:55	101692.0	46.78	4.1	1200.2	
29 9:56	102322.0	47.07	4.1	1200.3	
29 9:57	102999.0	47.45	4.1	1200.2	
29 9:58	101466.0	46.79	4.1	1200.3	
29 9:59	103572.0	47.76	4.1	1199.7	
29 10:00	102841.0	47.42	4.1	1200.0	

	(TG-741) Landfill Gas Flow scfh/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/9 10:01	100647.0	46.37	4.1	1200.3	
2/9 10:02	101911.0	46.99	4.1	1200.0	
2/9 10:03	103377.0	47.67	4.1	1199.8	
2/9 10:04	102682.0	47.35	4.1	1200.2	
2/9 10:05	102857.0	47.32	4.2	1200.2	
2/9 10:06	101321.0	46.70	4.1	1200.0	
2/9 10:07	101914.0	46.99	4.1	1200.0	
2/9 10:08	102688.0	47.35	4.1	1200.2	
2/9 10:09	100783.0	46.47	4.1	1200.2	
2/9 10:10	101910.0	46.99	4.1	1199.8	
2/9 10:11	101598.0	46.88	4.1	1199.8	
2/9 10:12	102322.0	47.12	4.1	1199.7	
2/9 10:13	100781.0	46.41	4.1	1200.2	
2/9 10:14	101675.0	46.80	4.1	1200.0	
2/9 10:15	102088.0	46.96	4.1	1200.0	
2/9 10:16	102725.0	47.33	4.1	1200.2	
2/9 10:17	101201.0	46.66	4.1	1200.3	
2/9 10:18	99748.0	45.90	4.1	1200.2	
2/9 10:19	103610.0	47.66	4.1	1199.8	
2/9 10:20	102459.0	47.13	4.1	1200.2	
2/9 10:21	102322.0	47.05	4.1	1200.0	
2/9 10:22	101104.0	46.45	4.1	1200.3	
2/9 10:23	102891.0	47.40	4.1	1199.8	
2/9 10:24	103096.0	47.48	4.1	1200.2	
2/9 10:25	101122.0	46.57	4.1	1200.5	
2/9 10:26	100593.0	46.38	4.1	1200.0	
2/9 10:27	101877.0	47.05	4.1	1200.2	
2/9 10:28	102444.0	47.32	4.1	1199.5	
2/9 10:29	101239.0	46.70	4.1	1199.8	
2/9 10:30	102618.0	47.37	4.1	1200.0	
2/9 10:31	102136.0	47.12	4.1	1200.0	
2/9 10:32	102026.0	47.16	4.1	1200.0	
2/9 10:33	99842.0	46.15	4.1	1200.0	
2/9 10:34	100459.0	46.43	4.1	1200.2	
2/9 10:35	101148.0	46.72	4.1	1200.0	
2/9 10:36	102374.0	47.27	4.1	1200.0	
2/9 10:37	100635.0	46.41	4.1	1200.0	
2/9 10:38	101035.0	46.64	4.1	1199.8	
2/9 10:39	100143.0	46.17	4.1	1200.0	
2/9 10:40	100887.0	46.52	4.1	1200.0	
2/9 10:41	101789.0	46.94	4.1	1200.3	
2/9 10:42	101763.0	46.92	4.1	1200.0	
2/9 10:43	102510.0	47.27	4.1	1199.7	
2/9 10:44	104293.0	47.99	4.1	1199.2	
2/9 10:45	103465.0	47.28	4.1	1199.5	
2/9 10:46	102299.0	46.67	4.1	1200.2	
2/9 10:47	101002.0	46.19	4.1	1200.5	
2/9 10:48	101416.0	46.63	4.1	1200.5	
2/9 10:49	100122.0	46.22	4.1	1199.8	

	(TG-741) Landfill Gas Flow scfh/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/9 10:50	100419.0	46.41	4.1	1199.8	
2/9 10:51	100733.0	46.56	4.1	1200.0	
2/9 10:52	102543.0	47.39	4.1	1200.2	
2/9 10:53	101699.0	47.01	4.1	1200.0	
2/9 10:54	100431.0	46.42	4.1	1200.0	
2/9 10:55	102314.0	47.31	4.1	1199.8	
2/9 10:56	102178.0	47.28	4.1	1199.7	
2/9 10:57	100417.0	46.41	4.1	1200.0	
2/9 10:58	99621.0	45.96	4.1	1200.2	
2/9 10:59	101221.0	46.78	4.1	1199.8	
2/9 11:00	101753.0	47.06	4.1	1200.2	
2/9 11:01	100747.0	46.68	4.1	1199.7	
2/9 11:02	99883.0	46.27	4.1	1200.2	
2/9 11:03	100143.0	46.39	4.1	1199.8	
2/9 11:04	101930.0	47.14	4.1	1200.0	
2/9 11:05	100612.0	46.52	4.1	1200.0	
2/9 11:06	103129.0	47.70	4.1	1200.2	
2/9 11:07	102225.0	47.33	4.1	1200.0	
2/9 11:08	99900.0	45.87	4.1	1200.0	
2/9 11:09	100631.0	46.56	4.1	1200.2	
2/9 11:10	100201.0	46.33	4.1	1199.8	
2/9 11:11	101899.0	47.10	4.1	1200.0	
2/9 11:12	100925.0	46.68	4.1	1200.0	
2/9 11:13	100796.0	46.64	4.1	1200.0	
2/9 11:14	99600.0	46.14	4.1	1200.2	
2/9 11:15	99428.0	46.07	4.1	1199.8	
2/9 11:16	102069.0	47.29	4.1	1200.2	
2/9 11:17	101185.0	46.84	4.1	1199.8	
2/9 11:18	101543.0	46.93	4.1	1200.0	
2/9 11:19	100286.0	46.40	4.1	1200.0	
2/9 11:20	100474.0	46.52	4.1	1200.0	
2/9 11:21	101600.0	46.99	4.1	1200.2	
2/9 11:22	100388.0	46.42	4.1	1200.3	
2/9 11:23	100911.0	46.64	4.1	1200.0	
2/9 11:24	101500.0	46.91	4.1	1200.0	
2/9 11:25	100680.0	46.53	4.1	1200.0	
2/9 11:26	99747.0	46.15	4.1	1200.2	
2/9 11:27	100377.0	46.45	4.1	1199.8	
2/9 11:28	101229.0	46.81	4.1	1200.3	
2/9 11:29	100085.0	46.37	4.1	1199.3	
2/9 11:30	100549.0	46.55	4.1	1200.2	
2/9 11:31	99884.0	45.81	4.1	1200.0	
2/9 11:32	98937.0	45.84	4.1	1200.0	
2/9 11:33	101576.0	47.06	4.1	1200.0	
2/9 11:34	101101.0	46.80	4.1	1199.7	
2/9 11:35	99912.0	46.21	4.1	1200.2	
2/9 11:36	100952.0	46.74	4.1	1200.0	
2/9 11:37	101056.0	46.84	4.1	1200.3	
2/9 11:38	98670.0	45.78	4.1	1200.0	

	(TG-741) Landfill Gas Flow scfh/r	(TG-741) Input mmBtu/hr	(TG-741) Heat 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	4.1	1200.0
2/9/11:39	99755.0	46.31	4.1	1199.8	
2/9/11:40	99706.0	46.27	4.1	1199.5	
2/9/11:41	101505.0	47.06	4.1	1199.5	
2/9/11:42	99941.0	48.30	4.1	1200.0	
2/9/11:43	100640.0	46.63	4.1	1200.3	
2/9/11:44	101183.0	46.88	4.1	1200.2	
2/9/11:45	101615.0	47.15	4.1	1200.0	
2/9/11:46	101252.0	46.98	4.1	1200.0	
2/9/11:47	100437.0	46.58	4.1	1200.2	
2/9/11:48	101305.0	47.04	4.1	1199.8	
2/9/11:49	101988.0	47.25	4.1	1199.8	
2/9/11:50	100339.0	46.57	4.1	1200.5	
2/9/11:51	100031.0	46.47	4.1	1200.0	
2/9/11:52	102462.0	47.66	4.1	1200.2	
2/9/11:53	99999.0	46.49	4.1	1199.7	
2/9/11:54	99835.0	46.34	4.1	1199.5	
2/9/11:55	100860.0	46.70	4.1	1199.8	
2/9/11:56	99201.0	45.92	4.1	1200.2	
2/9/11:57	100641.0	46.63	4.1	1200.5	
2/9/11:58	100332.0	46.56	4.1	1200.3	
2/9/11:59	100380.0	46.61	4.1	1200.0	
2/9/12:00	100559.0	46.71	4.1	1199.8	
2/9/12:01	101466.0	47.09	4.1	1200.2	
2/9/12:02	100362.0	46.52	4.1	1199.8	
2/9/12:03	100423.0	46.52	4.1	1200.0	
2/9/12:04	100367.0	46.50	4.1	1200.2	
2/9/12:05	99952.0	46.34	4.1	1200.2	
2/9/12:06	99549.0	46.22	4.1	1200.5	
2/9/12:07	100411.0	46.68	4.1	1200.2	
2/9/12:08	98760.0	45.85	4.1	1200.0	
2/9/12:09	100744.0	46.75	4.1	1199.8	
2/9/12:10	100437.0	46.63	4.1	1199.8	
2/9/12:11	99943.0	46.40	4.1	1200.3	
2/9/12:12	100630.0	46.81	4.1	1199.7	
2/9/12:13	99104.0	46.07	4.1	1199.8	
2/9/12:14	99914.0	46.39	4.1	1199.8	
2/9/12:15	100344.0	46.57	4.1	1199.8	
2/9/12:20	100417.0	46.66	4.1	1200.2	
2/9/12:21	101633.0	47.19	4.1	1199.7	
2/9/12:22	101526.0	47.06	4.1	1200.0	
2/9/12:23	101510.0	47.06	4.1	1200.2	
2/9/12:24	100680.0	46.74	4.1	1199.7	
2/9/12:25	100693.0	46.68	4.1	1199.8	
2/9/12:26	998930.0	46.35	4.1	1199.8	
2/9/12:27	100765.0	46.71	4.1	1200.5	

	(TG-741) Landfill Gas Flow scf/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp				
2/9 12:28	102087.0	47.40	4.1	1200.2
2/9 12:29	100070.0	46.54	4.1	1200.2
2/9 12:30	99808.0	46.38	4.1	1199.8
2/9 12:31	99935.0	46.40	4.1	1200.0
2/9 12:32	100912.0	46.85	4.1	1199.7
2/9 12:33	100997.0	46.71	4.1	1200.0
2/9 12:34	99934.0	46.22	4.1	1200.0
2/9 12:35	101862.0	47.19	4.1	1200.3
2/9 12:36	98988.0	45.96	4.1	1199.7
2/9 12:37	101404.0	47.01	4.1	1199.8
2/9 12:38	102369.0	47.48	4.1	1199.8
2/9 12:39	99491.0	46.03	4.1	1200.2
2/9 12:40	101753.0	47.05	4.1	1199.8
2/9 12:41	101952.0	47.12	4.1	1200.2
2/9 12:42	101174.0	46.76	4.1	1199.8
2/9 12:43	100399.0	46.46	4.1	1200.0
2/9 12:44	99927.0	46.32	4.1	1199.8
2/9 12:45	101429.0	48.24	4.1	1200.0
2/9 12:46	99778.0	46.23	4.1	1199.8
2/9 12:47	101896.0	47.21	4.1	1200.2
2/9 12:48	102598.0	47.53	4.1	1199.8
2/9 12:49	101530.0	47.06	4.1	1200.2
2/9 12:50	100573.0	46.69	4.1	1200.2
2/9 12:51	99941.0	46.30	4.1	1200.3
2/9 12:52	100156.0	46.47	4.1	1199.8
2/9 12:53	100992.0	46.95	4.1	1200.0
2/9 12:54	99095.0	46.05	4.1	1199.7
2/9 12:55	101755.0	47.26	4.1	1200.2
2/9 12:56	102150.0	47.47	4.1	1200.2
2/9 12:57	99875.0	46.37	4.1	1200.0
2/9 12:58	101588.0	47.21	4.1	1200.2
2/9 12:59	101282.0	47.11	4.1	1200.3
2/9 13:00	101023.0	47.01	4.1	1199.8
2/9 13:01	99815.0	46.46	4.1	1200.2
2/9 13:02	101212.0	47.16	4.1	1200.2
2/9 13:03	99245.0	46.19	4.1	1200.0
2/9 13:04	101095.0	47.05	4.1	1200.2
2/9 13:05	100490.0	46.83	4.1	1199.7
2/9 13:06	101137.0	47.12	4.1	1200.0
2/9 13:07	101071.0	47.04	4.1	1199.8
2/9 13:08	101218.0	47.09	4.1	1199.8
2/9 13:09	99371.0	46.14	4.1	1200.0
2/9 13:10	100766.0	46.79	4.1	1199.8
2/9 13:11	101834.0	47.36	4.1	1200.2
2/9 13:12	100596.0	46.82	4.1	1199.8
2/9 13:13	101067.0	47.04	4.1	1199.8
2/9 13:14	100623.0	46.80	4.1	1200.2
2/9 13:15	99896.0	46.41	4.1	1200.0
2/9 13:16	101788.0	47.18	4.1	1199.8

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	Exhaust Temp °F 1-Min
2/9 13:17	99779.0	46.31	4.1	4.1	1200.2
2/9 13:18	100042.0	46.45	4.1	4.1	1200.3
2/9 13:19	99679.0	46.28	4.1	4.1	1200.2
2/9 13:20	99950.0	46.47	4.1	4.1	1200.2
2/9 13:21	100842.0	46.80	4.1	4.1	1200.0
2/9 13:22	100493.0	46.64	4.1	4.1	1199.8
2/9 13:23	101830.0	47.28	4.1	4.1	1200.0
2/9 13:24	101094.0	46.89	4.1	4.1	1200.2
2/9 13:25	100740.0	46.77	4.1	4.1	1200.0
2/9 13:26	100578.0	46.76	4.1	4.1	1200.0
2/9 13:27	101390.0	47.12	4.1	4.1	1200.0
2/9 13:28	101225.0	47.03	4.1	4.1	1199.8
2/9 13:29	100242.0	46.65	4.1	4.1	1200.7
2/9 13:30	101796.0	47.36	4.1	4.1	1199.3
2/9 13:31	99831.0	46.44	4.1	4.1	1200.0
2/9 13:32	100222.0	46.61	4.1	4.1	1200.2
2/9 13:33	988467.0	45.83	4.1	4.1	1199.8
2/9 13:34	101049.0	46.90	4.1	4.1	1199.7
2/9 13:35	101150.0	46.77	4.1	4.1	1199.3
2/9 13:36	101514.0	46.79	4.1	4.1	1200.2
2/9 13:37	102198.0	47.10	4.1	4.1	1200.0
2/9 13:38	1006657.0	46.37	4.1	4.1	1199.8
2/9 13:39	103763.0	47.76	4.1	4.1	1200.0
2/9 13:40	101464.0	46.76	4.1	4.1	1199.7
2/9 13:41	102119.0	47.07	4.1	4.1	1199.8
2/9 13:42	103355.0	47.66	4.1	4.1	1199.8
2/9 13:43	101586.0	46.77	4.1	4.1	1199.8
2/9 13:44	102283.0	47.14	4.1	4.1	1200.2
2/9 13:45	100275.0	46.16	4.1	4.1	1200.2
2/9 13:46	101952.0	47.03	4.1	4.1	1200.2
2/9 13:47	101895.0	46.99	4.1	4.1	1199.8
2/9 13:48	100985.0	46.57	4.1	4.1	1199.8
2/9 13:49	103437.0	47.60	4.1	4.1	1200.0
2/9 13:50	99722.0	46.03	4.1	4.1	1200.3
2/9 13:51	100526.0	46.54	4.1	4.1	1200.3
2/9 13:52	100884.0	46.74	4.1	4.1	1200.0
2/9 13:53	100222.0	46.46	4.1	4.1	1200.0
2/9 13:54	101982.0	47.41	4.1	4.1	1199.7
2/9 13:55	101093.0	46.97	4.1	4.1	1200.0
2/9 14:00	100025.0	46.44	4.1	4.1	1200.2
2/9 14:01	100685.0	46.78	4.1	4.1	1200.3
2/9 14:02	101508.0	47.24	4.1	4.1	1199.7
2/9 14:03	100527.0	46.81	4.1	4.1	1200.2
2/9 14:04	100351.0	46.70	4.1	4.1	1199.7
2/9 14:05	100283.0	46.67	4.1	4.1	1199.7

	(TG-741) Landfill Gas Flow scfhhr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust °F 1-Min
2/9 14:06	100438.0	46.74	4.1	1199.8
2/9 14:07	99702.0	46.40	4.1	1199.7
2/9 14:08	101896.0	47.42	4.1	1200.2
2/9 14:09	101820.0	47.39	4.1	1200.0
2/9 14:10	100521.0	46.75	4.1	1200.0
2/9 14:11	100220.0	46.61	4.1	1200.3
2/9 14:12	996550.0	46.33	4.1	1200.0
2/9 14:13	99775.0	46.44	4.1	1200.2
2/9 14:14	100384.0	46.72	4.1	1199.5
2/9 14:15	100999.0	46.51	4.1	1200.2
2/9 14:16	101367.0	46.96	4.1	1200.0
2/9 14:17	102206.0	47.24	4.1	1199.5
2/9 14:18	101230.0	46.79	4.1	1200.5
2/9 14:19	101590.0	46.95	4.1	1199.8
2/9 14:20	100040.0	46.16	4.1	1200.2
2/9 14:21	100910.0	46.60	4.1	1199.8
2/9 14:22	998661.0	46.08	4.1	1200.2
2/9 14:23	100110.0	46.46	4.1	1200.2
2/9 14:24	99295.0	46.21	4.1	1200.0
2/9 14:25	99016.0	46.08	4.1	1199.8
2/9 14:26	100759.0	46.87	4.1	1200.0
2/9 14:27	996655.0	46.35	4.1	1199.7
2/9 14:28	101980.0	47.43	4.1	1200.0
2/9 14:29	101034.0	47.00	4.1	1200.0
2/9 14:30	100497.0	46.77	4.1	1199.8
2/9 14:31	100546.0	46.80	4.1	1200.0
2/9 14:32	101416.0	47.07	4.1	1199.7
2/9 14:33	100351.0	46.46	4.1	1199.8
2/9 14:34	101178.0	46.88	4.1	1200.3
2/9 14:35	99178.0	46.05	4.1	1200.5
2/9 14:36	99545.0	45.87	4.1	1200.2
2/9 14:37	99649.0	46.38	4.1	1200.0
2/9 14:38	100543.0	46.79	4.1	1199.7
2/9 14:39	100013.0	46.56	4.1	1199.8
2/9 14:40	98480.0	45.80	4.1	1199.8
2/9 14:41	101704.0	47.22	4.1	1200.3
2/9 14:42	98900.0	46.04	4.1	1200.2
2/9 14:43	100956.0	46.99	4.1	1200.0
2/9 14:44	101255.0	47.13	4.1	1200.2
2/9 14:45	100159.0	46.63	4.1	1199.8
2/9 14:46	101373.0	47.07	4.1	1200.0
2/9 14:47	100752.0	46.78	4.1	1199.7
2/9 14:48	102160.0	47.11	4.1	1199.3
2/9 14:49	99895.0	45.73	4.1	1200.2
2/9 14:50	100895.0	46.19	4.1	1200.2
2/9 14:51	101224.0	46.59	4.1	1201.3
2/9 14:52	102038.0	47.30	4.1	1199.8
2/9 14:53	99263.0	46.09	4.1	1199.7
2/9 14:54	100227.0	46.54	4.1	1200.0

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat: Input mmBtu/hr	(TG-741) Heat: Output mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	1-Min
2/9 14:55	100834.0	46.82	4.1	1199.7	
2/9 14:56	99351.0	46.11	4.1	1200.3	
2/9 14:57	100321.0	46.69	4.1	1200.3	
2/9 14:58	100121.0	46.58	4.1	1200.3	
2/9 14:59	100404.0	46.73	4.1	1199.8	
2/9 15:00	100463.0	46.70	4.1	1199.3	
2/9 15:01	101323.0	47.08	4.1	1199.8	
2/9 15:02	100579.0	46.70	4.1	1199.8	
2/9 15:03	101001.0	46.99	4.1	1200.2	
2/9 15:04	99037.0	46.07	4.1	1200.5	
2/9 15:05	98872.0	46.01	4.1	1200.0	
2/9 15:06	100314.0	46.68	4.1	1200.0	
2/9 15:07	100537.0	46.79	4.1	1200.0	
2/9 15:08	100343.0	46.70	4.1	1199.8	
2/9 15:09	98863.0	45.98	4.1	1200.0	
2/9 15:10	99685.0	46.35	4.1	1200.2	
2/9 15:11	98852.0	45.77	4.1	1199.8	
2/9 15:12	99721.0	46.30	4.1	1200.2	
2/9 15:13	100504.0	46.69	4.1	1200.0	
2/9 15:14	98322.0	45.69	4.1	1199.8	
2/9 15:15	99910.0	46.34	4.1	1199.3	
2/9 15:16	101013.0	46.61	4.1	1199.5	
2/9 15:17	100847.0	46.42	4.1	1200.8	
2/9 15:18	99728.0	46.22	4.1	1200.7	
2/9 15:19	99268.0	46.18	4.1	1200.0	
2/9 15:20	99656.0	46.38	4.1	1200.0	
2/9 15:21	98006.0	45.63	4.1	1200.2	
2/9 15:22	99432.0	46.29	4.1	1199.5	
2/9 15:23	99103.0	46.09	4.1	1199.5	
2/9 15:24	100556.0	46.73	4.1	1199.8	
2/9 15:25	102068.0	47.48	4.1	1199.7	
2/9 15:26	101026.0	47.00	4.1	1200.3	
2/9 15:27	100747.0	46.89	4.1	1200.0	
2/9 15:28	98864.0	46.02	4.1	1200.0	
2/9 15:29	100176.0	46.59	4.1	1199.8	
2/9 15:30	100343.0	46.59	4.1	1199.8	
2/9 15:31	100979.0	46.89	4.1	1200.0	
2/9 15:32	100478.0	46.71	4.1	1200.3	
2/9 15:33	100850.0	46.96	4.1	1200.0	
2/9 15:34	99954.0	46.56	4.1	1199.8	
2/9 15:35	99273.0	46.20	4.1	1199.3	
2/9 15:36	100367.0	46.71	4.1	1200.0	
2/9 15:37	100560.0	46.80	4.1	1200.0	
2/9 15:38	98788.0	45.98	4.1	1200.2	
2/9 15:39	100438.0	46.74	4.1	1200.2	
2/9 15:40	99847.0	46.45	4.1	1199.7	
2/9 15:41	99626.0	46.19	4.1	1199.7	
2/9 15:42	102052.0	47.26	4.1	1199.7	
2/9 15:43	102244.0	47.33	4.1	1200.2	

	(TG-741) Landfill Gas Flow scfh/ 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
2/9 15:44	101386.0	47.08	4.1	1200.2
2/9 15:45	101491.0	47.09	4.1	1200.0
2/9 15:46	100090.0	46.40	4.1	1199.5
2/9 15:47	100943.0	46.50	4.1	1200.0
2/9 15:48	102431.0	47.19	4.1	1200.8
2/9 15:49	101364.0	47.06	4.1	1200.5
2/9 15:50	100350.0	46.70	4.1	1200.0
2/9 15:51	101257.0	47.13	4.1	1199.8
2/9 15:52	100746.0	46.89	4.1	1199.8
2/9 15:53	100055.0	46.51	4.1	1199.5
2/9 15:54	100932.0	46.88	4.1	1200.0
2/9 15:55	100416.0	46.63	4.1	1200.3
2/9 15:56	99867.0	46.37	4.1	1200.5
2/9 15:57	101377.0	47.18	4.1	1200.2
2/9 15:58	98691.0	45.93	4.1	1200.0
2/9 15:59	100996.0	47.01	4.1	1199.8
2/9 16:00	99937.0	46.43	4.1	1199.7
2/9 16:01	99568.0	46.32	4.1	1199.8
2/9 16:02	101453.0	47.21	4.1	1200.0
2/9 16:03	98708.0	46.38	4.1	1199.8
2/9 16:04	100652.0	46.73	4.1	1199.8
2/9 16:05	98748.0	46.18	4.1	1199.3
2/9 16:06	100993.0	46.70	4.1	1200.2
2/9 16:07	100595.0	46.55	4.1	1200.0
2/9 16:08	101043.0	46.75	4.1	1199.8
2/9 16:09	101193.0	46.77	4.1	1200.0
2/9 16:10	102557.0	47.40	4.1	1200.0
2/9 16:11	101044.0	46.70	4.1	1200.2
2/9 16:12	100378.0	46.37	4.1	1199.8
2/9 16:13	100409.0	46.41	4.1	1200.0
2/9 16:14	100464.0	46.43	4.1	1200.2
2/9 16:15	98851.0	46.15	4.1	1200.0
2/9 16:16	102330.0	47.30	4.1	1200.0
2/9 16:17	101791.0	47.07	4.1	1199.8
2/9 16:18	102102.0	47.15	4.1	1199.7
2/9 16:19	102553.0	47.36	4.1	1200.2
2/9 16:20	100880.0	46.53	4.1	1200.2
2/9 16:21	101229.0	46.23	4.1	1200.0
2/9 16:22	103924.0	48.06	4.1	1200.0
2/9 16:23	98891.0	46.17	4.1	1200.3
2/9 16:24	101553.0	46.94	4.1	1200.0
2/9 16:25	100880.0	46.66	4.1	1199.8
2/9 16:26	101229.0	46.76	4.1	1200.0
2/9 16:27	101240.0	46.68	4.1	1200.0
2/9 16:28	103027.0	47.54	4.1	1200.3
2/9 16:29	101514.0	46.92	4.1	1200.0
2/9 16:30	101531.0	46.95	4.1	1200.0
2/9 16:31	101010.0	46.76	4.1	1200.0
2/9 16:32	101082.0	46.75	4.1	1199.8

	(TG-741) Landfill Gas Flow std/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) 1-Min	(TG-741) T7 Exhaust °F	(TG-741) T7 Exhaust 1-Min °F
Timestamp	1-Min	1-Min	Megawatts	1-Min	1-Min	1-Min
2/9/16:33	100622.0	46.51	4.1	1200.0	1199.7	1199.7
2/9/16:34	100251.0	46.28	4.1	1200.7	1200.7	1200.7
2/9/16:35	100792.0	46.47	4.1	1200.0	1200.0	1200.0
2/9/16:36	101075.0	46.72	4.1	1200.2	1200.2	1200.2
2/9/16:37	100823.0	46.60	4.1	1199.5	1199.5	1199.5
2/9/16:38	102344.0	47.30	4.1	1200.0	1200.0	1200.0
2/9/16:39	99926.0	46.19	4.1	1199.7	1199.7	1199.7
2/9/16:40	102326.0	47.30	4.1	1199.8	1199.8	1199.8
2/9/16:41	100468.0	46.35	4.1	1199.8	1199.8	1199.8
2/9/16:42	101139.0	46.64	4.1	1199.8	1199.8	1199.8
2/9/16:43	101727.0	46.91	4.1	1200.2	1200.2	1200.2
2/9/16:44	101675.0	46.88	4.1	1200.3	1200.3	1200.3
2/9/16:45	101469.0	46.86	4.1	1200.0	1200.0	1200.0
2/9/16:46	101940.0	47.12	4.1	1199.8	1199.8	1199.8
2/9/16:47	101356.0	46.76	4.1	1199.7	1199.7	1199.7
2/9/16:48	101823.0	46.95	4.1	1200.0	1200.0	1200.0
2/9/16:49	102571.0	47.30	4.1	1200.0	1200.0	1200.0
2/9/16:50	102222.0	47.13	4.1	1200.2	1200.2	1200.2
2/9/16:51	101464.0	46.80	4.1	1199.8	1199.8	1199.8
2/9/16:52	101264.0	46.61	4.1	1200.2	1200.2	1200.2
2/9/16:53	102274.0	47.14	4.1	1199.3	1199.3	1199.3
2/9/16:54	102562.0	47.32	4.1	1200.3	1200.3	1200.3
2/9/16:55	102851.0	47.65	4.1	1199.7	1199.7	1199.7
2/9/16:56	102170.0	47.22	4.2	1199.7	1199.7	1199.7
2/9/16:57	101603.0	46.99	4.2	1200.7	1200.7	1200.7
2/9/16:58	100149.0	46.48	4.1	1200.0	1200.0	1200.0
2/9/16:59	100243.0	46.54	4.1	1199.7	1199.7	1199.7
2/9/17:00	99867.0	46.26	4.1	1199.5	1199.5	1199.5
2/9/17:01	101110.0	46.76	4.2	1200.2	1200.2	1200.2
2/9/17:02	102159.0	47.25	4.2	1199.8	1199.8	1199.8
2/9/17:03	101786.0	47.08	4.2	1200.3	1200.3	1200.3
2/9/17:04	102149.0	47.33	4.2	1199.8	1199.8	1199.8
2/9/17:05	101511.0	46.92	4.2	1200.0	1200.0	1200.0
2/9/17:06	100470.0	46.46	4.2	1200.2	1200.2	1200.2
2/9/17:07	101116.0	46.77	4.2	1199.8	1199.8	1199.8
2/9/17:08	101247.0	46.91	4.2	1200.0	1200.0	1200.0
2/9/17:09	100814.0	46.71	4.2	1199.3	1199.3	1199.3
2/9/17:10	100529.0	46.50	4.2	1200.0	1200.0	1200.0
2/9/17:11	100919.0	46.65	4.2	1200.2	1200.2	1200.2
2/9/17:12	101396.0	46.87	4.2	1199.8	1199.8	1199.8
2/9/17:13	102190.0	47.23	4.2	1200.3	1200.3	1200.3
2/9/17:14	101060.0	46.71	4.1	1199.3	1199.3	1199.3
2/9/17:15	101634.0	46.75	4.2	1199.2	1199.2	1199.2
2/9/17:16	101121.0	46.34	4.2	1200.2	1200.2	1200.2
2/9/17:17	103093.0	47.44	4.2	1200.3	1200.3	1200.3
2/9/17:18	100236.0	46.35	4.2	1200.2	1200.2	1200.2
2/9/17:19	99964.0	46.25	4.1	1200.0	1200.0	1200.0
2/9/17:20	100910.0	46.75	4.2	1199.8	1199.8	1199.8
2/9/17:21	102880.0	47.57	4.2	1200.0	1200.0	1200.0

	(TG-741) Landfill Gas Flow scfh/r	(TG-741) Heat: Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	°F 1-Min
2/9 17:22	100436.0	48.42	4.2	4.2	1200.0
2/9 17:23	102686.0	47.48	4.2	4.2	1200.2
2/9 17:24	101245.0	46.85	4.2	4.2	1200.0
2/9 17:25	102750.0	47.62	4.2	4.2	1200.0
2/9 17:26	100661.0	46.61	4.2	4.2	1200.0
2/9 17:27	100738.0	46.58	4.2	4.2	1200.0
2/9 17:28	101788.0	47.05	4.2	4.2	1199.8
2/9 17:29	102559.0	47.36	4.2	4.2	1200.0
2/9 17:30	103627.0	47.86	4.2	4.2	1200.0
2/9 17:31	104803.0	48.41	4.2	4.2	1200.2
2/9 17:32	101200.0	46.77	4.2	4.2	1200.0
2/9 17:33	101748.0	47.08	4.2	4.2	1200.0
2/9 17:34	103226.0	47.74	4.2	4.2	1200.2
2/9 17:35	100292.0	46.37	4.2	4.2	1200.0
2/9 17:36	103655.0	47.93	4.2	4.2	1199.8
2/9 17:37	101802.0	47.05	4.2	4.2	1200.0
2/9 17:38	102355.0	47.21	4.2	4.2	1200.0
2/9 17:39	102974.0	47.53	4.2	4.2	1199.8
2/9 17:40	100561.0	46.40	4.2	4.2	1200.3
2/9 17:41	101519.0	46.97	4.2	4.2	1200.2
2/9 17:42	102086.0	47.19	4.2	4.2	1200.0
2/9 17:43	101714.0	47.04	4.2	4.2	1199.8
2/9 17:44	101386.0	46.86	4.2	4.2	1200.2
2/9 17:45	101487.0	46.88	4.2	4.2	1200.0
2/9 17:46	103035.0	47.63	4.2	4.2	1200.0
2/9 17:47	99903.0	46.13	4.2	4.2	1199.8
2/9 17:48	99566.0	45.80	4.2	4.2	1200.3
2/9 17:49	100653.0	46.41	4.2	4.2	1200.2
2/9 17:50	101255.0	46.80	4.2	4.2	1200.0
2/9 17:51	102132.0	47.17	4.2	4.2	1199.8
2/9 17:52	103786.0	47.91	4.2	4.2	1199.8
2/9 17:53	101504.0	46.85	4.2	4.2	1200.0
2/9 17:54	101581.0	46.95	4.2	4.2	1200.2
2/9 17:55	102276.0	47.36	4.2	4.2	1200.3
2/9 17:56	103316.0	47.87	4.2	4.2	1199.8
2/9 17:57	102196.0	47.26	4.2	4.2	1200.2
2/9 18:03	103162.0	46.82	4.2	4.2	1199.8
2/9 18:04	101889.0	47.78	4.2	4.2	1199.8
2/9 18:05	102550.0	47.40	4.2	4.2	1200.2
2/9 18:06	101592.0	46.95	4.2	4.2	1200.0
2/9 18:07	100969.0	46.56	4.2	4.2	1200.3
2/9 18:08	102028.0	47.16	4.2	4.2	1199.8
2/9 18:09	102636.0	47.38	4.2	4.2	1200.3
2/9 18:10	103281.0	47.64	4.2	4.2	1200.0

	(TG-741) Landfill Gas Flow scf/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
2/9 18:11	101385.0	46.77	4.2	1200.0
2/9 18:12	103717.0	47.86	4.2	1200.3
2/9 18:13	102556.0	47.32	4.2	1199.5
2/9 18:14	103614.0	47.81	4.2	1199.8
2/9 18:15	102170.0	47.11	4.2	1200.0
2/9 18:16	101208.0	46.70	4.2	1200.0
2/9 18:17	102503.0	47.22	4.2	1200.0
2/9 18:18	100523.0	46.27	4.2	1200.0
2/9 18:19	101265.0	46.70	4.2	1199.8
2/9 18:20	102296.0	47.11	4.2	1200.2
2/9 18:21	103768.0	47.85	4.2	1200.2
2/9 18:22	102135.0	47.10	4.2	1200.0
2/9 18:23	102656.0	47.34	4.2	1199.8
2/9 18:24	102301.0	47.17	4.2	1200.0
2/9 18:25	103375.0	47.63	4.2	1200.0
2/9 18:26	101275.0	46.59	4.2	1200.3
2/9 18:27	101723.0	46.79	4.2	1200.0
2/9 18:28	102982.0	47.42	4.2	1200.2
2/9 18:29	102336.0	47.15	4.2	1200.0
2/9 18:30	100591.0	46.36	4.2	1200.0
2/9 18:31	102421.0	47.23	4.2	1200.0
2/9 18:32	101458.0	46.78	4.2	1200.0
2/9 18:33	102527.0	47.24	4.2	1200.0
2/9 18:34	104514.0	48.11	4.2	1200.0
2/9 18:35	101833.0	46.84	4.2	1200.0
2/9 18:36	101885.0	46.89	4.2	1200.2
2/9 18:37	102715.0	47.28	4.2	1200.0
2/9 18:38	101455.0	46.76	4.2	1199.7
2/9 18:39	102299.0	47.11	4.2	1200.0
2/9 18:40	101650.0	46.76	4.2	1200.0
2/9 18:41	101880.0	46.86	4.2	1199.8
2/9 18:42	102655.0	47.22	4.2	1200.0
2/9 18:43	103700.0	47.70	4.2	1200.2
2/9 18:44	102264.0	47.13	4.2	1200.0
2/9 18:45	101917.0	47.00	4.2	1199.7
2/9 18:46	102033.0	47.01	4.2	1199.8
2/9 18:47	103363.0	47.55	4.2	1200.0
2/9 18:48	101323.0	46.61	4.2	1200.0
2/9 18:49	101210.0	46.54	4.2	1200.2
2/9 18:50	101746.0	46.81	4.2	1200.0
2/9 18:51	102751.0	47.27	4.2	1200.0
2/9 18:52	104485.0	48.09	4.2	1200.0
2/9 18:53	102847.0	47.31	4.2	1199.8
2/9 18:54	102857.0	47.32	4.2	1199.8
2/9 18:55	101324.0	46.61	4.2	1200.3
2/9 18:56	101625.0	46.78	4.2	1200.0
2/9 18:57	103343.0	47.61	4.2	1200.0
2/9 18:58	103241.0	47.49	4.2	1200.0
2/9 18:59	102837.0	47.31	4.2	1200.0

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/9 19:00	101940.0	46.86	4.2	1200.0
Average (all)	101447.7	46.92	4.1	1200.0
Total (all)	--	--	--	--
Minimum (all)	38006.0	45.63	4.1	1198.3
Maximum (all)	109254.0	48.45	4.2	1202.0
Average (valid values only)	101447.7	46.92	4.1	1200.0
Total (valid values only)	--	--	--	--
Count (valid values only)	781	781	781	781

CeDAR 1-Minute Data
Sunshine Gas Producers, LLC
Data for 2/10/2023 6:00 AM thru 2/10/2023 7:00 PM

(TG-741)		(TG-741) Heat Input mmBtu/hr		(TG-741) Megawatts 1-Min		(TG-741) T7 Exhaust Temp °F 1-Min	
Timestamp	Landfill Gas Flow scfhhr	1-Min	1-Min	1-Min	1-Min	1-Min	1-Min
2/10/6:00	102370.0	47.53		4.2		1200.0	
2/10/6:01	102298.0	47.50		4.2		1200.0	
2/10/6:02	104187.0	48.38		4.2		1200.2	
2/10/6:03	100569.0	46.69		4.2		1199.5	
2/10/6:04	103255.0	47.97		4.2		1199.8	
2/10/6:05	103452.0	48.11		4.2		1200.2	
2/10/6:06	101105.0	47.06		4.2		1200.0	
2/10/6:07	104217.0	48.50		4.2		1200.0	
2/10/6:08	103430.0	48.06		4.2		1200.0	
2/10/6:09	101361.0	47.06		4.2		1200.0	
2/10/6:10	100999.0	47.01		4.2		1200.2	
2/10/6:11	103633.0	48.21		4.2		1200.0	
2/10/6:12	103179.0	48.00		4.2		1199.8	
2/10/6:13	103905.0	48.31		4.2		1200.0	
2/10/6:14	102080.0	47.46		4.2		1199.8	
2/10/6:15	102474.0	47.61		4.2		1200.0	
2/10/6:16	103146.0	48.17		4.2		1200.0	
2/10/6:17	102503.0	47.59		4.2		1200.0	
2/10/6:18	102912.0	47.76		4.2		1199.5	
2/10/6:19	101202.0	46.99		4.2		1200.3	
2/10/6:20	102741.0	47.67		4.2		1200.0	
2/10/6:21	103298.0	47.96		4.2		1199.7	
2/10/6:22	102962.0	47.80		4.2		1199.8	
2/10/6:23	103744.0	48.17		4.2		1200.0	
2/10/6:24	103708.0	48.18		4.2		1200.0	
2/10/6:25	104212.0	48.38		4.2		1200.0	
2/10/6:26	103270.0	47.88		4.2		1200.0	
2/10/6:27	104315.0	48.33		4.2		1199.8	
2/10/6:28	101572.0	47.06		4.2		1200.2	
2/10/6:29	104055.0	48.21		4.2		1200.0	
2/10/6:30	103988.0	48.23		4.2		1200.2	
2/10/6:31	101739.0	47.24		4.2		1199.8	
2/10/6:32	104269.0	48.41		4.2		1200.0	
2/10/6:33	103003.0	47.98		4.2		1199.8	
2/10/6:34	103065.0	47.52		4.2		1200.3	
2/10/6:35	104180.0	48.49		4.2		1200.3	
2/10/6:36	100894.0	46.95		4.2		1200.0	
2/10/6:37	102229.0	47.53		4.2		1200.2	
2/10/6:38	103003.0	47.91		4.2		1199.8	
2/10/6:39	103065.0	47.89		4.2		1200.3	
2/10/6:40	104180.0	48.49		4.2		1200.3	
2/10/6:41	102258.0	47.54		4.2		1200.7	
2/10/6:42	102401.0	47.58		4.2		1199.7	
2/10/6:43	101660.0	47.20		4.2		1200.2	
2/10/6:44	100885.0	46.82		4.2		1200.0	

	(TG-741) Landfill Gas Flow scfhhr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/10/6:45	103549.0	48.03	4.2	1200.2
2/10/6:46	102961.0	47.73	4.2	1200.2
2/10/6:47	101609.0	47.18	4.2	1200.2
2/10/6:48	103012.0	47.76	4.2	1200.2
2/10/6:49	102508.0	47.60	4.2	1200.2
2/10/6:50	102136.0	47.40	4.2	1200.2
2/10/6:51	102214.0	47.37	4.2	1199.7
2/10/6:52	102140.0	47.32	4.2	1200.0
2/10/6:53	104148.0	48.27	4.2	1200.0
2/10/6:54	103371.0	47.99	4.2	1200.0
2/10/6:55	101498.0	47.05	4.2	1200.0
2/10/6:56	104687.0	48.50	4.2	1200.0
2/10/6:57	102571.0	47.52	4.2	1200.5
2/10/6:58	103824.0	48.20	4.2	1200.0
2/10/6:59	100627.0	46.72	4.2	1200.0
2/10/7:00	102230.0	47.38	4.2	1199.8
2/10/7:01	102471.0	47.47	4.1	1200.0
2/10/7:02	103377.0	47.83	4.1	1200.2
2/10/7:03	101148.0	46.82	4.1	1200.2
2/10/7:04	101524.0	46.99	4.2	1199.8
2/10/7:05	101175.0	46.77	4.2	1199.8
2/10/7:06	102479.0	47.37	4.2	1200.0
2/10/7:07	102359.0	47.31	4.2	1200.0
2/10/7:08	102570.0	47.41	4.2	1200.0
2/10/7:09	102473.0	47.41	4.2	1200.2
2/10/7:10	101017.0	46.87	4.2	1200.5
2/10/7:11	101746.0	47.27	4.2	1200.2
2/10/7:12	104011.0	48.39	4.2	1200.0
2/10/7:13	101546.0	47.26	4.2	1200.0
2/10/7:14	104098.0	48.43	4.2	1200.0
2/10/7:15	103296.0	48.00	4.2	1200.2
2/10/7:16	101512.0	47.11	4.2	1199.5
2/10/7:17	104813.0	48.41	4.2	1200.0
2/10/7:18	102903.0	47.56	4.2	1200.0
2/10/7:19	104410.0	48.33	4.2	1200.0
2/10/7:20	102421.0	47.41	4.2	1199.8
2/10/7:21	103319.0	47.84	4.2	1199.8
2/10/7:22	103641.0	48.02	4.2	1200.2
2/10/7:23	104183.0	48.29	4.2	1199.7
2/10/7:24	102593.0	47.55	4.2	1200.0
2/10/7:25	103748.0	48.12	4.2	1200.0
2/10/7:26	103567.0	48.07	4.2	1199.8
2/10/7:27	102894.0	47.77	4.2	1200.2
2/10/7:28	103837.0	48.21	4.2	1200.0
2/10/7:29	102262.0	47.48	4.2	1200.0
2/10/7:30	103056.0	47.77	4.2	1199.8
2/10/7:31	101828.0	47.20	4.2	1200.2
2/10/7:32	101841.0	47.18	4.2	1200.0
2/10/7:33	102727.0	47.59	4.2	1199.7

	(TG-741) Landfill Gas Flow sd/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust °F	(TG-741) T7 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	°F	1-Min
2/10/7:34	103646.0	47.93	4.2	1200.3		
2/10/7:35	103181.0	47.80	4.2	1199.8		
2/10/7:36	102764.0	47.57	4.2	1200.2		
2/10/7:37	101444.0	47.00	4.2	1200.0		
2/10/7:38	103624.0	48.01	4.2	1200.0		
2/10/7:39	103916.0	48.15	4.2	1199.8		
2/10/7:40	103096.0	47.68	4.2	1199.8		
2/10/7:41	102380.0	47.32	4.2	1199.8		
2/10/7:42	104020.0	48.08	4.2	1200.0		
2/10/7:43	104029.0	48.08	4.2	1200.2		
2/10/7:44	105675.0	48.88	4.2	1200.0		
2/10/7:45	103660.0	47.98	4.2	1200.0		
2/10/7:46	101346.0	46.86	4.2	1200.0		
2/10/7:47	104757.0	48.50	4.2	1200.2		
2/10/7:48	101565.0	46.95	4.2	1200.3		
2/10/7:49	102240.0	47.26	4.2	1200.0		
2/10/7:50	103326.0	47.78	4.2	1200.2		
2/10/7:51	103394.0	47.87	4.2	1199.8		
2/10/7:52	102698.0	47.43	4.2	1200.2		
2/10/7:53	103869.0	47.89	4.2	1199.7		
2/10/7:54	103689.0	47.70	4.2	1200.0		
2/10/7:55	103913.0	47.85	4.2	1200.2		
2/10/7:56	103097.0	47.57	4.2	1200.5		
2/10/7:57	102213.0	47.24	4.2	1200.2		
2/10/7:58	104138.0	48.09	4.2	1199.7		
2/10/7:59	102580.0	47.24	4.2	1199.7		
2/10/8:00	102808.0	47.29	4.2	1200.3		
2/10/8:01	103037.0	47.38	4.2	1200.0		
2/10/8:02	103838.0	47.77	4.2	1200.3		
2/10/8:03	103343.0	47.56	4.2	1200.0		
2/10/8:04	104644.0	48.25	4.2	1200.0		
2/10/8:05	103632.0	47.78	4.2	1200.0		
2/10/8:06	104729.0	48.29	4.2	1200.2		
2/10/8:07	103827.0	47.88	4.2	1200.0		
2/10/8:08	103520.0	47.73	4.2	1200.0		
2/10/8:09	103120.0	47.55	4.2	1199.8		
2/10/8:10	103417.0	47.62	4.2	1200.2		
2/10/8:11	102996.0	47.43	4.2	1200.0		
2/10/8:12	104543.0	48.20	4.2	1200.0		
2/10/8:13	104247.0	47.99	4.2	1200.2		
2/10/8:14	104685.0	48.16	4.2	1200.0		
2/10/8:15	103647.0	47.68	4.2	1200.5		
2/10/8:16	102498.0	47.20	4.2	1200.2		
2/10/8:17	102650.0	47.33	4.2	1200.2		
2/10/8:18	103616.0	47.85	4.2	1199.8		
2/10/8:19	103289.0	47.63	4.2	1200.0		
2/10/8:20	101447.0	46.80	4.2	1199.8		
2/10/8:21	103367.0	47.68	4.2	1200.0		
2/10/8:22	102432.0	47.23	4.2	1200.2		

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust °F 1-Min
Timestamp	1-Min	1-Min	Megawatts 1-Min	°F 1-Min
2/10 8:23	102846.0	47.42	4.2	1200.0
2/10 8:24	104616.0	48.24	4.2	1200.2
2/10 8:25	102464.0	47.22	4.2	1199.3
2/10 8:26	105926.0	48.61	4.2	1200.0
2/10 8:27	104355.0	47.80	4.2	1200.0
2/10 8:28	105339.0	48.22	4.2	1200.2
2/10 8:29	102711.0	47.07	4.2	1200.0
2/10 8:30	103369.0	47.41	4.2	1200.0
2/10 8:31	102899.0	47.27	4.2	1199.8
2/10 8:32	103848.0	47.63	4.2	1199.8
2/10 8:33	103182.0	47.33	4.2	1200.0
2/10 8:34	104224.0	47.85	4.2	1200.2
2/10 8:35	103795.0	47.75	4.2	1200.2
2/10 8:36	101750.0	46.81	4.2	1200.0
2/10 8:37	105177.0	48.41	4.2	1200.3
2/10 8:38	101902.0	46.99	4.2	1200.2
2/10 8:39	105172.0	48.47	4.2	1200.2
2/10 8:40	104435.0	48.07	4.2	1200.0
2/10 8:41	103085.0	47.53	4.2	1200.0
2/10 8:42	101956.0	47.01	4.2	1200.0
2/10 8:43	102757.0	47.41	4.2	1200.0
2/10 8:44	103581.0	47.87	4.2	1199.8
2/10 8:45	103349.0	47.77	4.2	1199.8
2/10 8:46	103222.0	47.76	4.2	1200.0
2/10 8:47	102887.0	47.56	4.2	1200.0
2/10 8:48	103620.0	47.94	4.2	1200.0
2/10 8:49	102490.0	47.37	4.2	1200.0
2/10 8:50	102495.0	47.38	4.2	1199.7
2/10 8:51	101641.0	46.98	4.2	1200.2
2/10 8:52	104775.0	48.45	4.2	1199.8
2/10 8:53	101110.0	46.75	4.2	1200.3
2/10 8:54	101293.0	46.93	4.2	1200.0
2/10 8:55	101447.0	46.92	4.2	1199.8
2/10 8:56	102274.0	47.30	4.2	1199.7
2/10 8:57	99796.0	46.07	4.2	1200.5
2/10 8:58	103002.0	47.61	4.2	1200.3
2/10 8:59	102046.0	47.24	4.2	1200.0
2/10 9:00	102166.0	47.24	4.2	1200.3
2/10 9:01	99770.0	46.18	4.2	1199.8
2/10 9:02	102560.0	47.52	4.2	1200.2
2/10 9:03	104576.0	48.39	4.2	1200.2
2/10 9:04	102714.0	47.55	4.2	1200.2
2/10 9:05	102135.0	47.32	4.2	1200.0
2/10 9:06	101847.0	47.10	4.2	1200.0
2/10 9:07	100787.0	46.59	4.2	1199.8
2/10 9:08	102402.0	47.33	4.2	1199.7
2/10 9:09	101746.0	47.00	4.2	1199.8
2/10 9:10	100812.0	46.53	4.2	1200.2
2/10 9:11	102174.0	47.18	4.2	1200.0

Page 4 of 17

Cedar 5 Reports 3/8/2023 6:42 AM, CeDAR 1-Minute Data

	(TG-741) Landfill Gas Flow-sf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/10/9:12	100780.0	46.54	4.2	1200.0
2/10/9:13	101779.0	47.04	4.2	1200.0
2/10/9:14	100137.0	46.33	4.2	1200.2
2/10/9:15	102480.0	47.48	4.2	1200.0
2/10/9:16	103211.0	47.76	4.2	1200.0
2/10/9:17	103043.0	47.65	4.2	1199.7
2/10/9:18	102310.0	47.25	4.2	1199.7
2/10/9:19	103624.0	47.86	4.2	1200.3
2/10/9:20	101431.0	46.85	4.2	1200.7
2/10/9:21	101546.0	46.97	4.2	1200.0
2/10/9:22	101215.0	46.78	4.2	1200.0
2/10/9:23	101769.0	47.04	4.2	1200.0
2/10/9:24	104334.0	48.22	4.2	1200.0
2/10/9:25	100716.0	46.55	4.2	1200.0
2/10/9:26	102397.0	47.33	4.1	1200.0
2/10/9:27	102322.0	47.18	4.2	1200.2
2/10/9:28	103630.0	47.74	4.1	1200.0
2/10/9:29	101402.0	46.76	4.2	1200.0
2/10/9:30	103124.0	47.63	4.2	1200.2
2/10/9:31	101746.0	47.03	4.2	1200.3
2/10/9:32	102815.0	47.52	4.2	1200.0
2/10/9:33	101776.0	47.04	4.1	1200.0
2/10/9:34	102767.0	47.44	4.1	1200.0
2/10/9:35	101634.0	46.86	4.1	1199.8
2/10/9:36	100733.0	46.52	4.1	1200.0
2/10/9:37	102471.0	47.38	4.1	1200.0
2/10/9:38	101427.0	46.91	4.2	1200.0
2/10/9:39	101378.0	46.86	4.2	1199.7
2/10/9:40	102041.0	47.16	4.2	1200.3
2/10/9:41	102833.0	47.41	4.2	1199.8
2/10/9:42	102144.0	47.04	4.2	1200.0
2/10/9:43	101186.0	46.64	4.2	1200.2
2/10/9:44	100405.0	46.33	4.2	1200.5
2/10/9:45	101333.0	46.83	4.1	1200.0
2/10/9:46	100516.0	46.40	4.2	1199.8
2/10/9:47	101922.0	47.08	4.1	1200.0
2/10/9:48	103286.0	47.63	4.1	1199.5
2/10/9:49	103218.0	47.51	4.2	1199.7
2/10/9:50	102109.0	47.38	4.1	1200.2
2/10/9:55	100745.0	46.86	4.1	1200.2
2/10/9:56	102330.0	47.18	4.1	1200.2
2/10/9:57	100493.0	46.45	4.1	1200.0
2/10/9:58	100013.0	47.05	4.1	1199.8
2/10/9:59	100774.0	46.47	4.1	1200.2
2/10/10:00	101163.0	46.76	4.1	1200.2

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	°F 1-Min
2/10 10:01	102462.0	47.24	4.1	1199.8	
2/10 10:02	102724.0	47.36	4.1	1199.8	
2/10 10:03	101902.0	46.99	4.1	1200.2	
2/10 10:04	102231.0	47.14	4.2	1199.8	
2/10 10:05	101826.0	46.95	4.2	1200.0	
2/10 10:06	102870.0	47.43	4.1	1200.2	
2/10 10:07	101692.0	46.91	4.1	1200.0	
2/10 10:08	102225.0	47.22	4.1	1200.2	
2/10 10:09	101423.0	46.88	4.1	1199.7	
2/10 10:10	103175.0	47.60	4.1	1199.8	
2/10 10:11	101650.0	46.92	4.1	1200.0	
2/10 10:12	101427.0	46.79	4.1	1200.3	
2/10 10:13	101929.0	47.00	4.1	1200.0	
2/10 10:14	103213.0	47.61	4.1	1200.0	
2/10 10:15	100086.0	46.15	4.1	1200.0	
2/10 10:16	102452.0	47.24	4.1	1200.2	
2/10 10:17	102206.0	47.13	4.1	1200.3	
2/10 10:18	101115.0	46.65	4.1	1199.8	
2/10 10:19	102941.0	47.54	4.1	1200.2	
2/10 10:20	102256.0	47.26	4.1	1199.7	
2/10 10:21	99926.0	46.19	4.1	1200.0	
2/10 10:22	101222.0	46.74	4.1	1199.7	
2/10 10:23	101044.0	46.61	4.1	1200.0	
2/10 10:24	101754.0	46.97	4.1	1200.2	
2/10 10:25	101123.0	46.76	4.1	1199.7	
2/10 10:26	101866.0	47.20	4.1	1200.3	
2/10 10:27	102302.0	47.50	4.1	1199.2	
2/10 10:28	101763.0	46.79	4.1	1199.0	
2/10 10:29	102812.0	46.95	4.2	1199.8	
2/10 10:30	104137.0	47.39	4.2	1200.7	
2/10 10:31	102948.0	47.00	4.2	1200.3	
2/10 10:32	102680.0	47.01	4.1	1200.2	
2/10 10:33	103424.0	47.46	4.1	1200.2	
2/10 10:34	100699.0	46.21	4.1	1199.8	
2/10 10:35	103029.0	47.28	4.1	1200.0	
2/10 10:36	102205.0	46.90	4.1	1200.7	
2/10 10:37	101744.0	46.87	4.1	1200.5	
2/10 10:38	101320.0	46.96	4.1	1200.7	
2/10 10:39	100636.0	46.76	4.1	1199.7	
2/10 10:40	101418.0	47.09	4.1	1199.7	
2/10 10:41	100664.0	46.74	4.1	1200.2	
2/10 10:42	101394.0	47.08	4.1	1200.2	
2/10 10:43	102021.0	47.46	4.1	1200.5	
2/10 10:44	100790.0	46.88	4.1	1200.0	
2/10 10:45	101197.0	47.03	4.1	1200.0	
2/10 10:46	99635.0	46.30	4.1	1200.7	
2/10 10:47	98221.0	46.07	4.1	1199.7	
2/10 10:48	101120.0	46.98	4.1	1200.0	
2/10 10:49	100221.0	46.53	4.1	1200.0	

Cedar 5 Reports 3/8/2023 6:42 AM, CeDAR 1-Minute Data

Page 6 of 17

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/10 10:50	99871.0	46.37	4.1	1200.0
2/10 10:51	102348.0	47.56	4.1	1200.0
2/10 10:52	101742.0	47.32	4.1	1199.7
2/10 10:53	100811.0	46.81	4.1	1200.0
2/10 10:54	99921.0	46.47	4.1	1199.7
2/10 10:55	100567.0	46.78	4.1	1200.2
2/10 10:56	102726.0	47.83	4.1	1200.0
2/10 10:57	100210.0	46.64	4.1	1200.0
2/10 10:58	101159.0	47.08	4.1	1200.0
2/10 10:59	99290.0	46.23	4.1	1200.3
2/10 11:00	100930.0	47.01	4.1	1200.0
2/10 11:01	100272.0	46.78	4.1	1200.3
2/10 11:02	100377.0	46.83	4.1	1200.0
2/10 11:03	99857.0	46.58	4.1	1200.0
2/10 11:04	101132.0	47.16	4.1	1199.7
2/10 11:05	99617.0	46.36	4.1	1200.0
2/10 11:06	98498.0	45.84	4.1	1200.0
2/10 11:07	99384.0	46.25	4.1	1200.0
2/10 11:08	99891.0	46.51	4.1	1200.0
2/10 11:09	99516.0	46.41	4.1	1199.7
2/10 11:10	99214.0	46.24	4.1	1200.2
2/10 11:11	100219.0	46.75	4.1	1200.0
2/10 11:12	99200.0	46.28	4.1	1200.0
2/10 11:13	100060.0	46.68	4.1	1200.0
2/10 11:14	102059.0	47.61	4.1	1200.0
2/10 11:15	99787.0	46.48	4.1	1199.8
2/10 11:16	101208.0	47.16	4.1	1200.0
2/10 11:17	100423.0	46.85	4.1	1199.8
2/10 11:18	99972.0	46.70	4.1	1200.0
2/10 11:19	101138.0	47.29	4.1	1200.0
2/10 11:20	100240.0	46.84	4.1	1200.0
2/10 11:21	99746.0	46.61	4.1	1200.2
2/10 11:22	100881.0	47.08	4.1	1199.8
2/10 11:23	101727.0	47.52	4.1	1200.0
2/10 11:24	101260.0	47.41	4.1	1200.5
2/10 11:25	100911.0	47.30	4.1	1200.0
2/10 11:26	100640.0	47.15	4.1	1200.0
2/10 11:27	100117.0	46.88	4.1	1200.0
2/10 11:28	98581.0	46.10	4.1	1199.8
2/10 11:29	101376.0	47.41	4.1	1199.7
2/10 11:30	99702.0	46.62	4.1	1199.8
2/10 11:31	99689.0	46.63	4.1	1200.2
2/10 11:32	101207.0	47.33	4.1	1200.2
2/10 11:33	100600.0	47.04	4.1	1200.0
2/10 11:34	99611.0	46.58	4.1	1200.2
2/10 11:35	100814.0	47.12	4.1	1200.0
2/10 11:36	100490.0	46.97	4.1	1200.2
2/10 11:37	99490.0	46.52	4.1	1199.8
2/10 11:38	99598.0	46.65	4.1	1200.0

	(TG-741) Landfill Gas Flow scfh/r	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	4.1	1200.2
2/10/11:39	100619.0	47.08	4.1	1200.0
2/10/11:40	100679.0	46.82	4.1	1200.0
2/10/11:41	97748.0	45.82	4.1	1200.0
2/10/11:42	99361.0	46.57	4.1	1200.0
2/10/11:43	99804.0	46.82	4.1	1200.0
2/10/11:44	99928.0	46.81	4.1	1200.0
2/10/11:45	99501.0	46.61	4.1	1200.2
2/10/11:46	99268.0	46.51	4.1	1200.0
2/10/11:47	98159.0	46.01	4.1	1200.2
2/10/11:48	98644.0	46.25	4.1	1200.0
2/10/11:49	102120.0	47.86	4.1	1200.0
2/10/11:50	100816.0	47.25	4.1	1200.0
2/10/11:51	100403.0	47.06	4.1	1199.8
2/10/11:52	100062.0	46.82	4.1	1200.3
2/10/11:53	101769.0	47.70	4.1	1200.3
2/10/11:54	99113.0	46.47	4.1	1200.2
2/10/11:55	100057.0	47.01	4.1	1200.0
2/10/11:56	100074.0	47.01	4.1	1200.2
2/10/11:57	100275.0	47.11	4.1	1199.5
2/10/11:58	100872.0	47.36	4.1	1200.2
2/10/11:59	99950.0	46.82	4.1	1199.8
2/10/12:00	99853.0	46.75	4.1	1200.5
2/10/12:01	99894.0	46.87	4.1	1200.2
2/10/12:02	99989.0	47.01	4.1	1200.2
2/10/12:03	100134.0	47.13	4.1	1200.0
2/10/12:04	100297.0	47.12	4.1	1199.8
2/10/12:05	98735.0	46.36	4.1	1199.8
2/10/12:06	99242.0	46.49	4.1	1199.8
2/10/12:07	99702.0	46.68	4.1	1200.2
2/10/12:08	99803.0	46.78	4.1	1200.3
2/10/12:09	99402.0	46.68	4.1	1200.2
2/10/12:10	100071.0	47.01	4.1	1199.8
2/10/12:11	100625.0	47.28	4.1	1200.0
2/10/12:12	98951.0	46.47	4.1	1199.8
2/10/12:13	100663.0	47.18	4.1	1200.0
2/10/12:14	98512.0	46.28	4.1	1200.0
2/10/12:15	100354.0	47.14	4.1	1200.0
2/10/12:16	99863.0	46.68	4.1	1200.0
2/10/12:17	101053.0	47.45	4.1	1200.5
2/10/12:18	100316.0	47.13	4.1	1199.7
2/10/12:19	97803.0	45.95	4.1	1200.0
2/10/12:20	100543.0	47.26	4.1	1200.2
2/10/12:21	98931.0	46.53	4.1	1200.0
2/10/12:22	99007.0	46.56	4.1	1200.0
2/10/12:23	99159.0	46.62	4.1	1200.0
2/10/12:24	100890.0	47.42	4.1	1199.8
2/10/12:25	100954.0	47.43	4.1	1199.8
2/10/12:26	100356.0	47.15	4.1	1200.0
2/10/12:27	101495.0	47.68	4.1	1200.2
Average Run 6	101773.4	47.1	4.1	1200.0

W002AS-023392-RT-4542

550 of 688

	(TG-741) Landfill Gas Flow scfh/hr	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust °F 1-Min
Timestamp					
2/10/12:28	99580.0	46.78	4.1	1200.2	
2/10/12:29	99259.0	46.72	4.1	1200.3	
2/10/12:30	100573.0	47.33	4.1	1200.0	
2/10/12:31	98928.0	46.57	4.1	1200.0	
2/10/12:32	100110.0	47.14	4.1	1200.2	
2/10/12:33	100239.0	47.20	4.1	1200.0	
2/10/12:34	100086.0	47.11	4.1	1199.7	
2/10/12:35	99613.0	46.91	4.1	1200.5	
2/10/12:36	98823.0	46.53	4.1	1200.0	
2/10/12:37	97762.0	46.12	4.1	1200.2	
2/10/12:38	100175.0	47.17	4.1	1199.8	
2/10/12:39	99405.0	46.84	4.1	1200.2	
2/10/12:40	100731.0	47.43	4.1	1199.7	
2/10/12:41	99786.0	46.96	4.1	1200.0	
2/10/12:42	98340.0	46.22	4.1	1200.0	
2/10/12:43	100016.0	47.01	4.1	1200.0	
2/10/12:44	99908.0	47.05	4.1	1200.3	
2/10/12:45	99221.0	46.72	4.1	1199.5	
2/10/12:46	99653.0	46.93	4.1	1200.2	
2/10/12:47	98463.0	46.34	4.1	1199.8	
2/10/12:48	99955.0	46.99	4.1	1200.2	
2/10/12:49	97700.0	46.01	4.1	1200.3	
2/10/12:50	98265.0	46.28	4.1	1200.0	
2/10/12:51	100576.0	47.34	4.1	1199.5	
2/10/12:52	97680.0	45.80	4.1	1200.2	
2/10/12:53	99214.0	46.66	4.1	1200.7	
2/10/12:54	100752.0	47.44	4.1	1199.8	
2/10/12:55	100075.0	47.13	4.1	1200.3	
2/10/12:56	100484.0	47.32	4.1	1200.0	
2/10/12:57	99080.0	46.68	4.1	1200.0	
2/10/12:58	98446.0	46.36	4.1	1200.0	
2/10/12:59	99293.0	46.76	4.1	1200.0	
2/10/13:00	99924.0	47.05	4.1	1199.8	
2/10/13:01	100245.0	47.21	4.1	1200.2	
2/10/13:02	97875.0	46.12	4.1	1200.0	
2/10/13:03	99702.0	46.98	4.1	1200.0	
2/10/13:04	98849.0	46.60	4.1	1200.0	
2/10/13:05	99109.0	46.76	4.1	1199.8	
2/10/13:06	98720.0	46.49	4.1	1200.0	
2/10/13:07	98398.0	46.36	4.1	1200.0	
2/10/13:08	99021.0	46.63	4.1	1200.0	
2/10/13:09	98458.0	46.47	4.1	1200.0	
2/10/13:10	99568.0	47.00	4.1	1200.0	
2/10/13:11	99442.0	46.94	4.1	1200.0	
2/10/13:12	98357.0	46.88	4.1	1200.0	
2/10/13:13	98570.0	46.86	4.1	1200.0	
2/10/13:14	97059.0	45.65	4.1	1200.2	
2/10/13:15	100405.0	47.33	4.1	1200.2	
2/10/13:16	100372.0	47.37	4.1	1200.0	

	(TG-741) Landfill Gas Flow scfh/r 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp				
2/10 13:17	99872.0	47.14	4.1	1200.0
2/10 13:18	97354.0	45.95	4.1	1200.2
2/10 13:19	99831.0	47.08	4.1	1200.0
2/10 13:20	98567.0	46.53	4.1	1200.0
2/10 13:21	100482.0	47.43	4.1	1200.0
2/10 13:22	100204.0	47.32	4.1	1199.8
2/10 13:23	99706.0	47.06	4.1	1199.7
2/10 13:24	97755.0	46.15	4.1	1200.0
2/10 13:25	98074.0	46.23	4.1	1200.0
2/10 13:26	97523.0	46.03	4.1	1199.8
2/10 13:27	100970.0	47.66	4.1	1200.0
2/10 13:28	98215.0	46.36	4.1	1200.2
2/10 13:29	98583.0	46.51	4.1	1200.0
2/10 13:30	99812.0	47.09	4.1	1200.0
2/10 13:31	99309.0	46.83	4.1	1200.0
2/10 13:32	98385.0	46.44	4.1	1200.0
2/10 13:33	98366.0	46.32	4.1	1200.0
2/10 13:34	98415.0	46.43	4.1	1200.0
2/10 13:35	99941.0	47.17	4.1	1199.8
2/10 13:36	97685.0	46.03	4.1	1199.8
2/10 13:37	99006.0	46.62	4.1	1200.0
2/10 13:38	98493.0	46.45	4.1	1200.0
2/10 13:39	98623.0	46.55	4.1	1200.0
2/10 13:40	98387.0	46.44	4.1	1200.2
2/10 13:41	99412.0	46.92	4.1	1199.7
2/10 13:42	99369.0	46.68	4.1	1197.0
2/10 13:43	101074.0	46.63	4.1	1199.0
2/10 13:44	102154.0	46.88	4.1	1200.0
2/10 13:45	102778.0	47.22	4.1	1200.0
2/10 13:46	100489.0	46.17	4.1	1199.7
2/10 13:47	102882.0	47.26	4.1	1200.0
2/10 13:48	99862.0	45.83	4.1	1200.0
2/10 13:49	102115.0	47.00	4.1	1201.0
2/10 13:50	100981.0	46.95	4.1	1201.5
2/10 13:51	99309.0	46.66	4.1	1200.3
2/10 13:52	99229.0	46.73	4.1	1200.0
2/10 13:53	99857.0	47.02	4.1	1199.8
2/10 13:54	99336.0	46.81	4.1	1199.8
2/10 13:55	99226.0	46.73	4.1	1200.3
2/10 13:56	99836.0	47.08	4.1	1200.5
2/10 13:57	99211.0	46.83	4.1	1200.3
2/10 13:58	99601.0	47.04	4.1	1199.8
2/10 13:59	97530.0	45.95	4.1	1199.3
2/10 14:00	100797.0	47.39	4.1	1199.3
2/10 14:01	100259.0	46.96	4.1	1200.8
2/10 14:02	99113.0	46.61	4.1	1200.2
2/10 14:03	100566.0	47.36	4.1	1200.0
2/10 14:04	100019.0	47.13	4.1	1200.0
2/10 14:05	99256.0	46.74	4.1	1199.7

	(TG-741) Landfill Gas Flow scfh/r	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 °F 1-Min
Timestamp					
2/10 14:06	99508.0	46.86	4.1	1200.0	
2/10 14:07	98768.0	46.51	4.1	1200.2	
2/10 14:08	100017.0	47.17	4.1	1199.8	
2/10 14:09	97984.0	46.25	4.1	1200.0	
2/10 14:10	99154.0	46.80	4.1	1199.8	
2/10 14:11	98256.0	46.83	4.1	1199.8	
2/10 14:12	99376.0	46.80	4.1	1200.2	
2/10 14:13	98557.0	46.41	4.1	1199.8	
2/10 14:14	98413.0	46.36	4.1	1199.7	
2/10 14:15	98665.0	46.48	4.1	1199.7	
2/10 14:16	100190.0	47.29	4.1	1200.0	
2/10 14:17	100878.0	47.53	4.1	1200.2	
2/10 14:18	97706.0	46.08	4.1	1199.8	
2/10 14:19	99285.0	46.76	4.1	1200.2	
2/10 14:20	98340.0	46.31	4.1	1199.7	
2/10 14:21	98318.0	46.32	4.1	1199.8	
2/10 14:22	98057.0	46.68	4.1	1200.0	
2/10 14:23	99272.0	46.80	4.1	1200.0	
2/10 14:24	98656.0	46.53	4.1	1199.8	
2/10 14:25	99110.0	46.72	4.1	1200.2	
2/10 14:26	97376.0	45.90	4.1	1199.8	
2/10 14:27	97975.0	46.23	4.1	1200.3	
2/10 14:28	99838.0	47.03	4.1	1200.2	
2/10 14:29	98334.0	46.82	4.1	1199.7	
2/10 14:30	98234.0	46.28	4.1	1200.0	
2/10 14:31	98718.0	46.51	4.1	1199.8	
2/10 14:32	98465.0	46.40	4.1	1200.3	
2/10 14:33	98666.0	46.57	4.1	1200.2	
2/10 14:34	98953.0	46.70	4.1	1200.2	
2/10 14:35	99371.0	46.95	4.1	1200.2	
2/10 14:36	98944.0	46.73	4.1	1199.8	
2/10 14:37	99155.0	46.80	4.1	1200.3	
2/10 14:38	98677.0	47.05	4.1	1199.7	
2/10 14:39	99500.0	46.96	4.1	1200.0	
2/10 14:40	97735.0	46.09	4.1	1199.8	
2/10 14:41	100098.0	47.19	4.1	1200.3	
2/10 14:42	98692.0	46.99	4.1	1200.2	
2/10 14:43	99175.0	46.81	4.1	1199.8	
2/10 14:44	99142.0	46.79	4.1	1200.5	
2/10 14:45	98845.0	47.15	4.1	1200.0	
2/10 14:46	99157.0	46.83	4.1	1200.0	
2/10 14:47	98262.0	46.40	4.1	1200.0	
2/10 14:48	97313.0	45.93	4.1	1200.0	
2/10 14:49	98034.0	46.32	4.1	1200.2	
2/10 14:50	99720.0	47.09	4.1	1200.2	
2/10 14:51	98747.0	46.64	4.1	1200.0	
2/10 14:52	98128.0	46.37	4.1	1200.0	
2/10 14:53	98937.0	47.17	4.1	1200.2	
2/10 14:54	97161.0	45.86	4.1	1199.8	

	(TG-741) Landfill Gas Flow set/hr 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
2/10 14:55	97646.0	46.03	4.1	1199.3
2/10 14:56	96287.0	46.20	4.1	1199.8
2/10 14:57	99589.0	46.88	4.1	1200.7
2/10 14:58	98417.0	46.91	4.1	1200.0
2/10 14:59	97218.0	45.97	4.1	1200.0
2/10 15:00	98756.0	46.72	4.1	1199.8
2/10 15:01	98901.0	46.75	4.1	1199.5
2/10 15:02	99282.0	46.86	4.1	1200.0
2/10 15:03	99199.0	46.82	4.1	1199.7
2/10 15:04	100559.0	47.23	4.1	1200.5
2/10 15:05	100274.0	47.33	4.1	1200.0
2/10 15:06	98525.0	46.51	4.1	1200.0
2/10 15:07	100281.0	47.35	4.1	1200.2
2/10 15:08	97207.0	45.96	4.1	1200.0
2/10 15:09	100574.0	47.58	4.1	1200.0
2/10 15:10	97403.0	46.02	4.1	1200.2
2/10 15:11	99554.0	46.99	4.1	1199.8
2/10 15:12	97408.0	46.06	4.1	1200.0
2/10 15:13	98381.0	46.46	4.1	1200.2
2/10 15:14	99582.0	47.11	4.1	1200.0
2/10 15:15	98917.0	46.80	4.1	1200.0
2/10 15:16	97542.0	46.06	4.1	1199.5
2/10 15:17	97529.0	46.03	4.1	1200.2
2/10 15:18	98698.0	46.62	4.1	1200.2
2/10 15:19	97881.0	46.31	4.1	1200.0
2/10 15:20	99309.0	46.98	4.1	1200.2
2/10 15:21	98939.0	47.24	4.1	1200.0
2/10 15:22	99078.0	46.82	4.1	1200.2
2/10 15:23	99069.0	46.87	4.1	1200.2
2/10 15:24	99671.0	47.04	4.1	1199.5
2/10 15:25	98772.0	46.62	4.1	1199.7
2/10 15:26	98396.0	46.92	4.1	1200.2
2/10 15:27	98381.0	46.44	4.1	1199.8
2/10 15:28	100081.0	47.18	4.1	1199.8
2/10 15:29	99254.0	46.81	4.1	1200.5
2/10 15:30	99241.0	46.84	4.1	1199.7
2/10 15:31	98351.0	46.89	4.1	1200.2
2/10 15:32	98456.0	47.05	4.1	1199.5
2/10 15:33	98579.0	46.53	4.1	1200.2
2/10 15:34	98752.0	46.61	4.1	1200.3
2/10 15:35	99134.0	46.32	4.1	1200.2
2/10 15:36	97860.0	46.27	4.1	1200.0
2/10 15:37	98609.0	46.59	4.1	1200.0
2/10 15:38	100087.0	47.26	4.1	1200.0
2/10 15:39	99745.0	47.10	4.1	1199.2
2/10 15:40	98282.0	46.39	4.1	1200.2
2/10 15:41	98856.0	46.66	4.1	1200.2
2/10 15:42	97871.0	46.24	4.1	1200.0
2/10 15:43	99034.0	46.82	4.1	1199.8

Cedar 5 Reports 3/8/2023 6:22 AM, CeDAR 1-Minute Data

Page 12 of 17

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Heat Input 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/10 15:44	99887.0	47.23	4.1	1199.7	
2/10 15:45	99116.0	46.81	4.1	1200.3	
2/10 15:46	98872.0	46.70	4.1	1200.2	
2/10 15:47	100791.0	47.53	4.1	1199.8	
2/10 15:48	99634.0	46.92	4.1	1199.7	
2/10 15:49	99961.0	47.09	4.1	1200.2	
2/10 15:50	100368.0	47.45	4.1	1200.0	
2/10 15:51	99875.0	47.25	4.1	1200.0	
2/10 15:52	98561.0	46.57	4.1	1200.0	
2/10 15:53	98545.0	46.55	4.1	1200.0	
2/10 15:54	98431.0	46.46	4.1	1200.2	
2/10 15:55	98315.0	46.95	4.1	1199.7	
2/10 15:56	98629.0	46.55	4.1	1200.0	
2/10 15:57	99607.0	47.02	4.1	1200.3	
2/10 15:58	99440.0	46.96	4.1	1200.5	
2/10 15:59	98626.0	45.61	4.1	1200.0	
2/10 16:00	99748.0	47.10	4.1	1200.0	
2/10 16:01	98058.0	46.31	4.1	1199.7	
2/10 16:02	98533.0	46.51	4.1	1199.8	
2/10 16:03	98233.0	46.36	4.1	1200.5	
2/10 16:04	98354.0	46.42	4.1	1199.8	
2/10 16:05	98254.0	46.85	4.1	1200.0	
2/10 16:06	95939.0	45.26	4.1	1199.8	
2/10 16:07	97572.0	46.05	4.1	1200.0	
2/10 16:08	98988.0	46.72	4.1	1200.0	
2/10 16:09	99691.0	47.05	4.1	1200.2	
2/10 16:10	99767.0	47.09	4.1	1200.0	
2/10 16:11	99020.0	46.74	4.1	1200.0	
2/10 16:12	98761.0	46.61	4.1	1200.0	
2/10 16:13	98490.0	46.49	4.1	1200.0	
2/10 16:14	98368.0	46.35	4.1	1200.0	
2/10 16:15	98144.0	46.21	4.1	1200.3	
2/10 16:16	98801.0	46.61	4.1	1200.0	
2/10 16:17	10006.0	47.20	4.1	1199.8	
2/10 16:18	98888.0	47.13	4.1	1200.0	
2/10 16:19	101509.0	47.91	4.1	1201.0	
2/10 16:20	98437.0	46.97	4.1	1200.5	
2/10 16:21	97361.0	46.03	4.1	1200.2	
2/10 16:22	98338.0	46.42	4.1	1199.8	
2/10 16:23	100079.0	47.22	4.1	1200.0	
2/10 16:24	99840.0	47.08	4.1	1199.7	
2/10 16:25	100616.0	47.49	4.1	1200.2	
2/10 16:26	98499.0	46.49	4.1	1199.3	
2/10 16:27	99044.0	46.75	4.1	1200.0	
2/10 16:28	100122.0	47.26	4.1	1200.0	
2/10 16:29	100081.0	47.16	4.1	1199.7	
2/10 16:30	98605.0	46.52	4.1	1199.7	
2/10 16:31	99578.0	46.94	4.1	1200.2	
2/10 16:32	100561.0	47.46	4.1	1200.2	

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/10 16:33	99137.0	46.79	4.1	1200.2	
2/10 16:34	98672.0	46.29	4.1	1200.0	
2/10 16:35	100354.0	47.40	4.1	1199.8	
2/10 16:36	99130.0	46.79	4.1	1200.2	
2/10 16:37	98667.0	46.57	4.1	1200.0	
2/10 16:38	98945.0	46.70	4.1	1199.7	
2/10 16:39	97483.0	45.95	4.1	1199.8	
2/10 16:40	99155.0	46.78	4.1	1200.0	
2/10 16:41	100140.0	47.18	4.1	1199.8	
2/10 16:42	99116.0	46.68	4.1	1200.0	
2/10 16:43	99313.0	46.79	4.1	1199.8	
2/10 16:44	99526.0	46.79	4.1	1199.2	
2/10 16:45	98823.0	46.53	4.1	1200.2	
2/10 16:46	98628.0	46.44	4.1	1200.3	
2/10 16:47	99718.0	47.05	4.1	1200.0	
2/10 16:48	99101.0	46.67	4.1	1200.0	
2/10 16:49	97408.0	45.98	4.1	1199.8	
2/10 16:50	100263.0	47.32	4.1	1200.0	
2/10 16:51	98105.0	46.25	4.1	1199.7	
2/10 16:52	98918.0	46.67	4.1	1199.8	
2/10 16:53	99763.0	47.09	4.1	1200.3	
2/10 16:54	99417.0	46.96	4.1	1200.2	
2/10 16:55	97902.0	46.24	4.1	1200.0	
2/10 16:56	100065.0	47.21	4.1	1200.0	
2/10 16:57	99508.0	46.93	4.1	1199.8	
2/10 16:58	99060.0	46.65	4.1	1200.0	
2/10 16:59	99364.0	46.79	4.1	1200.0	
2/10 17:00	98800.0	46.52	4.1	1200.0	
2/10 17:01	99399.0	46.81	4.1	1200.3	
2/10 17:02	101341.0	47.72	4.1	1200.0	
2/10 17:03	99945.0	47.04	4.1	1199.8	
2/10 17:04	100647.0	47.40	4.1	1199.7	
2/10 17:05	100455.0	47.31	4.1	1199.7	
2/10 17:06	99707.0	46.95	4.1	1199.7	
2/10 17:07	97195.0	45.77	4.1	1200.2	
2/10 17:08	99475.0	46.87	4.1	1200.0	
2/10 17:09	100477.0	47.32	4.1	1199.7	
2/10 17:10	99808.0	47.05	4.1	1200.0	
2/10 17:11	98780.0	46.52	4.1	1200.2	
2/10 17:12	99799.0	46.92	4.1	1200.2	
2/10 17:13	99766.0	46.96	4.1	1200.0	
2/10 17:14	100669.0	47.39	4.1	1200.0	
2/10 17:15	100218.0	47.19	4.1	1200.2	
2/10 17:16	99800.0	47.06	4.1	1200.3	
2/10 17:17	99706.0	46.97	4.1	1200.0	
2/10 17:18	100155.0	47.17	4.1	1200.0	
2/10 17:19	97753.0	46.05	4.1	1200.3	
2/10 17:20	99799.0	47.00	4.1	1199.7	
2/10 17:21	98895.0	46.55	4.1	1199.8	

	(TG-741) Landfill Gas Flow scfh 1-Min	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust °F 1-Min
Timestamp				
2/10/17:22	99647.0	46.82	4.1	1199.8
2/10/17:23	99609.0	46.89	4.1	1199.8
2/10/17:24	99879.0	47.03	4.1	1200.0
2/10/17:25	99294.0	46.70	4.1	1199.8
2/10/17:26	101167.0	47.53	4.1	1199.7
2/10/17:27	99561.0	46.75	4.1	1200.0
2/10/17:28	99767.0	46.87	4.1	1200.2
2/10/17:29	101058.0	47.48	4.1	1200.2
2/10/17:30	100222.0	47.08	4.1	1200.0
2/10/17:31	99667.0	46.83	4.1	1200.2
2/10/17:32	99528.0	46.79	4.1	1200.0
2/10/17:33	100320.0	47.24	4.1	1200.0
2/10/17:34	100077.0	47.05	4.1	1200.0
2/10/17:35	98204.0	46.13	4.1	1199.5
2/10/17:36	100324.0	47.13	4.1	1200.5
2/10/17:37	101113.0	47.52	4.1	1199.7
2/10/17:38	100034.0	46.99	4.2	1200.0
2/10/17:39	100391.0	47.16	4.2	1200.2
2/10/17:40	98556.0	46.30	4.1	1199.8
2/10/17:41	101256.0	47.55	4.1	1199.8
2/10/17:42	100504.0	47.18	4.1	1199.8
2/10/17:43	99426.0	46.60	4.1	1199.8
2/10/17:44	100082.0	46.91	4.1	1200.0
2/10/17:45	99803.0	46.78	4.1	1200.2
2/10/17:46	99604.0	46.73	4.1	1200.5
2/10/17:47	998983.0	46.50	4.1	1199.7
2/10/17:48	100959.0	47.35	4.1	1200.2
2/10/17:49	100222.0	47.05	4.1	1200.0
2/10/17:50	99633.0	46.78	4.1	1199.5
2/10/17:51	100604.0	47.15	4.1	1200.0
2/10/17:52	99895.0	46.82	4.2	1199.7
2/10/17:53	99201.0	46.50	4.2	1200.0
2/10/17:54	100112.0	46.92	4.2	1200.2
2/10/17:55	101337.0	47.50	4.2	1199.7
2/10/17:56	99256.0	46.52	4.1	1200.0
2/10/17:57	101149.0	47.41	4.1	1200.0
2/10/18:03	100428.0	47.15	4.1	1200.3
2/10/18:04	99687.0	46.81	4.1	1199.8
2/10/18:00	99464.0	46.64	4.1	1199.5
2/10/18:01	100634.0	47.14	4.1	1199.7
2/10/18:02	100673.0	47.04	4.2	1199.7
2/10/18:03	100767.0	47.07	4.2	1200.0
2/10/18:04	101456.0	47.44	4.2	1200.0
2/10/18:05	100514.0	47.11	4.2	1200.7
2/10/18:06	100073.0	47.01	4.2	1200.0
2/10/18:07	100064.0	46.95	4.2	1199.7
2/10/18:08	101147.0	47.38	4.2	1200.0
2/10/18:09	99819.0	46.71	4.2	1200.0
2/10/18:10	100418.0	46.96	4.2	1200.0

	(TG-741) Landfill Gas Flow scfh/r	(TG-741) Heat Input mmBtu/hr 1-Min	(TG-741) Megawatts 1-Min	(TG-741) T °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/10 18:11	98793.0	46.69	4.2	1200.0
2/10 18:12	100444.0	47.03	4.2	1199.8
2/10 18:13	99995.0	46.82	4.2	1200.0
2/10 18:14	98498.0	46.62	4.2	1200.0
2/10 18:15	101134.0	47.31	4.2	1200.0
2/10 18:16	100099.0	46.81	4.2	1200.2
2/10 18:17	99560.0	46.55	4.2	1200.0
2/10 18:18	99689.0	46.67	4.2	1200.2
2/10 18:19	102426.0	47.98	4.1	1199.5
2/10 18:20	98572.0	46.58	4.1	1200.0
2/10 18:21	100584.0	47.09	4.1	1199.8
2/10 18:22	100541.0	47.01	4.2	1200.2
2/10 18:23	101095.0	47.27	4.2	1200.0
2/10 18:24	102041.0	47.71	4.2	1200.0
2/10 18:25	99352.0	46.46	4.2	1199.7
2/10 18:26	99615.0	46.60	4.1	1200.0
2/10 18:27	99581.0	46.56	4.1	1200.0
2/10 18:28	101401.0	47.41	4.2	1200.0
2/10 18:29	100016.0	46.77	4.1	1199.7
2/10 18:30	101922.0	47.66	4.2	1199.8
2/10 18:31	101204.0	47.32	4.2	1200.0
2/10 18:32	98927.0	46.71	4.2	1199.8
2/10 18:33	101668.0	47.52	4.2	1200.0
2/10 18:34	100268.0	46.86	4.2	1200.0
2/10 18:35	101354.0	47.36	4.2	1199.8
2/10 18:36	101334.0	47.27	4.2	1200.2
2/10 18:37	100115.0	46.71	4.2	1200.2
2/10 18:38	100292.0	46.79	4.2	1200.0
2/10 18:39	99916.0	46.72	4.2	1200.0
2/10 18:40	100435.0	46.97	4.2	1199.8
2/10 18:41	100498.0	46.97	4.2	1199.8
2/10 18:42	101458.0	47.42	4.2	1200.0
2/10 18:43	100676.0	47.08	4.2	1199.8
2/10 18:44	98935.0	46.26	4.2	1200.0
2/10 18:45	101070.0	47.21	4.2	1200.2
2/10 18:46	100864.0	47.05	4.2	1200.2
2/10 18:47	102116.0	47.64	4.2	1200.0
2/10 18:48	99553.0	46.44	4.2	1200.2
2/10 18:49	101037.0	47.14	4.2	1200.0
2/10 18:50	99294.0	46.43	4.2	1200.2
2/10 18:51	100700.0	47.09	4.2	1200.0
2/10 18:52	101155.0	47.30	4.2	1200.0
2/10 18:53	100396.0	46.98	4.2	1200.0
2/10 18:54	101638.0	47.53	4.2	1199.8
2/10 18:55	99284.0	46.40	4.2	1200.0
2/10 18:56	100431.0	46.91	4.2	1199.8
2/10 18:57	100662.0	46.96	4.2	1200.0
2/10 18:58	99954.0	46.63	4.2	1199.8
2/10 18:59	100325.0	46.80	4.2	1200.0

	(TG-741) Landfill Gas Flow scf/hr	(TG-741) Heat Input mmBtu/hr	(TG-741) Megawatts 1-Min	(TG-741) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/10/19:00	100331.0	46.82	4.12	1200.2
Average (all)	100700.8	47.04	4.1	1200.0
Total (all)	--	--	--	--
Minimum (all)	95639.0	45.26	4.1	1197.7
Maximum (all)	10526.0	48.88	4.2	1201.5
Average (valid values only)	100700.8	47.04	4.1	1200.0
Total (valid values only)	--	--	--	--
Count (valid values only)	781	781	781	781

Appendix B.2 CT-5 Data

CeDAR 1-Minute Data
Sunshine Gas Producers, LLC
Data for 2/14/2023 6:00 AM thru 2/14/2023 7:00 PM

(TG-751)		Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts 1-Min	(TG-751) T [°] F 1-Min	(TG-751) T [°] F 1-Min
Timestamp	1-Min					
2/14 6:00	94959.0	44.43	3.8	1200.2		
2/14 6:01	95936.0	44.88	3.8	1200.0		
2/14 6:02	96550.0	45.17	3.8	1200.0		
2/14 6:03	96572.0	45.23	3.8	1200.0		
2/14 6:04	95467.0	44.67	3.8	1200.2		
2/14 6:05	95554.0	44.78	3.8	1199.8		
2/14 6:06	96191.0	45.06	3.8	1200.0		
2/14 6:07	95400.0	44.63	3.8	1200.0		
2/14 6:08	95354.0	44.67	3.8	1200.0		
2/14 6:09	95525.0	44.77	3.8	1200.0		
2/14 6:10	95513.0	44.77	3.8	1200.0		
2/14 6:11	95543.0	44.78	3.8	1200.0		
2/14 6:12	95076.0	44.56	3.8	1200.0		
2/14 6:13	95910.0	44.93	3.8	1200.0		
2/14 6:14	95791.0	44.88	3.8	1200.0		
2/14 6:15	95548.0	44.68	3.8	1200.0		
2/14 6:16	95521.0	44.68	3.8	1200.2		
2/14 6:17	97006.0	45.36	3.8	1200.0		
2/14 6:18	96095.0	44.93	3.8	1200.0		
2/14 6:19	95282.0	44.55	3.8	1200.0		
2/14 6:20	95797.0	44.80	3.8	1200.0		
2/14 6:21	96959.0	45.32	3.8	1200.2		
2/14 6:22	95903.0	44.84	3.8	1200.0		
2/14 6:23	95915.0	44.83	3.8	1200.0		
2/14 6:24	96497.0	45.12	3.8	1200.0		
2/14 6:25	95116.0	44.48	3.8	1200.0		
2/14 6:26	94833.0	44.37	3.8	1200.2		
2/14 6:27	96681.0	45.29	3.8	1200.0		
2/14 6:28	96015.0	44.90	3.8	1200.0		
2/14 6:29	96648.0	45.11	3.8	1200.0		
2/14 6:30	96370.0	44.96	3.8	1199.5		
2/14 6:31	96193.0	44.84	3.8	1200.0		
2/14 6:32	95621.0	44.61	3.8	1200.2		
2/14 6:33	96333.0	44.94	3.8	1200.0		
2/14 6:34	95934.0	44.75	3.8	1200.0		
2/14 6:35	96046.0	44.81	3.8	1200.0		
2/14 6:36	97095.0	45.33	3.8	1199.7		
2/14 6:37	95755.0	44.67	3.8	1199.8		
2/14 6:38	95829.0	44.60	3.8	1199.8		
2/14 6:39	95822.0	44.61	3.8	1199.8		
2/14 6:40	95923.0	44.64	3.8	1199.8		
2/14 6:41	96213.0	44.78	3.8	1199.8		
2/14 6:42	96307.0	44.90	3.8	1199.8		
2/14 6:43	95582.0	44.51	3.8	1200.3		
2/14 6:44	96157.0	44.86	3.8	1199.8		

	(TG-751) Landfill Gas Flow scfhhr	(TG-751) Heat Input mmBlfhr 1-Min	(TG-751) Heat Input mmBlfhr 1-Min	(TG-751) Megawatts · h·Min	(TG-751) T7 °F · 1-Min	(TG-751) T7 °F · 1-Min
Timestamp						
2/14 6:45	95252.0	44.43	3.8	1200.3		
2/14 6:46	96504.0	45.02	3.8	1199.8		
2/14 6:47	96195.0	44.79	3.8	1200.0		
2/14 6:48	94631.0	44.13	3.8	1199.8		
2/14 6:49	97006.0	45.15	3.8	1200.0		
2/14 6:50	96489.0	44.91	3.8	1200.0		
2/14 6:51	96527.0	44.96	3.8	1200.0		
2/14 6:52	95222.0	44.32	3.8	1200.0		
2/14 6:53	95353.0	44.41	3.8	1200.0		
2/14 6:54	96305.0	44.86	3.8	1200.0		
2/14 6:55	96014.0	44.72	3.8	1199.8		
2/14 6:56	96133.0	44.74	3.8	1200.0		
2/14 6:57	96728.0	45.06	3.8	1200.7		
2/14 6:58	96184.0	44.87	3.8	1199.7		
2/14 6:59	95776.0	44.68	3.8	1200.2		
2/14 7:00	96177.0	44.78	3.8	1199.7		
2/14 7:01	97130.0	45.18	3.8	1199.8		
2/14 7:02	97145.0	45.17	3.8	1200.0		
2/14 7:03	95569.0	44.40	3.8	1200.2		
2/14 7:04	96330.0	44.83	3.8	1200.0		
2/14 7:05	95470.0	44.40	3.8	1200.2		
2/14 7:06	95866.0	44.51	3.8	1200.0		
2/14 7:07	96114.0	44.56	3.8	1200.0		
2/14 7:08	96059.0	44.58	3.8	1200.3		
2/14 7:09	95344.0	44.37	3.8	1200.3		
2/14 7:10	95646.0	44.50	3.8	1200.0		
2/14 7:11	95530.0	44.46	3.8	1199.8		
2/14 7:12	95864.0	44.61	3.8	1200.0		
2/14 7:13	95454.0	44.42	3.8	1200.2		
2/14 7:14	95920.0	44.64	3.8	1200.0		
2/14 7:15	95569.0	44.38	3.8	1200.0		
2/14 7:16	96292.0	44.81	3.8	1200.0		
2/14 7:17	96028.0	44.64	3.8	1199.8		
2/14 7:18	95380.0	44.39	3.8	1200.0		
2/14 7:19	96231.0	44.79	3.8	1199.7		
2/14 7:20	96844.0	45.07	3.8	1199.8		
2/14 7:21	95457.0	44.43	3.8	1199.8		
2/14 7:22	95399.0	44.40	3.8	1200.0		
2/14 7:23	96124.0	44.81	3.8	1200.0		
2/14 7:24	95386.0	44.39	3.8	1200.0		
2/14 7:25	96369.0	44.87	3.8	1200.0		
2/14 7:26	96073.0	44.82	3.8	1200.3		
2/14 7:27	95720.0	44.63	3.8	1199.8		
2/14 7:28	96124.0	44.81	3.8	1200.0		
2/14 7:29	95792.0	44.62	3.8	1200.0		
2/14 7:30	95569.0	44.58	3.8	1200.0		
2/14 7:31	96344.0	44.84	3.8	1200.0		
2/14 7:32	94477.0	44.01	3.8	1199.8		
2/14 7:33	96070.0	44.71	3.8	1200.3		

	(TG-751) Landfill Gas Flow scfm/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min
Timestamp				
2/14 7:34	96312.0	44.82	3.8	1200.0
2/14 7:35	96599.0	44.49	3.8	1200.0
2/14 7:36	95544.0	44.46	3.8	1200.0
2/14 7:37	95814.0	44.67	3.8	1198.8
2/14 7:38	95861.0	44.69	3.8	1200.0
2/14 7:39	96009.0	44.77	3.8	1200.0
2/14 7:40	96224.0	44.89	3.8	1198.8
2/14 7:41	96070.0	44.73	3.8	1200.0
2/14 7:42	95984.0	44.76	3.8	1200.2
2/14 7:43	95872.0	44.69	3.8	1200.0
2/14 7:44	95976.0	44.69	3.8	1200.0
2/14 7:45	95818.0	44.65	3.8	1198.8
2/14 7:46	96820.0	45.06	3.8	1198.8
2/14 7:47	96090.0	44.72	3.8	1200.0
2/14 7:48	95027.0	44.23	3.8	1200.0
2/14 7:49	95667.0	44.55	3.8	1200.2
2/14 7:50	94577.0	44.06	3.8	1198.7
2/14 7:51	95822.0	44.59	3.8	1200.0
2/14 7:52	95850.0	44.61	3.8	1200.0
2/14 7:53	95015.0	44.24	3.8	1200.0
2/14 7:54	95193.0	44.30	3.8	1198.8
2/14 7:55	96238.0	44.80	3.8	1200.0
2/14 7:56	96638.0	44.98	3.8	1198.5
2/14 7:57	96220.0	44.71	3.8	1200.0
2/14 7:58	96046.0	44.60	3.8	1200.0
2/14 7:59	96289.0	44.71	3.8	1200.0
2/14 8:00	96767.0	44.99	3.8	1200.2
2/14 8:01	95148.0	44.28	3.8	1200.0
2/14 8:02	96196.0	44.70	3.8	1200.0
2/14 8:03	95537.0	44.40	3.8	1198.8
2/14 8:04	94830.0	44.13	3.8	1200.2
2/14 8:05	94828.0	44.13	3.8	1200.2
2/14 8:06	96808.0	45.06	3.8	1200.0
2/14 8:07	95714.0	44.54	3.8	1200.2
2/14 8:08	95943.0	44.65	3.8	1200.2
2/14 8:09	96748.0	45.03	3.8	1200.0
2/14 8:10	94674.0	44.08	3.8	1200.0
2/14 8:11	95007.0	44.22	3.8	1198.8
2/14 8:12	94983.0	44.17	3.8	1200.0
2/14 8:13	95263.0	44.29	3.8	1200.2
2/14 8:14	96465.0	44.85	3.8	1200.2
2/14 8:15	95824.0	44.57	3.8	1200.0
2/14 8:16	95778.0	44.58	3.8	1200.0
2/14 8:17	95341.0	44.37	3.8	1200.0
2/14 8:18	95779.0	44.58	3.8	1200.0
2/14 8:19	96183.0	44.78	3.8	1200.0
2/14 8:20	94928.0	44.18	3.8	1200.0
2/14 8:21	95156.0	44.29	3.8	1200.0
2/14 8:22	95796.0	44.60	3.8	1200.0

	(TG-751) Landfill Gas Flow scfmhr	(TG-751) Heat Input mmBtu/hr	(TG-751) Heat 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min	(TG-751) T °F 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	Exhaust Temp °F 1-Min	Exhaust Temp °F 1-Min
2/14 8:23	95665.0	44.66	3.8	1200.0		
2/14 8:24	96510.0	44.92	3.8	1200.0		
2/14 8:25	95509.0	44.36	3.8	1200.0		
2/14 8:26	94797.0	44.12	3.8	1200.0		
2/14 8:27	96105.0	44.73	3.8	1200.0		
2/14 8:28	95607.0	44.50	3.8	1200.0		
2/14 8:29	95713.0	44.54	3.8	1200.0		
2/14 8:30	95495.0	44.45	3.8	1200.0		
2/14 8:31	95688.0	44.51	3.8	1200.0		
2/14 8:32	94784.0	44.11	3.8	1200.2		
2/14 8:33	95595.0	44.46	3.8	1199.8		
2/14 8:34	95550.0	44.47	3.8	1199.7		
2/14 8:35	95210.0	44.31	3.8	1199.8		
2/14 8:36	95515.0	44.49	3.8	1200.2		
2/14 8:37	95274.0	44.40	3.8	1199.7		
2/14 8:38	94851.0	44.14	3.8	1200.0		
2/14 8:39	96291.0	44.85	3.8	1200.0		
2/14 8:40	95544.0	44.55	3.8	1199.8		
2/14 8:41	95446.0	44.42	3.8	1200.0		
2/14 8:42	95703.0	44.54	3.8	1200.0		
2/14 8:43	95647.0	44.64	3.8	1200.2		
2/14 8:44	94866.0	44.09	3.8	1199.8		
2/14 8:45	95553.0	44.36	3.8	1199.8		
2/14 8:46	95449.0	44.32	3.8	1200.3		
2/14 8:47	95347.0	44.35	3.8	1200.0		
2/14 8:48	95492.0	44.34	3.8	1200.2		
2/14 8:49	95295.0	44.25	3.8	1200.2		
2/14 8:50	95555.0	44.37	3.8	1200.0		
2/14 8:51	94688.0	43.96	3.8	1199.8		
2/14 8:52	95280.0	44.24	3.8	1200.2		
2/14 8:53	96230.0	44.68	3.8	1200.0		
2/14 8:54	95735.0	44.45	3.8	1200.0		
2/14 8:55	96385.0	44.75	3.8	1199.8		
2/14 8:56	95644.0	44.34	3.8	1200.0		
2/14 8:57	95394.0	44.21	3.8	1200.3		
2/14 8:58	95686.0	44.36	3.8	1200.3		
2/14 8:59	95503.0	44.31	3.8	1200.0		
2/14 9:00	94481.0	43.80	3.8	1199.8		
2/14 9:01	95215.0	44.12	3.8	1200.0		
2/14 9:02	94630.0	43.81	3.8	1200.0		
2/14 9:03	95718.0	44.18	3.8	1200.5		
2/14 9:04	95504.0	44.12	3.8	1200.0		
2/14 9:05	95676.0	44.33	3.8	1200.0		
2/14 9:06	95015.0	44.02	3.8	1200.0		
2/14 9:07	95026.0	43.97	3.8	1199.5		
2/14 9:08	94722.0	43.74	3.8	1199.8		
2/14 9:09	95534.0	44.29	3.8	1200.2		
2/14 9:10	95026.0	43.92	3.8	1200.2		
2/14 9:11	95542.0	44.13	3.8	1200.0		

(TG-751)		(TG-751) Heat Input mmBtu/hr	(TG-751) 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T°F 1-Min
Timestamp	Landfill Gas Flow scfh	1-Min	1-Min	1-Min	1-Min
2/14 9:12	94801.0	43.85	3.8	1200.7	
2/14 9:13	95484.0	44.28	3.8	1200.7	
2/14 9:14	95721.0	44.53	3.8	1200.0	
2/14 9:15	94835.0	44.14	3.8	1199.5	
2/14 9:16	95197.0	44.18	3.8	1199.7	
2/14 9:17	96369.0	44.68	3.8	1200.0	
2/14 9:18	95664.0	44.28	3.8	1200.2	
2/14 9:19	95959.0	44.40	3.8	1200.0	
2/14 9:20	95429.0	44.14	3.8	1200.2	
2/14 9:21	94525.0	43.89	3.8	1200.0	
2/14 9:22	95999.0	44.57	3.8	1199.7	
2/14 9:23	94778.0	44.04	3.8	1200.0	
2/14 9:24	95922.0	44.62	3.8	1199.8	
2/14 9:25	95172.0	44.19	3.8	1199.7	
2/14 9:26	96285.0	44.74	3.8	1199.8	
2/14 9:27	96556.0	44.83	3.8	1200.0	
2/14 9:28	96346.0	44.74	3.8	1199.7	
2/14 9:29	96210.0	44.67	3.8	1200.0	
2/14 9:30	95054.0	44.16	3.8	1200.5	
2/14 9:31	96005.0	44.62	3.8	1200.0	
2/14 9:32	94944.0	44.14	3.8	1200.3	
2/14 9:33	95946.0	44.58	3.8	1199.8	
2/14 9:34	95332.0	44.26	3.8	1199.8	
2/14 9:35	95269.0	44.21	3.8	1200.2	
2/14 9:36	95406.0	44.23	3.8	1199.5	
2/14 9:37	95404.0	44.11	3.8	1200.0	
2/14 9:38	95465.0	44.17	3.8	1200.5	
2/14 9:39	95219.0	44.18	3.8	1200.0	
2/14 9:40	94883.0	44.05	3.8	1199.7	
2/14 9:41	96068.0	44.47	3.8	1199.5	
2/14 9:42	95757.0	44.15	3.8	1200.2	
2/14 9:43	95672.0	44.19	3.8	1200.8	
2/14 9:44	95745.0	44.46	3.8	1199.7	
2/14 9:45	96464.0	44.72	3.8	1199.7	
2/14 9:46	95297.0	43.94	3.8	1199.7	
2/14 9:47	95078.0	43.87	3.8	1200.3	
2/14 9:48	95116.0	44.01	3.8	1200.3	
2/14 9:49	95557.0	44.27	3.8	1199.5	
2/14 9:50	95616.0	44.30	3.8	1199.7	
2/14 9:51	95119.0	44.45	3.8	1200.0	
2/14 9:52	95833.0	44.37	3.8	1199.8	
2/14 9:53	96105.0	44.56	3.8	1200.3	
2/14 9:54	95287.0	44.35	3.8	1199.8	
2/14 9:55	95635.0	44.31	3.8	1199.0	
2/14 9:56	96355.0	44.52	3.8	1200.0	
2/14 9:57	96933.0	44.48	3.8	1200.0	
2/14 9:58	96784.0	44.41	3.8	1200.0	
2/14 9:59	96400.0	44.32	3.8	1200.7	
2/14 10:00	95598.0	44.25	3.8	1200.8	

	(TG-751) Landfill Gas Flow scfh/r	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts / Min	(TG-751) T °F / Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/14 10:01	94932.0	44.11	3.8	1200.2
2/14 10:02	95367.0	44.31	3.8	1199.5
2/14 10:03	96689.0	44.89	3.8	1199.8
2/14 10:04	95535.0	44.36	3.8	1199.8
2/14 10:05	94970.0	44.12	3.8	1200.2
2/14 10:06	95688.0	44.48	3.8	1199.7
2/14 10:07	95363.0	44.30	3.8	1200.2
2/14 10:08	94776.0	44.11	3.8	1200.2
2/14 10:09	96875.0	45.09	3.8	1200.0
2/14 10:10	95038.0	44.18	3.8	1200.5
2/14 10:11	94365.0	43.92	3.7	1199.8
2/14 10:12	95537.0	44.46	3.8	1200.0
2/14 10:13	94451.0	43.99	3.8	1199.8
2/14 10:14	95323.0	44.36	3.8	1200.0
2/14 10:15	95130.0	44.29	3.8	1200.0
2/14 10:16	95126.0	44.27	3.8	1199.8
2/14 10:17	95209.0	44.26	3.8	1200.0
2/14 10:18	95516.0	44.39	3.8	1200.0
2/14 10:19	94920.0	44.11	3.8	1200.0
2/14 10:20	95588.0	44.41	3.8	1200.2
2/14 10:21	95113.0	44.26	3.8	1199.7
2/14 10:22	95028.0	44.23	3.8	1200.2
2/14 10:23	95012.0	44.22	3.8	1200.0
2/14 10:24	94198.0	44.77	3.8	1199.8
2/14 10:25	95567.0	44.40	3.8	1200.2
2/14 10:26	95781.0	44.58	3.8	1200.2
2/14 10:27	94638.0	44.05	3.8	1200.2
2/14 10:28	95262.0	44.39	3.8	1199.8
2/14 10:29	94628.0	44.04	3.8	1199.8
2/14 10:30	94144.0	43.78	3.8	1200.0
2/14 10:31	93886.0	43.66	3.7	1200.2
2/14 10:32	94981.0	44.16	3.7	1200.0
2/14 10:33	94484.0	43.87	3.7	1199.8
2/14 10:34	94513.0	43.91	3.8	1200.0
2/14 10:35	94426.0	43.93	3.8	1200.0
2/14 10:36	95543.0	44.46	3.8	1200.0
2/14 10:37	94584.0	44.04	3.8	1200.0
2/14 10:38	94544.0	44.07	3.8	1200.0
2/14 10:39	94195.0	43.94	3.8	1199.2
2/14 10:40	94939.0	44.00	3.8	1200.2
2/14 10:41	94292.0	43.90	3.8	1200.7
2/14 10:42	93887.0	43.80	3.8	1200.0
2/14 10:43	94604.0	44.05	3.7	1199.8
2/14 10:44	94733.0	44.09	3.7	1200.0
2/14 10:45	93537.0	43.57	3.7	1200.2
2/14 10:46	95267.0	44.40	3.7	1199.7
2/14 10:47	94992.0	44.31	3.7	1200.0
2/14 10:48	94934.0	44.28	3.7	1200.0
2/14 10:49	94177.0	43.99	3.7	1199.8

Cedar 5 Reports 3/8/2023 6:45 AM, CeDAR 1-Minute Data

Page 6 of 17

Timestamp	(TG-751) Landfill Gas Flow scfh/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T°F 1-Min	(TG-751) T°F Exhaust Temp °F 1-Min
2/14 10:50	93818.0	43.85		3.8	1200.0	
2/14 10:51	94583.0	44.12		3.8	1199.7	
2/14 10:52	95334.0	44.49		3.8	1200.2	
2/14 10:53	95588.0	44.63		3.8	1200.0	
2/14 10:54	93699.0	43.71		3.8	1199.7	
2/14 10:55	94621.0	44.16		3.8	1200.3	
2/14 10:56	95492.0	44.60		3.7	1199.7	
2/14 10:57	94156.0	43.93		3.7	1200.5	
2/14 10:58	94489.0	44.03		3.7	1199.7	
2/14 10:59	94635.0	44.06		3.7	1200.0	
2/14 11:00	95128.0	44.35		3.7	1200.0	
2/14 11:01	95070.0	44.26		3.7	1199.5	
2/14 11:02	95803.0	44.64		3.8	1200.0	
2/14 11:03	95148.0	44.37		3.8	1200.0	
2/14 11:04	94942.0	44.31		3.8	1200.2	
2/14 11:05	94596.0	44.40		3.8	1200.0	
2/14 11:06	94444.0	44.16		3.8	1199.7	
2/14 11:07	94687.0	44.25		3.8	1200.2	
2/14 11:08	93565.0	43.80		3.8	1200.0	
2/14 11:09	93557.0	43.75		3.8	1200.0	
2/14 11:10	95012.0	44.43		3.8	1200.0	
2/14 11:11	94943.0	44.41		3.7	1200.0	
2/14 11:12	93402.0	43.69		3.7	1200.2	
2/14 11:13	94145.0	44.04		3.7	1200.2	
2/14 11:14	94127.0	44.02		3.7	1200.0	
2/14 11:15	94022.0	43.96		3.7	1200.2	
2/14 11:16	94327.0	44.08		3.7	1200.0	
2/14 11:17	94294.0	44.07		3.7	1199.8	
2/14 11:18	93184.0	43.57		3.7	1200.3	
2/14 11:19	93148.0	43.61		3.7	1199.8	
2/14 11:20	94374.0	44.15		3.7	1200.2	
2/14 11:21	94221.0	44.16		3.7	1200.2	
2/14 11:22	94793.0	44.46		3.7	1200.0	
2/14 11:23	93999.0	44.09		3.7	1200.0	
2/14 11:24	94524.0	44.30		3.7	1199.8	
2/14 11:25	94596.0	44.25		3.7	1200.0	
2/14 11:26	95135.0	44.59		3.7	1200.2	
2/14 11:27	95210.0	44.64		3.7	1200.2	
2/14 11:28	93789.0	43.98		3.7	1200.2	
2/14 11:29	93954.0	44.03		3.7	1199.8	
2/14 11:30	94672.0	44.37		3.7	1199.8	
2/14 11:31	94114.0	44.08		3.7	1200.0	
2/14 11:32	93483.0	43.80		3.7	1200.0	
2/14 11:33	94325.0	44.13		3.7	1200.0	
2/14 11:34	94561.0	44.12		3.7	1200.0	
2/14 11:35	94598.0	44.46		3.7	1200.2	
2/14 11:36	94183.0	44.14		3.7	1200.0	
2/14 11:37	93566.0	43.93		3.7	1200.0	
2/14 11:38	93907.0	44.04		3.7	1200.2	

Oedar 5 Reports 3/8/2023 6:45 AM, CeDAR 1-Minute Data

Page 7 of 17

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min	(TG-751) T °F 1-Min
Timestamp					
2/14 11:39	94142.0	44.20	3.7	1199.8	
2/14 11:40	94116.0	44.13	3.7	1200.0	
2/14 11:41	938865.0	44.07	3.7	1200.0	
2/14 11:42	94084.0	44.10	3.7	1200.2	
2/14 11:43	93900.0	44.11	3.7	1200.2	
2/14 11:44	93441.0	43.90	3.7	1200.0	
2/14 11:45	94811.0	44.54	3.7	1200.0	
2/14 11:46	93658.0	43.97	3.7	1200.0	
2/14 11:47	92750.0	43.47	3.7	1200.0	
2/14 11:48	94643.0	44.34	3.7	1199.8	
2/14 11:49	93991.0	44.05	3.7	1200.0	
2/14 11:50	93867.0	44.02	3.7	1200.2	
2/14 11:51	94081.0	44.20	3.7	1200.0	
2/14 11:52	94076.0	44.23	3.7	1200.0	
2/14 11:53	94294.0	44.40	3.7	1200.0	
2/14 11:54	92984.0	43.78	3.7	1199.7	
2/14 11:55	93637.0	44.07	3.7	1199.7	
2/14 11:56	93586.0	43.95	3.7	1199.8	
2/14 11:57	94028.0	44.10	3.7	1200.2	
2/14 11:58	92781.0	43.59	3.7	1200.0	
2/14 11:59	94076.0	44.27	3.7	1200.2	
2/14 12:00	93792.0	44.08	3.7	1200.0	
2/14 12:01	93778.0	44.08	3.7	1199.8	
2/14 12:02	92873.0	43.63	3.7	1199.3	
2/14 12:03	94363.0	44.20	3.7	1200.0	
2/14 12:04	94937.0	44.50	3.7	1200.0	
2/14 12:05	94009.0	44.14	3.7	1199.8	
2/14 12:06	93330.0	43.85	3.7	1199.8	
2/14 12:07	93788.0	44.08	3.7	1200.3	
2/14 12:08	94219.0	44.39	3.7	1200.2	
2/14 12:09	93397.0	43.98	3.7	1199.8	
2/14 12:10	94016.0	44.34	3.7	1200.0	
2/14 12:11	92733.0	43.75	3.7	1200.0	
2/14 12:12	92880.0	43.82	3.7	1200.0	
2/14 12:13	93090.0	43.92	3.7	1200.0	
2/14 12:14	92791.0	43.80	3.7	1199.7	
2/14 12:15	94124.0	44.37	3.7	1200.0	
2/14 12:16	93312.0	44.04	3.7	1200.0	
2/14 12:17	93282.0	43.93	3.7	1200.0	
2/14 12:18	94135.0	44.40	3.7	1200.0	
2/14 12:19	92594.0	43.68	3.7	1200.0	
2/14 12:20	92070.0	43.46	3.7	1200.0	
2/14 12:21	93444.0	44.08	3.7	1199.3	
2/14 12:22	93768.0	44.08	3.7	1199.8	
2/14 12:23	93507.0	43.98	3.7	1200.0	
2/14 12:24	93624.0	44.06	3.7	1200.0	
2/14 12:25	93136.0	43.76	3.7	1200.3	
2/14 12:26	93508.0	43.93	3.7	1199.8	
2/14 12:27	93458.0	43.91	3.7	1199.8	
Average Run 1	95006.7	44.2	3.8	1200.0	

Timestamp	(TG-751) Landfill Gas Flow scfh	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751), T7 °F 1-Min
2/14 12:28	94/65.0	44.57	3.7	1200.2	
2/14 12:29	93/578.0	44.11	3.7	1200.3	
2/14 12:30	93/071.0	43.86	3.7	1200.2	
2/14 12:31	93/568.0	44.17	3.7	1200.2	
2/14 12:32	93/280.0	44.10	3.7	1200.0	
2/14 12:33	92/902.0	43.90	3.7	1199.2	
2/14 12:34	94/396.0	44.14	3.7	1199.5	
2/14 12:35	94/885.0	44.20	3.7	1200.2	
2/14 12:36	93/927.0	43.82	3.7	1199.8	
2/14 12:37	93/471.0	43.60	3.7	1200.0	
2/14 12:38	93/888.0	43.90	3.7	1200.2	
2/14 12:39	93/746.0	43.94	3.7	1200.2	
2/14 12:40	93/554.0	43.83	3.7	1200.0	
2/14 12:41	93/409.0	43.80	3.7	1200.2	
2/14 12:42	92/931.0	43.63	3.7	1199.5	
2/14 12:43	93/744.0	43.83	3.7	1200.2	
2/14 12:44	93/862.0	44.02	3.7	1200.2	
2/14 12:45	93/269.0	43.73	3.7	1200.0	
2/14 12:46	94/796.0	44.43	3.7	1200.0	
2/14 12:47	93/663.0	43.90	3.7	1199.7	
2/14 12:48	93/986.0	44.06	3.7	1200.2	
2/14 12:49	94/287.0	44.30	3.7	1199.8	
2/14 12:50	94/503.0	44.40	3.7	1200.2	
2/14 12:51	93/785.0	43.98	3.7	1199.8	
2/14 12:52	93/594.0	43.95	3.7	1200.7	
2/14 12:53	93/716.0	44.16	3.7	1199.7	
2/14 12:54	94/127.0	44.33	3.7	1199.8	
2/14 12:55	94/338.0	44.34	3.7	1200.0	
2/14 12:56	94/089.0	44.29	3.7	1200.5	
2/14 12:57	93/668.0	44.02	3.7	1200.2	
2/14 12:58	92/658.0	43.84	3.7	1200.0	
2/14 12:59	93/490.0	44.17	3.7	1200.3	
2/14 13:00	92/667.0	43.77	3.7	1199.8	
2/14 13:01	93/032.0	43.91	3.7	1200.0	
2/14 13:02	93/134.0	44.02	3.7	1199.8	
2/14 13:03	93/397.0	44.05	3.7	1199.5	
2/14 13:04	94/052.0	44.35	3.7	1200.2	
2/14 13:05	93/181.0	43.98	3.7	1200.0	
2/14 13:06	94/154.0	44.34	3.7	1199.5	
2/14 13:07	94/021.0	44.25	3.7	1201.7	
2/14 13:08	92/781.0	43.86	3.7	1200.5	
2/14 13:09	92/570.0	43.72	3.7	1198.7	
2/14 13:10	93/245.0	44.45	3.7	1199.0	
2/14 13:11	94/479.0	44.09	3.7	1201.7	
2/14 13:12	93/642.0	44.22	3.7	1200.3	
2/14 13:13	92/987.0	43.99	3.7	1199.8	
2/14 13:14	92/332.0	43.70	3.7	1200.2	
2/14 13:15	92/987.0	44.07	3.7	1199.3	
2/14 13:16	93/719.0	44.03	3.7	1200.3	

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts·Min	(TG-751) T °F 1-Min
2/14 13:17	93617.0	44.13	3.7	1197.3
2/14 13:18	99671.0	45.34	3.7	1196.2
2/14 13:19	101180.0	44.92	3.8	1200.3
2/14 13:20	96803.0	43.54	3.8	1205.5
2/14 13:21	92875.0	43.58	3.7	1201.0
2/14 13:22	92270.0	43.55	3.7	1199.5
2/14 13:23	95013.0	44.65	3.7	1196.2
2/14 13:24	96599.0	44.38	3.8	1202.8
2/14 13:25	94132.0	44.22	3.7	1201.7
2/14 13:26	93374.0	44.24	3.7	1199.7
2/14 13:27	93292.0	44.24	3.7	1199.7
2/14 13:28	93943.0	44.39	3.7	1199.7
2/14 13:29	94001.0	44.28	3.7	1200.0
2/14 13:30	93576.0	44.09	3.7	1200.2
2/14 13:31	93463.0	44.09	3.7	1200.3
2/14 13:32	92902.0	43.85	3.7	1200.0
2/14 13:33	93687.0	44.23	3.7	1200.0
2/14 13:34	93322.0	44.09	3.7	1200.2
2/14 13:35	93617.0	44.26	3.7	1199.8
2/14 13:36	93777.0	44.37	3.7	1200.0
2/14 13:37	93518.0	44.26	3.7	1200.0
2/14 13:38	93097.0	44.12	3.7	1200.0
2/14 13:39	92654.0	43.83	3.7	1199.8
2/14 13:40	93165.0	44.08	3.7	1200.0
2/14 13:41	93360.0	44.17	3.7	1199.8
2/14 13:42	92959.0	43.98	3.7	1200.2
2/14 13:43	93555.0	44.23	3.7	1200.3
2/14 13:44	93297.0	44.14	3.7	1199.8
2/14 13:45	93840.0	44.27	3.7	1199.0
2/14 13:46	93643.0	43.86	3.7	1200.5
2/14 13:47	93266.0	43.95	3.7	1200.2
2/14 13:48	92942.0	43.81	3.7	1200.0
2/14 13:49	94100.0	44.33	3.7	1200.0
2/14 13:50	92323.0	43.49	3.7	1200.2
2/14 13:51	93247.0	43.94	3.7	1199.8
2/14 13:52	93253.0	44.01	3.7	1199.8
2/14 13:53	93183.0	43.96	3.7	1199.3
2/14 13:54	92966.0	43.49	3.7	1200.5
2/14 13:55	92930.0	43.74	3.7	1200.3
2/14 13:56	93575.0	44.22	3.7	1200.0
2/14 13:57	93436.0	44.18	3.7	1199.7
2/14 13:58	92708.0	43.78	3.7	1199.8
2/14 13:59	92820.0	43.79	3.7	1199.8
2/14 14:00	93784.0	44.21	3.7	1200.2
2/14 14:01	94029.0	44.36	3.7	1200.0
2/14 14:02	93951.0	44.34	3.7	1200.0
2/14 14:03	93287.0	44.02	3.7	1199.3
2/14 14:04	93506.0	44.05	3.7	1200.0
2/14 14:05	93392.0	44.06	3.7	1200.0

Cedar 5 Reports 3/8/2023 6:45 AM, CeDAR 1-Minute Data

Page 10 of 17

	(TG-751) Landfill Gas Flow scfm/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 °F 1-Min
2/14 14:06	92976.0	43.89	3.7	1200.0
2/14 14:07	92797.0	43.80	3.7	1200.0
2/14 14:08	93409.0	44.14	3.7	1199.3
2/14 14:09	93809.0	44.09	3.7	1200.0
2/14 14:10	93022.0	43.70	3.7	1200.2
2/14 14:11	94276.0	44.32	3.7	1200.0
2/14 14:12	93613.0	44.06	3.7	1200.0
2/14 14:13	93485.0	44.01	3.7	1200.0
2/14 14:14	93395.0	43.98	3.7	1200.2
2/14 14:15	92885.0	43.83	3.7	1200.0
2/14 14:16	93899.0	44.22	3.7	1200.0
2/14 14:17	93613.0	44.08	3.7	1199.8
2/14 14:18	93415.0	43.99	3.7	1200.2
2/14 14:19	94449.0	44.56	3.7	1200.0
2/14 14:20	93678.0	44.16	3.7	1199.8
2/14 14:21	93719.0	44.11	3.7	1199.8
2/14 14:22	93014.0	43.80	3.7	1200.0
2/14 14:23	93088.0	43.84	3.7	1200.0
2/14 14:24	93309.0	43.91	3.7	1200.2
2/14 14:25	94167.0	44.29	3.7	1199.8
2/14 14:26	93063.0	43.72	3.7	1200.2
2/14 14:27	93318.0	43.79	3.7	1200.0
2/14 14:28	93725.0	43.93	3.7	1199.8
2/14 14:29	93858.0	43.99	3.7	1200.0
2/14 14:30	94316.0	44.21	3.7	1200.0
2/14 14:31	93369.0	43.76	3.7	1200.0
2/14 14:32	94840.0	44.45	3.7	1200.2
2/14 14:33	92475.0	43.35	3.7	1200.2
2/14 14:34	93888.0	44.06	3.7	1200.2
2/14 14:35	94136.0	44.21	3.7	1199.8
2/14 14:36	94888.0	44.43	3.7	1199.7
2/14 14:37	94168.0	44.03	3.7	1199.8
2/14 14:38	93995.0	43.94	3.7	1200.0
2/14 14:39	93611.0	43.74	3.7	1200.0
2/14 14:40	93838.0	43.95	3.7	1199.8
2/14 14:41	94566.0	44.22	3.7	1200.0
2/14 14:42	94183.0	44.07	3.7	1200.2
2/14 14:43	93475.0	43.79	3.7	1199.8
2/14 14:44	93976.0	43.96	3.7	1200.0
2/14 14:45	93923.0	43.89	3.7	1199.7
2/14 14:46	94283.0	44.09	3.7	1199.8
2/14 14:47	94092.0	43.97	3.7	1200.2
2/14 14:48	94821.0	44.26	3.7	1200.0
2/14 14:49	93007.0	43.39	3.7	1199.8
2/14 14:50	93481.0	43.63	3.7	1200.0
2/14 14:51	93984.0	43.85	3.7	1200.0
2/14 14:52	94118.0	43.91	3.7	1199.8
2/14 14:53	94482.0	44.07	3.7	1200.0
2/14 14:54	94428.0	44.05	3.7	1200.2

Cedar 5 Reports 3/8/2023 6:45 AM, CeDAR 1-Minute Data

Page 11 of 17

Timestamp	(TG-751) Landfill Gas Flow scf/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min
2/14 14:55	94917.0	44.28	3.7	1199.8
2/14 14:56	94849.0	44.30	3.7	1200.0
2/14 14:57	93457.0	43.70	3.8	1200.0
2/14 14:58	93614.0	43.77	3.7	1200.2
2/14 14:59	93398.0	43.70	3.7	1200.0
2/14 15:00	93209.0	43.59	3.7	1200.0
2/14 15:01	92921.0	43.42	3.7	1199.8
2/14 15:02	93839.0	43.86	3.7	1200.0
2/14 15:03	95069.0	44.37	3.7	1200.0
2/14 15:04	94413.0	44.04	3.7	1200.0
2/14 15:05	94471.0	44.07	3.7	1200.2
2/14 15:06	94338.0	44.03	3.7	1199.7
2/14 15:07	94596.0	44.13	3.8	1200.0
2/14 15:08	93730.0	43.66	3.8	1199.7
2/14 15:09	94868.0	44.28	3.8	1200.2
2/14 15:10	93986.0	43.85	3.8	1199.8
2/14 15:11	95273.0	44.41	3.8	1200.0
2/14 15:12	94513.0	44.02	3.8	1200.2
2/14 15:13	94847.0	44.28	3.7	1200.0
2/14 15:14	93946.0	43.83	3.7	1200.0
2/14 15:15	94427.0	44.03	3.7	1200.0
2/14 15:16	93280.0	43.52	3.7	1200.2
2/14 15:17	94719.0	44.19	3.7	1200.0
2/14 15:18	94038.0	43.87	3.7	1199.8
2/14 15:19	94189.0	43.91	3.7	1200.2
2/14 15:20	94334.0	44.00	3.7	1200.0
2/14 15:21	95004.0	44.30	3.7	1200.0
2/14 15:22	94763.0	44.12	3.7	1200.2
2/14 15:23	95189.0	44.34	3.7	1200.5
2/14 15:24	94765.0	44.19	3.7	1199.8
2/14 15:25	94963.0	44.15	3.7	1199.8
2/14 15:26	92939.0	43.29	3.7	1199.7
2/14 15:27	94868.0	44.15	3.8	1199.8
2/14 15:28	95707.0	44.54	3.7	1200.0
2/14 15:29	94918.0	44.16	3.7	1200.0
2/14 15:30	94766.0	44.12	3.7	1200.3
2/14 15:31	94525.0	44.07	3.7	1200.0
2/14 15:32	93415.0	43.60	3.7	1200.0
2/14 15:33	94116.0	43.91	3.7	1199.8
2/14 15:34	93836.0	43.73	3.7	1199.8
2/14 15:35	93619.0	43.67	3.7	1200.0
2/14 15:36	95041.0	44.25	3.7	1199.8
2/14 15:37	95118.0	44.27	3.7	1200.0
2/14 15:38	95111.0	44.28	3.7	1200.0
2/14 15:39	93766.0	43.72	3.7	1200.0
2/14 15:40	94273.0	43.98	3.7	1200.0
2/14 15:41	94441.0	44.08	3.7	1200.0
2/14 15:42	956973.0	44.79	3.7	1200.2
2/14 15:43	95913.0	44.71	3.7	1200.0

	(TG-751) Landfill Gas Flow scfhhr	(TG-751) Heat Input mmBtu/hr	(TG-751) Heat Input 1-Min	(TG-751) Megawats 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min					
2/14 15:44	9362.0	43.62	3.7	1199.8		
2/14 15:45	94975.0	44.20	3.7	1199.8		
2/14 15:46	94404.0	44.02	3.7	1200.0		
2/14 15:47	94112.0	43.86	3.7	1199.7		
2/14 15:48	94904.0	44.22	3.7	1200.0		
2/14 15:49	93454.0	43.51	3.7	1200.2		
2/14 15:50	94656.0	44.16	3.7	1200.0		
2/14 15:51	94663.0	44.09	3.7	1200.0		
2/14 15:52	94447.0	44.06	3.7	1200.0		
2/14 15:53	94860.0	44.16	3.7	1200.0		
2/14 15:54	94605.0	44.11	3.7	1200.2		
2/14 15:55	95181.0	44.33	3.7	1199.7		
2/14 15:56	94955.0	44.19	3.7	1200.0		
2/14 15:57	94413.0	43.94	3.7	1200.2		
2/14 15:58	94539.0	44.00	3.7	1200.0		
2/14 15:59	95651.0	44.52	3.7	1200.0		
2/14 16:00	94264.0	43.93	3.7	1199.8		
2/14 16:01	94584.0	44.10	3.7	1199.7		
2/14 16:02	94372.0	43.96	3.7	1199.8		
2/14 16:03	94427.0	43.95	3.7	1200.0		
2/14 16:04	95090.0	44.29	3.7	1200.0		
2/14 16:05	94410.0	44.02	3.7	1199.8		
2/14 16:06	94563.0	44.09	3.7	1200.3		
2/14 16:07	94203.0	43.97	3.7	1200.3		
2/14 16:08	94712.0	44.20	3.7	1200.0		
2/14 16:09	94168.0	43.99	3.7	1200.2		
2/14 16:10	93420.0	43.64	3.7	1199.7		
2/14 16:11	94839.0	44.27	3.7	1199.8		
2/14 16:12	95142.0	44.38	3.7	1199.8		
2/14 16:13	95480.0	44.47	3.7	1199.8		
2/14 16:14	93969.0	43.79	3.7	1200.0		
2/14 16:15	94737.0	44.09	3.7	1200.5		
2/14 16:16	94467.0	44.07	3.7	1200.3		
2/14 16:17	93317.0	43.55	3.7	1200.0		
2/14 16:18	94557.0	44.11	3.7	1200.0		
2/14 16:19	93197.0	43.53	3.7	1200.3		
2/14 16:20	94612.0	44.14	3.7	1200.0		
2/14 16:21	95649.0	44.62	3.7	1199.8		
2/14 16:22	94551.0	44.08	3.7	1200.2		
2/14 16:23	94670.0	44.06	3.7	1199.8		
2/14 16:24	94406.0	44.10	3.7	1200.3		
2/14 16:25	94336.0	44.03	3.7	1200.2		
2/14 16:26	94289.0	44.06	3.7	1200.2		
2/14 16:27	93735.0	43.83	3.7	1200.0		
2/14 16:28	94670.0	44.24	3.7	1200.2		
2/14 16:29	94435.0	44.08	3.7	1200.2		
2/14 16:30	95143.0	44.40	3.7	1200.0		
2/14 16:31	94281.0	43.98	3.7	1200.2		
2/14 16:32	95571.0	44.58	3.7	1200.0		
Average Run 2	94007.0	44.0	3.7	1200.0		

Timestamp	(TG-751) Landfill Gas Flow scfhhr		(TG-751) Heat Input mmBtu/hr		(TG-751) Megawatts 1-Min		(TG-751) T7 °F 1-Min	
	1-Min	1-Min	1-Min	1-Min	Megawatts 1-Min			
2/14 16:33	93480.0		43.66		3.7		1200.2	
2/14 16:34	94410.0		44.13		3.7		1200.0	
2/14 16:35	94617.0		44.24		3.7		1200.0	
2/14 16:36	94515.0		44.20		3.7		1200.0	
2/14 16:37	94517.0		44.17		3.7		1200.0	
2/14 16:38	93946.0		43.90		3.7		1199.8	
2/14 16:39	94714.0		44.21		3.7		1199.8	
2/14 16:40	94223.0		43.97		3.7		1200.0	
2/14 16:41	94867.0		44.34		3.7		1200.0	
2/14 16:42	93658.0		43.69		3.7		1200.0	
2/14 16:43	94021.0		43.94		3.7		1199.8	
2/14 16:44	94457.0		44.17		3.7		1200.2	
2/14 16:45	94161.0		44.03		3.7		1199.7	
2/14 16:46	95255.0		44.52		3.7		1200.0	
2/14 16:47	93050.0		43.51		3.7		1200.0	
2/14 16:48	95779.0		44.74		3.7		1200.0	
2/14 16:49	95659.0		44.73		3.7		1200.0	
2/14 16:50	94543.0		44.16		3.7		1200.0	
2/14 16:51	95732.0		44.66		3.8		1200.0	
2/14 16:52	95003.0		44.32		3.8		1200.0	
2/14 16:53	94725.0		44.27		3.7		1200.0	
2/14 16:54	94704.0		44.18		3.7		1200.2	
2/14 16:55	95689.0		44.63		3.7		1200.0	
2/14 16:56	95515.0		44.65		3.8		1199.8	
2/14 16:57	94779.0		44.30		3.8		1200.2	
2/14 16:58	94836.0		44.35		3.8		1200.0	
2/14 16:59	94831.0		44.34		3.8		1200.0	
2/14 17:00	95116.0		44.48		3.8		1199.8	
2/14 17:01	94688.0		44.28		3.8		1200.2	
2/14 17:02	95449.0		44.63		3.8		1200.0	
2/14 17:03	94066.0		43.99		3.8		1199.7	
2/14 17:04	94968.0		44.39		3.8		1199.8	
2/14 17:05	95620.0		44.71		3.8		1200.0	
2/14 17:06	94835.0		44.35		3.8		1200.2	
2/14 17:07	95055.0		44.45		3.8		1199.8	
2/14 17:08	95793.0		44.77		3.8		1199.5	
2/14 17:09	94555.0		44.14		3.8		1200.0	
2/14 17:10	94531.0		44.15		3.8		1200.0	
2/14 17:11	95202.0		44.49		3.8		1199.8	
2/14 17:12	96168.0		44.94		3.8		1200.0	
2/14 17:13	95312.0		44.52		3.8		1200.0	
2/14 17:14	95643.0		44.72		3.8		1199.8	
2/14 17:15	95617.0		44.71		3.8		1199.8	
2/14 17:16	95617.0		44.71		3.8		1200.2	
2/14 17:17	95529.0		44.58		3.8		1200.0	
2/14 17:18	95254.0		44.54		3.8		1200.0	
2/14 17:19	95123.0		44.51		3.8		1200.2	
2/14 17:20	95176.0		44.53		3.8		1199.5	
2/14 17:21	95566.0		44.76		3.8		1200.0	

Timestamp	(TG-751) Landfill Gas Flow scfhhr	(TG-751) Heat Input mmBtu/hr	(TG-751) T °F 1-Min	(TG-751) T °F 1-Min	(TG-751) T °F 1-Min
2/14/17:22	95761.0	44.81	3.8	1200.2	
2/14/17:23	95931.0	44.86	3.8	1200.0	
2/14/17:24	94933.0	44.39	3.8	1199.8	
2/14/17:25	95142.0	44.49	3.8	1200.0	
2/14/17:26	94812.0	44.35	3.8	1200.0	
2/14/17:27	93958.0	43.94	3.8	1199.8	
2/14/17:28	95102.0	44.47	3.8	1200.0	
2/14/17:29	95405.0	44.72	3.8	1200.0	
2/14/17:30	94406.0	44.25	3.8	1199.7	
2/14/17:31	95324.0	44.60	3.8	1200.2	
2/14/17:32	95409.0	44.72	3.8	1200.0	
2/14/17:33	95463.0	44.64	3.8	1199.8	
2/14/17:34	95292.0	44.56	3.8	1199.8	
2/14/17:35	96646.0	45.19	3.8	1200.2	
2/14/17:36	95938.0	44.86	3.8	1200.0	
2/14/17:37	95725.0	44.74	3.8	1200.2	
2/14/17:38	95851.0	44.82	3.8	1199.8	
2/14/17:39	96072.0	44.92	3.8	1200.0	
2/14/17:40	95112.0	44.47	3.8	1200.0	
2/14/17:41	95306.0	44.52	3.8	1200.0	
2/14/17:42	95867.0	44.81	3.8	1200.0	
2/14/17:43	95541.0	44.66	3.8	1199.8	
2/14/17:44	95751.0	44.69	3.8	1200.0	
2/14/17:45	95474.0	44.59	3.8	1200.0	
2/14/17:46	96135.0	44.85	3.8	1200.0	
2/14/17:47	96030.0	44.88	3.8	1200.0	
2/14/17:48	96091.0	44.93	3.8	1200.0	
2/14/17:49	96445.0	45.10	3.8	1200.0	
2/14/17:50	95616.0	44.68	3.8	1200.0	
2/14/17:51	95610.0	44.63	3.8	1200.0	
2/14/17:52	96304.0	44.94	3.8	1200.3	
2/14/17:53	96108.0	44.92	3.8	1200.0	
2/14/17:54	95781.0	44.79	3.8	1200.0	
2/14/17:55	95585.0	44.60	3.8	1199.8	
2/14/18:00	95556.0	44.59	3.8	1200.0	
2/14/18:01	95311.0	44.65	3.8	1200.5	
2/14/18:02	95639.0	44.87	3.8	1199.8	
2/14/18:03	96092.0	44.93	3.8	1200.3	
2/14/18:04	96002.0	45.00	3.8	1200.0	
2/14/18:05	95763.0	44.90	3.8	1200.0	
2/14/18:06	96039.0	44.83	3.8	1200.5	
2/14/18:07	95891.0	44.87	3.8	1200.0	
2/14/18:08	95204.0	44.52	3.8	1200.3	
2/14/18:09	96383.0	45.14	3.8	1200.0	
2/14/18:10	96822.0	45.36	3.8	1200.0	
	96449.0	45.19	3.8	1200.0	

Ceder 5 Reports 3/6/2023 6:45 AM, CeDAR 1-Minute Data

Page 15 of 17

Timestamp	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 °F 1-Min	(TG-751) T8 °F 1-Min
2/14 18:11	96108.0	45.05	3.8	1200.0	
2/14 18:12	94972.0	44.51	3.8	1200.0	
2/14 18:13	94719.0	44.47	3.8	1199.8	
2/14 18:14	95757.0	44.99	3.8	1200.3	
2/14 18:15	95875.0	45.04	3.8	1200.0	
2/14 18:16	95710.0	44.96	3.8	1200.0	
2/14 18:17	95852.0	45.03	3.8	1199.8	
2/14 18:18	95835.0	44.90	3.8	1200.0	
2/14 18:19	95356.0	45.14	3.8	1200.0	
2/14 18:20	95912.0	44.95	3.8	1200.0	
2/14 18:21	97230.0	45.57	3.8	1199.8	
2/14 18:22	95987.0	44.88	3.8	1200.0	
2/14 18:23	95544.0	44.68	3.8	1200.0	
2/14 18:24	96279.0	45.11	3.8	1200.0	
2/14 18:25	96905.0	45.40	3.8	1200.0	
2/14 18:26	97117.0	45.52	3.8	1200.0	
2/14 18:27	95617.0	44.82	3.8	1200.0	
2/14 18:28	95126.0	44.66	3.8	1199.8	
2/14 18:29	96258.0	45.14	3.8	1199.8	
2/14 18:30	96473.0	45.22	3.8	1200.0	
2/14 18:31	96818.0	45.38	3.8	1200.2	
2/14 18:32	95904.0	44.95	3.8	1200.0	
2/14 18:33	97040.0	45.43	3.8	1199.8	
2/14 18:34	96509.0	45.13	3.8	1200.0	
2/14 18:35	95678.0	44.74	3.8	1199.8	
2/14 18:36	96268.0	45.00	3.8	1200.0	
2/14 18:37	96104.0	44.94	3.8	1200.0	
2/14 18:38	96393.0	45.07	3.8	1200.0	
2/14 18:39	96408.0	45.06	3.8	1200.0	
2/14 18:40	97017.0	45.34	3.8	1200.0	
2/14 18:41	97434.0	45.54	3.8	1199.8	
2/14 18:42	96422.0	45.04	3.8	1200.0	
2/14 18:43	96099.0	44.94	3.8	1200.0	
2/14 18:44	96686.0	45.21	3.8	1200.0	
2/14 18:45	97160.0	45.43	3.8	1200.0	
2/14 18:46	96106.0	44.94	3.8	1200.0	
2/14 18:47	96174.0	44.97	3.8	1199.8	
2/14 18:48	96329.0	45.04	3.8	1199.8	
2/14 18:49	97319.0	45.43	3.8	1200.0	
2/14 18:50	96597.0	45.33	3.8	1199.7	
2/14 18:51	97553.0	45.55	3.8	1200.0	
2/14 18:52	97158.0	45.33	3.8	1200.0	
2/14 18:53	97677.0	45.63	3.8	1200.0	
2/14 18:54	96516.0	45.11	3.8	1200.2	
2/14 18:55	97143.0	45.40	3.8	1200.0	
2/14 18:56	97221.0	45.38	3.8	1200.0	
2/14 18:57	97387.0	45.54	3.8	1199.8	
2/14 18:58	96842.0	45.18	3.8	1200.2	
2/14 18:59	97100.0	45.27	3.8	1200.0	

Cedar 5 Reports 3/07/2023 6:45 AM, CeDAR 1-Minute Data

Page 16 of 17

	(TG-751) Landfill Gas Flow scf/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751), T7 Exhaust Temp °F 1-Min
Timestamp				
2/14 19:00	96643.0	46.06	3.8	1200.2
Average (all)	94931.2	44.35	3.8	1200.0
Total (all)	--	--	--	--
Minimum (all)	92070.0	43.29	3.7	1196.2
Maximum (all)	101180.0	45.63	3.8	1205.5
Average (valid values only)	94931.2	44.35	3.8	1200.0
Total (valid values only)	--	--	--	--
Count (valid values only)	781	781	781	781

CeDAR 1-Minute Data
Sunshine Gas Producers, LLC
Data for 2/15/2023 6:00 AM thru 2/15/2023 7:00 PM

Timestamp	Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts	(TG-751) T7 °F 1-Min
2/15 6:00	101878.0	46.51	3.9	1199.7
2/15 6:01	102286.0	46.59	3.9	1200.0
2/15 6:02	100971.0	46.00	3.9	1199.7
2/15 6:03	101516.0	46.20	3.9	1200.3
2/15 6:04	101673.0	46.30	3.9	1199.8
2/15 6:05	100583.0	45.82	3.9	1200.0
2/15 6:06	100880.0	45.99	3.9	1200.0
2/15 6:07	100934.0	46.00	3.9	1199.8
2/15 6:08	101609.0	46.41	3.9	1199.5
2/15 6:09	101267.0	46.16	3.9	1200.0
2/15 6:10	101811.0	46.38	3.9	1200.0
2/15 6:11	100897.0	45.95	3.9	1199.8
2/15 6:12	101849.0	46.35	3.9	1200.0
2/15 6:13	101288.0	46.10	3.9	1200.0
2/15 6:14	102153.0	46.45	3.9	1200.0
2/15 6:15	100722.0	45.78	3.9	1200.0
2/15 6:16	100732.0	45.84	3.9	1200.2
2/15 6:17	100874.0	45.94	3.9	1199.8
2/15 6:18	101319.0	46.16	3.9	1200.0
2/15 6:19	101248.0	46.13	3.9	1199.8
2/15 6:20	102404.0	46.68	3.9	1199.8
2/15 6:21	104121.0	46.23	3.9	1200.0
2/15 6:22	101323.0	46.13	3.9	1199.7
2/15 6:23	102109.0	46.43	3.9	1199.7
2/15 6:24	100704.0	45.75	3.9	1200.0
2/15 6:25	100691.0	45.85	3.9	1200.0
2/15 6:26	101390.0	46.19	3.9	1200.0
2/15 6:27	101199.0	46.11	3.9	1199.8
2/15 6:28	101048.0	45.95	3.9	1200.0
2/15 6:29	1022541.0	46.70	3.9	1200.0
2/15 6:30	101589.0	46.23	3.9	1200.0
2/15 6:31	100545.0	45.81	3.9	1200.0
2/15 6:32	101863.0	46.41	3.9	1200.0
2/15 6:33	100356.0	45.72	3.9	1199.8
2/15 6:34	101195.0	46.27	3.9	1200.2
2/15 6:35	101171.0	46.09	3.9	1199.8
2/15 6:36	101981.0	46.46	3.9	1200.0
2/15 6:37	101630.0	46.32	3.9	1200.0
2/15 6:38	100354.0	45.72	3.9	1199.8
2/15 6:39	101195.0	46.11	3.9	1200.0
2/15 6:40	100526.0	45.80	3.9	1200.0
2/15 6:41	101646.0	46.31	3.9	1200.0
2/15 6:42	100999.0	45.94	3.9	1200.0
2/15 6:43	101420.0	46.10	3.9	1200.0
2/15 6:44	101540.0	46.15	3.9	1199.8

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/15 6:45	10265.0	46.44	3.9	1200.0	
2/15 6:46	101063.0	46.01	3.9	1200.0	
2/15 6:47	101039.0	45.92	3.9	1200.0	
2/15 6:48	101202.0	46.04	3.9	1199.8	
2/15 6:49	99899.0	45.51	3.9	1200.0	
2/15 6:50	100908.0	45.95	3.9	1199.8	
2/15 6:51	101948.0	46.32	3.9	1200.2	
2/15 6:52	101385.0	46.14	3.9	1200.0	
2/15 6:53	102028.0	46.37	3.9	1200.0	
2/15 6:54	101568.0	46.14	3.9	1199.8	
2/15 6:55	101420.0	46.10	3.9	1200.7	
2/15 6:56	101514.0	46.16	3.9	1200.0	
2/15 6:57	101095.0	46.04	3.9	1200.5	
2/15 6:58	100587.0	45.83	3.9	1199.8	
2/15 6:59	100895.0	45.97	3.9	1199.7	
2/15 7:00	102128.0	46.44	3.9	1199.8	
2/15 7:01	101198.0	45.98	3.9	1200.0	
2/15 7:02	99677.0	45.30	3.9	1200.5	
2/15 7:03	100130.0	45.62	3.9	1199.8	
2/15 7:04	100326.0	45.71	3.9	1200.0	
2/15 7:05	99840.0	45.40	3.9	1199.8	
2/15 7:06	101194.0	45.97	3.9	1200.0	
2/15 7:07	100302.0	45.59	3.9	1200.0	
2/15 7:08	100150.0	45.61	3.9	1200.5	
2/15 7:09	101449.0	46.25	3.9	1200.7	
2/15 7:10	101205.0	46.33	3.9	1200.2	
2/15 7:11	99843.0	45.71	3.9	1200.2	
2/15 7:12	100291.0	45.83	3.9	1199.2	
2/15 7:13	99819.0	45.37	3.9	1199.2	
2/15 7:14	101356.0	45.94	3.9	1200.2	
2/15 7:15	100884.0	45.77	3.9	1200.3	
2/15 7:16	100193.0	45.58	3.9	1200.0	
2/15 7:17	100680.0	45.85	3.9	1200.0	
2/15 7:18	101051.0	46.07	3.9	1200.2	
2/15 7:19	101335.0	46.28	3.9	1200.2	
2/15 7:20	101016.0	46.16	3.9	1200.0	
2/15 7:21	101197.0	46.60	3.9	1200.2	
2/15 7:22	99802.0	45.69	3.9	1200.2	
2/15 7:23	99238.0	45.43	3.9	1199.8	
2/15 7:24	100523.0	46.02	3.9	1199.8	
2/15 7:25	99212.0	45.37	3.9	1199.5	
2/15 7:26	100638.0	45.96	3.9	1200.0	
2/15 7:27	99993.0	45.64	3.9	1199.7	
2/15 7:28	101597.0	46.29	3.9	1200.2	
2/15 7:29	102027.0	46.57	3.9	1200.0	
2/15 7:30	100264.0	45.68	3.9	1200.2	
2/15 7:31	101714.0	46.29	3.9	1200.0	
2/15 7:32	99711.0	45.36	3.9	1200.0	
2/15 7:33	101046.0	45.97	3.9	1199.7	

	(TG-751) Landfill Gas Flow ccf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts	(TG-751) T °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/15/7:34	100242.0	45.60	3.9	1200.0
2/15/7:35	98943.0	45.46	3.9	1200.2
2/15/7:36	100431.0	45.76	3.9	1200.2
2/15/7:37	100919.0	45.98	3.9	1200.0
2/15/7:38	101390.0	46.19	3.8	1199.8
2/15/7:38	101014.0	46.00	3.9	1199.5
2/15/7:40	100931.0	45.93	3.9	1200.7
2/15/7:41	100137.0	45.59	3.8	1200.2
2/15/7:42	101061.0	46.04	3.9	1200.0
2/15/7:43	101168.0	46.07	3.8	1199.8
2/15/7:44	100863.0	45.85	3.8	1200.0
2/15/7:45	100101.0	45.67	3.8	1200.0
2/15/7:46	100425.0	45.87	3.8	1200.0
2/15/7:47	100572.0	45.84	3.8	1199.8
2/15/7:48	100708.0	45.81	3.8	1199.8
2/15/7:49	100134.0	45.53	3.8	1200.2
2/15/7:50	102146.0	46.49	3.8	1200.0
2/15/7:51	99648.0	45.33	3.8	1200.0
2/15/7:52	98634.0	45.28	3.8	1199.2
2/15/7:53	102402.0	46.10	3.8	1199.8
2/15/7:54	102143.0	45.76	3.8	1200.5
2/15/7:55	101177.0	45.33	3.8	1199.8
2/15/7:56	101331.0	45.45	3.8	1200.3
2/15/7:57	101757.0	45.88	3.9	1200.2
2/15/7:58	100864.0	45.68	3.9	1199.8
2/15/7:59	102159.0	46.24	3.9	1199.3
2/15/8:00	101446.0	45.75	3.9	1199.3
2/15/8:01	102166.0	45.77	3.9	1200.2
2/15/8:02	101821.0	45.73	3.9	1200.2
2/15/8:03	102430.0	46.28	3.9	1200.3
2/15/8:04	100818.0	45.74	3.9	1199.8
2/15/8:05	101152.0	45.85	3.9	1200.7
2/15/8:06	102231.0	46.35	3.9	1200.2
2/15/8:07	101496.0	45.95	3.9	1200.0
2/15/8:08	100734.0	45.67	3.9	1200.5
2/15/8:09	100220.0	45.44	3.8	1199.8
2/15/8:10	100989.0	45.69	3.8	1200.2
2/15/8:11	101055.0	45.75	3.8	1200.0
2/15/8:12	101046.0	45.79	3.8	1200.0
2/15/8:13	99607.0	45.16	3.8	1200.0
2/15/8:14	100069.0	45.37	3.8	1200.2
2/15/8:15	100492.0	45.55	3.8	1200.0
2/15/8:16	100106.0	45.39	3.8	1200.2
2/15/8:17	100530.0	45.58	3.8	1199.8
2/15/8:18	101032.0	45.81	3.8	1200.0
2/15/8:19	99733.0	45.28	3.8	1200.0
2/15/8:20	100354.0	45.53	3.8	1200.0
2/15/8:21	101102.0	45.84	3.8	1199.8
2/15/8:22	101243.0	45.74	3.8	1199.8

Cedar 5 Reports 3/8/2023 6:45 AM, CeDAR 1-Minute Data

Page 3 of 17

	(TG-751) Landfill Gas Flow scfh/r	(TG-751) Heat Input mmBtu/hr	(TG-751) Heat 1-Min	(TG-751) Megawatts	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min				
2/15 8:23	101420.0	45.84	3.8	1200.2	
2/15 8:24	100299.0	45.38	3.8	1200.0	
2/15 8:25	100938.0	45.67	3.8	1200.0	
2/15 8:26	102095.0	46.22	3.9	1200.2	
2/15 8:27	101609.0	46.00	3.9	1199.8	
2/15 8:28	101210.0	45.86	3.8	1199.8	
2/15 8:29	101681.0	46.10	3.9	1200.0	
2/15 8:30	100667.0	45.67	3.8	1200.0	
2/15 8:31	100020.0	45.35	3.9	1200.2	
2/15 8:32	99742.0	45.31	3.9	1200.2	
2/15 8:33	100290.0	45.43	3.9	1200.0	
2/15 8:34	101247.0	45.74	3.9	1199.0	
2/15 8:35	103527.0	46.15	3.9	1199.3	
2/15 8:36	106139.0	46.68	3.9	1198.7	
2/15 8:37	110352.0	46.88	3.9	1197.5	
2/15 8:38	112762.0	46.30	3.9	1201.2	
2/15 8:39	98034.0	40.95	3.5	1165.3	
2/15 8:40	94461.0	40.45	3.5	1190.3	
2/15 8:41	94303.0	40.76	3.5	1189.7	
2/15 8:42	96847.0	41.65	3.5	1190.7	
2/15 8:43	96458.0	41.28	3.5	1189.7	
2/15 8:44	95257.0	40.84	3.5	1189.8	
2/15 8:45	96351.0	41.38	3.5	1189.5	
2/15 8:46	95296.0	40.96	3.5	1190.3	
2/15 8:47	94789.0	40.86	3.5	1189.8	
2/15 8:48	97560.0	41.69	3.5	1189.7	
2/15 8:49	94328.0	40.34	3.5	1190.0	
2/15 8:50	91870.0	40.96	3.5	1190.0	
2/15 8:51	90393.0	41.15	3.5	1190.7	
2/15 8:52	95039.0	43.49	3.7	1193.7	
2/15 8:53	101169.0	46.15	3.9	1197.2	
2/15 8:54	101149.0	46.01	3.9	1200.5	
2/15 8:55	100737.0	45.85	3.9	1200.5	
2/15 8:56	100401.0	45.80	3.8	1200.5	
2/15 8:57	100599.0	45.91	3.8	1200.3	
2/15 8:58	100203.0	45.73	3.8	1199.8	
2/15 8:59	99511.0	45.31	3.8	1200.0	
2/15 9:00	100472.0	45.66	3.8	1200.2	
2/15 9:01	101214.0	46.06	3.8	1200.0	
2/15 9:02	100743.0	45.93	3.8	1200.3	
2/15 9:03	99749.0	45.48	3.8	1199.8	
2/15 9:04	100005.0	45.62	3.8	1200.0	
2/15 9:05	99553.0	45.34	3.8	1199.7	
2/15 9:06	100628.0	45.85	3.8	1200.0	
2/15 9:07	100023.0	45.63	3.8	1200.3	
2/15 9:08	100867.0	46.07	3.8	1199.8	
2/15 9:09	99213.0	45.31	3.8	1200.0	
2/15 9:10	101665.0	46.34	3.8	1199.8	
2/15 9:11	99384.0	45.30	3.8	1200.0	

Cedar 5 Reports 3/8/2023 6:45 AM, CeDAR 1-Minute Data

Page 4 of 17

	(TG-751) Landfill Gas Flow scf/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts -Min	(TG-751) T7 Exhaust Temp °F 1-Min
2/15 9:12	99428.0	45.30	3.8	1200.2
2/15 9:13	101295.0	46.17	3.8	1200.0
2/15 9:14	100556.0	45.82	3.8	1200.0
2/15 9:15	99524.0	45.45	3.8	1200.0
2/15 9:16	98646.0	45.05	3.8	1200.2
2/15 9:17	99806.0	45.58	3.8	1200.0
2/15 9:18	99150.0	45.28	3.8	1200.0
2/15 9:19	99301.0	45.37	3.8	1200.3
2/15 9:20	98896.0	45.28	3.8	1200.0
2/15 9:21	101133.0	46.33	3.8	1199.7
2/15 9:22	99466.0	45.54	3.8	1200.0
2/15 9:23	100740.0	46.12	3.8	1200.0
2/15 9:24	99524.0	45.53	3.8	1200.0
2/15 9:25	100809.0	46.13	3.8	1200.0
2/15 9:26	99528.0	45.54	3.8	1200.5
2/15 9:27	99846.0	45.27	3.8	1200.0
2/15 9:28	100014.0	45.78	3.8	1200.0
2/15 9:29	99681.0	45.65	3.8	1200.2
2/15 9:30	99329.0	45.58	3.8	1199.8
2/15 9:31	98855.0	45.39	3.8	1201.0
2/15 9:32	99379.0	46.06	3.8	1200.5
2/15 9:33	99112.0	45.83	3.8	1199.5
2/15 9:34	99114.0	45.64	3.8	1199.8
2/15 9:35	98450.0	45.40	3.8	1199.7
2/15 9:36	98833.0	45.35	3.8	1199.8
2/15 9:37	99450.0	45.53	3.8	1200.0
2/15 9:38	98657.0	45.15	3.8	1199.5
2/15 9:39	99232.0	45.27	3.8	1199.8
2/15 9:40	99062.0	45.15	3.8	1200.0
2/15 9:41	99803.0	45.47	3.8	1200.2
2/15 9:42	99299.0	45.23	3.8	1199.8
2/15 9:43	99940.0	45.53	3.8	1200.2
2/15 9:44	99755.0	45.58	3.8	1200.3
2/15 9:45	99921.0	45.16	3.8	1199.3
2/15 9:46	99238.0	45.04	3.8	1199.7
2/15 9:47	100292.0	45.30	3.8	1200.0
2/15 9:52	100305.0	45.57	3.8	1200.2
2/15 9:53	99722.0	45.32	3.8	1199.8
2/15 9:54	99878.0	45.49	3.8	1200.0
2/15 9:55	99506.0	45.37	3.8	1200.5
2/15 9:56	98740.0	45.01	3.8	1199.7
2/15 9:57	99839.0	45.51	3.8	1200.0
2/15 9:58	99413.0	45.32	3.8	1200.0
2/15 9:59	99077.0	45.14	3.8	1200.2
2/15 10:00	98926.0	45.13	3.8	1200.0

Cedar 5 Reports 3/8/2023 6:45 AM. CEDAR 1-Minute Data

Page 5 of 17

	(TG-751) Landfill Gas Flow scf/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp				
2/15 10:01	100041.0	45.64	3.8	1200.0
2/15 10:02	99174.0	45.18	3.8	1199.5
2/15 10:03	100368.0	45.55	3.8	1199.5
2/15 10:04	100191.0	45.33	3.8	1200.0
2/15 10:05	100095.0	45.39	3.8	1200.7
2/15 10:06	98565.0	45.04	3.8	1201.0
2/15 10:07	98232.0	45.10	3.8	1199.7
2/15 10:08	98096.0	44.88	3.8	1199.5
2/15 10:09	98723.0	45.11	3.8	1200.0
2/15 10:10	98684.0	44.91	3.8	1200.0
2/15 10:11	98426.0	45.25	3.8	1199.8
2/15 10:12	100042.0	45.39	3.8	1200.2
2/15 10:13	98961.0	44.98	3.8	1200.0
2/15 10:14	98275.0	45.12	3.8	1200.2
2/15 10:15	98654.0	45.27	3.8	1200.2
2/15 10:16	98505.0	45.12	3.8	1199.7
2/15 10:17	100211.0	45.25	3.8	1199.2
2/15 10:18	100548.0	45.18	3.8	1199.5
2/15 10:19	100815.0	45.35	3.8	1200.2
2/15 10:20	100229.0	45.17	3.8	1200.3
2/15 10:21	98919.0	44.64	3.8	1199.7
2/15 10:22	100243.0	45.16	3.8	1199.5
2/15 10:23	99919.0	44.89	3.8	1199.5
2/15 10:24	100116.0	44.99	3.8	1200.2
2/15 10:25	99934.0	45.12	3.8	1200.7
2/15 10:26	98259.0	45.03	3.8	1199.7
2/15 10:27	97985.0	44.41	3.8	1200.0
2/15 10:28	98358.0	44.60	3.8	1199.7
2/15 10:29	98007.0	44.86	3.8	1200.0
2/15 10:30	100619.0	45.52	3.8	1199.8
2/15 10:31	98999.0	44.79	3.8	1200.7
2/15 10:32	97608.0	44.30	3.8	1200.3
2/15 10:33	98463.0	44.73	3.8	1200.2
2/15 10:34	98063.0	45.06	3.8	1199.8
2/15 10:35	98434.0	44.67	3.8	1199.3
2/15 10:36	98718.0	45.08	3.8	1199.7
2/15 10:37	98531.0	44.57	3.8	1200.0
2/15 10:38	98653.0	45.24	3.8	1200.5
2/15 10:39	98552.0	45.33	3.8	1200.2
2/15 10:40	97850.0	44.66	3.8	1200.3
2/15 10:41	97804.0	44.67	3.8	1199.3
2/15 10:42	98099.0	44.69	3.8	1199.7
2/15 10:43	97973.0	44.45	3.8	1199.7
2/15 10:44	98339.0	44.68	3.8	1200.7
2/15 10:45	98832.0	45.12	3.8	1200.3
2/15 10:46	97911.0	44.82	3.8	1200.0
2/15 10:47	98047.0	44.81	3.8	1199.2
2/15 10:48	98742.0	44.88	3.8	1199.7
2/15 10:49	98910.0	45.30	3.8	1199.8

Cedar 5 Reports 3/8/2023 6:45 AM, CGDAR 1-Minute Data

Page 6 of 17

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/15 10:50	98709.0	45.28	3.8	1200.5
2/15 10:51	98730.0	44.93	3.8	1200.3
2/15 10:52	98339.0	44.83	3.8	1200.0
2/15 10:53	98493.0	44.98	3.8	1199.7
2/15 10:54	98937.0	45.19	3.8	1199.8
2/15 10:55	98365.0	44.84	3.8	1199.7
2/15 10:56	98312.0	45.20	3.8	1200.0
2/15 10:57	98039.0	44.56	3.8	1199.8
2/15 10:58	98437.0	44.74	3.8	1200.3
2/15 10:59	98442.0	44.75	3.8	1200.0
2/15 11:00	97929.0	44.53	3.8	1199.7
2/15 11:01	98754.0	44.90	3.8	1200.0
2/15 11:02	98046.0	44.67	3.8	1200.0
2/15 11:03	97248.0	44.31	3.8	1200.3
2/15 11:04	98749.0	45.02	3.8	1199.7
2/15 11:05	98066.0	45.09	3.8	1200.0
2/15 11:06	98458.0	44.86	3.8	1199.7
2/15 11:07	98618.0	44.86	3.8	1200.0
2/15 11:08	97552.0	44.41	3.8	1200.0
2/15 11:09	97667.0	44.45	3.8	1199.7
2/15 11:10	98409.0	44.87	3.8	1200.0
2/15 11:11	98100.0	45.23	3.8	1200.0
2/15 11:12	97704.0	44.53	3.8	1199.7
2/15 11:13	97847.0	44.61	3.8	1200.0
2/15 11:14	98236.0	44.87	3.8	1200.0
2/15 11:15	98837.0	45.06	3.8	1200.0
2/15 11:16	97492.0	44.52	3.8	1200.2
2/15 11:17	98344.0	44.86	3.8	1200.3
2/15 11:18	97838.0	44.68	3.8	1200.0
2/15 11:19	97742.0	44.72	3.8	1199.8
2/15 11:20	98127.0	44.92	3.8	1200.0
2/15 11:21	98986.0	44.44	3.8	1200.0
2/15 11:22	97353.0	44.59	3.8	1199.8
2/15 11:23	98415.0	44.98	3.8	1200.2
2/15 11:24	97943.0	44.75	3.8	1199.5
2/15 11:25	98685.0	45.05	3.8	1200.0
2/15 11:26	98258.0	44.88	3.8	1200.0
2/15 11:27	97675.0	44.72	3.8	1200.2
2/15 11:28	97978.0	44.84	3.8	1199.8
2/15 11:29	97953.0	44.83	3.8	1200.0
2/15 11:30	97527.0	44.65	3.8	1200.2
2/15 11:31	98043.0	44.88	3.8	1200.2
2/15 11:32	98600.0	45.14	3.8	1200.0
2/15 11:33	97647.0	44.70	3.8	1200.0
2/15 11:34	97987.0	44.86	3.8	1200.2
2/15 11:35	97743.0	44.75	3.8	1200.0
2/15 11:36	98061.0	44.89	3.8	1199.8
2/15 11:37	98770.0	45.22	3.8	1200.0
2/15 11:38	97937.0	44.89	3.8	1200.2

Timestamp	(TG-751) Landfill Gas Flow scfm/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-561) Megawatts 1-Min	(TG-561) T °F 1-Min	(TG-751) T °F 1-Min
2/15 11:39	96265.0	44.21	3.8	1200.5	
2/15 11:40	97872.0	44.93	3.8	1199.7	
2/15 11:41	97197.0	44.61	3.8	1200.0	
2/15 11:42	97735.0	44.77	3.8	1199.7	
2/15 11:43	98260.0	44.98	3.8	1200.0	
2/15 11:44	98177.0	45.00	3.8	1200.0	
2/15 11:45	98308.0	45.09	3.8	1200.0	
2/15 11:46	98304.0	45.11	3.8	1200.0	
2/15 11:47	97670.0	44.79	3.8	1200.2	
2/15 11:48	97838.0	44.79	3.8	1200.0	
2/15 11:49	96370.0	44.17	3.8	1200.2	
2/15 11:50	97989.0	44.89	3.8	1200.0	
2/15 11:51	96782.0	44.39	3.8	1200.5	
2/15 11:52	98280.0	45.07	3.8	1199.8	
2/15 11:53	98642.0	44.27	3.8	1200.0	
2/15 11:54	97272.0	44.64	3.8	1200.0	
2/15 11:55	98578.0	44.32	3.8	1200.2	
2/15 11:56	96682.0	44.40	3.8	1200.2	
2/15 11:57	98829.0	44.05	3.8	1200.0	
2/15 11:58	97852.0	44.98	3.8	1200.0	
2/15 11:59	97720.0	44.86	3.8	1199.8	
2/15 12:00	98357.0	45.17	3.8	1199.7	
2/15 12:01	97553.0	44.77	3.8	1200.0	
2/15 12:02	96880.0	44.54	3.8	1199.5	
2/15 12:03	98077.0	45.01	3.8	1200.2	
2/15 12:04	97030.0	44.58	3.8	1200.0	
2/15 12:05	96927.0	44.48	3.8	1200.0	
2/15 12:06	96884.0	44.56	3.8	1200.0	
2/15 12:07	97611.0	44.88	3.8	1199.8	
2/15 12:08	97619.0	44.88	3.8	1200.0	
2/15 12:09	97758.0	44.97	3.8	1200.2	
2/15 12:10	96820.0	44.57	3.8	1199.8	
2/15 12:11	96893.0	44.60	3.8	1200.2	
2/15 12:12	96894.0	44.62	3.8	1199.7	
2/15 12:13	98826.0	44.51	3.8	1200.2	
2/15 12:14	97875.0	45.04	3.8	1200.0	
2/15 12:15	98655.0	44.44	3.8	1200.0	
2/15 12:16	98665.0	44.56	3.8	1200.2	
2/15 12:17	96771.0	44.62	3.8	1200.0	
2/15 12:18	96978.0	44.66	3.8	1200.0	
2/15 12:19	96988.0	44.62	3.8	1200.0	
2/15 12:20	97582.0	44.52	3.8	1200.0	
2/15 12:21	97836.0	45.01	3.8	1200.0	
2/15 12:22	96800.0	44.55	3.8	1199.8	
2/15 12:23	98506.0	44.42	3.8	1200.2	
2/15 12:24	97582.0	44.99	3.8	1200.0	
2/15 12:25	97183.0	44.81	3.8	1200.0	
2/15 12:26	97146.0	44.78	3.8	1200.2	
2/15 12:27	96885.0	44.68	3.8	1200.0	
	99437.0	45.1	3.8	1199.4	

	(TG-751) Landfill Gas Flow scfhhr	(TG-751) Heat Input mmBtu/hr	(TG-751) Temp 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp					
2/15 12:28	97088.0	44.77	3.8	1200.5	
2/15 12:29	96654.0	44.52	3.8	1199.7	
2/15 12:30	97983.0	44.90	3.8	1200.0	
2/15 12:31	97665.0	44.95	3.8	1199.8	
2/15 12:32	96024.0	44.17	3.8	1200.0	
2/15 12:33	96658.0	44.46	3.8	1200.0	
2/15 12:34	96640.0	44.45	3.8	1200.2	
2/15 12:35	97874.0	44.88	3.8	1200.0	
2/15 12:36	96919.0	44.69	3.8	1200.0	
2/15 12:37	96763.0	44.54	3.8	1200.3	
2/15 12:38	98328.0	45.34	3.8	1199.8	
2/15 12:39	97095.0	44.75	3.8	1200.2	
2/15 12:40	96983.0	44.45	3.8	1200.0	
2/15 12:41	96960.0	44.71	3.8	1200.0	
2/15 12:42	96373.0	44.44	3.8	1200.0	
2/15 12:43	97072.0	44.76	3.8	1200.3	
2/15 12:44	96443.0	44.47	3.8	1200.2	
2/15 12:45	96854.0	44.68	3.8	1199.8	
2/15 12:46	96173.0	44.41	3.8	1200.2	
2/15 12:47	97317.0	44.90	3.8	1200.0	
2/15 12:48	96521.0	44.52	3.8	1200.3	
2/15 12:49	97161.0	44.80	3.8	1200.0	
2/15 12:50	96374.0	44.44	3.8	1200.0	
2/15 12:51	97212.0	44.82	3.8	1200.0	
2/15 12:52	96950.0	44.52	3.8	1200.0	
2/15 12:53	95649.0	44.13	3.8	1199.8	
2/15 12:54	96244.0	44.42	3.8	1199.7	
2/15 12:55	96827.0	44.65	3.8	1200.0	
2/15 12:56	97716.0	45.06	3.8	1200.0	
2/15 12:57	96566.0	44.53	3.8	1200.3	
2/15 12:58	95834.0	44.67	3.8	1200.2	
2/15 12:59	95992.0	44.34	3.8	1200.0	
2/15 13:00	95685.0	44.23	3.8	1200.0	
2/15 13:01	95609.0	44.19	3.8	1200.0	
2/15 13:02	96434.0	44.53	3.8	1199.7	
2/15 13:03	97401.0	44.96	3.8	1200.0	
2/15 13:04	96767.0	44.62	3.8	1199.8	
2/15 13:05	95889.0	44.21	3.8	1200.0	
2/15 13:06	96659.0	44.64	3.8	1199.7	
2/15 13:07	97485.0	44.72	3.8	1199.3	
2/15 13:08	98217.0	44.89	3.8	1200.2	
2/15 13:09	98580.0	45.11	3.8	1200.0	
2/15 13:10	98604.0	45.06	3.8	1199.8	
2/15 13:11	96769.0	44.19	3.8	1200.0	
2/15 13:12	97961.0	44.74	3.8	1199.7	
2/15 13:13	98453.0	44.96	3.8	1200.0	
2/15 13:14	98949.0	45.16	3.8	1200.2	
2/15 13:15	97654.0	44.66	3.8	1199.8	
2/15 13:16	97909.0	44.74	3.8	1199.8	

Cedar 5 Reports 3/6/2023 6:45 AM, CEDAR 1-Minute Data

Page 9 of 17

(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min
2/15 13:17	97558.0	44.66	3.8	1200.0
2/15 13:18	96952.0	44.35	3.8	1199.8
2/15 13:19	98154.0	44.88	3.8	1200.5
2/15 13:20	97540.0	44.62	3.8	1200.0
2/15 13:21	96427.0	44.23	3.8	1200.7
2/15 13:22	96245.0	44.30	3.8	1200.0
2/15 13:23	96533.0	44.59	3.8	1199.3
2/15 13:24	97252.0	44.87	3.8	1200.2
2/15 13:25	96285.0	44.50	3.8	1199.8
2/15 13:26	96496.0	44.60	3.8	1200.2
2/15 13:27	97189.0	44.92	3.8	1200.0
2/15 13:28	97514.0	45.10	3.8	1199.8
2/15 13:29	96708.0	44.72	3.8	1200.0
2/15 13:30	96705.0	44.70	3.8	1199.8
2/15 13:31	96802.0	44.74	3.8	1200.0
2/15 13:32	96340.0	44.50	3.8	1200.0
2/15 13:33	96741.0	44.71	3.8	1200.3
2/15 13:34	96716.0	44.70	3.8	1200.0
2/15 13:35	97550.0	45.09	3.8	1200.2
2/15 13:36	97051.0	44.86	3.8	1199.8
2/15 13:37	96866.0	44.85	3.8	1200.0
2/15 13:38	97355.0	45.05	3.8	1199.5
2/15 13:39	98009.0	45.26	3.8	1200.0
2/15 13:40	96929.0	44.80	3.8	1200.0
2/15 13:41	95169.0	43.99	3.8	1199.8
2/15 13:42	95941.0	44.34	3.8	1200.0
2/15 13:43	96583.0	44.64	3.8	1200.5
2/15 13:44	96205.0	44.50	3.8	1199.8
2/15 13:45	96559.0	44.59	3.8	1199.8
2/15 13:46	96978.0	44.82	3.8	1200.2
2/15 13:47	96958.0	44.81	3.8	1200.0
2/15 13:48	97354.0	44.97	3.8	1200.2
2/15 13:49	96721.0	44.70	3.8	1199.8
2/15 13:50	96630.0	44.66	3.8	1200.0
2/15 13:51	95592.0	44.18	3.8	1199.8
2/15 13:52	96787.0	44.67	3.8	1200.0
2/15 13:53	95454.0	44.06	3.8	1200.3
2/15 13:54	97398.0	44.98	3.8	1200.2
2/15 13:55	96541.0	44.30	3.8	1200.0
2/15 14:00	98852.0	45.20	3.8	1200.0
2/15 14:01	98030.0	44.97	3.8	1199.3
2/15 14:02	99092.0	45.36	3.8	1200.0
2/15 14:03	98010.0	44.82	3.8	1199.7
2/15 14:04	97562.0	44.58	3.8	1200.7
2/15 14:05	96959.0	44.48	3.8	1199.3

Cedar 5 Reports 3/8/2023 6:45 AM, CEDAR 1-Minute Data

Page 10 of 17

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) T °F	(TG-751) T °F	(TG-751) T °F
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	1-Min
2/15 14:06	98489.0	44.84	3.8	1200.5	
2/15 14:07	97466.0	44.53	3.8	1200.2	
2/15 14:08	97139.0	44.50	3.8	1200.2	
2/15 14:09	97046.0	44.54	3.8	1200.2	
2/15 14:10	98033.0	44.97	3.8	1199.8	
2/15 14:11	98520.0	44.97	3.8	1200.0	
2/15 14:12	99090.0	44.18	3.8	1199.7	
2/15 14:13	97922.0	44.83	3.8	1199.8	
2/15 14:14	97281.0	44.53	3.8	1200.2	
2/15 14:15	97560.0	44.74	3.8	1199.5	
2/15 14:16	98520.0	44.67	3.8	1199.7	
2/15 14:17	99090.0	45.04	3.8	1200.3	
2/15 14:18	98010.0	44.73	3.8	1200.7	
2/15 14:19	97693.0	44.70	3.8	1200.0	
2/15 14:20	97198.0	44.55	3.8	1200.0	
2/15 14:21	97873.0	44.89	3.8	1199.8	
2/15 14:22	96581.0	44.29	3.8	1200.5	
2/15 14:23	96854.0	44.55	3.8	1200.2	
2/15 14:24	97700.0	44.99	3.8	1200.7	
2/15 14:25	95254.0	43.95	3.8	1199.5	
2/15 14:26	96210.0	44.32	3.8	1200.0	
2/15 14:27	96074.0	44.22	3.8	1199.7	
2/15 14:28	97336.0	44.83	3.8	1200.3	
2/15 14:29	97290.0	44.86	3.8	1200.0	
2/15 14:30	96682.0	44.58	3.8	1200.0	
2/15 14:31	97062.0	44.73	3.8	1200.2	
2/15 14:32	96615.0	44.53	3.8	1200.2	
2/15 14:33	96915.0	44.69	3.8	1199.8	
2/15 14:34	97331.0	44.82	3.8	1200.0	
2/15 14:35	97136.0	44.73	3.8	1200.0	
2/15 14:36	96374.0	44.35	3.8	1200.3	
2/15 14:37	97330.0	44.88	3.8	1200.2	
2/15 14:38	97072.0	44.76	3.8	1200.0	
2/15 14:39	97274.0	44.93	3.8	1200.0	
2/15 14:40	97145.0	44.86	3.8	1200.0	
2/15 14:41	97525.0	45.05	3.8	1200.0	
2/15 14:42	96503.0	44.60	3.8	1200.0	
2/15 14:43	95842.0	44.22	3.8	1200.5	
2/15 14:44	96102.0	44.29	3.8	1199.0	
2/15 14:45	96887.0	45.32	3.8	1200.2	
2/15 14:46	97301.0	44.76	3.8	1200.5	
2/15 14:47	97973.0	45.17	3.8	1199.5	
2/15 14:48	97653.0	44.97	3.8	1200.5	
2/15 14:49	96887.0	44.69	3.8	1200.0	
2/15 14:50	96793.0	44.70	3.8	1200.5	
2/15 14:51	96433.0	44.64	3.8	1199.5	
2/15 14:52	96934.0	44.76	3.8	1200.2	
2/15 14:53	96941.0	44.73	3.8	1200.0	
2/15 14:54	96620.0	44.60	3.8	1200.0	

Timestamp	(TG-751) Landfill Gas Flow scfhhr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
2/15 14:55	96388.0	44.55	3.8	1200.0
2/15 14:56	97256.0	44.95	3.8	1200.0
2/15 14:57	97266.0	44.96	3.8	1200.0
2/15 14:58	96129.0	44.45	3.8	1200.0
2/15 14:59	96823.0	44.86	3.8	1200.0
2/15 15:00	97177.0	44.95	3.8	1200.0
2/15 15:01	97255.0	44.97	3.8	1200.0
2/15 15:02	96681.0	44.79	3.8	1200.0
2/15 15:03	94854.0	43.97	3.8	1200.0
2/15 15:04	96706.0	44.77	3.8	1199.8
2/15 15:05	95725.0	44.25	3.8	1200.0
2/15 15:06	96095.0	44.38	3.8	1199.8
2/15 15:07	97754.0	45.03	3.8	1199.5
2/15 15:08	98637.0	45.65	3.8	1200.0
2/15 15:09	97866.0	44.96	3.8	1199.8
2/15 15:10	98324.0	45.17	3.8	1199.5
2/15 15:11	98974.0	44.42	3.8	1200.0
2/15 15:12	98834.0	44.33	3.8	1200.0
2/15 15:13	97613.0	44.72	3.8	1200.0
2/15 15:14	98422.0	45.09	3.8	1200.2
2/15 15:15	97590.0	44.70	3.8	1199.8
2/15 15:16	97315.0	44.55	3.8	1199.3
2/15 15:17	98278.0	44.75	3.8	1199.8
2/15 15:18	100772.0	45.44	3.8	1198.5
2/15 15:19	99918.0	45.03	3.8	1201.3
2/15 15:20	99170.0	45.04	3.8	1200.5
2/15 15:21	96776.0	44.20	3.8	1201.3
2/15 15:22	96962.0	44.69	3.8	1200.3
2/15 15:23	98051.0	45.12	3.8	1197.5
2/15 15:24	99433.0	44.79	3.8	1200.7
2/15 15:25	98610.0	44.66	3.8	1201.2
2/15 15:26	98086.0	44.93	3.8	1201.3
2/15 15:27	97295.0	44.89	3.8	1200.7
2/15 15:28	96148.0	44.44	3.8	1198.7
2/15 15:29	98267.0	44.88	3.8	1199.7
2/15 15:30	97938.0	44.65	3.8	1200.5
2/15 15:31	97248.0	44.54	3.8	1200.7
2/15 15:32	97365.0	44.76	3.8	1200.0
2/15 15:33	97974.0	45.07	3.8	1199.8
2/15 15:34	98621.0	45.35	3.8	1199.7
2/15 15:35	98421.0	45.15	3.8	1199.8
2/15 15:36	98508.0	45.08	3.8	1199.3
2/15 15:37	99008.0	45.04	3.8	1201.3
2/15 15:38	98730.0	44.33	3.8	1201.2
2/15 15:39	97277.0	45.07	3.8	1200.5
2/15 15:40	98616.0	44.86	3.8	1199.3
2/15 15:41	97838.0	45.33	3.8	1199.5
2/15 15:42	95874.0	44.38	3.8	1200.0
2/15 15:43	963377.0	44.55	3.8	1200.0

	(TG-751) Landfill Gas Flow soft/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp				
2/15 15:44	96347.0	44.53	3.8	1200.3
2/15 15:45	95700.0	44.39	3.8	1199.8
2/15 15:46	96194.0	44.61	3.8	1199.5
2/15 15:47	96749.0	44.90	3.8	1199.7
2/15 15:48	96272.0	44.60	3.8	1200.0
2/15 15:49	96986.0	44.94	3.8	1200.0
2/15 15:50	97378.0	45.12	3.8	1200.0
2/15 15:51	96518.0	44.75	3.8	1200.3
2/15 15:52	96864.0	44.44	3.8	1200.2
2/15 15:53	95753.0	44.36	3.8	1199.7
2/15 15:54	96928.0	44.91	3.8	1200.0
2/15 15:55	97189.0	45.03	3.8	1199.8
2/15 15:56	96797.0	44.85	3.8	1199.8
2/15 15:57	96111.0	44.47	3.8	1200.0
2/15 15:58	97399.0	45.02	3.8	1200.0
2/15 15:59	96638.0	44.70	3.8	1200.3
2/15 16:00	96285.0	44.63	3.8	1199.8
2/15 16:01	95956.0	44.45	3.8	1199.5
2/15 16:02	96650.0	44.78	3.8	1200.0
2/15 16:03	96253.0	44.61	3.8	1200.2
2/15 16:04	97357.0	45.11	3.8	1200.2
2/15 16:05	96652.0	44.78	3.8	1200.0
2/15 16:06	96587.0	44.71	3.8	1200.0
2/15 16:07	96569.0	44.74	3.8	1200.0
2/15 16:08	96521.0	44.72	3.8	1200.0
2/15 16:09	96362.0	44.74	3.8	1200.0
2/15 16:10	96912.0	44.95	3.8	1199.7
2/15 16:11	96693.0	44.76	3.8	1199.5
2/15 16:12	96433.0	44.65	3.8	1200.0
2/15 16:13	97088.0	44.98	3.8	1200.2
2/15 16:14	97106.0	44.99	3.8	1200.2
2/15 16:15	96572.0	44.74	3.8	1200.0
2/15 16:16	96484.0	44.70	3.8	1199.8
2/15 16:17	96615.0	44.76	3.8	1199.8
2/15 16:18	96046.0	44.52	3.8	1199.8
2/15 16:19	97554.0	45.16	3.8	1199.8
2/15 16:20	96371.0	44.65	3.8	1200.0
2/15 16:21	97192.0	44.97	3.8	1200.0
2/15 16:22	96112.0	44.49	3.8	1199.8
2/15 16:23	96752.0	44.72	3.8	1200.0
2/15 16:24	96595.0	44.65	3.8	1200.2
2/15 16:25	96793.0	44.29	3.8	1200.0
2/15 16:26	96508.0	44.64	3.8	1200.5
2/15 16:27	96424.0	44.64	3.8	1200.2
2/15 16:28	96571.0	44.28	3.8	1200.0
2/15 16:29	96738.0	44.74	3.8	1200.0
2/15 16:30	96231.0	44.48	3.8	1200.0
2/15 16:31	96362.0	44.51	3.8	1199.8
2/15 16:32	96393.0	44.52	3.8	1199.7
	97103.2	44.7	3.8	1200.0

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T Exhaust Temp °F 1-Min
Timestamp				
2/15 16:33	98021.0	45.22	3.8	1200.2
2/15 16:34	98114.0	45.31	3.8	1200.0
2/15 16:35	98562.0	44.63	3.8	1199.8
2/15 16:36	98493.0	44.18	3.8	1200.2
2/15 16:37	98897.0	44.43	3.8	1200.0
2/15 16:38	98746.0	44.43	3.8	1199.8
2/15 16:39	98971.0	44.46	3.8	1200.0
2/15 16:40	98913.0	44.90	3.8	1199.7
2/15 16:41	97723.0	45.20	3.8	1200.2
2/15 16:42	97390.0	45.01	3.8	1200.0
2/15 16:43	97263.0	44.95	3.8	1200.2
2/15 16:44	98611.0	44.19	3.8	1200.2
2/15 16:45	97364.0	44.97	3.8	1200.3
2/15 16:46	98159.0	44.45	3.8	1199.8
2/15 16:47	98218.0	44.49	3.8	1200.0
2/15 16:48	98862.0	44.82	3.8	1200.2
2/15 16:49	98288.0	44.15	3.8	1199.8
2/15 16:50	98843.0	44.37	3.8	1199.7
2/15 16:51	97223.0	44.94	3.8	1200.2
2/15 16:52	98523.0	44.11	3.8	1199.8
2/15 16:53	97295.0	44.97	3.8	1199.8
2/15 16:54	98058.0	45.26	3.8	1200.2
2/15 16:55	97589.0	45.15	3.8	1199.8
2/15 16:56	98406.0	44.56	3.8	1199.8
2/15 16:57	97588.0	45.08	3.8	1200.0
2/15 16:58	98389.0	45.40	3.8	1199.5
2/15 16:59	98406.0	45.40	3.8	1200.2
2/15 17:00	98154.0	45.26	3.8	1200.0
2/15 17:01	97203.0	44.84	3.8	1200.0
2/15 17:02	97752.0	45.10	3.8	1200.7
2/15 17:03	96944.0	44.77	3.8	1199.7
2/15 17:04	98349.0	44.45	3.8	1200.0
2/15 17:05	98770.0	45.54	3.8	1200.0
2/15 17:06	96888.0	44.68	3.8	1200.0
2/15 17:07	98573.0	44.53	3.8	1200.0
2/15 17:08	96971.0	44.74	3.8	1200.0
2/15 17:09	98503.0	44.50	3.8	1200.2
2/15 17:10	97117.0	44.81	3.8	1199.8
2/15 17:11	98183.0	45.27	3.8	1200.0
2/15 17:12	97369.0	44.88	3.8	1200.2
2/15 17:13	98673.0	44.50	3.8	1199.5
2/15 17:14	97624.0	44.95	3.8	1200.2
2/15 17:15	97531.0	44.95	3.8	1200.0
2/15 17:16	97922.0	45.09	3.8	1200.0
2/15 17:17	97356.0	44.79	3.8	1200.0
2/15 17:18	98465.0	45.22	3.8	1200.0
2/15 17:19	97180.0	44.70	3.8	1200.2
2/15 17:20	97172.0	44.81	3.8	1200.2
2/15 17:21	96487.0	44.49	3.8	1200.0

Cedar 5 Reports 3/6/2023 6:45 AM, CoDAR 1-Minute Data

Page 14 of 17

	(TG-751) Landfill Gas Flow scfm/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T Exhaust Temp °F 1-Min
Timestamp				
2/15/17:22	98052.0	45.13	3.8	1200.0
2/15/17:23	98123.0	45.14	3.8	1200.2
2/15/17:24	97741.0	44.96	3.8	1199.8
2/15/17:25	97238.0	44.65	3.8	1200.0
2/15/17:26	98164.0	45.15	3.8	1200.0
2/15/17:27	98334.0	45.25	3.8	1199.7
2/15/17:28	97644.0	44.83	3.8	1200.3
2/15/17:29	98073.0	45.11	3.8	1199.8
2/15/17:30	97015.0	44.68	3.8	1199.8
2/15/17:31	97935.0	45.08	3.8	1200.0
2/15/17:32	98136.0	45.14	3.8	1200.0
2/15/17:33	97608.0	44.88	3.8	1200.0
2/15/17:34	97990.0	45.08	3.8	1200.0
2/15/17:35	97013.0	44.55	3.8	1200.0
2/15/17:36	97655.0	44.82	3.8	1199.8
2/15/17:37	98868.0	44.45	3.8	1200.3
2/15/17:38	97161.0	44.57	3.8	1200.3
2/15/17:39	97299.0	44.73	3.8	1200.2
2/15/17:40	97141.0	44.68	3.8	1200.0
2/15/17:41	97617.0	44.89	3.8	1199.7
2/15/17:42	97268.0	44.64	3.8	1199.8
2/15/17:43	97920.0	44.94	3.8	1199.8
2/15/17:44	97158.0	44.59	3.8	1200.0
2/15/17:45	96881.0	44.46	3.8	1199.8
2/15/17:46	98558.0	45.20	3.8	1200.0
2/15/17:47	97145.0	44.49	3.8	1199.8
2/15/17:48	97876.0	44.84	3.8	1200.2
2/15/17:49	97345.0	44.60	3.8	1200.0
2/15/17:50	98277.0	45.47	3.8	1199.8
2/15/17:51	97963.0	44.83	3.8	1199.8
2/15/17:52	99186.0	45.41	3.8	1199.8
2/15/17:53	97906.0	44.82	3.8	1200.0
2/15/17:54	97895.0	44.62	3.8	1200.0
2/15/17:55	98670.0	45.17	3.8	1199.8
2/15/17:56	98512.0	45.05	3.8	1200.0
2/15/17:57	97379.0	44.55	3.8	1200.0
2/15/18:02	97705.0	44.64	3.8	1199.7
2/15/18:03	98287.0	44.87	3.8	1200.2
2/15/18:04	99575.0	45.40	3.8	1200.2
2/15/18:00	98897.0	45.26	3.8	1200.0
2/15/18:05	98137.0	44.86	3.8	1200.0
2/15/18:06	98126.0	44.80	3.8	1199.7
2/15/18:07	98563.0	45.01	3.8	1199.8
2/15/18:08	97978.0	44.72	3.8	1200.0
2/15/18:09	99013.0	45.19	3.8	1199.8
2/15/18:10	98501.0	44.91	3.8	1200.2

	(TG-751) Landfill Gas Flow scf/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp				
2/15 18:11	99276.0	45.23	3.8	1200.0
2/15 18:12	99168.0	45.20	3.8	1200.0
2/15 18:13	98198.0	44.80	3.8	1200.3
2/15 18:14	99299.0	45.35	3.8	1200.0
2/15 18:15	98277.0	44.88	3.8	1200.0
2/15 18:16	97823.0	44.70	3.8	1200.0
2/15 18:17	98413.0	44.94	3.8	1200.2
2/15 18:18	98898.0	45.15	3.8	1199.7
2/15 18:19	98494.0	44.93	3.8	1199.8
2/15 18:20	98589.0	44.95	3.8	1199.8
2/15 18:21	99517.0	45.34	3.8	1199.8
2/15 18:22	98261.0	44.77	3.8	1200.2
2/15 18:23	98546.0	44.90	3.8	1200.0
2/15 18:24	98180.0	44.71	3.8	1199.7
2/15 18:25	98492.0	44.87	3.8	1200.3
2/15 18:26	99118.0	45.19	3.8	1199.8
2/15 18:27	98177.0	44.76	3.8	1200.2
2/15 18:28	98523.0	44.92	3.8	1199.8
2/15 18:29	99127.0	45.16	3.8	1200.0
2/15 18:30	98298.0	44.79	3.8	1200.3
2/15 18:31	98532.0	44.89	3.8	1200.2
2/15 18:32	98411.0	45.18	3.8	1200.0
2/15 18:33	98192.0	44.71	3.8	1200.0
2/15 18:34	97981.0	44.61	3.8	1200.0
2/15 18:35	98240.0	44.71	3.8	1200.0
2/15 18:36	98434.0	44.84	3.8	1200.2
2/15 18:37	98779.0	45.00	3.8	1200.0
2/15 18:38	98350.0	44.81	3.8	1200.0
2/15 18:39	98500.0	44.88	3.8	1200.0
2/15 18:40	99251.0	45.22	3.8	1199.8
2/15 18:41	98467.0	44.86	3.8	1200.0
2/15 18:42	98724.0	44.93	3.8	1200.0
2/15 18:43	99155.0	45.18	3.8	1199.8
2/15 18:44	98828.0	45.01	3.8	1200.0
2/15 18:45	100000.0	45.53	3.8	1200.0
2/15 18:46	98884.0	45.00	3.8	1200.2
2/15 18:47	99210.0	45.09	3.8	1200.0
2/15 18:48	99152.0	45.15	3.8	1200.0
2/15 18:49	99776.0	45.46	3.8	1200.0
2/15 18:50	98453.0	44.78	3.8	1200.0
2/15 18:51	98990.0	45.08	3.8	1199.8
2/15 18:52	99148.0	45.08	3.8	1199.8
2/15 18:53	98805.0	44.91	3.8	1200.0
2/15 18:54	99367.0	45.18	3.8	1200.2
2/15 18:55	98742.0	44.88	3.8	1200.0
2/15 18:56	98946.0	44.97	3.8	1199.8
2/15 18:57	98780.0	44.95	3.8	1200.2
2/15 18:58	100171.0	45.64	3.8	1200.0
2/15 18:59	99140.0	45.20	3.8	1200.2

Cedar Reports 3/2/2023 6:45 AM, CetDAR 1-Minute Data

Page 16 of 17

	(TG-751) Landfill Gas Flow scf/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp				
2/15 19:00	98411.0	44.87	3.8	1200.0
Average (all)	98483.4	45.03	3.8	1199.8
Total (all)	--	--	--	--
Minimum (all)	90393.0	40.34	3.5	1185.3
Maximum (all)	112762.0	46.88	3.9	1201.3
Average (valid values only)	98483.4	45.03	3.8	1199.8
Total (valid values only)	--	--	--	--
Count (valid values only)	781	781	781	781

CeDAR 1-Minute Data
 Sunshine Gas Producers, LLC
 Data for 2/16/2023 6:00 AM thru 2/16/2023 7:00 PM

Timestamp	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Heat 1-Min	(TG-751) Megawatts 1-Min	(TG-751) TT Exhaust Temp °F -1-Min
2/16 6:00	99269.0	45.69	3.8	1199.8	
2/16 6:01	99511.0	45.77	3.8	1199.8	
2/16 6:02	98632.0	45.35	3.8	1200.3	
2/16 6:03	100048.0	46.02	3.8	1200.2	
2/16 6:04	99797.0	45.88	3.8	1200.0	
2/16 6:05	99817.0	45.86	3.8	1199.8	
2/16 6:06	100495.0	46.17	3.8	1200.0	
2/16 6:07	99187.0	45.61	3.8	1200.0	
2/16 6:08	99497.0	45.66	3.8	1199.8	
2/16 6:09	100532.0	46.22	3.8	1200.0	
2/16 6:10	100022.0	46.00	3.9	1199.8	
2/16 6:11	99966.0	45.80	3.8	1200.0	
2/16 6:12	100120.0	46.06	3.8	1200.0	
2/16 6:13	99959.0	45.98	3.9	1200.0	
2/16 6:14	99882.0	45.71	3.9	1200.2	
2/16 6:15	100562.0	46.15	3.8	1200.2	
2/16 6:16	100384.0	46.06	3.8	1200.2	
2/16 6:17	98988.0	45.45	3.8	1200.0	
2/16 6:18	99227.0	45.59	3.8	1200.2	
2/16 6:19	99656.0	45.75	3.8	1200.0	
2/16 6:20	99613.0	45.79	3.8	1200.0	
2/16 6:21	100386.0	46.07	3.8	1200.0	
2/16 6:22	100077.0	45.98	3.8	1200.2	
2/16 6:23	100498.0	46.12	3.8	1199.7	
2/16 6:24	100433.0	46.09	3.9	1199.5	
2/16 6:25	100529.0	46.10	3.9	1199.8	
2/16 6:26	99373.0	45.49	3.9	1200.0	
2/16 6:27	100584.0	46.08	3.9	1199.7	
2/16 6:28	101179.0	46.32	3.9	1200.0	
2/16 6:29	100058.0	45.92	3.9	1200.2	
2/16 6:30	100541.0	46.14	3.9	1199.8	
2/16 6:31	100849.0	46.28	3.8	1200.0	
2/16 6:32	100296.0	46.01	3.9	1200.0	
2/16 6:33	98065.0	44.92	3.9	1200.2	
2/16 6:34	99094.0	45.41	3.8	1199.8	
2/16 6:35	100787.0	46.14	3.9	1200.0	
2/16 6:36	100067.0	45.83	3.9	1200.0	
2/16 6:37	100597.0	46.10	3.9	1199.7	
2/16 6:38	99641.0	45.59	3.9	1200.2	
2/16 6:39	99961.0	45.76	3.9	1200.0	
2/16 6:40	99560.0	45.58	3.9	1200.2	
2/16 6:41	99330.0	45.47	3.9	1200.0	
2/16 6:42	99103.0	45.39	3.9	1199.8	
2/16 6:43	100596.0	46.03	3.9	1200.0	
2/16 6:44	100125.0	45.82	3.9	1200.3	

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Heat 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min	(TG-751) T °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min	1-Min
2/16 6:45	100855.0	46.17	3.9	1200.2		
2/16 6:46	101082.0	46.27	3.9	1200.2		
2/16 6:47	100687.0	46.09	3.9	1200.2		
2/16 6:48	100032.0	45.79	3.9	1200.0		
2/16 6:49	100285.0	45.91	3.9	1199.8		
2/16 6:50	100365.0	46.22	3.9	1200.2		
2/16 6:51	100023.0	45.71	3.9	1199.8		
2/16 6:52	101828.0	46.51	3.9	1200.2		
2/16 6:53	101447.0	46.36	3.9	1200.2		
2/16 6:54	100988.0	46.23	3.9	1200.0		
2/16 6:55	99385.0	45.52	3.9	1199.5		
2/16 6:56	101892.0	46.56	3.9	1200.2		
2/16 6:57	100006.0	45.76	3.9	1200.5		
2/16 6:58	100192.0	45.98	3.9	1200.2		
2/16 6:59	99412.0	45.54	3.9	1199.5		
2/16 7:00	100857.0	46.17	3.9	1199.8		
2/16 7:01	101869.0	46.61	3.9	1200.0		
2/16 7:02	100823.0	46.10	3.9	1199.8		
2/16 7:03	100594.0	46.05	3.9	1200.0		
2/16 7:04	100119.0	45.83	3.9	1199.5		
2/16 7:05	101637.0	46.45	3.9	1200.0		
2/16 7:06	100608.0	45.95	3.9	1199.8		
2/16 7:07	101171.0	46.15	3.9	1200.0		
2/16 7:08	100096.0	45.69	3.9	1200.2		
2/16 7:09	100271.0	45.80	3.9	1200.0		
2/16 7:10	100271.0	45.87	3.9	1200.5		
2/16 7:11	100528.0	46.11	3.9	1200.2		
2/16 7:12	99008.0	45.52	3.9	1200.0		
2/16 7:13	99375.0	45.74	3.9	1199.7		
2/16 7:14	100163.0	46.05	3.9	1199.8		
2/16 7:15	101174.0	46.52	3.9	1200.5		
2/16 7:16	101360.0	46.43	3.9	1199.7		
2/16 7:17	100540.0	45.92	3.9	1199.5		
2/16 7:18	101298.0	46.15	3.9	1200.0		
2/16 7:19	101350.0	46.27	3.9	1199.7		
2/16 7:20	101079.0	46.16	3.9	1200.3		
2/16 7:21	101124.0	46.24	3.9	1200.0		
2/16 7:22	101262.0	46.36	3.9	1200.2		
2/16 7:23	101712.0	46.58	3.9	1200.0		
2/16 7:24	100521.0	46.04	3.9	1200.0		
2/16 7:25	99543.0	45.57	3.9	1200.0		
2/16 7:26	100981.0	46.25	3.9	1199.8		
2/16 7:27	101034.0	46.20	3.9	1200.0		
2/16 7:28	100594.0	46.07	3.9	1199.8		
2/16 7:29	99816.0	45.81	3.9	1200.0		
2/16 7:30	100453.0	46.08	3.9	1200.0		
2/16 7:31	99470.0	45.56	3.9	1199.8		
2/16 7:32	100531.0	46.02	3.9	1200.0		
2/16 7:33	101521.0	46.48	3.9	1200.2		

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Heat 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/16 7:34	100773.0	46.13	3.9	1200.0	
2/16 7:35	99987.0	45.78	3.9	1199.8	
2/16 7:36	100965.0	46.22	3.9	1199.8	
2/16 7:37	101715.0	46.46	3.9	1200.0	
2/16 7:38	101185.0	46.21	3.9	1200.0	
2/16 7:39	101636.0	46.42	3.9	1200.0	
2/16 7:40	100912.0	46.09	3.9	1199.8	
2/16 7:41	101394.0	46.28	3.9	1200.0	
2/16 7:42	101732.0	46.46	3.9	1200.3	
2/16 7:43	99698.0	45.62	3.9	1200.2	
2/16 7:44	100436.0	46.03	3.9	1200.3	
2/16 7:45	100457.0	46.01	3.9	1200.0	
2/16 7:46	100400.0	46.05	3.9	1200.3	
2/16 7:47	100516.0	46.13	3.9	1200.2	
2/16 7:48	100602.0	46.20	3.8	1199.8	
2/16 7:49	100074.0	46.01	3.8	1199.8	
2/16 7:50	99983.0	45.99	3.8	1200.2	
2/16 7:51	98747.0	45.43	3.8	1200.0	
2/16 7:52	101015.0	46.47	3.9	1199.7	
2/16 7:53	99225.0	45.62	3.8	1200.0	
2/16 7:54	99403.0	45.70	3.8	1199.8	
2/16 7:55	98989.0	45.46	3.8	1200.0	
2/16 7:56	100866.0	46.32	3.8	1200.2	
2/16 7:57	99133.0	45.62	3.8	1199.5	
2/16 7:58	99798.0	45.91	3.9	1200.2	
2/16 7:59	100235.0	46.11	3.9	1200.0	
2/16 8:00	99933.0	46.04	3.9	1200.0	
2/16 8:01	99118.0	45.81	3.8	1200.0	
2/16 8:02	99259.0	45.75	3.8	1200.0	
2/16 8:03	99449.0	45.87	3.8	1200.7	
2/16 8:04	97627.0	45.31	3.8	1201.7	
2/16 8:05	96679.0	45.53	3.8	1201.7	
2/16 8:06	96345.0	45.82	3.8	1200.0	
2/16 8:07	96920.0	46.16	3.8	1199.5	
2/16 8:08	96800.0	45.90	3.8	1199.2	
2/16 8:09	98299.0	46.36	3.8	1199.2	
2/16 8:10	98149.0	46.11	3.8	1199.7	
2/16 8:11	97385.0	45.65	3.8	1200.0	
2/16 8:12	98453.0	46.02	3.8	1199.0	
2/16 8:13	99671.0	46.32	3.8	1200.7	
2/16 8:14	98418.0	45.62	3.8	1199.8	
2/16 8:15	98747.0	45.66	3.8	1200.3	
2/16 8:16	99634.0	46.05	3.8	1200.0	
2/16 8:17	98482.0	45.66	3.8	1200.7	
2/16 8:18	98161.0	45.77	3.8	1200.2	
2/16 8:19	98847.0	46.20	3.8	1200.0	
2/16 8:20	98274.0	45.98	3.8	1200.3	
2/16 8:21	97151.0	45.53	3.8	1200.0	
2/16 8:22	97941.0	45.90	3.8	1200.0	

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T Exhaust Temp °F 1-Min
2/16 8:23	96296.0	46.07	3.8	1200.3
2/16 8:24	96925.0	46.46	3.8	1200.0
2/16 8:25	96899.0	45.49	3.8	1200.0
2/16 8:26	97639.0	45.81	3.8	1200.3
2/16 8:27	97853.0	46.11	3.8	1200.0
2/16 8:28	97248.0	45.84	3.8	1199.8
2/16 8:29	97469.0	45.99	3.8	1200.5
2/16 8:30	97186.0	45.80	3.8	1200.0
2/16 8:31	97721.0	46.02	3.8	1200.0
2/16 8:32	96723.0	45.57	3.8	1200.0
2/16 8:33	96620.0	45.59	3.8	1200.2
2/16 8:34	98259.0	46.38	3.8	1200.0
2/16 8:35	96995.0	45.77	3.8	1200.0
2/16 8:36	96487.0	45.54	3.8	1200.0
2/16 8:37	96841.0	45.71	3.8	1199.8
2/16 8:38	97163.0	45.86	3.8	1199.7
2/16 8:39	96830.0	45.68	3.8	1200.2
2/16 8:40	96298.0	46.40	3.8	1199.7
2/16 8:41	97204.0	45.88	3.8	1200.5
2/16 8:42	97311.0	45.90	3.8	1199.8
2/16 8:43	96756.0	45.56	3.8	1200.0
2/16 8:44	97079.0	45.71	3.8	1200.5
2/16 8:45	97662.0	46.06	3.8	1200.3
2/16 8:46	97210.0	45.88	3.8	1200.0
2/16 8:47	96731.0	45.60	3.8	1199.8
2/16 8:48	97159.0	45.76	3.8	1200.0
2/16 8:49	96838.0	45.63	3.8	1199.8
2/16 8:50	97344.0	45.93	3.8	1200.0
2/16 8:51	96723.0	45.65	3.8	1200.0
2/16 8:52	96905.0	45.74	3.8	1199.8
2/16 8:53	96902.0	45.77	3.8	1199.8
2/16 8:54	96385.0	45.50	3.8	1199.7
2/16 8:55	96373.0	45.49	3.8	1199.8
2/16 8:56	96135.0	45.38	3.8	1200.2
2/16 8:57	96532.0	45.59	3.8	1200.3
2/16 8:58	96522.0	45.69	3.8	1199.8
2/16 8:59	96207.0	45.64	3.8	1200.2
2/16 9:00	96672.0	45.84	3.8	1200.2
2/16 9:05	98124.0	46.01	3.8	1199.5
2/16 9:06	97344.0	45.80	3.8	1200.2
2/16 9:07	96347.0	45.16	3.8	1200.0
2/16 9:08	97073.0	45.55	3.8	1199.8
2/16 9:09	97349.0	45.63	3.8	1199.7
2/16 9:10	96642.0	45.30	3.8	1200.2
2/16 9:11	97244.0	45.65	3.8	1200.7

Cedar 5 Reports 3/8/2023 6:46 AM, CGDAR 1-Minute Data

Page 4 of 17

	(TG-751) Landfill Gas Flow scfh/r	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts -Min	(TG-751) T7 Exhaust Temp °F -Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/16 9:12	96629.0	45.52	3.8	1200.0
2/16 9:13	95564.0	45.13	3.8	1200.5
2/16 9:14	97013.0	45.90	3.8	1199.7
2/16 9:15	96271.0	45.55	3.8	1199.8
2/16 9:16	96104.0	45.57	3.8	1199.8
2/16 9:17	96232.0	45.63	3.8	1200.0
2/16 9:18	96327.0	45.68	3.8	1199.8
2/16 9:19	96607.0	45.81	3.8	1200.0
2/16 9:20	96368.0	45.71	3.8	1200.2
2/16 9:21	97325.0	46.15	3.8	1200.0
2/16 9:22	96118.0	45.58	3.8	1200.0
2/16 9:23	97414.0	46.19	3.8	1199.8
2/16 9:24	95099.0	45.10	3.8	1200.0
2/16 9:25	96486.0	45.77	3.8	1200.0
2/16 9:26	96042.0	45.64	3.8	1200.2
2/16 9:27	96234.0	45.71	3.8	1200.0
2/16 9:28	96057.0	45.58	3.8	1200.0
2/16 9:29	96227.0	45.63	3.8	1200.0
2/16 9:30	96072.0	45.56	3.8	1200.2
2/16 9:31	96727.0	45.84	3.8	1200.2
2/16 9:32	95469.0	45.27	3.8	1199.7
2/16 9:33	96337.0	45.68	3.8	1200.7
2/16 9:34	95562.0	45.31	3.8	1200.2
2/16 9:35	94460.0	44.86	3.8	1199.8
2/16 9:36	95419.0	45.34	3.8	1200.3
2/16 9:37	96122.0	45.66	3.8	1199.5
2/16 9:38	97350.0	46.11	3.8	1199.8
2/16 9:39	96012.0	45.47	3.8	1199.8
2/16 9:40	956925.0	45.38	3.8	1200.0
2/16 9:41	95768.0	45.31	3.8	1200.2
2/16 9:42	96185.0	45.38	3.8	1199.0
2/16 9:43	96493.0	45.12	3.8	1199.0
2/16 9:44	97520.0	45.37	3.8	1200.0
2/16 9:45	96761.0	45.03	3.8	1200.0
2/16 9:46	98494.0	45.70	3.8	1199.8
2/16 9:47	99444.0	46.07	3.8	1199.7
2/16 9:48	98853.0	45.62	3.8	1200.0
2/16 9:49	98884.0	45.66	3.8	1198.5
2/16 9:50	104542.0	47.02	3.8	1198.3
2/16 9:51	10326.0	45.67	3.8	1200.3
2/16 9:52	102103.0	45.77	3.8	1200.7
2/16 9:53	100329.0	45.30	3.8	1201.5
2/16 9:54	98512.0	45.26	3.8	1201.5
2/16 9:55	98528.0	45.61	3.8	1199.2
2/16 9:56	99666.0	45.87	3.8	1199.3
2/16 9:57	99812.0	45.83	3.8	1200.0
2/16 9:58	98342.0	45.27	3.8	1200.8
2/16 9:59	97830.0	45.22	3.8	1200.7
2/16 10:00	97752.0	45.42	3.8	1200.3

Page 5 of 17

Cedar 5 Reports 3/8/2023 6:46 AM. CeDAR 1-Minute Data

	(TG-751) Landfill Gas Flow scfh/r	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts	(TG-751) T °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min
2/16 10:01	98428.0	45.78	3.8	1199.7
2/16 10:02	98599.0	45.78	3.8	1199.8
2/16 10:03	97919.0	45.50	3.8	1200.3
2/16 10:04	98332.0	45.74	3.8	1200.2
2/16 10:05	97369.0	45.42	3.8	1200.0
2/16 10:06	97322.0	45.37	3.8	1199.5
2/16 10:07	98863.0	46.01	3.8	1199.5
2/16 10:08	98090.0	45.58	3.8	1200.0
2/16 10:09	97492.0	45.26	3.8	1200.3
2/16 10:10	98675.0	45.82	3.8	1200.2
2/16 10:11	98503.0	45.76	3.8	1200.3
2/16 10:12	97858.0	45.52	3.8	1199.8
2/16 10:13	98294.0	45.73	3.8	1199.7
2/16 10:14	97427.0	45.27	3.8	1199.8
2/16 10:15	98235.0	45.64	3.8	1199.8
2/16 10:16	98723.0	45.84	3.8	1200.0
2/16 10:17	97852.0	45.43	3.8	1200.3
2/16 10:18	97605.0	45.32	3.8	1200.2
2/16 10:19	986894.0	45.09	3.8	1200.5
2/16 10:20	97738.0	45.43	3.8	1199.3
2/16 10:21	97980.0	45.47	3.8	1199.7
2/16 10:22	98207.0	45.58	3.8	1199.8
2/16 10:23	98270.0	45.56	3.8	1200.0
2/16 10:24	98263.0	45.49	3.8	1200.0
2/16 10:25	98608.0	45.66	3.8	1200.2
2/16 10:26	96904.0	44.99	3.8	1200.2
2/16 10:27	97076.0	45.10	3.8	1200.2
2/16 10:28	96920.0	45.04	3.8	1199.8
2/16 10:29	97681.0	45.30	3.8	1199.8
2/16 10:30	97131.0	45.03	3.8	1199.8
2/16 10:31	97901.0	45.30	3.8	1199.8
2/16 10:32	97314.0	45.08	3.8	1200.0
2/16 10:33	97315.0	45.12	3.8	1200.5
2/16 10:34	986795.0	44.90	3.8	1199.8
2/16 10:35	96172.0	44.58	3.8	1200.2
2/16 10:36	97424.0	45.18	3.8	1200.2
2/16 10:37	97941.0	45.40	3.8	1199.7
2/16 10:38	97130.0	45.03	3.8	1200.7
2/16 10:39	96678.0	44.89	3.8	1200.2
2/16 10:40	97821.0	45.34	3.8	1200.0
2/16 10:41	96124.0	44.53	3.8	1200.0
2/16 10:42	97476.0	45.16	3.8	1199.8
2/16 10:43	97497.0	45.17	3.8	1200.0
2/16 10:44	96591.0	44.75	3.8	1200.2
2/16 10:45	98346.0	45.57	3.8	1200.3
2/16 10:46	97036.0	44.92	3.8	1199.7
2/16 10:47	97522.0	45.07	3.8	1200.0
2/16 10:48	96970.0	44.82	3.8	1200.3
2/16 10:49	96010.0	44.45	3.8	1200.0

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 °F	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min		
2/16 10:50	96479.0	44.64	3.8	1199.8		
2/16 10:51	97114.0	44.99	3.8	1200.0		
2/16 10:52	98867.0	45.71	3.8	1199.8		
2/16 10:53	97176.0	45.02	3.8	1200.0		
2/16 10:54	97617.0	45.20	3.8	1199.8		
2/16 10:55	98652.0	45.60	3.8	1200.3		
2/16 10:56	97625.0	45.14	3.8	1200.0		
2/16 10:57	97100.0	44.90	3.8	1200.2		
2/16 10:58	96335.0	44.83	3.8	1200.0		
2/16 10:59	97173.0	45.02	3.8	1200.0		
2/16 11:00	96982.0	44.90	3.8	1200.0		
2/16 11:01	96787.0	44.81	3.8	1200.0		
2/16 11:02	97502.0	45.06	3.8	1200.0		
2/16 11:03	98153.0	45.36	3.8	1200.0		
2/16 11:04	97932.0	45.26	3.8	1199.8		
2/16 11:05	97364.0	44.97	3.8	1200.0		
2/16 11:06	96729.0	44.63	3.8	1200.0		
2/16 11:07	97924.0	45.26	3.8	1200.3		
2/16 11:08	98288.0	45.34	3.8	1200.2		
2/16 11:09	97775.0	45.19	3.8	1200.2		
2/16 11:10	97130.0	44.85	3.8	1200.0		
2/16 11:11	96501.0	44.53	3.8	1200.0		
2/16 11:12	96488.0	44.57	3.8	1200.0		
2/16 11:13	97397.0	45.02	3.8	1200.3		
2/16 11:14	96318.0	44.52	3.8	1200.3		
2/16 11:15	97671.0	45.25	3.8	1200.0		
2/16 11:16	97615.0	45.23	3.8	1200.0		
2/16 11:17	96628.0	44.77	3.8	1199.7		
2/16 11:18	97086.0	44.98	3.8	1200.2		
2/16 11:19	98553.0	45.54	3.8	1200.0		
2/16 11:20	97173.0	45.02	3.8	1200.3		
2/16 11:21	95903.0	44.43	3.8	1199.8		
2/16 11:22	96831.0	44.89	3.8	1200.0		
2/16 11:23	97119.0	45.00	3.8	1200.0		
2/16 11:24	95996.0	44.48	3.8	1200.3		
2/16 11:25	97226.0	45.02	3.8	1200.2		
2/16 11:26	96842.0	44.87	3.8	1200.0		
2/16 11:27	97458.0	45.15	3.8	1200.0		
2/16 11:28	96869.0	44.88	3.8	1200.2		
2/16 11:29	9624.0	44.47	3.8	1200.3		
2/16 11:30	95994.0	44.57	3.8	1200.0		
2/16 11:31	95342.0	44.25	3.8	1199.5		
2/16 11:32	97711.0	45.27	3.8	1199.8		
2/16 11:33	97544.0	45.05	3.8	1200.0		
2/16 11:34	96821.0	44.71	3.8	1200.0		
2/16 11:35	97220.0	44.94	3.8	1200.0		
2/16 11:36	96455.0	44.66	3.8	1200.0		
2/16 11:37	97148.0	45.03	3.8	1199.5		
2/16 11:38	96741.0	44.82	3.8	1200.0		

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat: Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min	(TG-751) T °F 1-Min
Timestamp					
2/16 11:39	96040.0	44.50	3.8	1200.2	
2/16 11:40	96635.0	44.77	3.8	1199.7	
2/16 11:41	97594.0	45.15	3.8	1200.0	
2/16 11:42	96308.0	44.59	3.8	1200.0	
2/16 11:43	96895.0	44.89	3.8	1200.0	
2/16 11:44	95820.0	44.39	3.8	1200.3	
2/16 11:45	95819.0	44.46	3.8	1200.0	
2/16 11:46	96571.0	44.79	3.8	1199.8	
2/16 11:47	96575.0	44.81	3.8	1199.8	
2/16 11:48	97090.0	45.08	3.8	1200.0	
2/16 11:49	97411.0	45.16	3.8	1200.3	
2/16 11:50	97025.0	44.97	3.8	1200.3	
2/16 11:51	97171.0	45.02	3.8	1200.0	
2/16 11:52	96770.0	44.88	3.8	1200.3	
2/16 11:53	95822.0	44.46	3.8	1200.0	
2/16 11:54	96071.0	44.61	3.8	1200.0	
2/16 11:55	96267.0	44.74	3.8	1200.0	
2/16 11:56	97172.0	45.10	3.8	1200.0	
2/16 11:57	96654.0	44.87	3.8	1200.0	
2/16 11:58	96178.0	44.66	3.8	1200.0	
2/16 11:59	96726.0	44.86	3.8	1199.7	
2/16 12:00	96459.0	44.69	3.8	1200.2	
2/16 12:01	96686.0	44.77	3.8	1200.0	
2/16 12:02	96029.0	44.51	3.8	1200.3	
2/16 12:03	95833.0	44.47	3.8	1200.2	
2/16 12:04	96232.0	44.77	3.8	1200.2	
2/16 12:05	96776.0	44.86	3.8	1200.0	
2/16 12:06	95579.0	44.42	3.8	1200.0	
2/16 12:07	97500.0	45.27	3.8	1199.7	
2/16 12:08	96187.0	44.58	3.8	1200.0	
2/16 12:09	97061.0	44.97	3.8	1200.0	
2/16 12:10	96356.0	44.72	3.8	1200.2	
2/16 12:11	96901.0	45.02	3.8	1200.2	
2/16 12:12	96885.0	45.09	3.8	1200.0	
2/16 12:13	98725.0	45.02	3.8	1200.2	
2/16 12:14	95751.0	44.67	3.8	1200.0	
2/16 12:15	96907.0	45.18	3.8	1200.0	
2/16 12:16	97226.0	45.27	3.8	1200.0	
2/16 12:17	96297.0	44.86	3.8	1200.0	
2/16 12:18	96022.0	44.73	3.8	1200.0	
2/16 12:19	96236.0	44.79	3.8	1200.2	
2/16 12:20	96331.0	44.87	3.8	1199.8	
2/16 12:21	97048.0	45.23	3.8	1200.0	
2/16 12:22	96053.0	44.26	3.8	1200.0	
2/16 12:23	95520.0	44.47	3.8	1200.0	
2/16 12:24	96570.0	45.03	3.8	1200.0	
2/16 12:25	94844.0	44.24	3.8	1200.0	
2/16 12:26	96479.0	45.01	3.8	1199.8	
2/16 12:27	95979.0	44.67	3.8	1200.0	
Average Run 5	97640.5	45.5	3.8	1200.0	

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min
Timestamp				
2/16 12:28	95970.0	44.64	3.8	1199.8
2/16 12:29	96983.0	45.03	3.8	1200.2
2/16 12:30	96331.0	44.73	3.8	1200.2
2/16 12:31	95636.0	44.51	3.8	1200.0
2/16 12:32	97008.0	45.15	3.8	1200.0
2/16 12:33	95778.0	44.56	3.8	1200.0
2/16 12:34	96780.0	45.02	3.8	1199.8
2/16 12:35	96165.0	44.73	3.8	1200.0
2/16 12:36	95381.0	44.32	3.8	1199.8
2/16 12:37	96296.0	44.75	3.8	1200.0
2/16 12:38	97374.0	45.27	3.8	1200.0
2/16 12:39	96984.0	45.08	3.8	1200.0
2/16 12:40	95487.0	44.44	3.8	1199.7
2/16 12:41	96787.0	45.07	3.8	1200.0
2/16 12:42	95928.0	44.68	3.8	1199.8
2/16 12:43	95953.0	44.73	3.8	1200.3
2/16 12:44	95297.0	44.43	3.8	1200.2
2/16 12:45	95093.0	44.29	3.8	1199.8
2/16 12:46	96150.0	44.76	3.8	1200.0
2/16 12:47	95741.0	44.64	3.8	1199.8
2/16 12:48	96413.0	44.89	3.8	1200.0
2/16 12:49	96575.0	44.95	3.8	1200.0
2/16 12:50	96821.0	45.03	3.8	1200.0
2/16 12:51	96833.0	45.06	3.8	1200.2
2/16 12:52	96063.0	44.81	3.8	1199.8
2/16 12:53	95840.0	44.68	3.8	1200.5
2/16 12:54	96011.0	44.81	3.8	1199.8
2/16 12:55	96273.0	44.91	3.8	1199.8
2/16 12:56	96129.0	44.84	3.8	1199.7
2/16 12:57	96233.0	44.80	3.8	1199.7
2/16 12:58	96960.0	45.13	3.8	1200.0
2/16 12:59	95991.0	44.67	3.8	1200.2
2/16 13:00	96632.0	44.95	3.8	1200.0
2/16 13:01	97137.0	45.23	3.8	1200.0
2/16 13:02	96032.0	44.78	3.8	1199.7
2/16 13:03	96222.0	44.87	3.8	1200.0
2/16 13:04	96508.0	45.02	3.8	1200.0
2/16 13:05	96579.0	45.05	3.8	1200.2
2/16 13:06	95535.0	44.60	3.8	1200.3
2/16 13:11	96367.0	44.55	3.8	1200.0
2/16 13:12	96586.0	44.98	3.8	1199.8
2/16 13:13	96116.0	44.95	3.8	1200.0
2/16 13:14	96185.0	44.51	3.8	1200.0
2/16 13:15	95540.0	44.70	3.8	1200.0
2/16 13:16	96226.0	44.95	3.8	1199.8

	(TG-751) Landfill Gas Flow scfh 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min
2/16 13:17	95970.0	44.85	3.8	1200.3
2/16 13:18	96358.0	45.06	3.8	1199.8
2/16 13:19	95642.0	44.72	3.8	1200.0
2/16 13:20	95291.0	44.54	3.8	1200.0
2/16 13:21	95469.0	45.11	3.8	1199.8
2/16 13:22	95251.0	44.54	3.8	1199.8
2/16 13:23	96074.0	45.01	3.8	1200.0
2/16 13:24	95497.0	44.68	3.8	1199.8
2/16 13:25	97096.0	45.40	3.8	1199.3
2/16 13:26	95821.0	44.72	3.8	1200.5
2/16 13:27	95761.0	44.78	3.8	1200.2
2/16 13:28	95485.0	44.67	3.8	1200.2
2/16 13:29	95018.0	44.51	3.8	1199.7
2/16 13:30	96087.0	44.90	3.8	1199.8
2/16 13:31	96134.0	44.95	3.8	1198.3
2/16 13:32	96860.0	44.66	3.8	1200.8
2/16 13:33	96720.0	44.88	3.8	1200.5
2/16 13:34	96036.0	44.62	3.8	1200.3
2/16 13:35	96227.0	44.68	3.8	1200.0
2/16 13:36	96594.0	44.78	3.8	1199.8
2/16 13:37	96475.0	44.72	3.8	1200.0
2/16 13:38	96854.0	44.99	3.8	1200.5
2/16 13:39	96679.0	44.99	3.8	1200.0
2/16 13:40	96430.0	44.88	3.8	1199.7
2/16 13:41	95843.0	44.60	3.8	1200.0
2/16 13:42	96629.0	44.92	3.8	1200.0
2/16 13:43	96476.0	44.94	3.8	1200.2
2/16 13:44	96293.0	44.75	3.8	1199.7
2/16 13:45	98521.0	45.66	3.8	1198.5
2/16 13:46	98801.0	45.30	3.8	1199.0
2/16 13:47	103769.0	46.17	3.8	1199.8
2/16 13:48	102886.0	44.38	3.8	1199.8
2/16 13:49	98778.0	44.30	3.8	1202.7
2/16 13:50	96551.0	44.41	3.8	1201.8
2/16 13:51	95215.0	44.51	3.8	1200.7
2/16 13:52	95549.0	44.81	3.8	1199.8
2/16 13:53	96413.0	44.99	3.8	1199.7
2/16 13:54	96328.0	44.97	3.8	1200.3
2/16 13:55	965680.0	44.77	3.8	1200.7
2/16 14:00	96356.0	45.06	3.8	1199.8
2/16 14:01	96006.0	44.89	3.8	1199.8
2/16 14:02	96669.0	45.12	3.8	1200.3
2/16 14:03	96406.0	45.08	3.8	1200.5
2/16 14:04	95632.0	44.72	3.8	1199.8
2/16 14:05	95160.0	44.50	3.8	1199.7

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) T °F -Min	(TG-751) T °F -Min
Timestamp	1-Min	1-Min	Megawatts	1-Min
2/16 14:06	94571.0	44.22	3.8	1199.8
2/16 14:07	96266.0	44.99	3.8	1200.0
2/16 14:08	96122.0	44.95	3.8	1200.2
2/16 14:09	95985.0	44.89	3.8	1200.0
2/16 14:10	95989.0	44.86	3.8	1199.7
2/16 14:11	95887.0	44.80	3.8	1198.7
2/16 14:12	98811.0	45.70	3.8	1200.2
2/16 14:13	98682.0	45.44	3.8	1199.0
2/16 14:14	98658.0	44.29	3.8	1202.8
2/16 14:15	98008.0	44.45	3.8	1201.0
2/16 14:16	95569.0	44.84	3.8	1199.5
2/16 14:17	95574.0	44.75	3.8	1198.8
2/16 14:18	95930.0	44.62	3.8	1200.3
2/16 14:19	94442.0	44.13	3.8	1200.7
2/16 14:20	94877.0	44.37	3.8	1200.0
2/16 14:21	96289.0	45.06	3.8	1199.5
2/16 14:22	94985.0	44.40	3.8	1200.0
2/16 14:23	94761.0	44.33	3.8	1200.0
2/16 14:24	95048.0	44.45	3.8	1199.8
2/16 14:25	95739.0	44.77	3.8	1199.8
2/16 14:26	96730.0	45.29	3.8	1200.0
2/16 14:27	95386.0	44.60	3.8	1200.0
2/16 14:28	95696.0	44.71	3.8	1200.0
2/16 14:29	95784.0	44.79	3.8	1199.8
2/16 14:30	95543.0	44.67	3.8	1199.8
2/16 14:31	95805.0	44.82	3.8	1200.0
2/16 14:32	95516.0	44.77	3.8	1200.0
2/16 14:33	95178.0	44.59	3.8	1200.0
2/16 14:34	96343.0	45.08	3.8	1200.0
2/16 14:35	94930.0	44.39	3.8	1199.8
2/16 14:36	95770.0	44.78	3.8	1200.0
2/16 14:37	96572.0	45.16	3.8	1200.0
2/16 14:38	96172.0	44.97	3.8	1200.2
2/16 14:39	96316.0	45.07	3.8	1199.5
2/16 14:40	95584.0	44.69	3.8	1200.2
2/16 14:41	95683.0	44.82	3.8	1200.0
2/16 14:42	96638.0	45.21	3.8	1200.0
2/16 14:43	95050.0	44.55	3.8	1199.8
2/16 14:44	94167.0	44.14	3.8	1200.2
2/16 14:45	94917.0	44.49	3.8	1199.8
2/16 14:46	95630.0	44.85	3.8	1200.2
2/16 14:47	95271.0	44.67	3.8	1199.8
2/16 14:48	95274.0	44.63	3.8	1199.8
2/16 14:49	95487.0	44.71	3.8	1200.2
2/16 14:50	95685.0	44.76	3.8	1199.8
2/16 14:51	95073.0	44.51	3.8	1200.0
2/16 14:52	95243.0	44.64	3.8	1200.0
2/16 14:53	95790.0	44.90	3.8	1199.8
2/16 14:54	96252.0	45.03	3.8	1200.0

	(TG-751) Landfill Gas Flow scfhhr	(TG-751) Heat Input mmBtu/hr	(TG-751) Heat 1-Min	(TG-751) Megawatts / Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min
2/16 14:55	95907.0	44.92	3.8	1200.0	
2/16 14:56	94885.0	44.43	3.8	1200.0	
2/16 14:57	95716.0	44.84	3.8	1200.2	
2/16 14:58	95421.0	44.62	3.8	1200.2	
2/16 14:59	95469.0	44.64	3.8	1199.8	
2/16 15:00	95068.0	44.54	3.8	1199.8	
2/16 15:01	96321.0	45.10	3.8	1199.8	
2/16 15:02	95790.0	44.81	3.8	1200.0	
2/16 15:03	96836.0	45.39	3.8	1200.2	
2/16 15:04	95399.0	44.65	3.8	1200.0	
2/16 15:05	95451.0	44.69	3.8	1200.0	
2/16 15:06	96320.0	44.57	3.8	1199.8	
2/16 15:07	96427.0	45.09	3.8	1200.2	
2/16 15:08	95846.0	44.91	3.8	1200.2	
2/16 15:09	96290.0	44.66	3.8	1199.5	
2/16 15:10	94540.0	44.28	3.8	1200.2	
2/16 15:11	96151.0	45.04	3.8	1199.8	
2/16 15:12	96305.0	45.03	3.8	1199.7	
2/16 15:13	95858.0	44.82	3.8	1199.8	
2/16 15:14	96705.0	45.13	3.8	1199.8	
2/16 15:15	94732.0	44.27	3.8	1200.3	
2/16 15:16	96133.0	44.95	3.8	1200.0	
2/16 15:17	95485.0	44.73	3.8	1200.0	
2/16 15:18	95282.0	44.61	3.8	1199.8	
2/16 15:19	95721.0	44.79	3.8	1199.7	
2/16 15:20	95433.0	44.62	3.8	1200.2	
2/16 15:21	95334.0	44.60	3.8	1200.3	
2/16 15:22	96158.0	44.96	3.8	1200.0	
2/16 15:23	96104.0	45.01	3.8	1200.0	
2/16 15:24	95708.0	44.75	3.8	1199.8	
2/16 15:25	95413.0	44.69	3.8	1200.2	
2/16 15:26	95687.0	44.84	3.8	1199.8	
2/16 15:27	96935.0	45.33	3.8	1199.5	
2/16 15:28	96074.0	44.90	3.8	1200.2	
2/16 15:29	95568.0	44.69	3.8	1199.7	
2/16 15:30	94888.0	44.29	3.8	1200.0	
2/16 15:31	95700.0	44.72	3.8	1199.7	
2/16 15:32	95836.0	44.74	3.8	1200.0	
2/16 15:33	96761.0	45.26	3.8	1200.7	
2/16 15:34	95596.0	44.76	3.8	1200.2	
2/16 15:35	96095.0	44.99	3.8	1200.0	
2/16 15:36	96106.0	45.05	3.8	1199.8	
2/16 15:37	95985.0	44.99	3.8	1199.5	
2/16 15:38	96823.0	45.24	3.8	1200.0	
2/16 15:39	96839.0	45.28	3.8	1199.8	
2/16 15:40	96457.0	45.08	3.8	1200.2	
2/16 15:41	96840.0	44.64	3.8	1200.2	
2/16 15:42	95878.0	44.81	3.8	1199.8	
2/16 15:43	96328.0	44.96	3.8	1200.2	

	(TG-751) Landfill Gas Flow scfh 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts - Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp				
2/16 15:44	96226.0	45.00	3.8	1200.0
2/16 15:45	95168.0	44.50	3.8	1199.8
2/16 15:46	95638.0	44.72	3.8	1199.8
2/16 15:47	96827.0	45.19	3.8	1200.0
2/16 15:48	96108.0	44.84	3.8	1200.7
2/16 15:49	96604.0	45.06	3.8	1200.0
2/16 15:50	96035.0	44.80	3.8	1200.2
2/16 15:51	95122.0	44.43	3.8	1199.7
2/16 15:52	94760.0	44.21	3.8	1199.7
2/16 15:53	96370.0	44.91	3.8	1200.2
2/16 15:54	96383.0	44.93	3.8	1199.7
2/16 15:55	96635.0	45.03	3.8	1200.0
2/16 15:56	96195.0	44.88	3.8	1200.2
2/16 15:57	97052.0	45.27	3.8	1199.7
2/16 15:58	96950.0	45.16	3.8	1200.0
2/16 15:59	97370.0	45.39	3.8	1199.8
2/16 16:00	96642.0	45.00	3.8	1199.8
2/16 16:01	95857.0	44.72	3.8	1200.2
2/16 16:02	96240.0	44.85	3.8	1200.0
2/16 16:03	96520.0	44.56	3.8	1200.0
2/16 16:04	96485.0	45.01	3.8	1199.8
2/16 16:05	96664.0	45.06	3.8	1200.2
2/16 16:06	95736.0	44.66	3.8	1199.7
2/16 16:07	96913.0	45.10	3.8	1200.0
2/16 16:08	96796.0	45.05	3.8	1199.8
2/16 16:09	96967.0	45.15	3.8	1199.8
2/16 16:10	96492.0	44.91	3.8	1200.0
2/16 16:11	96048.0	44.70	3.8	1200.0
2/16 16:12	95987.0	44.74	3.8	1200.2
2/16 16:13	96389.0	44.88	3.8	1200.0
2/16 16:14	96545.0	44.92	3.8	1200.0
2/16 16:15	96022.0	44.67	3.8	1200.0
2/16 16:16	95564.0	44.47	3.8	1200.0
2/16 16:17	95421.0	44.43	3.8	1200.0
2/16 16:18	96323.0	44.85	3.8	1199.8
2/16 16:19	96302.0	44.90	3.8	1199.8
2/16 16:20	96568.0	45.05	3.8	1199.8
2/16 16:21	96460.0	44.98	3.8	1199.8
2/16 16:22	96079.0	44.72	3.8	1200.0
2/16 16:23	96826.0	45.17	3.8	1200.0
2/16 16:24	96354.0	44.84	3.8	1200.0
2/16 16:25	96223.0	44.78	3.8	1200.0
2/16 16:26	96325.0	44.83	3.8	1200.0
2/16 16:27	97060.0	45.17	3.8	1200.0
2/16 16:28	96099.0	44.72	3.8	1200.0
2/16 16:29	96580.0	44.95	3.8	1200.0
2/16 16:30	97255.0	45.26	3.8	1200.5
2/16 16:31	95105.0	44.35	3.8	1200.0
2/16 16:32	96466.0	44.96	3.8	1200.0
Average Run 6	96136.4	44.8	3.8	1200.0

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Temp °F	(TG-751) T7 Exhaust Temp °F
	1-Min	1-Min	1-Min	1-Min
2/16 16:33	95714.0	44.65	3.8	1199.7
2/16 16:34	96057.0	44.74	3.8	1199.7
2/16 16:35	96876.0	45.07	3.8	1200.0
2/16 16:36	97107.0	45.17	3.8	1200.2
2/16 16:37	96133.0	44.72	3.8	1200.0
2/16 16:38	95461.0	44.43	3.8	1200.0
2/16 16:39	96287.0	44.81	3.8	1200.0
2/16 16:40	95612.0	44.54	3.8	1200.2
2/16 16:41	96234.0	44.80	3.8	1199.8
2/16 16:42	95685.0	44.49	3.8	1200.0
2/16 16:43	95577.0	44.38	3.8	1200.0
2/16 16:44	97412.0	45.23	3.8	1200.3
2/16 16:45	96718.0	44.88	3.8	1200.2
2/16 16:46	95523.0	44.35	3.8	1200.0
2/16 16:47	96768.0	45.04	3.8	1199.8
2/16 16:48	97430.0	45.30	3.8	1200.0
2/16 16:49	96067.0	44.71	3.8	1199.7
2/16 16:50	95020.0	44.22	3.8	1200.2
2/16 16:51	96940.0	45.10	3.8	1199.7
2/16 16:52	96485.0	44.80	3.8	1200.0
2/16 16:53	96040.0	44.59	3.8	1200.0
2/16 16:54	96669.0	44.88	3.8	1199.8
2/16 16:55	96188.0	44.66	3.8	1200.0
2/16 16:56	96744.0	44.92	3.8	1200.3
2/16 16:57	97017.0	45.13	3.8	1200.0
2/16 16:58	95845.0	44.61	3.8	1200.0
2/16 16:59	96122.0	44.73	3.8	1199.7
2/16 17:00	96275.0	44.79	3.8	1199.8
2/16 17:01	95958.0	44.64	3.8	1199.8
2/16 17:02	97447.0	45.28	3.8	1200.2
2/16 17:03	97295.0	45.18	3.8	1199.8
2/16 17:04	97512.0	45.27	3.8	1200.0
2/16 17:05	97977.0	45.49	3.8	1200.2
2/16 17:06	97013.0	45.12	3.8	1200.0
2/16 17:07	94956.0	44.19	3.8	1200.2
2/16 17:08	96443.0	44.82	3.8	1200.0
2/16 17:09	97220.0	45.14	3.8	1200.2
2/16 17:10	97698.0	45.36	3.8	1200.0
2/16 17:11	95717.0	44.44	3.8	1200.0
2/16 17:12	96761.0	44.93	3.8	1200.0
2/16 17:13	96684.0	44.89	3.8	1200.0
2/16 17:14	96810.0	44.95	3.8	1200.2
2/16 17:15	95900.0	44.60	3.8	1200.0
2/16 17:16	96324.0	44.89	3.8	1199.8
2/16 17:17	96564.0	44.77	3.8	1199.8
2/16 17:18	96801.0	44.94	3.8	1199.8
2/16 17:19	95960.0	44.55	3.8	1200.2
2/16 17:20	97376.0	45.31	3.8	1200.0
2/16 17:21	96391.0	44.75	3.8	1199.8

	(TG-751) Landfill Gas Flow scfh/r	(TG-751) Heat Input mmBtu/hr	(TG-751) 1-Min	Megawatts 1-Min	(TG-751) T7 % F -Min	(TG-751) T7 Exhaust Temp °F -Min
Timestamp	1-Min	1-Min	1-Min	1-Min	1-Min	1-Min
2/16 17:22	96237.0	44.68	3.8	1200.0		
2/16 17:23	95462.0	44.32	3.8	1200.2		
2/16 17:24	96855.0	44.97	3.8	1200.0		
2/16 17:25	96708.0	44.90	3.8	1200.0		
2/16 17:26	96716.0	44.91	3.8	1199.8		
2/16 17:27	96872.0	44.98	3.8	1200.0		
2/16 17:28	96793.0	44.97	3.8	1199.8		
2/16 17:29	96328.0	44.73	3.8	1200.0		
2/16 17:30	96489.0	44.80	3.8	1199.7		
2/16 17:31	97797.0	45.41	3.8	1199.8		
2/16 17:32	97060.0	45.04	3.8	1200.3		
2/16 17:33	97805.0	45.41	3.8	1200.0		
2/16 17:34	97205.0	45.09	3.8	1200.2		
2/16 17:35	96292.0	44.71	3.8	1200.0		
2/16 17:36	96843.0	44.96	3.8	1200.0		
2/16 17:37	95118.0	44.16	3.8	1200.3		
2/16 17:38	97011.0	45.04	3.8	1200.0		
2/16 17:39	97348.0	45.20	3.8	1199.8		
2/16 17:40	97413.0	45.18	3.8	1200.2		
2/16 17:41	96489.0	44.80	3.8	1199.7		
2/16 17:42	96552.0	44.76	3.8	1199.8		
2/16 17:43	95845.0	44.50	3.8	1199.8		
2/16 17:44	96791.0	44.92	3.8	1200.3		
2/16 17:45	97563.0	45.33	3.8	1200.0		
2/16 17:46	97985.0	45.22	3.8	1200.2		
2/16 17:47	97122.0	45.07	3.8	1199.8		
2/16 17:48	96330.0	44.86	3.8	1200.2		
2/16 17:49	97385.0	45.15	3.8	1199.8		
2/16 17:50	96922.0	44.90	3.8	1200.5		
2/16 17:51	97388.0	45.15	3.8	1199.8		
2/16 17:52	95683.0	44.35	3.8	1200.0		
2/16 17:53	97397.0	45.19	3.8	1200.0		
2/16 17:54	97664.0	45.32	3.8	1200.0		
2/16 17:55	96812.0	44.93	3.8	1200.0		
2/16 18:00	96562.0	44.81	3.8	1199.7		
2/16 18:01	97212.0	45.09	3.8	1200.0		
2/16 18:02	97639.0	45.24	3.8	1200.0		
2/16 18:03	98222.0	45.47	3.8	1199.8		
2/16 18:04	97509.0	45.07	3.8	1200.0		
2/16 18:05	97257.0	45.06	3.8	1200.0		
2/16 18:06	96622.0	44.61	3.8	1199.7		
2/16 18:07	97471.0	45.16	3.8	1200.0		
2/16 18:08	98146.0	45.47	3.8	1199.8		
2/16 18:09	97927.0	45.37	3.8	1200.0		
2/16 18:10	97669.0	45.33	3.8	1200.0		

Cedar 5 Reports 3/8/2023 6:46 AM, CEDAR 1-Minute Data

Page 15 of 17

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min	(TG-751) T °F 1-Min
Timestamp					
2/16 18:11	96623.0	44.83	3.8	1200.0	
2/16 18:12	97477.0	45.18	3.8	1199.7	
2/16 18:13	97658.0	45.17	3.8	1200.0	
2/16 18:14	97586.0	45.21	3.8	1200.2	
2/16 18:15	98020.0	45.35	3.8	1200.2	
2/16 18:16	98015.0	45.38	3.8	1200.0	
2/16 18:17	97388.0	45.03	3.8	1199.8	
2/16 18:18	97698.0	45.21	3.8	1199.8	
2/16 18:19	97575.0	45.13	3.8	1199.8	
2/16 18:20	98105.0	45.37	3.8	1200.0	
2/16 18:21	96644.0	44.67	3.8	1200.0	
2/16 18:22	97178.0	44.94	3.8	1200.0	
2/16 18:23	97553.0	45.17	3.8	1200.0	
2/16 18:24	97124.0	44.91	3.8	1199.8	
2/16 18:25	96951.0	44.92	3.8	1199.7	
2/16 18:26	98181.0	45.40	3.8	1199.8	
2/16 18:27	96376.0	44.55	3.8	1200.0	
2/16 18:28	97434.0	45.03	3.8	1200.0	
2/16 18:29	96749.0	44.77	3.8	1199.8	
2/16 18:30	97141.0	44.95	3.8	1200.0	
2/16 18:31	97665.0	45.21	3.8	1200.0	
2/16 18:32	97570.0	45.17	3.8	1200.0	
2/16 18:33	96823.0	44.86	3.8	1199.8	
2/16 18:34	97330.0	45.01	3.8	1200.0	
2/16 18:35	97683.0	45.15	3.8	1200.0	
2/16 18:36	97960.0	45.25	3.8	1200.0	
2/16 18:37	97400.0	44.99	3.8	1200.2	
2/16 18:38	97708.0	45.16	3.8	1200.2	
2/16 18:39	96927.0	44.87	3.8	1199.8	
2/16 18:40	98454.0	44.66	3.8	1199.8	
2/16 18:41	98675.0	44.76	3.8	1200.0	
2/16 18:42	98390.0	45.48	3.8	1199.7	
2/16 18:43	97596.0	45.11	3.8	1200.0	
2/16 18:44	98349.0	45.46	3.8	1199.8	
2/16 18:45	98664.0	45.63	3.8	1200.0	
2/16 18:46	98357.0	45.46	3.8	1200.0	
2/16 18:47	97137.0	44.90	3.8	1200.0	
2/16 18:48	97081.0	44.89	3.8	1200.0	
2/16 18:49	97811.0	45.27	3.8	1200.0	
2/16 18:50	97198.0	44.95	3.8	1200.3	
2/16 18:51	97287.0	45.00	3.8	1200.0	
2/16 18:52	97686.0	45.26	3.8	1200.5	
2/16 18:53	97299.0	45.08	3.8	1199.8	
2/16 18:54	97811.0	45.32	3.8	1199.8	
2/16 18:55	97593.0	45.21	3.8	1200.0	
2/16 18:56	96682.0	44.71	3.8	1200.0	
2/16 18:57	97374.0	45.00	3.8	1200.0	
2/16 18:58	98510.0	45.53	3.8	1200.2	
2/16 18:59	98196.0	45.39	3.8	1200.2	

Cedar 5 Reports 3/8/2023 6:46 AM, CeDAR 1-Minute Data

Page 16 of 17

	(TG-751) Landfill Gas Flow scf/hr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp				
2/16 19:00	98755.0	45.46	3.8	1200.3
Average (all)	97305.9	45.21	3.8	1200.0
Total (all)	--	--	--	--
Minimum (all)	94167.0	44.13	3.8	1197.3
Maximum (all)	104542.0	47.02	3.9	1202.8
Averages (valid values only)	97305.9	45.21	3.8	1200.0
Total (valid values only)	--	--	--	--
Count (valid values only)	781	781	781	781

CeDAR 1-Minute Data
Sunshine Gas Producers, LLC
Data for 2/17/2023 6:00 AM thru 2/17/2023 7:00 PM

Timestamp	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts 1-Min	(TG-751) T7 °F 1-Min
2/17 6:00	96692.0	45.30	3.8	1199.8
2/17 6:01	97159.0	45.46	3.8	1200.0
2/17 6:02	96941.0	45.33	3.8	1199.7
2/17 6:03	97711.0	45.67	3.8	1199.8
2/17 6:04	97290.0	45.52	3.8	1200.0
2/17 6:05	96464.0	45.13	3.8	1199.7
2/17 6:06	97195.0	45.45	3.8	1199.8
2/17 6:07	97515.0	45.60	3.8	1200.3
2/17 6:08	97735.0	45.73	3.8	1199.5
2/17 6:09	97054.0	45.38	3.8	1200.2
2/17 6:10	97716.0	45.72	3.8	1200.0
2/17 6:11	96515.0	45.17	3.8	1200.2
2/17 6:12	98803.0	46.26	3.8	1199.8
2/17 6:13	97284.0	45.49	3.8	1200.0
2/17 6:14	98076.0	45.86	3.8	1200.0
2/17 6:15	98385.0	46.01	3.8	1200.2
2/17 6:16	97516.0	45.58	3.8	1200.0
2/17 6:17	97656.0	45.67	3.8	1200.0
2/17 6:18	97333.0	45.53	3.8	1200.0
2/17 6:19	96844.0	45.39	3.8	1200.0
2/17 6:20	97835.0	45.84	3.8	1200.0
2/17 6:21	97665.0	45.78	3.8	1200.0
2/17 6:22	97699.0	45.70	3.8	1200.2
2/17 6:23	97778.0	45.74	3.8	1200.0
2/17 6:24	96859.0	45.29	3.8	1199.8
2/17 6:25	96915.0	45.34	3.8	1200.0
2/17 6:26	97938.0	45.80	3.8	1200.0
2/17 6:27	97272.0	45.48	3.8	1199.7
2/17 6:28	97966.0	45.79	3.8	1200.0
2/17 6:29	97370.0	45.45	3.8	1200.2
2/17 6:30	98542.0	46.05	3.8	1200.2
2/17 6:31	99449.0	46.50	3.8	1200.0
2/17 6:32	98071.0	45.86	3.8	1199.8
2/17 6:33	97728.0	45.70	3.8	1200.0
2/17 6:34	96335.0	45.05	3.8	1200.0
2/17 6:35	96922.0	45.32	3.8	1199.8
2/17 6:36	96871.0	45.25	3.8	1200.0
2/17 6:37	97134.0	45.34	3.8	1199.8
2/17 6:38	95578.0	44.67	3.8	1200.0
2/17 6:39	96844.0	45.19	3.8	1200.0
2/17 6:40	97281.0	45.46	3.8	1199.8
2/17 6:41	96806.0	45.22	3.8	1200.0
2/17 6:42	96971.0	45.34	3.8	1200.0
2/17 6:43	96327.0	45.06	3.8	1200.0
2/17 6:44	98031.0	45.82	3.8	1199.3

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) Megawatts 1-Min	(TG-751) 1-Min	(TG-751) 1-Min
Timestamp	1-Min	1-Min	1-Min	1-Min	Exhaust Temp °F 1-Min
2/17/6:45	97277.0	45.47	3.8	1200.2	
2/17/6:46	98538.0	46.06	3.8	1200.0	
2/17/6:47	97029.0	45.26	3.8	1199.8	
2/17/6:48	97451.0	45.46	3.8	1200.2	
2/17/6:49	97730.0	45.61	3.8	1200.2	
2/17/6:50	97389.0	45.54	3.8	1199.8	
2/17/6:51	97395.0	45.52	3.8	1200.0	
2/17/6:52	97812.0	45.76	3.8	1200.0	
2/17/6:53	97520.0	45.60	3.8	1200.0	
2/17/6:54	97141.0	45.42	3.8	1200.0	
2/17/6:55	96799.0	45.22	3.8	1199.7	
2/17/6:56	98241.0	45.83	3.8	1200.0	
2/17/6:57	98601.0	45.09	3.8	1200.7	
2/17/6:58	96754.0	45.24	3.8	1200.0	
2/17/6:59	97046.0	45.44	3.8	1200.0	
2/17/7:00	97405.0	45.61	3.8	1200.0	
2/17/7:01	96979.0	45.43	3.8	1200.0	
2/17/7:02	98318.0	45.07	3.8	1200.2	
2/17/7:03	96934.0	45.32	3.8	1200.0	
2/17/7:04	97136.0	45.53	3.8	1200.2	
2/17/7:05	96886.0	45.41	3.8	1199.8	
2/17/7:06	97596.0	45.75	3.8	1200.0	
2/17/7:07	96832.0	45.28	3.8	1200.0	
2/17/7:08	96795.0	45.26	3.8	1200.3	
2/17/7:09	97975.0	45.89	3.8	1200.2	
2/17/7:10	96342.0	45.15	3.8	1200.2	
2/17/7:11	96451.0	45.25	3.8	1200.0	
2/17/7:12	96034.0	45.11	3.8	1199.7	
2/17/7:13	97015.0	45.47	3.8	1199.5	
2/17/7:14	96422.0	45.19	3.8	1199.7	
2/17/7:15	97206.0	45.51	3.8	1200.0	
2/17/7:16	97035.0	45.46	3.8	1200.0	
2/17/7:17	97265.0	45.59	3.8	1200.0	
2/17/7:18	96958.0	45.45	3.8	1200.0	
2/17/7:19	97098.0	45.51	3.8	1200.3	
2/17/7:20	98397.0	46.14	3.8	1199.2	
2/17/7:21	97160.0	45.54	3.8	1200.0	
2/17/7:22	98467.0	45.24	3.8	1199.5	
2/17/7:23	98051.0	45.96	3.8	1200.0	
2/17/7:24	98080.0	45.97	3.8	1200.0	
2/17/7:25	96229.0	45.19	3.8	1200.0	
2/17/7:26	96158.0	45.16	3.8	1200.0	
2/17/7:27	98474.0	45.23	3.8	1200.0	
2/17/7:28	98603.0	45.45	3.8	1200.3	
2/17/7:29	97005.0	45.47	3.8	1200.2	
2/17/7:30	97377.0	45.69	3.8	1199.8	
2/17/7:31	97019.0	45.47	3.8	1200.0	
2/17/7:32	97406.0	45.69	3.8	1200.0	
2/17/7:33	97418.0	45.66	3.8	1200.0	

	(TG-751) Landfill Gas Flow scfh/r 1 Min	(TG-751) Heat Input mmwts/hr 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T °F 1 Min	(TG-751) T °F 1 Min
2/17 7:34	95747.0	44.86	3.8	1199.8	
2/17 7:35	98504.0	46.17	3.8	1200.0	
2/17 7:36	97588.0	45.72	3.8	1200.2	
2/17 7:37	97206.0	45.56	3.8	1200.0	
2/17 7:38	97051.0	45.49	3.8	1199.8	
2/17 7:39	97380.0	45.55	3.8	1200.0	
2/17 7:40	96685.0	45.29	3.8	1200.0	
2/17 7:41	96487.0	45.12	3.8	1200.0	
2/17 7:42	96080.0	45.89	3.8	1200.0	
2/17 7:43	96867.0	45.30	3.8	1199.8	
2/17 7:44	96895.0	45.31	3.8	1200.3	
2/17 7:45	97013.0	45.36	3.8	1200.0	
2/17 7:46	96481.0	45.14	3.8	1200.2	
2/17 7:47	97636.0	45.73	3.8	1199.8	
2/17 7:48	97632.0	45.68	3.8	1200.0	
2/17 7:49	97809.0	45.84	3.8	1200.3	
2/17 7:50	95803.0	44.90	3.8	1199.8	
2/17 7:51	97178.0	45.50	3.8	1200.0	
2/17 7:52	97520.0	45.60	3.8	1199.5	
2/17 7:53	98634.0	45.16	3.8	1199.8	
2/17 7:54	97931.0	45.68	3.8	1200.0	
2/17 7:55	96701.0	45.11	3.8	1200.3	
2/17 7:56	96303.0	45.11	3.8	1200.0	
2/17 7:57	97095.0	45.43	3.8	1200.0	
2/17 7:58	98196.0	45.92	3.8	1199.8	
2/17 7:59	98136.0	45.89	3.8	1200.2	
2/17 8:00	97200.0	45.47	3.8	1199.8	
2/17 8:01	97286.0	45.55	3.8	1199.8	
2/17 8:02	97695.0	45.68	3.8	1199.8	
2/17 8:03	97515.0	45.57	3.8	1200.2	
2/17 8:04	98118.0	45.79	3.8	1200.0	
2/17 8:05	97250.0	45.39	3.8	1200.0	
2/17 8:06	97484.0	45.53	3.8	1200.2	
2/17 8:07	96941.0	45.33	3.8	1200.2	
2/17 8:08	96994.0	45.46	3.8	1199.8	
2/17 8:09	97881.0	45.83	3.8	1200.0	
2/17 8:10	96720.0	45.28	3.8	1199.7	
2/17 8:11	96970.0	45.36	3.8	1200.0	
2/17 8:12	97523.0	45.60	3.8	1200.0	
2/17 8:13	97821.0	45.85	3.8	1200.2	
2/17 8:14	96812.0	45.40	3.8	1200.5	
2/17 8:15	97738.0	45.81	3.8	1199.0	
2/17 8:16	97696.0	45.56	3.8	1200.0	
2/17 8:17	97517.0	45.37	3.8	1200.0	
2/17 8:18	98901.0	45.73	3.8	1199.3	
2/17 8:19	97834.0	45.22	3.8	1201.0	
2/17 8:20	97062.0	45.25	3.8	1200.0	
2/17 8:21	97144.0	45.30	3.8	1200.0	
2/17 8:22	96693.0	45.08	3.8	1200.0	

Timestamp	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
2/17 8:23	98207.0	45.81	3.8	1200.0
2/17 8:24	97477.0	45.47	3.8	1200.2
2/17 8:25	97622.0	45.54	3.8	1200.2
2/17 8:26	96645.0	45.15	3.8	1200.5
2/17 8:27	97928.0	45.77	3.8	1199.7
2/17 8:28	97862.0	45.73	3.8	1200.3
2/17 8:29	96106.0	44.94	3.8	1200.0
2/17 8:30	96919.0	45.38	3.8	1200.2
2/17 8:31	96386.0	45.09	3.8	1199.8
2/17 8:32	97117.0	45.41	3.8	1199.8
2/17 8:33	97518.0	45.62	3.8	1200.2
2/17 8:34	96669.0	45.31	3.8	1200.2
2/17 8:35	96854.0	45.39	3.8	1200.2
2/17 8:36	97600.0	45.72	3.8	1200.0
2/17 8:37	96996.0	45.44	3.8	1200.2
2/17 8:38	96268.0	45.04	3.8	1200.2
2/17 8:39	96201.0	45.07	3.8	1199.5
2/17 8:40	96152.0	44.98	3.8	1200.2
2/17 8:41	97625.0	45.68	3.8	1199.2
2/17 8:42	95962.0	44.87	3.8	1200.2
2/17 8:43	97250.0	45.47	3.8	1200.2
2/17 8:44	96929.0	45.34	3.8	1200.0
2/17 8:45	97813.0	45.79	3.8	1199.8
2/17 8:46	98038.0	45.87	3.8	1200.0
2/17 8:47	97373.0	45.61	3.8	1200.2
2/17 8:48	96486.0	45.21	3.8	1200.0
2/17 8:49	96438.0	45.10	3.8	1200.0
2/17 8:50	95627.0	44.79	3.8	1199.8
2/17 8:51	96968.0	45.34	3.8	1200.0
2/17 8:52	97213.0	45.38	3.8	1200.0
2/17 8:53	97635.0	45.64	3.8	1200.0
2/17 8:54	97540.0	45.56	3.8	1199.5
2/17 8:55	98360.0	45.82	3.8	1200.2
2/17 8:56	97657.0	45.51	3.8	1200.0
2/17 8:57	96727.0	45.12	3.8	1200.2
2/17 8:58	97332.0	45.40	3.8	1200.0
2/17 8:59	97732.0	45.50	3.8	1199.3
2/17 9:00	99017.0	45.71	3.8	1199.5
2/17 9:05	98084.0	45.89	3.8	1199.5
2/17 9:06	97584.0	45.74	3.8	1201.0
2/17 9:07	96646.0	45.46	3.8	1201.0
2/17 9:03	96464.0	45.29	3.8	1200.0
2/17 9:04	97085.0	45.54	3.8	1199.5
2/17 9:05	96990.0	45.23	3.8	1200.0
2/17 9:10	96768.0	45.31	3.8	1199.8
2/17 9:11	97033.0	45.37	3.8	1200.2

	(TG-751) Landfill Gas Flow scfh/r 1 Min	(TG-751) Heat Input mmBtu/hr 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T7 Exhaust Temp °F 1 Min
Timestamp				
2/17 9:12	97412.0	45.57	3.8	1199.5
2/17 9:13	96993.0	45.25	3.8	1200.0
2/17 9:14	96936.0	45.19	3.8	1199.7
2/17 9:15	97022.0	45.21	3.8	1200.8
2/17 9:16	96118.0	44.95	3.8	1200.5
2/17 9:17	97383.0	45.30	3.8	1199.3
2/17 9:18	97310.0	45.08	3.8	1199.0
2/17 9:19	98010.0	45.27	3.8	1200.5
2/17 9:20	96924.0	45.13	3.8	1201.2
2/17 9:21	96510.0	45.21	3.8	1200.2
2/17 9:22	96947.0	45.33	3.8	1199.5
2/17 9:23	96583.0	45.18	3.8	1200.0
2/17 9:24	98777.0	45.25	3.8	1200.0
2/17 9:25	96458.0	45.02	3.8	1200.0
2/17 9:26	96897.0	45.28	3.8	1200.0
2/17 9:27	96664.0	45.17	3.8	1200.0
2/17 9:28	98716.0	46.16	3.8	1199.8
2/17 9:29	97267.0	45.43	3.8	1199.8
2/17 9:30	97017.0	45.26	3.8	1200.0
2/17 9:31	97246.0	45.37	3.8	1200.0
2/17 9:32	97940.0	45.75	3.8	1200.0
2/17 9:33	97959.0	45.65	3.8	1199.7
2/17 9:34	97546.0	45.42	3.8	1200.5
2/17 9:35	96218.0	44.92	3.8	1200.0
2/17 9:36	97972.0	45.70	3.8	1200.0
2/17 9:37	97501.0	45.48	3.8	1200.0
2/17 9:38	97283.0	45.38	3.8	1200.2
2/17 9:39	98662.0	45.12	3.8	1200.0
2/17 9:40	97006.0	45.28	3.8	1199.8
2/17 9:41	97511.0	45.60	3.8	1200.0
2/17 9:42	97331.0	45.51	3.8	1200.0
2/17 9:43	97595.0	45.56	3.8	1200.0
2/17 9:44	98675.0	45.13	3.8	1200.0
2/17 9:45	96979.0	45.22	3.8	1200.2
2/17 9:46	98041.0	45.76	3.8	1200.2
2/17 9:47	98500.0	45.93	3.8	1198.8
2/17 9:48	98019.0	45.37	3.8	1200.2
2/17 9:49	98687.0	44.92	3.8	1200.7
2/17 9:50	97443.0	45.54	3.8	1200.5
2/17 9:51	96312.0	45.03	3.8	1199.8
2/17 9:52	96476.0	45.17	3.8	1200.0
2/17 9:53	96639.0	45.25	3.8	1200.2
2/17 9:54	98672.0	45.33	3.8	1200.0
2/17 9:55	98162.0	46.01	3.8	1200.0
2/17 9:56	95986.0	44.99	3.8	1199.8
2/17 9:57	96150.0	45.02	3.8	1200.0
2/17 9:58	96657.0	45.30	3.8	1199.8
2/17 9:59	98608.0	45.04	3.8	1200.0
2/17 10:00	97091.0	45.46	3.8	1200.2

	(TG-751) Landfill Gas Flow scfh/ 1. Min	(TG-751) Heat Input mmBtu/hr 1. Min	(TG-751) Megawatts 1. Min	(TG-751) T7 Exhaust Temp °F 1. Min
2/17 10:01	96494.0	45.20	3.8	1200.3
2/17 10:02	96558.0	45.26	3.8	1200.7
2/17 10:03	96749.0	45.37	3.8	1199.8
2/17 10:04	96000.0	45.00	3.8	1199.8
2/17 10:05	96039.0	45.10	3.8	1199.0
2/17 10:06	98721.0	45.92	3.8	1199.0
2/17 10:07	98015.0	45.23	3.8	1200.2
2/17 10:08	98150.0	45.34	3.8	1200.3
2/17 10:09	97206.0	44.93	3.8	1199.5
2/17 10:10	98907.0	45.48	3.8	1198.8
2/17 10:11	99814.0	45.64	3.8	1200.3
2/17 10:12	98098.0	45.04	3.8	1201.0
2/17 10:13	98830.0	45.61	3.8	1201.8
2/17 10:14	97872.0	45.76	3.8	1199.2
2/17 10:15	98400.0	45.73	3.8	1199.3
2/17 10:16	98608.0	45.60	3.8	1200.3
2/17 10:17	96851.0	44.94	3.8	1200.5
2/17 10:18	96570.0	45.07	3.8	1200.8
2/17 10:19	97047.0	45.41	3.8	1200.0
2/17 10:20	96672.0	45.31	3.8	1200.0
2/17 10:21	96784.0	45.38	3.8	1200.0
2/17 10:22	96548.0	45.25	3.8	1200.3
2/17 10:23	96501.0	45.26	3.8	1200.0
2/17 10:24	97529.0	45.66	3.8	1198.8
2/17 10:25	97333.0	45.17	3.8	1201.3
2/17 10:26	96321.0	45.12	3.8	1200.3
2/17 10:27	96053.0	45.07	3.8	1200.3
2/17 10:28	96578.0	45.35	3.8	1199.5
2/17 10:29	96452.0	45.21	3.8	1199.5
2/17 10:30	97308.0	45.52	3.8	1200.0
2/17 10:31	96705.0	45.22	3.8	1200.2
2/17 10:32	97179.0	45.53	3.8	1200.0
2/17 10:33	96840.0	45.37	3.8	1200.5
2/17 10:34	95456.0	44.82	3.8	1200.2
2/17 10:35	95187.0	44.66	3.8	1199.8
2/17 10:36	95425.0	44.73	3.8	1199.7
2/17 10:37	97064.0	45.47	3.8	1199.8
2/17 10:38	96878.0	45.32	3.8	1200.2
2/17 10:39	96509.0	45.13	3.8	1200.0
2/17 10:40	95715.0	44.76	3.8	1200.3
2/17 10:41	96403.0	45.18	3.8	1200.7
2/17 10:42	95973.0	44.98	3.8	1200.2
2/17 10:43	95792.0	44.90	3.8	1199.8
2/17 10:44	96834.0	45.38	3.8	1200.0
2/17 10:45	98479.0	45.19	3.8	1199.3
2/17 10:46	96358.0	45.01	3.8	1200.3
2/17 10:47	97875.0	45.75	3.8	1200.0
2/17 10:48	96582.0	45.14	3.8	1200.5
2/17 10:49	93932.0	44.02	3.8	1200.3

	(TG-751) Landfill Gas Flow scf/hr 1 Min	(TG-751) Heat Input mmBtu/hr 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T °F 1 Min	(TG-751) T Exhaust Temp °F 1 Min
Timestamp					
2/17 10:50	96291.0	45.13	3.8	1200.3	
2/17 10:51	96063.0	45.04	3.8	1199.7	
2/17 10:52	95446.0	44.74	3.8	1200.0	
2/17 10:53	94803.0	44.43	3.8	1199.7	
2/17 10:54	96051.0	44.93	3.8	1199.8	
2/17 10:55	96177.0	44.97	3.8	1200.0	
2/17 10:56	96323.0	44.63	3.8	1200.0	
2/17 10:57	95497.0	44.76	3.8	1200.0	
2/17 10:58	95765.0	44.89	3.8	1200.0	
2/17 10:59	97191.0	45.55	3.8	1200.0	
2/17 11:00	95861.0	44.96	3.8	1200.0	
2/17 11:01	96690.0	44.94	3.8	1200.0	
2/17 11:02	95592.0	44.83	3.8	1199.8	
2/17 11:03	95045.0	44.63	3.8	1200.2	
2/17 11:04	95414.0	44.82	3.8	1199.8	
2/17 11:05	95547.0	44.81	3.8	1199.7	
2/17 11:06	95462.0	44.74	3.8	1200.0	
2/17 11:07	95768.0	44.89	3.8	1199.8	
2/17 11:08	95891.0	44.94	3.8	1199.8	
2/17 11:09	96108.0	45.08	3.8	1200.3	
2/17 11:10	96042.0	45.06	3.8	1200.0	
2/17 11:11	93889.0	44.03	3.8	1200.0	
2/17 11:12	95859.0	44.98	3.8	1200.0	
2/17 11:13	96222.0	45.07	3.8	1200.0	
2/17 11:14	94843.0	44.45	3.8	1200.0	
2/17 11:15	94861.0	44.46	3.8	1200.3	
2/17 11:16	95336.0	44.71	3.8	1200.0	
2/17 11:17	94892.0	44.47	3.8	1199.8	
2/17 11:18	95768.0	44.91	3.8	1200.0	
2/17 11:19	95493.0	44.76	3.8	1199.8	
2/17 11:20	96301.0	45.14	3.8	1200.2	
2/17 11:21	94873.0	44.45	3.8	1199.8	
2/17 11:22	94648.0	44.36	3.8	1200.3	
2/17 11:23	95306.0	44.75	3.8	1200.5	
2/17 11:24	94502.0	44.40	3.8	1199.8	
2/17 11:25	95296.0	44.70	3.8	1200.0	
2/17 11:26	95061.0	44.55	3.8	1200.2	
2/17 11:27	95401.0	44.79	3.7	1199.7	
2/17 11:28	95770.0	44.89	3.7	1200.0	
2/17 11:29	95306.0	44.67	3.8	1199.7	
2/17 11:30	95150.0	44.55	3.8	1199.8	
2/17 11:31	95382.0	44.62	3.8	1200.0	
2/17 11:32	95482.0	44.73	3.8	1199.7	
2/17 11:33	95586.0	44.76	3.8	1200.2	
2/17 11:34	95002.0	44.53	3.8	1200.2	
2/17 11:35	95000.0	44.53	3.8	1200.0	
2/17 11:36	94945.0	44.50	3.8	1199.8	
2/17 11:37	95010.0	44.53	3.8	1200.0	
2/17 11:38	94614.0	44.34	3.8	1200.0	

	(TG-751) Landfill Gas Flow scfh/r 1 Min	(TG-751) Heat Input mmBtu/hr 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T7 Exhaust Temp °F 1 Min
2/17 11:39	95386.0	44.76	3.8	1200.0
2/17 11:40	95138.0	44.61	3.8	1200.0
2/17 11:41	94089.0	44.10	3.8	1200.2
2/17 11:42	94949.0	44.53	3.8	1200.2
2/17 11:43	95071.0	44.66	3.8	1200.0
2/17 11:44	94579.0	44.41	3.7	1199.8
2/17 11:45	95717.0	44.86	3.7	1199.7
2/17 11:46	95013.0	44.46	3.8	1199.8
2/17 11:47	94804.0	44.31	3.8	1200.0
2/17 11:48	95153.0	44.51	3.8	1200.2
2/17 11:49	94658.0	44.37	3.8	1200.0
2/17 11:50	94804.0	44.40	3.8	1199.8
2/17 11:51	94172.0	44.11	3.8	1199.8
2/17 11:52	95313.0	44.59	3.8	1200.3
2/17 11:53	95395.0	44.71	3.8	1200.2
2/17 11:54	94155.0	44.11	3.7	1200.0
2/17 11:55	95486.0	43.80	3.7	1199.8
2/17 11:56	95070.0	44.51	3.7	1200.0
2/17 11:57	95798.0	44.87	3.7	1199.8
2/17 11:58	94213.0	44.14	3.7	1200.0
2/17 11:59	94998.0	44.50	3.7	1200.0
2/17 12:00	94365.0	44.18	3.7	1199.8
2/17 12:01	94536.0	44.28	3.7	1200.2
2/17 12:02	94114.0	44.11	3.8	1200.0
2/17 12:03	94928.0	44.49	3.7	1200.0
2/17 12:04	95131.0	44.59	3.7	1199.8
2/17 12:05	94508.0	44.30	3.8	1200.0
2/17 12:06	95077.0	44.56	3.8	1200.0
2/17 12:07	95634.0	44.80	3.7	1200.2
2/17 12:08	95693.0	44.87	3.8	1200.2
2/17 12:09	94090.0	44.20	3.8	1200.0
2/17 12:10	95248.0	44.75	3.8	1199.3
2/17 12:11	94860.0	44.28	3.8	1200.2
2/17 12:12	96330.0	44.87	3.8	1200.0
2/17 12:13	95779.0	44.58	3.8	1199.8
2/17 12:14	95894.0	44.61	3.8	1199.3
2/17 12:15	95792.0	44.25	3.8	1199.7
2/17 12:16	95474.0	44.59	3.8	1200.0
2/17 12:17	97548.0	45.06	3.8	1199.8
2/17 12:18	96769.0	44.73	3.8	1200.7
2/17 12:19	94557.0	43.88	3.8	1201.5
2/17 12:20	94313.0	43.98	3.7	1199.7
2/17 12:21	94772.0	44.19	3.7	1199.7
2/17 12:22	94876.0	44.26	3.7	1199.8
2/17 12:23	94465.0	44.07	3.7	1199.8
2/17 12:24	95522.0	45.03	3.7	1200.0
2/17 12:25	95638.0	44.64	3.7	1200.2
2/17 12:26	95027.0	44.33	3.8	1200.3
2/17 12:27	95852.0	44.73	3.7	1200.2

	(TG-751) Landfill Gas Flow scfh	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1-Min
Timestamp				
2/17 12:28	98538.0	44.63	3.8	1200.0
2/17 12:29	98083.0	44.38	3.7	1199.8
2/17 12:30	98426.0	45.01	3.8	1200.0
2/17 12:31	98545.0	44.59	3.8	1200.5
2/17 12:32	94464.0	44.12	3.7	1200.0
2/17 12:33	98871.0	44.78	3.8	1200.3
2/17 12:34	98295.0	44.56	3.7	1200.0
2/17 12:35	94443.0	44.16	3.7	1199.7
2/17 12:36	94440.0	44.16	3.7	1199.7
2/17 12:37	94652.0	44.28	3.8	1200.0
2/17 12:38	95033.0	44.39	3.7	1199.5
2/17 12:39	98502.0	44.78	3.8	1199.8
2/17 12:40	98890.0	44.63	3.8	1201.0
2/17 12:41	98461.0	44.61	3.7	1200.3
2/17 12:42	98078.0	44.48	3.7	1199.7
2/17 12:43	95706.0	44.50	3.7	1199.0
2/17 12:44	98343.0	44.56	3.8	1200.0
2/17 12:45	98255.0	44.51	3.7	1199.8
2/17 12:46	98345.0	44.55	3.7	1200.2
2/17 12:47	98875.0	44.42	3.7	1200.0
2/17 12:48	95432.0	44.18	3.7	1200.0
2/17 12:49	98393.0	44.66	3.7	1200.2
2/17 12:50	98920.0	44.47	3.7	1200.5
2/17 12:51	98542.0	44.50	3.7	1201.0
2/17 12:52	94684.0	44.27	3.7	1200.0
2/17 12:53	94612.0	44.32	3.7	1199.8
2/17 12:54	93610.0	43.79	3.7	1200.0
2/17 12:55	94609.0	44.27	3.7	1199.7
2/17 12:56	98649.0	44.73	3.7	1200.0
2/17 12:57	94957.0	44.40	3.7	1199.8
2/17 12:58	98447.0	45.10	3.7	1200.0
2/17 12:59	95063.0	44.45	3.7	1199.8
2/17 13:00	95111.0	44.47	3.7	1200.2
2/17 13:01	95362.0	44.56	3.7	1199.7
2/17 13:02	94463.0	44.08	3.7	1200.8
2/17 13:03	94691.0	44.31	3.7	1199.7
2/17 13:04	95015.0	44.46	3.7	1199.2
2/17 13:05	98034.0	44.49	3.7	1199.0
2/17 13:06	97554.0	44.89	3.7	1198.8
2/17 13:07	98337.0	45.04	3.7	1199.3
2/17 13:08	98111.0	44.43	3.8	1201.8
2/17 13:09	98216.0	44.16	3.7	1200.3
2/17 13:10	94427.0	43.92	3.7	1200.0
2/17 13:11	95168.0	44.33	3.7	1199.3
2/17 13:12	95176.0	44.35	3.7	1200.7
2/17 13:13	94032.0	44.09	3.7	1200.0
2/17 13:14	93559.0	44.00	3.7	1200.8
2/17 13:15	94963.0	44.74	3.7	1200.0
2/17 13:16	94782.0	44.65	3.7	1200.0

	(TG-751) Landfill Gas Flow scfh/r 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T °F 1 Min	(TG-751) T °F 1 Min
Timestamp					
2/17 13:17	94917.0	44.70	3.7	1199.8	
2/17 13:18	93768.0	44.14	3.7	1200.0	
2/17 13:19	94285.0	44.32	3.7	1199.8	
2/17 13:20	93473.0	44.00	3.7	1200.0	
2/17 13:21	94397.0	44.47	3.7	1200.0	
2/17 13:22	93159.0	43.87	3.7	1199.2	
2/17 13:23	93399.0	43.98	3.7	1200.0	
2/17 13:24	94270.0	44.37	3.7	1199.5	
2/17 13:25	95297.0	44.59	3.7	1199.0	
2/17 13:26	96795.0	45.03	3.7	1200.0	
2/17 13:27	95853.0	44.58	3.7	1200.0	
2/17 13:28	95268.0	44.32	3.7	1200.2	
2/17 13:29	95320.0	44.34	3.7	1200.0	
2/17 13:30	95328.0	44.37	3.7	1200.0	
2/17 13:31	94261.0	43.87	3.7	1199.8	
2/17 13:32	95577.0	44.50	3.7	1200.5	
2/17 13:33	94357.0	44.25	3.7	1200.7	
2/17 13:34	93146.0	43.86	3.7	1200.0	
2/17 13:35	93812.0	44.24	3.7	1200.0	
2/17 13:36	94273.0	44.50	3.7	1199.5	
2/17 13:37	94793.0	44.66	3.7	1199.8	
2/17 13:38	94140.0	44.33	3.7	1199.7	
2/17 13:39	96007.0	45.05	3.7	1199.0	
2/17 13:40	94726.0	44.11	3.7	1200.0	
2/17 13:41	95582.0	44.48	3.7	1199.8	
2/17 13:42	95140.0	44.28	3.7	1200.0	
2/17 13:43	95737.0	44.61	3.8	1200.3	
2/17 13:44	94640.0	44.10	3.7	1199.5	
2/17 13:45	95452.0	44.46	3.8	1200.8	
2/17 13:46	94215.0	44.24	3.7	1199.8	
2/17 13:47	95114.0	44.60	3.7	1199.7	
2/17 13:48	95064.0	44.57	3.7	1200.0	
2/17 13:49	94429.0	44.36	3.7	1200.2	
2/17 13:50	95051.0	44.67	3.7	1199.8	
2/17 13:51	94731.0	44.50	3.7	1200.2	
2/17 13:52	95078.0	45.58	3.7	1199.3	
2/17 13:53	96711.0	45.07	3.7	1200.3	
2/17 13:54	95826.0	44.73	3.7	1200.3	
2/17 13:55	94916.0	44.40	3.7	1199.5	
2/17 13:56	94272.0	44.05	3.7	1200.7	
2/17 13:57	94379.0	44.28	3.7	1200.0	
2/17 13:58	93755.0	43.99	3.7	1200.0	
2/17 13:59	94164.0	44.21	3.7	1199.5	
2/17 14:00	94440.0	44.26	3.7	1200.2	
2/17 14:01	92690.0	44.03	3.7	1200.0	
2/17 14:02	94740.0	44.56	3.7	1200.0	
2/17 14:03	95102.0	44.75	3.7	1200.0	
2/17 14:04	95384.0	44.81	3.7	1200.0	
2/17 14:05	94721.0	44.50	3.7	1200.0	

	(TG-751) Landfill Gas Flow scf/hr	(TG-751) Heat Input mmBtu/hr	(TG-751) 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T7 °F 1 Min	(TG-751) T7 Exhaust Temp °F 1 Min
Timestamp	1 Min	1 Min	1 Min	1 Min	1 Min	1 Min
2/17 14:06	94345.0	44.31	3.7	1200.0		
2/17 14:07	94750.0	44.44	3.7	1200.2		
2/17 14:08	94914.0	44.47	3.7	1199.0		
2/17 14:09	95703.0	44.36	3.7	1199.0		
2/17 14:10	95632.0	43.97	3.7	1200.8		
2/17 14:11	95220.0	44.04	3.7	1199.2		
2/17 14:12	97160.0	44.48	3.7	1199.5		
2/17 14:13	96139.0	44.77	3.8	1200.0		
2/17 14:14	97813.0	44.65	3.8	1200.3		
2/17 14:15	96562.0	44.28	3.7	1200.0		
2/17 14:16	96485.0	44.07	3.8	1199.7		
2/17 14:17	97747.0	44.47	3.8	1199.3		
2/17 14:18	97967.0	44.45	3.8	1200.3		
2/17 14:19	97717.0	44.52	3.8	1200.7		
2/17 14:20	97891.0	44.79	3.8	1200.2		
2/17 14:21	97181.0	44.49	3.7	1200.2		
2/17 14:22	97027.0	44.42	3.8	1199.5		
2/17 14:23	97154.0	44.40	3.8	1200.3		
2/17 14:24	96887.0	44.36	3.7	1200.0		
2/17 14:25	97394.0	44.61	3.8	1200.0		
2/17 14:26	96794.0	44.36	3.8	1199.8		
2/17 14:27	97869.0	44.80	3.8	1200.2		
2/17 14:28	97305.0	44.60	3.8	1200.0		
2/17 14:29	96873.0	44.33	3.8	1199.7		
2/17 14:30	97384.0	44.47	3.8	1200.0		
2/17 14:31	97747.0	44.75	3.8	1200.0		
2/17 14:32	97379.0	44.58	3.8	1200.0		
2/17 14:33	97160.0	44.48	3.7	1199.7		
2/17 14:34	97840.0	44.74	3.7	1199.8		
2/17 14:35	97474.0	44.57	3.8	1199.8		
2/17 14:36	96908.0	44.37	3.8	1200.0		
2/17 14:37	99062.0	45.35	3.8	1200.0		
2/17 14:38	97619.0	44.69	3.8	1200.0		
2/17 14:39	97969.0	44.76	3.8	1199.7		
2/17 14:40	98091.0	44.86	3.7	1200.0		
2/17 14:41	96911.0	44.24	3.7	1199.8		
2/17 14:42	96798.0	44.34	3.8	1200.5		
2/17 14:43	97688.0	44.77	3.8	1199.7		
2/17 14:44	96952.0	44.46	3.8	1200.0		
2/17 14:45	98056.0	45.00	3.8	1199.8		
2/17 14:46	97753.0	44.75	3.8	1200.0		
2/17 14:47	97567.0	44.77	3.8	1199.7		
2/17 14:48	97777.0	44.85	3.8	1200.0		
2/17 14:49	95794.0	43.96	3.8	1200.2		
2/17 14:50	96908.0	44.49	3.8	1200.0		
2/17 14:51	96830.0	44.45	3.7	1200.0		
2/17 14:52	96362.0	44.34	3.7	1200.3		
2/17 14:53	95712.0	44.15	3.7	1200.5		
2/17 14:54	95460.0	44.12	3.7	1200.2		

	(TG-751) Landfill Gas Flow scfh/r 1 Min	(TG-751) Heat Input mmBtu/hr 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T °F 1 Min
2/17 14:55	96294.0	44.53	3.7	1199.8
2/17 14:56	96431.0	44.60	3.7	1199.8
2/17 14:57	96286.0	44.51	3.7	1200.2
2/17 14:58	96852.0	44.76	3.7	1200.0
2/17 14:59	95470.0	44.20	3.7	1200.3
2/17 15:00	96223.0	44.54	3.7	1199.8
2/17 15:01	95524.0	44.18	3.7	1200.0
2/17 15:02	96247.0	44.55	3.7	1200.0
2/17 15:03	97551.0	45.14	3.7	1199.5
2/17 15:04	97153.0	44.87	3.7	1200.7
2/17 15:05	95165.0	44.26	3.7	1200.8
2/17 15:06	95259.0	44.44	3.7	1199.8
2/17 15:07	95081.0	44.37	3.7	1199.8
2/17 15:08	95481.0	44.52	3.7	1199.3
2/17 15:09	95716.0	44.61	3.8	1200.0
2/17 15:10	96272.0	44.91	3.7	1200.0
2/17 15:11	95436.0	44.50	3.7	1200.7
2/17 15:12	94819.0	44.25	3.7	1199.5
2/17 15:13	96757.0	44.93	3.7	1200.0
2/17 15:14	96053.0	44.65	3.7	1200.0
2/17 15:15	96466.0	44.82	3.7	1199.8
2/17 15:16	96189.0	44.58	3.7	1199.0
2/17 15:17	96808.0	44.69	3.8	1199.8
2/17 15:18	95437.0	44.08	3.7	1200.2
2/17 15:19	99500.0	44.38	3.8	1201.7
2/17 15:20	93909.0	44.09	3.7	1199.8
2/17 15:21	94657.0	44.58	3.7	1199.8
2/17 15:22	94599.0	44.49	3.7	1199.5
2/17 15:23	95597.0	44.89	3.7	1200.2
2/17 15:24	95601.0	44.63	3.7	1200.0
2/17 15:25	94443.0	44.40	3.7	1200.0
2/17 15:26	94565.0	44.53	3.7	1200.0
2/17 15:27	94401.0	44.37	3.7	1199.5
2/17 15:28	95340.0	44.69	3.7	1200.2
2/17 15:29	96046.0	44.84	3.7	1199.5
2/17 15:30	95360.0	44.46	3.7	1200.7
2/17 15:31	94212.0	44.11	3.7	1200.3
2/17 15:32	95008.0	44.50	3.7	1200.0
2/17 15:33	95494.0	44.74	3.7	1200.0
2/17 15:34	96048.0	44.91	3.7	1200.0
2/17 15:35	95277.0	44.55	3.7	1199.5
2/17 15:36	95395.0	44.61	3.7	1200.3
2/17 15:37	95113.0	44.56	3.7	1200.2
2/17 15:38	95817.0	44.91	3.7	1199.8
2/17 15:39	94638.0	44.36	3.7	1200.0
2/17 15:40	94229.0	44.17	3.7	1200.0
2/17 15:41	94994.0	44.60	3.7	1200.0
2/17 15:42	94317.0	44.21	3.7	1199.8
2/17 15:43	95918.0	44.83	3.7	1199.5

	(TG-751) Landfill Gas Flow scfhhr	(TG-751) Heat Input mmBtu/hr	(TG-751) 1-Min	Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp	1-Min	1-Min	1-Min	Megawatts 1-Min	1-Min
2/17 15:44	96261.0	44.84	3.7	1201.0	
2/17 15:45	94667.0	44.35	3.7	1200.3	
2/17 15:46	93970.0	44.12	3.7	1200.2	
2/17 15:47	94075.0	44.18	3.7	1199.8	
2/17 15:48	95893.0	45.03	3.7	1199.8	
2/17 15:49	95267.0	44.78	3.7	1199.8	
2/17 15:50	95753.0	44.97	3.7	1199.8	
2/17 15:51	94490.0	44.29	3.7	1200.0	
2/17 15:52	93831.0	44.01	3.7	1199.8	
2/17 15:53	95380.0	44.77	3.7	1200.0	
2/17 15:54	94822.0	44.53	3.7	1200.0	
2/17 15:55	95142.0	44.68	3.7	1200.0	
2/17 15:56	95813.0	45.01	3.7	1200.0	
2/17 15:57	95370.0	44.75	3.7	1200.0	
2/17 15:58	95746.0	44.90	3.7	1200.2	
2/17 15:59	95298.0	44.66	3.7	1199.8	
2/17 16:00	92918.0	43.60	3.7	1200.0	
2/17 16:01	94251.0	44.28	3.7	1200.0	
2/17 16:02	94314.0	44.28	3.7	1199.7	
2/17 16:03	94840.0	44.47	3.7	1200.2	
2/17 16:04	95156.0	44.63	3.7	1199.8	
2/17 16:05	94098.0	44.19	3.7	1200.0	
2/17 16:06	93980.0	44.12	3.7	1200.0	
2/17 16:07	94113.0	44.21	3.7	1199.8	
2/17 16:08	94291.0	44.33	3.7	1199.8	
2/17 16:09	95108.0	44.79	3.7	1200.0	
2/17 16:10	94194.0	44.35	3.7	1200.0	
2/17 16:11	94092.0	44.32	3.7	1200.0	
2/17 16:12	94310.0	44.44	3.7	1199.8	
2/17 16:13	95456.0	44.82	3.7	1200.0	
2/17 16:14	95109.0	44.49	3.7	1199.8	
2/17 16:15	94830.0	44.32	3.7	1199.8	
2/17 16:16	94334.0	44.06	3.7	1200.5	
2/17 16:17	94170.0	44.05	3.7	1199.3	
2/17 16:18	94630.0	44.38	3.7	1199.3	
2/17 16:19	93813.0	43.88	3.7	1199.8	
2/17 16:20	95343.0	44.60	3.7	1200.0	
2/17 16:21	93785.0	43.91	3.7	1200.0	
2/17 16:22	94568.0	44.25	3.7	1199.7	
2/17 16:23	94949.0	44.40	3.7	1200.0	
2/17 16:24	94292.0	44.17	3.7	1199.8	
2/17 16:25	95145.0	44.57	3.7	1200.0	
2/17 16:26	94724.0	44.40	3.7	1200.0	
2/17 16:27	94482.0	44.31	3.7	1200.3	
2/17 16:28	93372.0	44.01	3.7	1200.2	
2/17 16:29	94357.0	44.38	3.7	1199.8	
2/17 16:30	95129.0	44.71	3.7	1200.0	
2/17 16:31	95047.0	44.65	3.7	1199.8	
2/17 16:32	95248.0	44.64	3.7	1200.0	

(TG-751) Timestamp	Landfill Gas 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 °F 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
2/17 16:33	95196.0	44.62	3.7	1200.3	
2/17 16:34	94831.0	44.55	3.7	1200.2	
2/17 16:35	94628.0	44.46	3.7	1200.2	
2/17 16:36	95152.0	44.70	3.7	1200.0	
2/17 16:37	94789.0	44.53	3.7	1199.7	
2/17 16:38	94207.0	44.26	3.7	1200.0	
2/17 16:39	93423.0	43.89	3.7	1200.0	
2/17 16:40	95273.0	44.76	3.7	1200.0	
2/17 16:41	95140.0	44.70	3.7	1200.0	
2/17 16:42	95608.0	44.92	3.7	1200.0	
2/17 16:43	94721.0	44.48	3.7	1199.8	
2/17 16:44	95742.0	44.89	3.7	1200.0	
2/17 16:45	95144.0	44.72	3.7	1200.2	
2/17 16:46	95096.0	44.57	3.7	1199.8	
2/17 16:47	95138.0	44.59	3.7	1200.0	
2/17 16:48	94241.0	44.22	3.7	1200.2	
2/17 16:49	95207.0	44.70	3.7	1199.7	
2/17 16:50	94346.0	44.31	3.7	1200.2	
2/17 16:51	94885.0	44.58	3.7	1199.8	
2/17 16:52	94630.0	44.46	3.7	1200.0	
2/17 16:53	94450.0	44.37	3.7	1199.7	
2/17 16:54	95696.0	44.98	3.7	1199.7	
2/17 16:55	96525.0	45.26	3.7	1200.0	
2/17 16:56	94224.0	44.25	3.7	1200.0	
2/17 16:57	94984.0	44.60	3.7	1200.0	
2/17 16:58	94834.0	44.55	3.8	1199.7	
2/17 16:59	96757.0	45.35	3.8	1200.0	
2/17 17:00	94975.0	44.55	3.8	1200.0	
2/17 17:01	95502.0	44.84	3.8	1200.0	
2/17 17:02	95706.0	44.91	3.8	1200.0	
2/17 17:03	95945.0	44.97	3.8	1199.7	
2/17 17:04	95272.0	44.65	3.8	1200.0	
2/17 17:05	94506.0	44.33	3.8	1200.0	
2/17 17:06	95260.0	44.70	3.8	1199.7	
2/17 17:07	95213.0	44.62	3.8	1200.2	
2/17 17:08	95527.0	44.77	3.8	1200.0	
2/17 17:09	96060.0	45.02	3.8	1199.8	
2/17 17:10	95086.0	44.57	3.8	1200.0	
2/17 17:11	94580.0	44.33	3.8	1200.2	
2/17 17:12	94848.0	44.38	3.8	1199.7	
2/17 17:13	95190.0	44.51	3.8	1200.0	
2/17 17:14	96138.0	44.96	3.8	1199.8	
2/17 17:15	95583.0	44.62	3.8	1200.0	
2/17 17:16	96034.0	44.83	3.8	1200.3	
2/17 17:17	95234.0	44.51	3.8	1200.2	
2/17 17:18	94533.0	44.20	3.8	1199.8	
2/17 17:19	95008.0	44.45	3.8	1200.0	
2/17 17:20	94688.0	44.35	3.8	1200.0	
2/17 17:21	95156.0	44.53	3.8	1200.0	

Timestamp	(TG-751) Landfill Gas Flow scfhhr 1-Min	(TG-751) Heat Input mmBtu/hr 1-Min	(TG-751) Megawatts 1-Min	(TG-751) T7 Exhaust Temp °F 1-Min
2/17 17:22	96799.0	45.28	3.8	1199.5
2/17 17:23	95845.0	44.82	3.8	1199.8
2/17 17:24	96074.0	44.92	3.8	1200.0
2/17 17:25	95708.0	44.75	3.8	1200.2
2/17 17:26	96273.0	45.02	3.8	1199.8
2/17 17:27	95480.0	44.65	3.8	1200.0
2/17 17:28	96536.0	45.14	3.8	1200.2
2/17 17:29	95022.0	44.43	3.8	1199.8
2/17 17:30	95612.0	44.71	3.8	1200.2
2/17 17:31	96589.0	45.17	3.8	1200.0
2/17 17:32	95850.0	44.82	3.8	1200.0
2/17 17:33	95027.0	44.46	3.8	1200.3
2/17 17:34	96070.0	44.98	3.8	1199.8
2/17 17:35	95575.0	44.69	3.8	1200.0
2/17 17:36	95404.0	44.59	3.8	1199.8
2/17 17:37	94999.0	44.32	3.8	1200.2
2/17 17:38	95668.0	44.63	3.8	1200.0
2/17 17:39	96118.0	44.84	3.8	1199.8
2/17 17:40	95277.0	44.52	3.8	1200.0
2/17 17:41	96006.0	44.89	3.8	1199.8
2/17 17:42	94858.0	44.36	3.8	1200.0
2/17 17:43	94606.0	44.21	3.8	1200.0
2/17 17:44	94789.0	44.30	3.8	1199.8
2/17 17:45	95838.0	44.77	3.8	1200.0
2/17 17:46	95949.0	44.76	3.8	1200.0
2/17 17:47	95666.0	44.63	3.8	1200.0
2/17 17:48	95268.0	44.44	3.8	1200.2
2/17 17:49	95667.0	44.63	3.8	1199.8
2/17 17:50	96389.0	44.97	3.8	1200.0
2/17 17:51	95208.0	44.42	3.8	1200.2
2/17 17:52	96376.0	44.93	3.8	1200.0
2/17 17:53	94786.0	44.19	3.8	1200.2
2/17 17:54	95657.0	44.63	3.8	1200.0
2/17 17:55	95812.0	44.70	3.8	1199.8
2/17 17:56	95653.0	44.62	3.8	1200.0
2/17 17:57	97083.0	45.22	3.8	1199.8
2/17 17:58	96240.0	44.79	3.8	1200.2
2/17 17:59	96683.0	44.99	3.8	1200.0
2/17 18:00	96290.0	44.81	3.8	1200.2
2/17 18:01	96319.0	44.73	3.8	1199.8
2/17 18:02	95537.0	44.46	3.8	1200.2
2/17 18:03	96104.0	44.72	3.8	1199.8
2/17 18:04	95716.0	44.55	3.8	1200.0
2/17 18:05	96053.0	44.70	3.8	1200.2
2/17 18:06	96055.0	44.73	3.8	1199.8
2/17 18:07	95756.0	44.57	3.8	1200.0
2/17 18:08	95050.0	44.26	3.8	1200.0
2/17 18:09	96775.0	45.04	3.8	1199.5
2/17 18:10	96547.0	44.86	3.8	1199.8

	(TG-751) Landfill Gas Flow scfh/ 1 Min	(TG-751) Heat Input mmBtu/hr 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T °F 1 Min	(TG-751) T Exhaust Temp °F 1 Min
2/17 18:11	95878.0	44.59	3.8	1199.8	
2/17 18:12	95736.0	44.48	3.8	1200.0	
2/17 18:13	95667.0	44.62	3.8	1200.2	
2/17 18:14	96110.0	44.75	3.8	1200.0	
2/17 18:15	94625.0	44.13	3.8	1200.0	
2/17 18:16	96752.0	45.13	3.8	1200.0	
2/17 18:17	96392.0	44.97	3.8	1200.0	
2/17 18:18	95197.0	44.38	3.8	1200.0	
2/17 18:19	95752.0	44.53	3.8	1199.8	
2/17 18:20	96131.0	44.71	3.8	1199.8	
2/17 18:21	95403.0	44.35	3.8	1200.2	
2/17 18:22	95655.0	44.52	3.8	1199.8	
2/17 18:23	95659.0	44.52	3.8	1200.0	
2/17 18:24	94699.0	44.07	3.8	1200.0	
2/17 18:25	95955.0	44.66	3.8	1200.0	
2/17 18:26	96825.0	45.10	3.8	1200.2	
2/17 18:27	95965.0	44.66	3.8	1200.2	
2/17 18:28	94817.0	44.13	3.8	1200.0	
2/17 18:29	95531.0	44.44	3.8	1200.0	
2/17 18:30	97029.0	45.16	3.8	1200.0	
2/17 18:31	95662.0	44.61	3.8	1200.0	
2/17 18:32	95147.0	44.28	3.8	1200.2	
2/17 18:33	95852.0	44.50	3.8	1200.5	
2/17 18:34	96206.0	44.39	3.8	1200.2	
2/17 18:35	95041.0	44.29	3.8	1199.7	
2/17 18:36	95402.0	44.40	3.8	1199.8	
2/17 18:37	95917.0	44.59	3.8	1200.2	
2/17 18:38	96092.0	44.64	3.8	1199.8	
2/17 18:39	95657.0	44.76	3.8	1200.0	
2/17 18:40	95111.0	44.16	3.8	1200.0	
2/17 18:41	96098.0	44.62	3.8	1200.0	
2/17 18:42	96933.0	45.00	3.8	1200.2	
2/17 18:43	96451.0	44.81	3.8	1200.2	
2/17 18:44	95843.0	44.60	3.8	1200.2	
2/17 18:45	96009.0	44.68	3.8	1200.0	
2/17 18:46	95215.0	44.32	3.8	1200.2	
2/17 18:47	96451.0	44.84	3.8	1199.8	
2/17 18:48	98229.0	44.32	3.8	1200.0	
2/17 18:49	95248.0	44.25	3.8	1199.8	
2/17 18:50	96490.0	44.83	3.8	1200.0	
2/17 18:51	95518.0	44.35	3.8	1199.8	
2/17 18:52	96387.0	44.81	3.8	1200.3	
2/17 18:53	96087.0	44.67	3.8	1199.8	
2/17 18:54	94968.0	44.15	3.8	1200.2	
2/17 18:55	96121.0	44.71	3.8	1200.0	
2/17 18:56	95520.0	44.46	3.8	1200.0	
2/17 18:57	95950.0	44.61	3.8	1200.0	
2/17 18:58	95694.0	44.43	3.8	1200.0	
2/17 18:59	95565.0	44.82	3.8	1200.0	

	(TG-751) Landfill Gas Flow scf/hr 1 Min	(TG-751) Heat Input mmBtu/hr 1 Min	(TG-751) Megawatts 1 Min	(TG-751) T7 Exhaust Temp °F 1-Min
Timestamp				
2/17 19:00	96456.0	44.74	3.8	1200.3
Average (all)	96104.4	44.87	3.8	1200.0
Total (all)	--	--	--	--
Minimum (all)	92918.0	43.60	3.7	1198.8
Maximum (all)	99814.0	46.50	3.8	1201.8
Average (valid values only)	96104.4	44.87	3.8	1200.0
Total (valid values only)	--	--	--	--
Count (valid values only)	781	781	781	781

APPENDIX C CALCULATIONS

Appendix C.1 General Emissions Calculations

GENERAL EMISSIONS CALCULATIONS

I. Stack Gas Velocity

A. Stack gas molecular weight, lb/lb-mole

$$MW_{dry} = 0.44 * \% CO_2 + 0.32 * \% O_2 + 0.28 * \% N_2$$

$$MW_{wet} = MW_{dry} * (1 - B_{wo}) + 18 * B_{wo}$$

B. Absolute stack pressure, iwg

$$P_s = P_{bar} + \frac{P_{sg}}{13.6}$$

C. Stack gas velocity, ft/sec

$$V_s = 85.49 * C_p * \sqrt{\frac{\Delta P * T_s}{P_s * MW_{wet}}}$$

II. Moisture

A. Sample gas volume, dscf

$$V_{mstd} = 0.033422 * V_m * \left(P_{bar} + \frac{\Delta H}{13.6} \right) * \frac{T_{ref}}{T_m} * Y_d$$

B. Water vapor volume, scf

$$V_{wstd} = 0.04716 * V_{ic} * \frac{T_{ref}}{528^{\circ}R}$$

C. Moisture content, dimensionless

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

III. Stack Gas Volumetric Flow Rate

A. Actual stack gas volumetric flow rate, wacfm

$$Q = V_s * A_s * 60$$

B. Standard stack gas flow rate, dscfm

$$Q_{sd} = Q * (1 - B_{wo}) * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

C. Standard stack gas flow rate, scfm

$$Q_s = Q * \frac{T_{ref}}{T_s} * \frac{P_s}{29.92}$$

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5

IV. Gaseous Mass Emission Rates, lb/hr

$$M = \frac{\text{ppm} * \text{MW}_i * Q_{sd} * 60}{\text{SV} * 10^6}$$

V. Emission Rates, lb/MMBtu

$$\frac{\text{lb}}{\text{MMBtu}} = \frac{\text{ppm} * \text{MW}_i * F}{\text{SV} * 10^6} * \frac{20.9}{20.9 - \% \text{ O}_2}$$

VI. Percent Isokinetic

$$I = \frac{17.32 * T_s (V_{std})}{(1 - B_{wo}) 0 * V_s * P_s * Dn^2} * \frac{520^\circ R}{T_{ref}}$$

VII. Particulate Emissions

- (a) Grain loading, gr/dscf
 $C = 0.01543 (M_n/V_m \text{ std})$

- (b) Grain loading at 12% CO₂, gr/dscf
 $C_{12\% \text{ CO}_2} = C (12/\% \text{ CO}_2)$

- (b) Grain loading at 15% O₂, gr/dscf
 $C_{15\% \text{ O}_2} = C * 5.9/(20.9-\text{O}_2)$

- (c) Mass emissions, lb/hr
 $M = C * Q_{sd} * (60 \text{ min/hr}) / (7000 \text{ gr/lb})$

- (d) Particulate emission factor

$$\text{lb}/10^6 \text{ Btu} = Cx \frac{1 \text{ lb}}{7000 \text{ gr}} * F * \frac{20.9}{20.9 - \% \text{ O}_2}$$

VII. Metal Emissions

- (a) Concentration, mg/dscf
 $C_{mg/dscf} = (M_n/V_m \text{ std})$

- (b) Concentration, mg/dscm
 $C_{mg/dscm} = (M_n/V_m \text{ std}) \times (35.31 \text{ ft}^3/1\text{m}^3)$

- (c) Concentration at 15% O₂, mg/dscm
 $C_{15\% \text{ O}_2} = C_{mg/dscm} * 5.9/(20.9-\text{O}_2)$

- (d) Mass emissions, lb/hr
 $M = C_{mg/dscf} * Q_{sd} * (60 \text{ min/hr}) / (454 \times 10^3 \text{ mg/lb})$

Nomenclature:

A_s	=	stack area, ft ²
B_{wo}	=	flue gas moisture content, dimensionless
$C_{12\%CO_2}$	=	particulate grain loading, gr/dscf corrected to 12% CO ₂
$C_{15\%O_2}$	=	particulate grain loading, gr/dscf corrected to 15% O ₂
C_p	=	pitot calibration factor, dimensionless
D_n	=	nozzle diameter, inches
F	=	fuel F-Factor, dscf/MMBtu @ 0% O ₂
H	=	orifice differential pressure, iwg
I	=	% isokinetics
M_n	=	mass of collected particulate, mg
M_i	=	mass emission rate of specie i, lb/hr
MW	=	molecular weight of flue gas, lb/lb-mole
M_{wi}	=	molecular weight of specie i: SO ₂ : 64 NO _x : 46 CO: 28 HC: 16 HCHO: 30.03 HCL: 36.458 HF: 20.01
t_0	=	sample time, minutes
ΔP	=	average velocity head, iwg = $(\sqrt{\Delta P})^2$
P_{bar}	=	barometric pressure, inches Hg
P_s	=	stack absolute pressure, inches Hg
P_{sg}	=	stack static pressure, iwb
Q	=	wet stack flow rate at actual conditions, wacfm
Q_{sd}	=	dry standard stack flow rate, dscfm
SV	=	specific molar volume of an ideal gas at standard conditions, ft ³ /lb-mole
T_m	=	meter temperature, °R
T_{ref}	=	reference temperature, °R
T_s	=	stack temperature, °R
V_s	=	stack gas velocity, ft/sec
V_{lc}	=	volume of liquid collected in impingers, ml
V_m	=	uncorrected dry meter volume, dcf
V_{mstd}	=	dry meter volume at standard conditions, dscf
V_{wstd}	=	volume of water vapor at standard conditions, scf
Y_d	=	meter calibration coefficient

Appendix C.2 Data Summaries

Appendix C.2.1 CT-4 Data

Gaseous Emissions Test Summary
SUNSHINE GAS CT 4

Test Number	RUN 1-CT4	RUN 2-CT4	RUN 3-CT4	RUN 4-CT4	RUN 5-CT4	RUN 6-CT4	RUN 7-CT4	Averages
Date	2/7/2023	2/8/2023	2/8/2023	2/9/2023	2/9/2023	2/10/2023	2/10/2023	
Start Time	10:53	8:11	13:06	8:06	12:41	7:51	12:16	
Stop Time	15:03	12:18	17:12	12:21	16:55	12:00	16:25	
Pre-Test Information:								
Reference Temperature, °F	68	68	68	68	68	68	68	
Diluent Emissions and Stack Flow Rate:								
O ₂ , % vol. dry	16.02	16.01	16.07	16.04	15.98	16.01	16.05	16.03
CO ₂ , % vol. dry	4.40	4.52	4.47	4.37	4.30	4.49	4.54	4.44
Stack Flow Rate, dscfm	34,673	34,670	34,381	34,767	34,864	34,564	34,491	34,630
Pollutant Emissions:								
Carbon Monoxide (CO)								
ppm vol. dry	1.22	1.27	0.96	0.63	1.04	0.43	0.22	0.82
ppmc vol. dry @ 15% O ₂	1.48	1.53	1.18	0.77	1.25	0.52	0.26	1.00
lb/hr	0.18	0.19	0.14	0.10	0.16	0.06	0.03	0.12

EPA 10 EXAMPLE CALCULATION

TEST NUMBER: CT-4- 1-EPA 10

Identifier	Description	Units	Equation	Run 1
Using Data from Run 1:				
A	CO Pre-Test Zero Bias Response	ppm	--	-0.09
B	CO Post-Test Zero Bias Response	ppm	--	-0.05
C	CO Pre-Test Span Bias Response	ppm	--	4.59
D	CO Post-Test Span Bias Response	ppm	--	4.65
E	Avg. Pre-Test Zero Bias Response	ppm	(A+B)/2	-0.07
F	Avg. Post-Test Span Bias Response	ppm	(C+D)/2	4.62
G	CO Span Gas Value	ppm	--	4.68
H	CO Average (raw)	ppm	--	1.15
I	Drift/Bias Corrected CO:	ppm	(H-E)/(F-E)*G	1.22
J	Drift/Bias Corrected O ₂ :	%	--	16.02
K	Drift/Bias Corrected CO ₂ :	%	--	4.40
L	Meter Volume	acf	--	199.991
M	Barometric Pressure	" Hg	--	28.36
N	Delta H	" H ₂ O	--	2.0125
O	Reference Temperature	R	--	528
P	Meter Temperature	R	--	544.5
Q	Y _d	--	--	0.992
R	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	183.286
S	Liquid Collected	grams	--	219
T	Water vapor volume	scf	0.04716 * S * F/528	10.328
U	Moisture Content	--	T/(T + R)	0.053
V	Molecular weight, dry	lb/lb-mole	0.44 * K + 0.32 * J + 0.28 * (100 - J - K)	29.35
W	Molecular weight, wet	lb/lb-mole	V * (1 - U) + 18 * U	28.74
X	Static Pressure	" H ₂ O	--	-0.55
Y	Stack Pressure	" Hg	M + X/13.6	28.32
Z	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	1.0065
AA	Stack Temperature	R	--	1163.458
AB	Pitot Tube Coeficient	--	--	0.84
AC	Stack Velocity	fps	85.49 * AB * sqrt(Z * AA / Y / W)	86.14
AD	Stack Area	ft ²	--	16.50
AE	Stack Flow Rate	acfmin	AC * AD * 60	85,268
AF	Stack Flow Rate	dscfm	AE * (1 - U) * O * Y / AA / 29.92	34,673
AG	Specific Molar Volume	SCF/lb-mole	385.3 * O / 528	385.3
AH	CO emission rate	lb/hr	I * 28 * AF * 60 / AG / 10 ⁶	0.18
AI	CO concentration, corrected	ppm@15%O ₂	I*5.9/(20.9-J)	1.48

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only. Stack gas velocity and moisture content was reported from EPA Method 5, R1.

Montrose
Particulate Matter Test Summary

Client/Location.....	DTE Sunshine	Sample Location.....	CT4	Test No.....	1-EPA 5	2-EPA 5	3-EPA 5	4-EPA 5	5-EPA 5	6-EPA 5	7-EPA 5	Reference Temp (F):	68 Landfill DHAD
Date.....	February 7, 2023	February 8, 2023	February 8, 2023	February 9, 2023	February 9, 2023	February 9, 2023	February 9, 2023	February 10, 2023	February 10, 2023	February 10, 2023	February 10, 2023	Data By.....	Average
Start Time.....	10:50	8:10	13:05	8:05	12:40	7:50	12:40	12:15	12:15	12:15	12:15	*	*
Stop Time.....	15:00	12:20	17:15	12:15	16:50	12:00	16:50	16:25	16:25	16:25	16:25	*	*
Bar Press (in Hg).....	28.36	28.34	28.34	28.32	28.32	28.32	28.32	28.26	28.26	28.26	28.26	*	*
Test Method.....	EPA M5	EPA M5	EPA M5	EPA M5	EPA M5	EPA M5	EPA M5	EPA M5	EPA M5	EPA M5	EPA M5	*	*
Sample Time (Min).....	240	240	240	240	240	240	240	240	240	240	240	*	*
Sample Train.....	42 WCS	42 WCS	42 WCS	42 WCS	42 WCS	42 WCS	42 WCS	42 WCS	42 WCS	42 WCS	42 WCS	*	*
Meter Cal Factor.....	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	*	*
Pitot Factor.....	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	*	*
Nozzle Diam (in).....	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	*	*
Stack Area (sq ft).....	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	*	*
Stack CO2 (%).....	16.02	16.01	16.07	16.04	15.98	16.01	16.04	16.05	16.05	16.05	16.05	16.03	16.03
Stack CO2 (%).....	4.40	4.52	4.47	4.37	4.30	4.49	4.30	4.54	4.54	4.54	4.54	4.44	4.44
Stack Press (wg).....	-0.55	-0.54	-0.54	-0.57	-0.57	-0.55	-0.57	-0.55	-0.55	-0.55	-0.55	-0.55	-0.55
Stack Temp (F).....	703.5	701.7	700.4	702.9	703.5	703.5	703.5	715.2	715.2	716.1	716.1	706.2	706.2
Vel Head (wg).....	1.0065	1.0036	0.9857	1.0025	1.0087	1.0083	1.0083	1.0086	1.0086	1.0086	1.0086	1.0034	1.0034
Meter Temp (F).....	84.5	76.6	91.5	84.8	91.5	74.4	91.5	86.3	86.3	86.3	86.3	84.2	84.2
Meter Press (wg).....	2.013	2.000	1.967	2.004	2.008	2.013	2.008	2.013	2.013	2.013	2.013	2.002	2.002
Meter Vol (acf).....	199.991	198.273	196.276	201.295	199.297	194.565	199.297	192.868	192.868	192.868	192.868	197.509	197.509
Liquid Vol (ml).....	219.0	214.0	206.1	194.2	191.3	201.8	191.3	203.6	203.6	203.6	203.6	204.3	204.3
Std Sample Vol (SCF).....	183.286	184.257	177.453	184.188	180.091	181.069	180.091	175.574	175.574	175.574	175.574	180.840	180.840
Moisture Fraction.....	0.053	0.052	0.052	0.047	0.048	0.048	0.048	0.052	0.052	0.052	0.052	0.051	0.051
Stack Gas Mol Wt.....	28.74	28.77	28.77	28.80	28.79	28.79	28.79	28.78	28.78	28.78	28.78	*	*
Stack Gas Velocity (ft/sec).....	86.14	85.93	85.12	85.91	86.23	86.72	86.23	86.79	86.79	86.79	86.79	86.12	86.12
Isokinetic Ratio (%).....	100.9	101.4	98.5	101.1	98.6	100.0	98.6	97.1	97.1	97.1	97.1	99.6	99.6
Stack Flow Rate (wcfm).....	85.268	85.063	84.263	85.048	85.359	85.851	85.359	85.252	85.252	85.252	85.252	*	*
Stack Flow Rate (dscfm).....	34.673	34.670	34.381	34.767	34.864	34.564	34.864	34.630	34.630	34.630	34.630	*	*
Stack Flow Rate (scfm).....	36.626	36.568	36.265	36.496	36.610	36.380	36.380	36.377	36.377	36.377	36.377	36.475	36.475
Heated Filter, mg.....	0.0	1.3	0.9	0.0	0.8	0.4	0.8	1.3	1.3	1.3	1.3	0.7	0.7
Probe Wash, mg.....	0.7	0.2	0.3	0.7	0.5	0.1	0.5	0.1	0.1	0.1	0.1	0.4	0.4
Total Weight Gain, mg.....	0.7	1.5	1.2	0.7	1.3	0.5	1.3	1.4	1.4	1.4	1.4	1.0	1.0
Particulate Emissions													
Grain Loading, g/rdsfc	0.00006	0.00013	0.00010	0.00006	0.00011	0.00004	0.00004	0.00012	0.00012	0.00012	0.00012	0.00009	0.00009
Grain Loading @ 15% O ₂	0.00007	0.00015	0.00013	0.00007	0.00013	0.00005	0.00005	0.00015	0.00015	0.00015	0.00015	0.00011	0.00011
Mass Emissions, lb/hr.....	0.018	0.037	0.031	0.017	0.033	0.013	0.013	0.036	0.036	0.036	0.036	0.026	0.026

EPA 5 EXAMPLE CALCULATION
TEST NUMBER: CT-4- 1-EPA 5

Identifier	Description	Units	Equation	Run 1 Value
A	Stack O2	%	--	16.02
B	Stack CO2	%	--	4.40
C	Meter Volume	acf	--	199.991
D	Barometric Pressure	" Hg	--	28.36
E	Delta H	" H ₂ O	--	2.0
F	Reference Temperature	R	--	528
G	Meter Temperature	R	--	544.5
H	Y _d	--	--	0.992
I	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	183.286
J	Liquid Collected	grams	--	219.0
K	Water vapor volume	scf	0.04716 * J * F/528	10.328
L	Moisture Content	--	T/(T + R)	0.053
M	Molecular weight, dry	lb/lb-mole	0.44 * B + 0.32 * A + 0.28 * (100 - A - B)	29.35
N	Molecular weight, wet	lb/lb-mole	M * (1 - L) + 18 * L	28.74
O	Static Pressure	" H ₂ O	--	-0.55
P	Stack Pressure	" Hg	D + O/13.6	28.32
Q	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	1.0065
R	Stack Temperature	R	--	1163.458333
S	Pitot Tube Coeficient	--	--	0.84
T	Stack Velocity	fps	85.49 * S * sqrt(Q * R / P / N)	86.14
U	Stack Area	ft ²	--	16.50
V	Stack Flow Rate	acfm	T * U * 60	85,268
W	Stack Flow Rate	dscfm	V * (1 - L) * F * P / R / 29.92	34,673
X	Sample Time	minutes	--	240.0
Y	Nozzle Diameter	inches	--	0.257
Z	Isokinetic Sampling Rate	%	14,128*528/F*R*I/X/T/60/(D*13.6+O)/Y ²	100.9
AA	Particulate Catch	mg	--	0.7
AB	Particulate Catch	lbs	AA / 454,000	1.54E-06
AC	Particulate Cate	grains	AB * 7,000	0.011
AD	Particulate Emissions	gr/dscf	AC / I	0.000059
AE	Particulate Emissions	gr/dscf @ 15% O ₂	AD * 5.9 / (20.9 - A)	0.000071
AF	Particulate Emissions	gr/dscf @ 12% CO ₂	AD * 12 / B	0.000161
AG	Particulate Emissions	lb/hr	AD * 60 / 7,000 * V	0.0175

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

TRACE METALS TEST RESULTS
DTE SUNSHINE
CT4 STACK

Species	Test No.:										AVERAGES			
	1-EPA 29	2-EPA 29	3-EPA 29	4-EPA 29	5-EPA 29	6-EPA 29	7-EPA 29	8-EPA 29	9-EPA 29	10-EPA 29	11-EPA 29	12-EPA 29	13-EPA 29	14-EPA 29
Antimony														
mg/m ³	0.00009	0.00006	< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	< 0.00007	< 0.00007
mg/lbm@ 15% O ₂	0.00011	0.00008	< 0.00008	ND< 0.00007	ND< 0.00008	ND< 0.00008	ND< 0.00008	< 0.00008	< 0.00008					
lb/hr	1.14E-05	8.22E-06	< 8.14E-06	ND< 7.73E-06	ND< 7.98E-06	ND< 7.98E-06	ND< 7.98E-06	< 8.49E-06	< 8.49E-06					
Arsenic														
mg/m ³	< 0.00014	< 0.00016	< 0.00015	ND< 0.00014	ND< 0.00014	ND< 0.00014	ND< 0.00014	ND< 0.00015	< 0.00015	< 0.00015				
mg/lbm@ 15% O ₂	< 0.00017	< 0.00019	< 0.00018	ND< 0.00017	ND< 0.00017	ND< 0.00017	ND< 0.00017	ND< 0.00018	< 0.00018	< 0.00018				
lb/hr	< 1.88E-05	< 2.03E-05	< 1.90E-05	ND< 1.84E-05	ND< 1.84E-05	ND< 1.84E-05	ND< 1.84E-05	ND< 1.88E-05	ND< 1.88E-05	ND< 1.91E-05	ND< 1.91E-05	ND< 1.92E-05	< 1.91E-05	< 1.91E-05
Beryllium														
mg/m ³	0.00003	0.00004	ND< 0.00001	ND< 0.00002	ND< 0.00002	ND< 0.00002	< 0.00002	< 0.00002						
mg/lbm@ 15% O ₂	0.00004	0.00004	ND< 0.00002	< 0.00002	< 0.00002									
lb/hr	3.81E-06	4.72E-06	ND< 1.80E-06	ND< 1.86E-06	ND< 1.86E-06	ND< 1.86E-06	< 1.97E-06	< 1.97E-06						
Chromium														
mg/m ³	0.00017	0.00006	< 0.00003	< 0.00004	< 0.00004	< 0.00004	< 0.00004	< 0.00004	< 0.00004	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002
mg/lbm@ 15% O ₂	0.00021	0.00008	< 0.00004	< 0.00004	< 0.00004	< 0.00004	< 0.00004	< 0.00004	< 0.00004	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002
lb/hr	2.24E-05	8.27E-06	< 3.78E-06	< 4.67E-06	< 2.08E-06	< 2.08E-06	< 2.08E-06	< 1.93E-06	< 1.93E-06					
Manganese														
mg/m ³	0.00136	0.00098	0.00130	0.00136	0.00097	0.00097	0.00097	0.00097	0.00097	0.00097	0.00097	0.00097	< 0.00005	< 0.00005
mg/lbm@ 15% O ₂	0.00124	0.00121	0.00121	0.00121	0.00158	0.00163	0.00163	0.00163	0.00163	0.00164	0.00164	0.00164	< 0.00006	< 0.00006
lb/hr	1.34E-04	1.77E-04	1.29E-04	1.29E-04	1.69E-04	1.69E-04	1.69E-04	1.69E-04	1.77E-04	1.25E-04	1.74E-04	1.74E-04	< 6.43E-06	< 6.43E-06
Cobalt														
mg/m ³	0.00004	0.00005	0.00023	0.00002	0.00003	0.00003	0.00002	0.00002	0.00002	0.00002	0.00002	0.00002	< 0.00002	< 0.00002
mg/lbm@ 15% O ₂	0.00005	0.00006	0.00028	0.00028	0.00028	0.00028	0.00028	0.00028	0.00028	0.00028	0.00028	0.00028	< 0.00007	< 0.00007
lb/hr	5.82E-06	7.01E-06	2.98E-05	3.06E-06	3.06E-06	3.06E-06	3.06E-06	3.06E-06	3.06E-06	< 2.42E-06	< 2.42E-06	< 2.42E-06	< 2.19E-06	< 2.19E-06
Lead														
mg/m ³	0.00027	0.00020	0.00011	0.00014	0.00014	0.00012	0.00010	0.00010	0.00010	0.00012	0.00012	0.00010	< 0.00002	< 0.00002
mg/lbm@ 15% O ₂	0.00033	0.00024	0.00013	0.00016	0.00016	0.00015	0.00015	0.00015	0.00015	0.00015	0.00015	0.00015	< 0.00002	< 0.00002
lb/hr	3.53E-05	2.62E-05	1.41E-05	1.75E-05	1.75E-05	1.59E-05	1.33E-05	1.33E-05	1.33E-05	1.33E-05	1.24E-05	1.24E-05	< 1.92E-05	< 1.92E-05
Mercury														
mg/m ³	< 0.00011	< 0.00020	< 0.00010	< 0.00009	< 0.00009	< 0.00009	< 0.00009	< 0.00009	< 0.00009	< 0.00009	< 0.00009	< 0.00009	< 0.00012	< 0.00012
mg/lbm@ 15% O ₂	< 0.00018	< 0.00024	< 0.00013	< 0.00013	< 0.00013	< 0.00013	< 0.00013	< 0.00013	< 0.00013	< 0.00013	< 0.00013	< 0.00013	< 0.00014	< 0.00014
lb/hr	< 1.95E-05	< 1.44E-05	< 2.57E-05	< 1.38E-05	< 1.35E-05	< 1.35E-05	< 1.10E-05	< 1.10E-05						
Nickel														
mg/m ³	0.00071	0.00048	0.00042	0.00053	0.00041	0.00041	0.00033	0.00033	0.00033	0.00040	0.00040	0.00037	0.00046	0.00046
mg/lbm@ 15% O ₂	0.00086	0.00058	0.00052	0.00064	0.00049	0.00049	0.00045	0.00045	0.00045	0.00045	0.00045	0.00045	0.00056	0.00056
lb/hr	9.28E-05	6.25E-05	5.48E-05	6.80E-05	5.29E-05	4.26E-05	6.02E-05	6.02E-05						
Manganese														
mg/m ³	< 0.00028	< 0.00012	< 0.00029	< 0.00097	< 0.00029	< 0.00029	< 0.000169	< 0.000169	< 0.000169	< 0.000169	< 0.000169	< 0.000169	< 0.00018	< 0.00018
mg/lbm@ 15% O ₂	< 0.00034	< 0.00015	< 0.00035	< 0.00118	< 0.00035	< 0.00035	< 0.00118	< 0.00118	< 0.00118	< 0.00118	< 0.00118	< 0.00118	< 0.00022	< 0.00022
lb/hr	< 3.70E-05	< 1.60E-05	< 3.75E-05	< 1.26E-04	< 3.75E-05	< 3.75E-05	< 3.80E-05	< 3.80E-05	< 3.80E-05	< 2.19E-04	< 2.19E-04	< 2.19E-04	< 2.29E-05	< 2.29E-05

N_{ND} = number not detected in sample $N_{ND} \leq RDI$

NDE - species not detected in sample, NMC = BUL

< - species detected in at least one sample or one

FRONT HALFTRACE METALS LABORATORY SUMMARY
DTE SUNSHINE
CT4 STACK

Species	Test No.:	1-EPA 29 2/8/23	2-EPA 29 8/10	3-EPA 29 13/05	4-EPA 29 8/05	5-EPA 29 12/40	6-EPA 29 12/50	7-EPA 29 21/02/23	AVERAGES
Antimony F_{1/2}									
mg/dscm	0.00007	0.00005	ND< 0.00005	ND< 0.00005	ND< 0.00005	ND< 0.00005	ND< 0.00005	ND< 0.00005	< 0.00005
Ib/hr	0.00008	0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	< 0.00006
Arsenic F_{1/2}									
mg/dscm	ND< 0.00013	ND< 0.00013	ND< 0.00013	ND< 0.00013	ND< 0.00013	ND< 0.00013	ND< 0.00014	ND< 0.00014	ND< 0.00013
Ib/hr	ND< 0.00016	ND< 0.00016	ND< 0.00016	ND< 0.00016	ND< 0.00016	ND< 0.00016	ND< 0.00017	ND< 0.00017	ND< 0.00016
Beryllium F_{1/2}									
mg/dscm	0.00002	0.00003	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00002
Ib/hr	0.00003	0.00004	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00002
Cadmium F_{1/2}									
mg/dscm	0.00005	0.00003	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00002
Ib/hr	0.00006	0.00004	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00002
Chromium F_{1/2}									
mg/dscm	0.00090	0.00124	0.00089	0.00119	0.00125	0.00087	0.00126	0.00126	0.00108
Ib/hr	0.00108	0.00149	0.00109	0.00144	0.00150	0.00105	0.00153	0.00153	0.00131
Cobalt F_{1/2}									
mg/dscm	0.00003	0.00004	0.00022	0.00022	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00005
Ib/hr	0.00003	0.00005	0.00027	0.00022	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00006
Lead F_{1/2}									
mg/dscm	0.00013	0.00011	0.00007	0.00007	0.00008	0.00008	0.00008	0.00008	0.00008
Ib/hr	0.00015	0.00013	1.40E-05	8.34E-06	8.98E-06	1.05E-05	8.20E-06	9.13E-06	1.09E-05
Manganese F_{1/2}									
mg/dscm	0.00020	0.00019	0.00015	0.00015	0.00014	0.00018	0.00017	0.00016	0.00021
Ib/hr	0.00025	0.00023	0.00018	0.00018	1.95E-05	1.88E-05	3.82E-05	4.27E-05	2.71E-05
Mercury F_{1/2}									
mg/dscm	ND< 0.00000	ND< 0.00000	ND< 0.00000	ND< 0.00000	ND< 0.00000	ND< 0.00000	ND< 0.00001	ND< 0.00001	ND< 0.00000
Ib/hr	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
Nickel F_{1/2}									
mg/dscm	0.00043	0.00036	0.00027	0.00038	0.00030	0.00025	0.00030	0.00030	0.00033
Ib/hr	0.00052	0.00044	4.74E-05	3.51E-05	4.92E-05	3.87E-05	3.29E-05	3.90E-05	0.00040
Selenium F_{1/2}									
mg/dscm	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00007	ND< 0.00006	ND< 0.00006
Ib/hr	ND< 0.00007	ND< 0.00007	ND< 7.78E-06	ND< 7.79E-06	ND< 7.67E-06	ND< 7.89E-06	ND< 8.01E-06	ND< 8.07E-06	ND< 7.86E-06

ND< - species not detected in sample. ND< = BDL

< species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = ADL

BACK HALF TRACE METALS LABORATORY SUMMARY
DTE SUNSHINE
CT4 STACK

Species	Test No:	1-EPA 29 2/8/23	2-EPA 29 8/10	3-EPA 29 13.05	4-EPA 29 8.05	5-EPA 29 12.40	6-EPA 29 16.50	7-EPA 29 21/10/23	AVERAGES
Antimony B½		0.00002	0.00001	0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00001
mg/dscm		0.00002	0.00002	0.00002	ND< 0.0001	ND< 0.0001	ND< 0.0001	ND< 0.0001	< 0.0002
Ib/hr		2.60E-06	1.80E-06	1.73E-06	ND< 1.42E-06	ND< 1.37E-06	ND< 1.40E-06	ND< 1.41E-06	< 1.68E-06
Arsenic B½		0.00001	0.00002	0.00001	ND< 0.0001	ND< 0.0001	ND< 0.0001	ND< 0.0001	< 0.00001
mg/dscm		0.00001	0.00003	0.00002	ND< 0.0001	ND< 0.0001	ND< 0.0001	ND< 0.0001	< 0.00002
Ib/hr		1.53E-06	3.07E-06	1.79E-06	ND< 1.42E-06	ND< 1.37E-06	ND< 1.40E-06	ND< 1.41E-06	< 1.71E-06
Beryllium B½		0.000006	0.000004	0.000003	ND< 0.00004	ND< 0.00003	ND< 0.00004	ND< 0.00004	< 0.000004
mg/dscm		0.000006	0.000005	0.000004	ND< 0.00004	ND< 0.00004	ND< 0.00004	ND< 0.00005	< 0.000005
Ib/hr		8.22E-07	5.25E-07	4.41E-07	ND< 4.59E-07	ND< 4.46E-07	ND< 4.53E-07	ND< 5.60E-07	< 5.29E-07
Cadmium B½		0.000013	0.000003	0.000002	0.000003	0.000001	0.000000	ND< 0.00000	< 0.000003
mg/dscm		0.000015	0.000004	0.000002	0.000003	0.000001	0.000001	ND< 0.00001	< 0.00004
Ib/hr		1.64E-06	3.84E-06	2.44E-06	3.36E-06	7.29E-07	ND< 5.40E-07	ND< 5.44E-07	< 3.98E-06
Chromium B½		0.000013	0.000012	0.000010	0.000011	0.000011	0.000010	0.000009	0.000011
mg/dscm		0.000016	0.000014	0.000012	0.000014	0.000013	0.000013	0.000011	0.000013
Ib/hr		1.70E-05	1.55E-05	1.26E-05	1.47E-05	1.45E-05	1.35E-05	1.19E-05	1.42E-05
Cobalt B½		0.000002	0.000001	0.000000	0.000001	0.000001	0.000001	0.000001	0.000001
mg/dscm		0.000002	0.000002	0.000001	0.000001	0.000001	0.000001	0.000001	0.000001
Ib/hr		2.16E-06	1.87E-06	6.18E-07	1.10E-06	9.60E-07	7.11E-07	9.23E-07	1.19E-06
Lead B½		0.000015	0.000009	0.000004	0.000007	0.000004	0.000004	0.000003	0.000006
mg/dscm		0.000018	1.90E-05	1.22E-05	5.25E-06	8.53E-06	5.40E-06	5.06E-06	0.000008
Ib/hr								3.24E-06	8.38E-06
Manganese B½		0.000024	0.000017	0.000008	0.000011	0.000013	0.000021	0.000028	0.000018
mg/dscm		0.000029	0.000021	0.000010	0.000014	0.000016	0.000025	0.000035	0.000021
Ib/hr		3.12E-05	2.23E-05	1.07E-05	1.45E-05	1.70E-05	2.69E-05	3.66E-05	2.27E-05
Mercury B½		< 0.00014	< 0.00011	< 0.00019	< 0.00010	< 0.00008	< 0.00010	< 0.00008	< 0.00011
mg/dscm		< 0.00017	< 0.00013	< 0.00024	< 0.00012	< 0.00010	< 0.00012	< 0.00010	< 0.00014
Ib/hr		< 1.88E-05	< 1.37E-05	< 2.51E-05	< 1.27E-05	< 1.07E-05	< 1.29E-05	< 1.04E-05	< 1.49E-05
Nickel B½		0.000028	0.000012	0.000015	0.000016	0.000011	0.000007	0.000007	0.000014
mg/dscm		0.000034	0.000014	0.000019	0.000018	0.000013	0.000009	0.000009	0.000016
Ib/hr		3.71E-05	1.51E-05	1.97E-05	1.88E-05	1.43E-05	9.62E-06	9.02E-06	1.77E-05
Selenium B½		0.000022	0.000006	0.000023	0.000091	0.00023	0.000163	0.000011	0.000049
mg/dscm		0.000027	0.000008	2.97E-06	1.18E-04	3.01E-05	0.000196	0.00014	0.000059
Ib/hr		2.91E-05	8.24E-06				2.10E-05	1.48E-05	6.29E-05

ND< - species not detected in sample. ND< = BDL

< - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL

Data reported without ND< or < = DLL

EPA 29 - TRACE METALS EXAMPLE CALCULATION
TEST NUMBER: CT-4-1-EPA 29

Identifier	Description	Units	Equation	Example For Antimony (Sb)
A	Stack O2	%	--	16.02
B	Stack CO2	%	--	4.40
C	Meter Volume	acf	--	189.103
D	Barometric Pressure	" Hg	--	28.36
E	Delta H	" H ₂ O	--	2.0
F	Reference Temperature	R	--	528
G	Meter Temperature	R	--	540.4
H	Y _d	--	--	1.014
I	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	178.482
J	Liquid Collected	grams	--	200.4
K	Water vapor volume	scf	0.04716 * J * F/528	9.451
L	Moisture Content	--	T/(T + R)	0.050
M	Molecular weight, dry	lb/lb-mole	0.44 * B + 0.32 * A + 0.28 * (100 - A - B)	29.35
N	Molecular weight, wet	lb/lb-mole	M * (1 - L) + 18 * L	28.77
O	Static Pressure	" H ₂ O	--	-0.55
P	Stack Pressure	" Hg	D + O/13.6	28.32
Q	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	1.0087
R	Stack Temperature	R	--	1163.54
S	Pitot Tube Coeficient	--	--	0.84
T	Stack Velocity	fps	85.49 * S * sqrt(Q * R / P / N)	86.18
U	Stack Area	ft ²	--	16.50
V	Stack Flow Rate	acfm	T * U * 60	85,314
W	Stack Flow Rate	dscfm	V * (1 - L) * F * P / R / 29.92	34,801
X	Sample Time	minutes	--	240.0
Y	Nozzle Diameter	inches	--	0.254
Z	Isokinetic Sampling Rate	%	14,128*528/F*R*I/X/T/60/(D*13.6+O)/Y ²	100.2
AA	Antimony Catch	ug	--	0.44
AB	Antimony Concentration	ug/dscf	AA / I	0.0025
AC	Antimony Concentration	mg/dscm	AB * 35.31/10 ³	0.000088
AD	Antimony Concentration	mg/dscfm @15%O ₂	AC*5.9/(20.9-A)	0.000106
AE	Antimony Emissions	lb/hr	W* 60*AB / 454x10 ⁶	1.14E-05

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

Gaseous Emissions Test Summary
SUNSHINE GAS CT 4

Test Number	1-EPA320	2-EPA320	3-EPA320	4-EPA320	5-EPA320	6-EPA320	7-EPA320	Averages
Date	2/7/2023	2/7/2023	2/7/2023	2/8/2023	2/8/2023	2/8/2023	2/8/2023	
Start Time	10:50	12:00	13:15	9:06	10:19	11:23	13:05	
Stop Time	11:50	13:08	14:15	10:06	11:19	12:32	14:05	
Pre-Test Information:								
Reference Temperature, °F	68	68	68	68	68	68	68	
Diluent Emissions and Stack Flow Rate:								
O ₂ , % vol. dry	16.02	16.02	16.02	16.01	16.01	16.01	16.07	16.03
CO ₂ , % vol. dry	4.40	4.40	4.40	4.52	4.52	4.52	4.47	4.46
Stack Flow Rate, dscfm	34,673	34,673	34,673	34,670	34,670	34,670	34,381	34,630
Pollutant Emissions:								
Hydrochloric Acid (HCl)								
ppm vol. dry	0.54	0.49	0.50	0.45	0.51	0.56	0.60	0.52
ppmc vol. dry @ 15% O ₂	0.65	0.59	0.61	0.54	0.61	0.68	0.73	0.63
lb/hr	0.11	0.10	0.10	0.09	0.10	0.11	0.12	0.10
Hydrogen Fluoride (HF)								
ppm vol. dry	1.72	1.67	1.79	1.62	1.81	1.90	2.00	1.79
ppmc vol. dry @ 15% O ₂	2.08	2.02	2.16	1.95	2.19	2.30	2.44	2.16
lb/hr	0.19	0.18	0.19	0.17	0.20	0.21	0.21	0.19
Formaldehyde (CH₂O)								
ppm vol. dry	0.021	0.021	0.028	0.035	0.026	0.028	0.030	0.027
ppmc vol. dry @ 15% O ₂	0.026	0.025	0.034	0.042	0.032	0.034	0.037	0.033
lb/hr	0.003	0.003	0.005	0.006	0.004	0.005	0.005	0.004

EPA 320 EXAMPLE CALCULATION
TEST NUMBER: CT-4- 1-EPA 320

Identifier	Description	Units	Equation	Run 1 Value
Using Data from Run 1:				
A	Formaldehyde (from FTIR)	ppmvw	--	0.02
B	Formaldehyde (from FTIR)	ppmvd	--	0.02
C	HCL (from FTIR)	ppmvw	--	0.51
D	HCL (from FTIR)	ppmvd	--	0.54
E	HF (from FTIR)	ppmvw	--	1.62
F	HF (from FTIR)	ppmvd	--	1.72
G	Formaldehyde	ppmvd@15%O2	B*5.9/(20.9-J)	0.03
H	HCL	ppmvd@15%O2	D*5.9/(20.9-J)	0.65
I	HF	ppmvd@15%O2	F*5.9/(20.9-J)	2.08
J	Drift/Bias Corrected O ₂	%	--	16.02
K	Drift/Bias Corrected CO ₂	%	--	4.40
L	Meter Volume	acf	--	199.991
M	Barometric Pressure	" Hg	--	28.36
N	Delta H	" H ₂ O	--	2.0125
O	Reference Temperature	R	--	528
P	Meter Temperature	R	--	544.5
Q	Y _d	--	--	0.992
R	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	183.286
S	Liquid Collected	grams	--	219
T	Water vapor volume	scf	0.04716 * S * F/528	10.328
U	Moisture Content	--	T/(T + R)	0.053
V	Molecular weight, dry	lb/lb-mole	0.44 * K + 0.32 * J + 0.28 * (100 - J - K)	29.35
W	Molecular weight, wet	lb/lb-mole	V * (1 - U) + 18 * U	28.74
X	Static Pressure	" H ₂ O	--	-0.55
Y	Stack Pressure	" Hg	M + X/13.6	28.32
Z	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	1.0065
AA	Stack Temperature	R	--	1163.458
AB	Pitot Tube Coeficient	--	--	0.84
AC	Stack Velocity	fps	85.49 * AB * sqrt(Z * AA / Y / W)	86.14
AD	Stack Area	ft ²	--	16.50
AE	Stack Flow Rate	acfm	AC * AD * 60	85,268
AF	Stack Flow Rate	dscfm	AE * (1 - U) * O * Y / AA / 29.92	34,673
AG	Specific Molar Volume	SCF/lb-mole	385.3 * O / 528	385.3
AH	Formaldehyde Emission Rate	lb/hr	B * 30.031 * AF * 60 / AG / 10 ⁶	0.003
AI	HCL Emission Rate	lb/hr	D * 36.458 * AF * 60 / AG / 10 ⁶	0.106
AJ	HF Emission Rate	lb/hr	F * 20.01 * AF * 60 / AG / 10 ⁶	0.185

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only. Stack gas velocity and moisture content was reported from EPA Method 5, R1.

Appendix C.2.2 CT-5 Data

Gaseous Emissions Test Summary
SUNSHINE GAS CT 5

Test Number	RUN 1-CT5	RUN 2-CT5	RUN 3-CT5	RUN 4-CT5	RUN 5-CT5	RUN 6-CT5	RUN 7-CT5	Averages
Date	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/16/2023	2/16/2023	2/17/2023	
Start Time	8:01	12:21	7:36	12:01	7:36	12:01	7:31	
Stop Time	12:10	16:30	11:46	16:11	11:45	16:10	11:40	
Pre-Test Information:								
Reference Temperature, °F	68	68	68	68	68	68	68	
Diluent Emissions and Stack Flow Rate:								
O ₂ , % vol. dry	16.08	16.08	16.11	16.15	16.20	16.22	16.17	16.15
CO ₂ , % vol. dry	4.3	4.3	4.2	4.2	4.2	4.1	4.3	4.2
Stack Flow Rate, dscfm	33,956	33,815	34,017	33,819	34,037	34,235	33,840	33,960
Pollutant Emissions:								
Carbon Monoxide (CO)								
ppm vol. dry	0.39	0.08	0.14	0.12	0.15	0.08	0.26	0.18
ppmc vol. dry @ 15% O ₂	0.48	0.09	0.17	0.15	0.19	0.10	0.33	0.22
lb/hr	0.06	0.01	0.02	0.02	0.02	0.01	0.04	0.03

EPA 10 EXAMPLE CALCULATION

TEST NUMBER: CT-5- 1-EPA 10

Identifier	Description	Units	Equation	Run 1 Value
Using Data from Run 1:				
A	CO Pre-Test Zero Bias Response	ppm	--	-0.03
B	CO Post-Test Zero Bias Response	ppm	--	0.02
C	CO Pre-Test Span Bias Response	ppm	--	4.61
D	CO Post-Test Span Bias Response	ppm	--	4.68
E	Avg. Pre-Test Zero Bias Response	ppm	(A+B)/2	-0.01
F	Avg. Post-Test Span Bias Response	ppm	(C+D)/2	4.64
G	CO Span Gas Value	ppm	--	4.68
H	CO Average (raw)	ppm	--	0.38
I	Drift/Bias Corrected CO:	ppm	(H-E)/(F-E)*G	0.39
J	Drift/Bias Corrected O ₂ :	%	--	16.08
K	Drift/Bias Corrected CO ₂ :	%	--	4.29
L	Meter Volume	acf	--	189.534
M	Barometric Pressure	" Hg	--	27.98
N	Delta H	" H ₂ O	--	1.991667
O	Reference Temperature	R	--	528
P	Meter Temperature	R	--	528.6
Q	Y _d	--	--	0.992
R	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	176.538
S	Liquid Collected	grams	--	227.8
T	Water vapor volume	scf	0.04716 * S * F/528	10.743
U	Moisture Content	--	T/(T + R)	0.057
V	Molecular weight, dry	lb/lb-mole	0.44 * K + 0.32 * J + 0.28 * (100 - J - K)	29.33
W	Molecular weight, wet	lb/lb-mole	V * (1 - U) + 18 * U	28.68
X	Static Pressure	" H ₂ O	--	-0.58
Y	Stack Pressure	" Hg	M + X/13.6	27.94
Z	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	0.9831
AA	Stack Temperature	R	--	1161.458
AB	Pitot Tube Coeficient	--	--	0.84
AC	Stack Velocity	fps	85.49 * AB * sqrt(Z * AA / Y / W)	85.73
AD	Stack Area	ft ²	--	16.50
AE	Stack Flow Rate	acfmin	AC * AD * 60	84,863
AF	Stack Flow Rate	dscfm	AE * (1 - U) * O * Y / AA / 29.92	33,956
AG	Specific Molar Volume	SCF/lb-mole	385.3 * O / 528	385.3
AH	CO emission rate	lb/hr	I * 28 * AF * 60 / AG / 10 ⁶	0.06
AI	CO concentration, corrected	ppm@15%O ₂	I*5.9/(20.9-J)	0.48

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only. Stack gas velocity and moisture content was reported from EPA Method 5, R1.

Montrose
Particulate Matter Test Summary

Test No.	Client/Location	DTE Sunshine	Sample Location	CT5	1-EPA 5	2-EPA 5	3-EPA 5	4-EPA 5	5-EPA 5	6-EPA 5	7-EPA 5	Average
Date.....	February 14, 2023	February 14, 2023	February 15, 2023	February 16, 2023	February 16, 2023	February 17, 2023	*					
Start Time.....	8:00	12:20	7:35	12:00	7:35	16:10	11:45	12:00	12:00	11:40	11:40	*
Stop Time.....	12:10	16:30	11:45	28.15	28.15	28.33	28.33	28.33	28.33	28.14	28.14	*
Bar Press (in Hg).....	27.98	27.98	EPA M5	*								
Test Method.....	EPA M5	EPA M5	240	240	240	42 WCS	42 WCS	42 WCS	42 WCS	240	240	*
Sample Time (Min).....	240	42 WCS	42	42	42	42 WCS	42	42	42	42	42	*
Sample Train.....	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	0.992	*
Meter Cal Factor.....	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	0.84	*
Pilot Factor.....	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	0.257	*
Nozzle Diam (in).....	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	16.50	*
Stack Area (sq ft).....	16.08	16.08	16.11	16.11	16.11	16.20	16.20	16.20	16.22	16.17	16.17	*
Stack CO2 (%).....	4.29	4.29	4.25	4.23	4.23	4.18	4.18	4.18	4.19	4.14	4.14	*
Stack Press (wg).....	-0.58	-0.58	-0.48	-0.48	-0.48	-0.48	-0.48	-0.48	-0.49	-0.49	-0.49	*
Stack Temp (F).....	701.5	701.4	700.2	701.5	701.5	701.5	701.5	701.5	701.5	701.5	701.5	*
Vel Head (wg).....	0.9831	0.9715	0.9751	0.9692	0.9739	0.9686	0.9686	0.9686	0.9686	0.9665	0.9725	*
Meter Temp (F).....	68.6	76.1	57.9	72.7	61.7	76.0	68.3	68.3	68.3	68.3	68.8	*
Meter Press (wg).....	1.992	1.971	1.971	1.963	1.971	1.971	1.971	1.971	1.971	1.954	1.970	*
Meter Vol (acf).....	189.534	192.261	190.825	191.308	189.553	190.937	191.228	191.228	191.228	190.807	190.807	*
Liquid Vol (ml).....	227.8	219.8	225.3	218.5	214.5	213.4	213.4	213.4	213.4	213.3	213.3	*
Sid Sample Vol (SCF).....	176.538	176.563	182.502	177.880	181.113	177.555	179.211	178.766	178.766	178.766	178.766	*
Moisture Fraction.....	0.05736	0.055	0.055	0.055	0.053	0.044	0.053	0.053	0.053	0.053	0.053	*
Stack Gas Mol Wt.....	28.68	28.70	28.69	28.70	28.69	28.72	28.81	28.73	28.73	28.72	28.72	*
Stack Gas Velocity (ft/sec).....	85.73	85.19	85.03	85.04	85.00	84.56	84.56	84.56	84.56	84.80	85.05	*
Isokinetic Ratio (%).....	99.2	99.6	102.4	100.4	101.5	99.0	99.0	99.0	99.0	101.0	100.4	*
Stack Flow Rate (wacfm).....	84.863	84.333	84.176	84.188	84.147	83.942	83.942	83.942	83.942	84.194	84.194	*
Stack Flow Rate (dscfm).....	33.956	33.815	34.017	33.819	34.037	34.235	34.235	34.235	34.235	33.840	33.960	*
Stack Flow Rate (scfm).....	36.022	35.800	35.988	35.778	35.938	35.812	35.812	35.812	35.812	35.745	35.871	*
Heated Filter, mg.....	0.6	1.1	0.8	0.6	0.0	0.5	0.5	0.5	0.5	0.7	0.6	*
Probe Wash, mg.....	0.0	0.0	0.0	0.1	0.0	1.2	0.0	0.0	0.0	0.2	0.2	*
Total Weight Gain, mg.....	0.6	1.1	0.8	0.7	0.0	1.7	0.0	0.7	0.7	0.8	0.8	*
Particulate Emissions												
Grain Loading, g/hr/scf.....	0.00005	0.00010	0.00007	0.00006	0.00008	0.00009	0.00015	0.00006	0.00015	0.00007	0.00007	*
Grain Loading @ 15% O ₂	0.00006	0.00012	0.00008	0.00008	0.00009	0.00019	0.00019	0.00008	0.00019	0.00009	0.00009	*
Mass Emissions, lb/hr.....	0.015	0.028	0.020	0.018	0.018	0.043	0.017	0.017	0.017	0.020	0.020	*

EPA 5 EXAMPLE CALCULATION
TEST NUMBER: CT-5- 1-EPA 5

Identifier	Description	Units	Equation	Run 1 Value
A	Stack O2	%	--	16.08
B	Stack CO2	%	--	4.29
C	Meter Volume	acf	--	189.534
D	Barometric Pressure	" Hg	--	27.98
E	Delta H	" H ₂ O	--	2.0
F	Reference Temperature	R	--	528
G	Meter Temperature	R	--	528.6
H	Y _d	--	--	0.992
I	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	176.538
J	Liquid Collected	grams	--	227.8
K	Water vapor volume	scf	0.04716 * J * F/528	10.743
L	Moisture Content	--	T/(T + R)	0.057
M	Molecular weight, dry	lb/lb-mole	0.44 * B + 0.32 * A + 0.28 * (100 - A - B)	29.33
N	Molecular weight, wet	lb/lb-mole	M * (1 - L) + 18 * L	28.68
O	Static Pressure	" H ₂ O	--	-0.58
P	Stack Pressure	" Hg	D + O/13.6	27.94
Q	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	0.9831
R	Stack Temperature	R	--	1161.458333
S	Pitot Tube Coeficient	--	--	0.84
T	Stack Velocity	fps	85.49 * S * sqrt(Q * R / P / N)	85.73
U	Stack Area	ft ²	--	16.50
V	Stack Flow Rate	acfm	T * U * 60	84,863
W	Stack Flow Rate	dscfm	V * (1 - L) * F * P / R / 29.92	33,956
X	Sample Time	minutes	--	240.0
Y	Nozzle Diameter	inches	--	0.257
Z	Isokinetic Sampling Rate	%	14,128*528/F*R*I/X/T/60/(D*13.6+O)/Y ²	99.2
AA	Particulate Catch	mg	--	0.6
AB	Particulate Catch	lbs	AA / 454,000	1.32E-06
AC	Particulate Cate	grains	AB * 7,000	0.009
AD	Particulate Emissions	gr/dscf	AC / I	0.000052
AE	Particulate Emissions	gr/dscf @ 15% O ₂	AD * 5.9 / (20.9 - A)	0.000064
AF	Particulate Emissions	gr/dscf @ 12% CO ₂	AD * 12 / B	0.000147
AG	Particulate Emissions	lb/hr	AD * 60 / 7,000 * V	0.0153

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

TOTAL TRACE METALS LABORATORY SUMMARY
DTE SUNSHINE
CT5 STACK

Species	Test No.:	1-EPA 29 2/14/23	2-EPA 29 2/14/23	3-EPA 29 2/15/23	4-EPA 29 2/16/23	5-EPA 29 2/16/23	6-EPA 29 2/16/23	7-EPA 29 2/17/23	AVERAGES
	Date:	8:00	12:20	7:35	12:00	7:35	12:00	16:10	7:30
Stop Time:	12:10	16:30	12:45	16:10	11:45	13:37	17:46	11:40	
Flow Rate, discfm:	33.749	33.854	33.920	33.742	33.727	33.785	33.652	33.777	
Sample Volume, discf:	175.69	171.57	178.59	174.82	179.16	173.04	174.67	175.38	
O2, % volume dry:	16.08	16.08	16.11	16.15	16.20	16.22	16.17	16.15	
CO2, % volume dry:	4.29	4.25	4.23	4.18	4.19	4.14	4.27	4.22	
Moisture, % by volume:	5.09	4.79	4.95	4.97	4.76	4.81	4.91	4.90	
Antimony mg/m ³ @ 15% O ₂ lb/hr	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006
Arsenic mg/m ³ @ 15% O ₂ lb/hr	ND< 0.00007	ND< 0.00008	ND< 0.00007	ND< 0.00007	ND< 0.00007	ND< 0.00008	ND< 0.00008	ND< 0.00008	ND< 0.00008
Beryllium mg/m ³ @ 15% O ₂ lb/hr	ND< 0.00015	ND< 0.00015	ND< 0.00014	ND< 0.00014	ND< 0.00015	ND< 0.00015	ND< 0.00015	ND< 0.00015	ND< 0.00015
Cadmium mg/m ³ @ 15% O ₂ lb/hr	ND< 0.00018	ND< 0.00018	ND< 0.00018	ND< 0.00018	ND< 0.00018	ND< 0.00018	ND< 0.00018	ND< 0.00018	ND< 0.00018
Chromium mg/m ³ @ 15% O ₂ lb/hr	ND< 1.84E-05	ND< 1.89E-05	ND< 1.82E-05	ND< 1.85E-05	ND< 1.80E-05	ND< 1.87E-05	ND< 1.84E-05	ND< 1.84E-05	ND< 1.84E-05
Cobalt mg/m ³ @ 15% O ₂ lb/hr	ND< 0.00002	ND< 0.00002	ND< 0.00002	ND< 0.00002	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00002	< 0.00001
Lead mg/m ³ @ 15% O ₂ lb/hr	ND< 1.79E-06	ND< 1.84E-06	ND< 1.84E-06	ND< 1.79E-06	ND< 1.80E-06	ND< 1.75E-06	ND< 1.82E-06	< 2.17E-06	< 1.85E-06
Nickel mg/m ³ @ 15% O ₂ lb/hr	ND< 1.84E-06	< 3.17E-06	< 0.00003	< 0.00002	ND< 0.00002	ND< 0.00001	ND< 0.00001	< 0.00002	< 0.00002
Manganese mg/m ³ @ 15% O ₂ lb/hr	0.00125	0.00136	0.00104	0.00101	0.00100	0.00098	0.00111	0.00105	0.00130
Mercury mg/m ³ @ 15% O ₂ lb/hr	ND< 0.00001	ND< 0.00001	< 0.00002	< 0.00001	< 0.00002	ND< 0.00001	< 0.00002	< 0.00002	< 0.00002
Selenium mg/m ³ @ 15% O ₂ lb/hr	ND< 0.00002	ND< 0.00002	ND< 0.00002	< 1.96E-06	< 1.87E-06	< 2.00E-06	< 1.87E-06	< 2.10E-06	< 1.93E-06

ND< - species not detected in sample. ND< = BDL
 < - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL
 Data reported without ND< or < = ADL

FRONT HALF TRACE METALS LABORATORY SUMMARY
DTE SUNSHINE
CT5 STACK

Species	Test No.:	1-EPA 29 2/14/23	2-EPA 29 2/14/23	3-EPA 29 2/15/23	4-EPA 29 2/15/23	5-EPA 29 2/16/23	6-EPA 29 2/16/23	7-EPA 29 2/17/23	AVERAGES
Antimony F%		ND< 0.00005	ND< 0.00005						
mg/dscm	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006	ND< 0.00006
lb/hr	ND< 6.35E-06	ND< 6.52E-06	ND< 6.52E-06	ND< 6.27E-06	ND< 6.38E-06	ND< 6.22E-06	ND< 6.45E-06	ND< 6.37E-06	ND< 6.36E-06
Arsenic F%		ND< 0.00013	ND< 0.00014	ND< 0.00013	ND< 0.00014	ND< 0.00013	ND< 0.00014	ND< 0.00014	ND< 0.00014
mg/dscm	ND< 0.00017	ND< 0.00017	ND< 0.00016	ND< 0.00017	ND< 0.00017				
lb/hr	ND< 1.70E-05	ND< 1.75E-05	ND< 1.68E-05	ND< 1.71E-05	ND< 1.67E-05	ND< 1.73E-05	ND< 1.71E-05	ND< 1.71E-05	ND< 1.71E-05
Beryllium F%		ND< 0.00001	< 0.00001						
mg/dscm	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00001
lb/hr	ND< 1.35E-06	ND< 1.39E-06	ND< 1.33E-06	ND< 1.36E-06	ND< 1.36E-06	ND< 1.32E-06	ND< 1.37E-06	ND< 1.37E-06	< 1.41E-06
Cadmium F%		ND< 0.00001	< 0.00001						
mg/dscm	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	< 0.00001
lb/hr	ND< 1.32E-06	ND< 1.36E-06	ND< 1.30E-06	ND< 1.36E-06	ND< 1.32E-06	ND< 1.29E-06	ND< 1.34E-06	ND< 1.34E-06	< 1.32E-06
Chromium F%		0.00092	0.000126	0.000091	0.000089	0.000089	0.000072	0.000093	0.000093
mg/dscm	0.00112	0.00154	0.00112	0.00111	0.00111	0.00112	0.00116	0.00115	0.00115
lb/hr	1.16E-04	1.60E-04	1.15E-04	1.13E-04	1.13E-04	1.12E-04	1.17E-04	1.18E-04	1.18E-04
Cobalt F%		ND< 0.00001	ND< 0.00001						
mg/dscm	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
lb/hr	ND< 1.43E-06	ND< 1.47E-06	ND< 1.41E-06	ND< 1.43E-06	ND< 1.43E-06	ND< 1.40E-06	ND< 1.45E-06	ND< 1.43E-06	ND< 1.43E-06
Lead F%		0.00006	0.00006	0.00006	0.00006	0.00006	0.00007	0.00007	0.00006
mg/dscm	0.00008	0.00008	0.00007	0.00007	0.00007	0.00009	0.00009	0.00009	0.00008
lb/hr	8.15E-06	8.19E-06	7.40E-06	7.12E-06	7.40E-06	8.66E-06	8.60E-06	8.76E-06	8.12E-06
Manganese F%		0.00013	0.00047	0.00014	0.00014	0.00013	0.00053	0.00025	0.00026
mg/dscm	0.00016	0.00057	0.00017	0.00017	0.00017	0.00017	0.00067	0.00031	0.00032
lb/hr	1.65E-05	5.95E-05	1.72E-05	1.78E-05	1.78E-05	1.67E-05	6.69E-05	3.13E-05	3.23E-05
Mercury F%		ND< 0.00001	ND< 0.00001	ND< 0.00000	ND< 0.00001	ND< 0.00000	ND< 0.00001	ND< 0.00001	ND< 0.00001
mg/dscm	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
lb/hr	ND< 6.35E-07	ND< 6.52E-07	ND< 6.27E-07	ND< 6.38E-07	ND< 6.38E-07	ND< 6.22E-07	ND< 6.45E-07	ND< 6.37E-07	ND< 6.36E-07
Nickel F%		0.00028	0.00034	0.00028	0.00028	0.00028	0.00028	0.00025	0.00030
mg/dscm	0.00035	0.00042	0.00035	0.00035	0.00035	0.00048	0.00035	0.00031	0.00037
lb/hr	3.58E-05	4.33E-05	3.59E-05	3.57E-05	3.57E-05	4.83E-05	3.54E-05	3.16E-05	3.80E-05
Selenium F%		ND< 0.00006	ND< 0.00006						
mg/dscm	ND< 0.00007	ND< 0.00008	ND< 7.63E-06	ND< 7.73E-06	ND< 7.63E-06	ND< 7.56E-06	ND< 7.35E-06	ND< 7.74E-06	ND< 7.74E-06

ND< - species not detected in sample. ND< = BDL.
 < - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL.
 Data reported without ND< or < = ADL.

BACK HALF TRACE METALS LABORATORY SUMMARY
DTE SUNSHINE
CT5 STACK

Species	Test No.:	1-EPA 29 2/14/23	2-EPA 29 12:20	3-EPA 29 2/15/23	4-EPA 29 12:45	5-EPA 29 33:920	6-EPA 29 16:10	7-EPA 29 17:467	AVERAGES
Antimony B½		ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
mg/dscm	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
lb/hr	ND< 1.35E-06	ND< 1.38E-06	ND< 1.41E-06	ND< 1.35E-06	ND< 1.38E-06	ND< 1.41E-06	ND< 1.35E-06	ND< 1.37E-06	ND< 1.36E-06
Arsenic B½		ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
mg/dscm	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
lb/hr	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001
Beryllium B½		ND< 0.00003	ND< 0.00004	ND< 0.00004	ND< 0.00004	ND< 0.00003	ND< 0.00004	ND< 0.00003	ND< 0.00003
mg/dscm	ND< 0.00003	ND< 0.00004	ND< 0.00004	ND< 0.00004	ND< 0.00004	ND< 0.00004	ND< 0.00004	ND< 0.00004	ND< 0.00004
lb/hr	ND< 4.37E-07	ND< 4.49E-07	ND< 4.57E-07	ND< 4.57E-07	ND< 4.59E-07	ND< 4.59E-07	ND< 4.44E-07	ND< 4.38E-07	ND< 4.41E-07
Cadmium B½		ND< 0.00000	0.000001	0.000001	0.000000	ND< 0.00000	ND< 0.00000	ND< 0.00000	< 0.000003
mg/dscm	ND< 0.00000	0.000002	0.000001	0.000001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00001	ND< 0.00004
lb/hr	ND< 5.20E-07	1.82E-06	8.96E-07	ND< 5.23E-07	ND< 5.10E-07	ND< 5.29E-07	ND< 5.22E-07	ND< 4.41E-07	< 0.00004
Chromium B½		0.000011	0.000010	0.000013	0.000012	0.000010	0.000010	0.000019	< 0.00001
mg/dscm	0.000013	0.000012	0.000016	0.000015	0.000013	0.000012	0.000012	0.000015	< 0.00001
lb/hr	1.35E-05	1.25E-05	1.67E-05	1.53E-05	1.30E-05	1.21E-05	1.23E-05	1.52E-05	< 0.00001
Cobalt B½		ND< 0.00000	ND< 0.00000	0.000000	0.000000	ND< 0.00000	ND< 0.00000	0.000001	< 0.00000
mg/dscm	ND< 0.00000	ND< 0.00000	ND< 0.00001	0.000000	ND< 0.00001	ND< 0.00001	ND< 0.00001	0.000001	< 0.00000
lb/hr	ND< 4.16E-07	ND< 4.28E-07	5.52E-07	4.34E-07	6.00E-07	4.23E-07	6.70E-07	5.03E-07	< 0.00000
Lead B½		0.00002	0.00003	0.00002	0.00002	0.00002	0.00002	0.00001	0.00002
mg/dscm	0.00002	0.00003	0.00002	0.00003	0.00003	0.00002	0.00002	0.00002	0.00002
lb/hr	2.51E-06	2.92E-06	3.69E-06	2.73E-06	2.36E-06	1.59E-06	2.49E-06	2.61E-06	< 0.00000
Manganese B½		0.00310	0.00010	0.00035	0.00099	0.00018	0.00013	0.00034	0.00061
mg/dscm	0.00379	0.00013	0.00043	0.00011	0.00023	0.00017	0.00043	0.00075	0.00075
lb/hr	3.91E-04	1.33E-05	4.47E-05	1.08E-05	2.20E-05	1.70E-05	4.30E-05	7.75E-05	7.75E-05
Mercury B½		< 0.00008	< 0.00009	< 0.00008	< 0.00008	< 0.00008	< 0.00009	< 0.00008	< 0.00008
mg/dscm	< 0.00010	< 0.00011	< 0.00010	< 0.00010	< 0.00010	< 0.00010	< 0.00011	< 0.00010	< 0.00010
lb/hr	< 1.02E-05	< 1.10E-05	< 1.04E-05	< 1.05E-05	< 1.04E-05	< 1.11E-05	< 1.04E-05	< 1.06E-05	< 1.06E-05
Nickel B½		0.00008	0.00008	0.00009	0.00011	0.00013	0.00008	0.00015	0.00010
mg/dscm	0.00010	0.00010	0.00011	0.00011	0.00016	0.00010	0.00019	0.00013	0.00013
lb/hr	9.85E-06	1.06E-05	1.09E-05	1.09E-05	1.59E-05	1.01E-05	1.88E-05	1.29E-05	1.29E-05
Selenium B½		0.00168	0.00047	0.00399	0.00007	0.00016	0.00005	0.00019	0.00094
mg/dscm	0.00206	0.00058	0.00492	0.00008	0.00020	0.00006	0.00023	0.00116	0.00116
lb/hr	2.15E-04	5.97E-05	5.07E-04	8.32E-06	6.17E-06	2.05E-05	2.36E-05	1.20E-05	1.20E-05

ND< - species not detected in sample ND< = BDL
 < - species detected in at least one sample or one sample fraction but not in all samples or fractions. < = DLL
 Data reported without ND< or < = ADL

EPA 29 - TRACE METALS EXAMPLE CALCULATION
TEST NUMBER: CT-5-1-EPA 29

Identifier	Description	Units	Equation	Example For Chromium (Cr)
A	Stack O2	%	--	16.08
B	Stack CO2	%	--	4.29
C	Meter Volume	acf	--	182.643
D	Barometric Pressure	" Hg	--	27.98
E	Delta H	" H ₂ O	--	2.0
F	Reference Temperature	R	--	528
G	Meter Temperature	R	--	523.2
H	Y _d	--	--	1.014
I	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	175.689
J	Liquid Collected	grams	--	199.9
K	Water vapor volume	scf	0.04716 * J * F/528	9.427
L	Moisture Content	--	T/(T + R)	0.051
M	Molecular weight, dry	lb/lb-mole	0.44 * B + 0.32 * A + 0.28 * (100 - A - B)	29.33
N	Molecular weight, wet	lb/lb-mole	M * (1 - L) + 18 * L	28.75
O	Static Pressure	" H ₂ O	--	-0.58
P	Stack Pressure	" Hg	D + O/13.6	27.94
Q	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	0.9604
R	Stack Temperature	R	--	1161.46
S	Pitot Tube Coeficient	--	--	0.84
T	Stack Velocity	fps	85.49 * S * sqrt(Q * R / P / N)	84.63
U	Stack Area	ft ²	--	16.50
V	Stack Flow Rate	acfm	T * U * 60	83,773
W	Stack Flow Rate	dscfm	V * (1 - L) * F * P / R / 29.92	33,749
X	Sample Time	minutes	--	240.0
Y	Nozzle Diameter	inches	--	0.254
Z	Isokinetic Sampling Rate	%	14,128*528/F*R*I/X/T/60/(D*13.6+O)/Y ²	101.7
AA	Antimony Catch	ug	--	5.09
AB	Antimony Concentration	ug/dscf	AA / I	0.0290
AC	Antimony Concentration	mg/dscm	AB * 35.31/10 ³	0.001023
AD	Antimony Concentration	mg/dscfm @15%O ₂	AC*5.9/(20.9-A)	0.001252
AE	Antimony Emissions	lb/hr	W* 60*AB / 454x10 ⁶	1.29E-04

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only.

Gaseous Emissions Test Summary
SUNSHINE GAS CT 5

Test Number	1-EPA320	2-EPA320	3-EPA320	4-EPA320	5-EPA320	6-EPA320	7-EPA320	Averages
Date	2/14/2023	2/14/2023	2/14/2023	2/14/2023	2/15/2023	2/15/2023	2/15/2023	
Start Time	9:15	10:20	11:25	12:40	9:05	10:10	11:15	
Stop Time	10:15	11:20	12:34	13:40	10:05	11:10	12:30	
Pre-Test Information:								
Reference Temperature, °F	68	68	68	68	68	68	68	
Diluent Emissions and Stack Flow Rate:								
O ₂ , % vol. dry	16.08	16.08	16.08	16.08	16.11	16.11	16.11	16.09
CO ₂ , % vol. dry	4.29	4.29	4.29	4.25	4.23	4.23	4.23	4.26
Stack Flow Rate, dscfm	33,956	33,956	33,956	33,815	34,017	34,017	34,017	33,962
Pollutant Emissions:								
Hydrochloric Acid (HCl)								
ppm vol. dry	0.29	0.31	0.35	0.38	0.29	0.33	0.39	0.34
ppmc vol. dry @ 15% O ₂	0.35	0.38	0.43	0.47	0.35	0.41	0.49	0.41
lb/hr	0.06	0.06	0.07	0.07	0.06	0.06	0.08	0.06
Hydrogen Fluoride (HF)								
ppm vol. dry	1.26	1.34	1.40	1.45	1.21	1.52	1.64	1.40
ppmc vol. dry @ 15% O ₂	1.54	1.64	1.72	1.77	1.49	1.87	2.02	1.72
lb/hr	0.13	0.14	0.15	0.15	0.13	0.16	0.17	0.15
Formaldehyde (CH₂O)								
ppm vol. dry	0.096	0.081	0.092	0.077	0.051	0.054	0.040	0.070
ppmc vol. dry @ 15% O ₂	0.118	0.100	0.112	0.094	0.063	0.066	0.049	0.086
lb/hr	0.015	0.013	0.015	0.012	0.008	0.009	0.006	0.011

EPA 320 EXAMPLE CALCULATION

TEST NUMBER: CT-5- 1-EPA 320

Identifier	Description	Units	Equation	Run 1 Value
Using Data from Run 1:				
A	Formaldehyde (from FTIR)	ppmvw	--	0.09
B	Formaldehyde (from FTIR)	ppmvd	--	0.10
C	HCL (from FTIR)	ppmvw	--	0.27
D	HCL (from FTIR)	ppmvd	--	0.29
E	HF (from FTIR)	ppmvw	--	1.19
F	HF (from FTIR)	ppmvd	--	1.26
G	Formaldehyde	ppmvd@15%O2	B*5.9/(20.9-J)	0.12
H	HCL	ppmvd@15%O2	D*5.9/(20.9-J)	0.35
I	HF	ppmvd@15%O2	F*5.9/(20.9-J)	1.54
J	Drift/Bias Corrected O ₂ :	%	--	16.08
K	Drift/Bias Corrected CO ₂ :	%	--	4.29
L	Meter Volume	acf	--	189.534
M	Barometric Pressure	" Hg	--	27.98
N	Delta H	" H ₂ O	--	1.991667
O	Reference Temperature	R	--	528
P	Meter Temperature	R	--	528.6
Q	Y _d	--	--	0.992
R	Meter Volume (standard)	dscf	1/29.92 * C * (D + E/13.6) * F/G * H	176.538
S	Liquid Collected	grams	--	227.8
T	Water vapor volume	scf	0.04716 * S * F/528	10.743
U	Moisture Content	--	T/(T + R)	0.057
V	Molecular weight, dry	lb/lb-mole	0.44 * K + 0.32 * J + 0.28 * (100 - J - K)	29.33
W	Molecular weight, wet	lb/lb-mole	V * (1 - U) + 18 * U	28.68
X	Static Pressure	" H ₂ O	--	-0.58
Y	Stack Pressure	" Hg	M + X/13.6	27.94
Z	Average Velocity Differential Pressure	" H ₂ O	square of the average of the square roots	0.9831
AA	Stack Temperature	R	--	1161.458
AB	Pitot Tube Coeficient	--	--	0.84
AC	Stack Velocity	fps	85.49 * AB * sqrt(Z * AA / Y / W)	85.73
AD	Stack Area	ft ²	--	16.50
AE	Stack Flow Rate	acfm	AC * AD * 60	84,863
AF	Stack Flow Rate	dscfm	AE * (1 - U) * O * Y / AA / 29.92	33,956
AG	Specific Molar Volume	SCF/lb-mole	385.3 * O / 528	385.3
AH	Formaldehyde Emission Rate	lb/hr	B * 30.031 * AF * 60 / AG / 10 ⁶	0.015
AI	HCL Emission Rate	lb/hr	D * 36.458 * AF * 60 / AG / 10 ⁶	0.055
AJ	HF Emission Rate	lb/hr	F * 20.01 * AF * 60 / AG / 10 ⁶	0.133

Note:

(1) Some values may be slightly different from those shown on the run sheets due to round off errors. This page is intended to show the calculation methodology only. Stack gas velocity and moisture content was reported from EPA Method 5, R1.

APPENDIX D

QUALITY ASSURANCE INFORMATION

Appendix D.1

Quality Assurance Program Summary

QUALITY ASSURANCE PROGRAM SUMMARY

As part of Montrose Air Quality Services, LLC (Montrose) ASTM D7036-04 certification, Montrose is committed to providing emission related data which is complete, precise, accurate, representative, and comparable. Montrose quality assurance program and procedures are designed to ensure that the data meet or exceed the requirements of each test method for each of these items. The quality assurance program consists of the following items:

- Assignment of an Internal QA Officer
- Development and use of an internal QA Manual
- Personnel training
- Equipment maintenance and calibration
- Knowledge of current test methods
- Chain-of-custody
- QA reviews of test programs

Assignment of an Internal QA Officer: Montrose has assigned an internal QA Officer who is responsible for administering all aspects of the QA program.

Internal Quality Assurance Manual: Montrose has prepared a QA Manual according to the requirements of ASTM D7036-04 and guidelines issued by EPA. The manual documents and formalizes all of Montrose's QA efforts. The manual is revised upon periodic review and as Montrose adds capabilities. The QA manual provides details on the items provided in this summary.

Personnel Testing and Training: Personnel testing and training is essential to the production of high quality test results. Montrose training programs include:

- A requirement for all technical personnel to read and understand the test methods performed
- A requirement for all technical personnel to read and understand the Montrose QA manual
- In-house testing and training
- Quality Assurance meetings
- Third party testing where available
- Maintenance of training records.

Equipment Maintenance and Calibration: All laboratory and field equipment used as a part of Montrose's emission measurement programs is maintained according to manufacturer's recommendations. A summary of the major equipment maintenance schedules is summarized in Table 1. In addition to routine maintenance, calibrations are performed on all sampling equipment according to the procedures outlined in the applicable test method. The calibration intervals and techniques for major equipment components is summarized in Table 2. The calibration technique may vary to meet regulatory agency requirements.

Knowledge of Current Test Methods: Montrose maintains current copies of EPA, ARB, and SCAQMD Source Test Manuals and Rules and Regulations.

Chain-of-Custody: Montrose maintains chain-of-custody documentation on all data sheets and samples. Samples are stored in a locked area accessible only to Montrose source test personnel. Data sheets are kept in the custody of the originator, program manager, or in locked storage until return to Montrose office. Electronic field data is duplicated for backup on secure storage media. The original data sheets are used for report preparation and any additions are initialed and dated.

QA Reviews: Periodic field, laboratory, and report reviews are performed by the in-house QA coordinator. Periodically, test plans are reviewed to ensure proper test methods are selected and reports are reviewed to ensure that the methods were followed and any deviations from the methods are justified and documented.

ASTM D7036-04 Required Information

Uncertainty Statement

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is presented in the report appendices.

Performance Data

Performance data are available for review.

Qualified Personnel

A qualified individual (QI), defined by performance on a third party or internal test on the test methods, is present on each test event.

Plant Entry and Safety Requirements

Plant Entry

All test personnel are required to check in with the guard at the entrance gate or other designated area. Specific details are provided by the facility and project manager.

Safety Requirements

All personnel shall have the following personal protective equipment (PPE) and wear them where designated:

- Hard Hat
- Safety Glasses
- Steel Toe Boots
- Hearing Protection
- Gloves
- High Temperature Gloves (if required)
- Flame Resistant Clothing (if required)

The following safety measures are followed:

- Good housekeeping
- SDS for all on-site hazardous materials
- Confine selves to necessary areas (stack platform, mobile laboratory, CEMS data acquisition system, control room, administrative areas)
- Knowledge of evacuation procedures

Each facility will provide plant specific safety training.

TABLE 1
EQUIPMENT MAINTENANCE SCHEDULE

Equipment	Acceptance Limits	Frequency of Service	Methods of Service
Pumps	1. Absence of leaks 2. Ability to draw manufacturers required vacuum and flow	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Replace parts 4. Leak check
Flow Meters	1. Free mechanical movement	As recommended by manufacturer	1. Visual inspection 2. Clean 3. Calibrate
Sampling Instruments	1. Absence of malfunction 2. Proper response to zero span gas	As recommended by manufacturer	As recommended by manufacturer
Integrated Sampling Tanks	1. Absence of leaks	Depends on nature of use	1. Steam clean 2. Leak check
Mobile Van Sampling System	1. Absence of leaks	Depends on nature of use	1. Change filters 2. Change gas dryer 3. Leak check 4. Check for system contamination
Sampling Lines	1. Sample degradation less than 2%	After each test series	1. Blow dry, inert gas through line until dry

TABLE 2
MAJOR SAMPLING EQUIPMENT CALIBRATION REQUIREMENTS

Sampling Equipment	Calibration Frequency	Calibration Procedure	Acceptable Calibration Criteria
Continuous Analyzers	Before and After Each Test Day	3-point calibration error test	< 2% of analyzer range
Continuous Analyzers	Before and After Each Test Run	2-point sample system bias check	< 5% of analyzer range
Continuous Analyzers	After Each Test Run	2-point analyzer drift determination	< 3% of analyzer range
CEMS System	Beginning of Each Day	leak check	< 1 in. Hg decrease in 5 min. at > 20 in. Hg
Continuous Analyzers	Semi-Annually	3-point linearity	< 1% of analyzer range
NO _x Analyzer	Daily	NO ₂ -> NO converter efficiency	> 90%
Differential Pressure Gauges (except for manometers)	Semi-Annually	Correction factor based on 5-point comparison to standard	± 5%
Differential Pressure Gauges (except for manometers)	Bi-Monthly	3-point comparison to standard, no correction factor	± 5%
Barometer	Semi-Annually	Adjusted to mercury-in-glass or National Weather Service Station	± 0.1 inches Hg
Dry Gas Meter	Semi-Annually	Calibration check at 4 flow rates using a NIST traceable standard	± 2%
Dry Gas Meter	Bi-Monthly	Calibration check at 2 flow rates using a NIST traceable standard	± 2% of semi-annual factor
Dry Gas Meter Orifice	Annually	4-point calibration for ΔH@	--
Temperature Sensors	Semi-Annually	3-point calibration vs. NIST traceable standard	± 1.5%

Note: Calibration requirements that meet applicable regulatory agency requirements are used.

Appendix D.2 CARB and STAC Certifications

Sunshine Gas Producers, LLC
2023 ICR on CT-4 and CT-5



Gavin Newsom, Governor
Jared Blumenfeld, CalEPA Secretary
Liane M. Randolph, Chair

June 30, 2022

Mr. Matt McCune
Montrose Air Quality Services , LLC
1631 East Saint Andrew Place
Santa Ana, California 92705
mmccune@montrose-env.com

Dear Mr. McCune:

I am pleased to inform you that the California Air Resources Board (CARB) has renewed Montrose Air Quality Services , LLC as an Independent Contractor, by means of the enclosed Executive Order I-22-003. This approval will allow Montrose Air Quality Services , LLC to perform CARB Test Methods 1, 2, 3, 4, 5, 6, 8, 17, 20, and 100 (CO, CO₂, NO_x, O₂, SO₂, THC), Visible Emission Evaluation (VEE), and U.S. Environmental Protection Agency (U.S. EPA) Test Methods 201A, 202, and 205. The approval is valid through June 30, 2024, during which time additional audits of Montrose Air Quality Services , LLC's testing ability may be performed.

If you have questions or need further assistance, please contact Kathryn Gugeler at kathryn.gugeler@arb.ca.gov or Daniel Moore at Daniel.Moore@arb.ca.gov.

Sincerely,

Catherine
Dunwoody

 Digitally signed by Catherine
Dunwoody
Date: 2022.06.30 14:05:25 -07'00'

Catherine Dunwoody, Chief, Monitoring and Laboratory Division

Enclosure

cc: (via email)

Kathryn M. Gugeler, Monitoring and Laboratory Division

Daniel Moore, Monitoring and Laboratory Division



American Association for Laboratory Accreditation

Accredited Air Emission Testing Body

A2LA has accredited

MONTROSE AIR QUALITY SERVICES

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036/2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 4th day of February 2022.

A handwritten signature in blue ink, appearing to read "John Doe".

Vice President, Accreditation Services
For the Accreditation Council
Certificate Number 3925.01
Valid to February 29, 2024



This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.

Appendix D.3 Individual QI Certificates

CERTIFICATE OF COMPLETION

James F Navarrete

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

Source Evaluation Society Group 1: EPA Manual/ Gas Volume and Flow Measurements and Isokinetic Particulate Sampling Methods

Certificate Number: 002-2021-1

Tate Strickler

DATE OF ISSUE: 1/4/21

Tate Strickler, VP – Quality Systems

DATE OF EXPIRATION: 1/4/26

CERTIFICATE OF COMPLETION

James F Navarrete

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

Source Evaluation Society Group 3: EPA Gaseous Pollutants /Instrument Sampling Methods

Certificate Number: 002-2021-13

Tate Strickler

DATE OF ISSUE:

2/11/21

Tate Strickler, VP – Quality Systems

DATE OF EXPIRATION:

2/10/26



CERTIFICATE OF COMPLETION

James F Navarrete

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

Source Evaluation Society Group 4: EPA Hazardous Metals Measurement Methods

Certificate Number: 002-2021-12

Tate Strickler

DATE OF ISSUE:

1/19/21

Tate Strickler, VP - Quality Systems

DATE OF EXPIRATION:

1/18/26



CERTIFICATE OF COMPLETION

Phil Kauppi

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

EPA Methods 318, 320, 321 & FTIR Protocol

Certificate Number: PRISM_2018-2

Tate Strickler

DATE OF ISSUE:

11/1/18

Tate Strickler, Accreditation Director

DATE OF
EXPIRATION:

11/1/23



CERTIFICATE OF COMPLETION

Phil Kauppi

This document certifies that this individual has passed a comprehensive examination and is now a Qualified Individual (QI) as defined in Section 8.3 of ASTM D7036-04 for the following method(s):

ASTM Method D6348-12

Certificate Number: PRISM-2021-1

Tate Strickler

DATE OF ISSUE:

1/27/21

Tate Strickler, VP – Quality Systems

DATE OF EXPIRATION:

1/27/26



APPENDIX E
STATIONARY COMBUSTION TURBINES EMISSIONS
INFORMATION COLLECTION DOCUMENT

STATIONARY COMBUSTION TURBINES EMISSIONS INFORMATION COLLECTION

Test Procedures, Methods and Reporting Requirements for the Section 114 Request for Stationary Combustion Turbines

This document provides an overview of the required testing, approved sampling and analysis methods, target pollutants and units of measure, and reporting requirements for stationary combustion turbines that are required to provide emission test data to the U.S. Environmental Protection Agency (EPA) under Clean Air Act (CAA) section 114 (42 U.S.C. 7414). The purpose for this testing is to gather data on air pollutant emissions from stationary combustion turbines in this source category to inform the EPA's decision-making process for regulation of these sources. All recipients must complete and submit test results no later than 6 months after receipt of this request. The document is organized as follows:

- 1.0 Testing Procedures and Methods**
- 2.0 How to Report Data**
- 3.0 How to Submit Data**
- 4.0 Contact Information for Questions on Test Plan and Reporting**

1.0 Testing Procedures and Methods

The EPA requires emissions and other test data for several pollutants, including specific hazardous air pollutants (HAP), criteria pollutants, and potential surrogate groups. If the EPA is requesting that you complete emissions testing, the cover letter of this CAA section 114 request will include a list of emissions sources selected for testing at your facility. For stationary combustion turbines as specified in Enclosure 1 of your section 114 cover letter, you must perform an emissions test for some combination of pollutants (*i.e.*, simultaneous measurements per group) and diluents according to the test protocols and test methods for air emissions presented in Section 1.1 of this document.

You may have conducted tests for some of these pollutants already. If you have conducted any of the requested groups of tests (*i.e.*, any complete set of tests required to be conducted simultaneously as described in Footnote 2 to Table 1) in the past 5 years, these test data may be submitted for this section 114 request according to the procedures in Section 2 and no additional testing for those pollutants is required, provided the test data you submit is representative of your operations and the previous testing met the testing requirements specified in this document (*e.g.*, test method, sample volume) and contains all required data elements.

Please refer to the Stationary Combustion Turbines website (<https://www.epa.gov/stationary-sources-air-pollution/stationary-combustion-turbines-national-emission-standards>) for additional

testing information. Please note that you do not have to submit a test plan to the EPA for approval prior to testing; however, we recommend that you prepare a test plan for your own use to assist in the planning of the test program and to verify that you address all of the testing and reporting requirements specified in this document. Please note that you also must report your process and emissions testing data using the EPA's Electronic Reporting Tool (ERT), where applicable. You are directed to the ERT website (<https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>) for a more complete and interactive description of the ERT, list of methods currently supported by the ERT, and a link to download the ERT. Some of the emissions test methods listed in this document are supported in the ERT while others are not (e.g., U.S. EPA Method 320).

You must follow all of the procedures as specified in the test methods, including the quality assurance and quality control measures, and document the results in the ERT and in any test report provided to the EPA. For this program, you do not need to obtain audit materials from your state or local agency or from the EPA. You may apply any third-party audit materials you have on hand and document the results, but you are not required to do so.

If Enclosure 1 of your section 114 cover letter is missing any stationary combustion turbines subject to 40 CFR part 63, subpart YYYY, or if any of the stationary combustion turbines included in Enclosure 1 are misclassified (e.g., units are not in the appropriate test group or are not subject to subpart YYYY), please contact Melanie King (see Section 4.0 of this document). If a facility has units that are required to be tested according to your section 114 cover letter but you are unable to respond to an item exactly as requested and you are unable to test another similar unit, please explain why you cannot respond and/or provide any information you believe may be related in a submission to Melanie King (see Section 4.0 of this document) within **35 days** of postmark date of your section 114 cover letter. *NOTE:* The EPA reserves all of its enforcement rights provided by CAA section 113, including the right to bring a claim in the U.S. District Court to enforce the CAA section 114 obligation to comply with all the requests described in this document.

1.1 Stack Test Methods

You must follow the stack test method procedures described in this section for each stationary combustion turbine that you are required to test.

The owner/operator of the stationary combustion turbine must certify that the unit tested was operating in a normal and representative manner during the performance test. The owner/operator must also certify that it operated the air pollution control device (APCD), if any, on the unit tested in accordance with manufacturers' specifications and requirements for proper operation during the emissions testing.

1.1.1 Sample Location

You should collect emissions samples for the identified pollutants downstream of the last relevant APCD (*i.e.*, stack or other point representing the composition of the flue gases at the exit to the atmosphere), unless otherwise indicated. You must use U.S. EPA Method 1 or 1A of Appendix A-1 to 40 CFR Part 60, as applicable, to select the locations and number of traverse

points for sampling for the tests in this section. See <https://www.epa.gov/emc/method-1-samplevelocity-traverses> and <https://www.epa.gov/emc/method-1a-small-ducts> for copies of the methods and guidance information for sampling situations not meeting Method 1 criteria.

1.1.2 Emissions Measurement Methods

Table 1 summarizes the testing required to be performed for each type of stationary combustion turbine. When possible, testing for each of the pollutants listed in Table 1 should be conducted simultaneously for your stationary combustion turbine. However, if simultaneous testing is not possible, then you must at least conduct the tests for formaldehyde and carbon monoxide simultaneously and conduct the tests for filterable particulate matter (PM) and HAP metals testing simultaneously. It is not necessary to test the different pollutants in any particular order.

The primary reason for concurrent testing is to obtain a clear understanding about the overall HAP emissions profile from each emission process point. A second reason is to gather information that will help us evaluate the correlations of emissions of one pollutant to another pollutant, to potentially establish surrogate relationships. For example, the metal HAP tests and PM tests from the APCD or main stack are required to be done at the same time. Where a predictable relationship between metal HAP and PM exists, a surrogate relationship can be established for compliance purposes. *Tests that are required to be concurrent under this test request that are not done in this manner may be considered invalid and may need to be repeated.*

Table 1 also presents a list of the test methods to use for completing the required tests. For copies of the U.S. EPA test methods and additional information, please refer to the EPA's Emission Measurement Center (EMC) website, <https://www.epa.gov/emc>.

Report all pollutant emission data as indicated in Table 1. Report the results of your emissions tests according to the directions provided in Section 2.0 of this document.

Unless otherwise specified, each pollutant emissions test should consist of at least seven test runs for the sampling duration and/or volume indicated for each specified unit.

Table 1. Summary of Test Methods¹

Pollutant ²	Method	Alternative Procedure	Target Reported Units of Measure
Formaldehyde (50000)	U.S. EPA Method 320. Minimum sample time of 1 hour per run. Validate according to Section 13.0 of Method 320. ^{3,4}	ASTM D-6348-12e1 ^{3,4,5}	lb/hr, ppmvd, and ppmvd @ 15% O ₂
Carbon monoxide	U.S. EPA Method 10.* Minimum sample time of 1 hour per run.	CEMS ⁶ (if installed).	lb/hr, ppmvd, and ppmvd @ 15% O ₂
Acid gases (Hydrochloric acid and Hydrogen fluoride)	U.S. EPA Method 320. Minimum sample time of 1 hour per run. Validate according to Section 13.0 of Method 320. ^{3,4}	ASTM D-6348-12e1 ^{3,4,5}	lb/hr, ppmvd, and ppmvd @ 15% O ₂
Metals ⁷ and PM (filterable)	U.S. EPA Method 29.* Collect a minimum volume of 141 dscf (4 dscm) per run. Use inductively coupled (argon) plasma with mass spectrometry (ICAP/MS) for the analytical finish with the exception of mercury analysis, which should be conducted by cold vapor atomic absorption spectroscopy (CVAAAS). Analyze front and back half samples separately. Report results for front half and back half analyses for individual metals separately. Determine filterable PM emissions according to section 8.3.1.1. Maintain a filter temperature of 248°F ± 25°F.	You may opt to conduct a separate EPA Method 5* test with a filter temperature of 248°F ± 25°F in lieu of measuring PM with the Method 29 train.	lb/hr and concentration (for metals, mg/dscm and mg/dscm @ 15% O ₂ and for PM, gr/dscf and gr/dscf @ 15% O ₂)
Gas flow rate	U.S. EPA Method 2*, 2A, 2B, 2C*, 2D, 2F, or 2G, as appropriate, simultaneous with each pollutant test run.		acf m, scfm, and dscfm
O ₂ /CO ₂	U.S. EPA Method 3A* or 3B, as appropriate, simultaneous with each pollutant test run.		percent volume, dry
Moisture	U.S. EPA Method 4* or Method 320, simultaneous with each pollutant test run.	ASTM D-6348-12e1 ⁴	percent volume

¹ lb/hr = pounds per hour; ppmvd = parts per million by volume, dry basis; % = percent; O₂ = oxygen; dscf = dry standard cubic feet; dscm = dry standard cubic meters; °F = degrees Fahrenheit; mg/dscm = milligrams per dry standard cubic meter; gr/dscf = grains per dry standard cubic foot; acfm = actual cubic feet per minute; scfm = standard cubic feet per minute; dscfm = dry standard cubic feet per minute.

² For each turbine, at a minimum, conduct simultaneous sampling for formaldehyde and carbon monoxide and simultaneous sampling for metals and PM

³ Method detection limit for FTIR measurements is considered to be the Minimum Analyte Uncertainty (MAU) and should be calculated per the method. Alternatively, if the FTIR measurements are performed according to ASTM D6348 the method detection limit is considered to be the Minimum Detection Concentration #3 (MDC#3) and should be calculated per the method.

⁴ For analyte spiking, you must use the analyte(s) of interest, the use of surrogate compound(s) is prohibited for the purpose of this section 114 request.

⁵ The test plan preparation and implementation in the Annexes to ASTM D6348-03, Sections A1 through A8 are mandatory; (2) For ASTM D6348-03 Annex A5 (Analyte Spiking Technique), the percent R must be determined for each target analyte (A5.8) and be within 30%; (3) The percent R value for each target analyte must be reported in the test report; and (4) the analytical accuracy of the algorithm (A7.6) must be documented and reported in the test report.

⁶ If you provide data from a plant Continuous Emissions Monitoring System (CEMS), your CEMS must be certified according to the appropriate performance specification in 40 CFR part 60 Appendix B, and you must perform the continuing quality assurance/control measures outlined in 40 CFR part 60 Appendix F.

⁷ Metals to be tested include antimony (Sb), arsenic (As), beryllium (Be), cadmium (Cd), chromium (Cr), cobalt (Co), lead (Pb), manganese (Mn), mercury (Hg), nickel (Ni), and selenium (Se).

* Methods supported by ERT.

During testing, you should monitor, record and report process data for each test run. For process data that you record during testing, make clear the correlation between emissions measurements and process data (e.g., identify Method 5, run 1 for the associated process data on the process data details tab of the ERT or be sure to enter the process data on the correct row of the Stationary Combustion Turbines Testing Supplement, as applicable; see Section 2.2 for more information on the Stationary Combustion Turbines Testing Supplement).

The process data to be documented during each test run (as applicable) include:

- Fuel type (e.g., natural gas, propane, fuel oil), and heat input (British thermal units per hour (Btu/hr)).
- Actual fuel feed rate during test (based on HHV) and permitted fuel feed rate (based on HHV) (MMBtu/hr). You must explain the procedure that you used (e.g., EPA Method 19) to determine the actual fuel feed rate and provide the calculation in the notes field for this data element in the Microsoft® Excel template that is used to report results to the EPA.
- Turbine load (percent).
- Emission unit operating temperature (°F).
- Operating parameters relevant for the APCD, including, for example, oxidation catalyst inlet temperature.

You must keep the following records for 3 years:

- Documentation that each emissions test was conducted in accordance with the enclosed sampling protocol; and
- The results of each emissions test.

1.2 Ensuring Data Quality of the Source Tests Performed

While in most cases we are not specifying numerical minimum detection levels for the tests to be performed, we have specified the testing conditions and methods required, including minimum test run sample volumes or times when appropriate, which we believe will provide data of a quality sufficient for decision making.

We remind source owners and testers of the CAA section 114(a)(1) requirement to provide information requested for the development of emissions standards using methods that provide data necessary for the decisions. This information includes data of quality sufficient to support those decisions. For the most part, we can identify test methods and procedures that will satisfy those decision-making needs (e.g., minimum sampling times). In other cases, we recognize that the source owner's or tester's selection of test procedures or equipment could bear significantly on the quality of the data. See Appendix A of this document for information regarding guidance for calculating and reporting values measured below method detection levels.

We believe that the CAA is clear that it is incumbent on the source owner/operator and the tester to apply methods and procedures that result in data quality necessary for our decisions, including providing for the lowest possible detection limits considering practical and reasonable limitations. For example, source owners/operators and testers should not automatically choose to

use low or medium quality equipment for testing (*e.g.*, for cost reasons) if high quality equipment is reasonably available. We will review test reports in light of this expectation and will be particularly mindful of whether the testing procedures applied are representative of the highest reasonably expected capabilities (*e.g.*, comparing reported minimum measurement detection levels between tests and testers).

On completion of your required tests, please provide a complete test report, including appendices. A complete test report includes the following information, at a minimum:

- General identification information for facility including a mailing address; the actual facility address; the owner or operator, responsible official, or an appropriate representative (where applicable) and an email address for this person; and the appropriate Federal Registry System (FRS) number for the facility;
- A brief process description, including a flow diagram clearly showing the turbine and the sampling site;
- A complete unit description, including the unit ID, the stationary combustion turbine subcategory, the appropriate source classification code (SCC), the latitude and longitude of the emission point being tested (decimal degrees to five decimal points), and the maximum permitted process rate (where applicable);
- Emissions control measures in use during the test, including:
 - APCD description and APCD ID (if applicable)
 - A description of any pollution prevention or other HAP emission reduction approaches being implemented during the test program;
- Any process data and control device monitoring data required in this document;
- Sampling site description; description of sampling and analysis procedures and any modifications to standard procedures; quality assurance procedures;
- Description of any deviations from the test methods or other anomalies that occurred with the process or APCD operations during the test;
- Run-by-run emission data in the units of measure specified in Table 1;
- Stack or exhaust gas flow rate (as determined using U.S. EPA Method 2 or alternatives) at the time of and during the emissions test, as appropriate;
- Example calculations of all applicable stack gas parameters, emission rates and analytical results, as applicable;
- Raw field sampling data sheets and notes;
- Laboratory data and analysis reports, including instrument calibrations and raw analytical data;
- Chain-of-custody documentation;
- Explanation of laboratory data qualifiers;
- Quality assurance and quality control activities performed;
- Identification information for the company conducting the performance test, including a contact person and his/her email address; and
- Any other information required by the test method, a relevant standard, or the Administrator.

If we believe that a source owner/operator or tester has failed to meet the requirement of the CAA to provide data of sufficient quality or quantity for our decisions, we can and will request

additional measurements that require the use of improved testing procedures. The permitted facility representative and the testing company representative must complete the Final Verification form of the ERT certifying that the report is accurate and complete.

2.0 How to Report Data

The method for reporting the results of any testing and monitoring requests depend on the type of tests and the type of methods used to complete the test requirements. This section discusses the requirements for reporting the data.

2.1 Reporting Stack Test Data within ERT

For testing conducted using one of the methods listed in Table 2, you must report your data using the EPA's ERT Version 6.0 or newer. ERT is a Microsoft Access® database application available at <https://www.epa.gov/electronic-reporting-air-emissions/electronic-reporting-tool-ert>. If you are not a registered owner of Microsoft Access®, you can install the runtime version of Microsoft Access® from the link on the ERT website in order to run the ERT Application. The ERT must be downloaded onto your computer prior to data entry. A series of Microsoft Excel®-based templates can be used to assist with the upload of the field sampling data. These templates are also available on the ERT website. After completing the data entry into the ERT, you will also need to attach supporting documentation to the Attachments module of the ERT. The supporting documentation should include: complete lab reports, chain of custodies, field data and sample/moisture recovery sheets, CEMS raw data, calibrations of equipment, gases and instruments, QA/QA data, audit sample results (if applicable), and field notes. If a full test report is attached in the ERT, any of the preceding supporting documentation included in the full test report does not need to also be individually attached. The ERT database file should be transmitted to EPA using one of the options described in Section 3.0 of this document.

The list of fields within the ERT with notes explaining whether the field is required or optional can be found on the Stationary Combustion Turbines website (<https://www.epa.gov/stationary-sources-air-pollution/stationary-combustion-turbines-national-emission-standards>).

Table 2: List of ICR Test Methods Supported by ERT

EPA Test Methods (40 CFR parts 60 and 61; EMC website, https://www.epa.gov/emc)
Methods 1 through 4 (testing locations, velocity, moisture, dilution gases)
Method 3A (O ₂ and CO ₂)
Method 5 (filterable PM)
Method 10 (Carbon Monoxide)
Method 29 (metals and filterable PM)

*For data entry purposes- if PM is collected by Method 29, the data entry is only performed once by selecting PM as a compound/analyte under Method 29.

2.2 Reporting Other Test Data Not Listed in ERT

At present, of the methods required by this request, only the methods shown in Table 2 are supported by the ERT. For testing you conducted using a method not currently supported by the ERT (including the use of a plant CEMS), you must report the results of this test in the Stationary Combustion Turbines Testing Supplement. The Stationary Combustion Turbines Testing Supplement can be downloaded from the Stationary Combustion Turbines website (<https://www.epa.gov/stationary-sources-air-pollution/stationary-combustion-turbines-national-emission-standards>).

You must report the results of each test on the appropriately labeled form corresponding to the specific tests requested at your emissions source. If you conducted testing at more than one source at a facility using methods not currently supported by the ERT, follow the instructions in the Stationary Combustion Turbines Testing Supplement, found on the Stationary Combustion Turbines website. For plant CEMS data used in lieu of EPA Method 10, the test run average is calculated as the average of the one-minute averages collected over the duration of the test run.

After completing the Stationary Combustion Turbines Testing Supplement, you must also submit an electronic copy of the emission test report (PDF format preferred) for air sampling. If the complete emission test report is attached to the ERT file containing the associated flow rate measurements, a second copy does not need to be submitted. Both the completed Stationary Combustion Turbines Testing Supplement and the emission test report(s) should be included as attachments to the ERT file for simultaneous tests done using methods supported by the ERT (at a minimum, EPA Methods 1 through 3) and transmitted to the EPA as described in Section 3.0 of this document. For plant CEMS data used in lieu of EPA Method 10, the one-minute averages during each of the seven test runs must be included as an attachment in the ERT and the test run averages reported in the testing supplement.

2.3 Guidance for Calculating and Reporting Measurements Less Than In-Stack Method Detection Levels for Emissions Data Submitted in Response to CAA Section 114 Requests

See Appendix A to this document for guidance on calculating and reporting measurements less than detection levels for emissions data collection programs.

3.0 How to Submit Data

As explained in the previous section, where applicable, you must report your data using the ERT. If the ERT does not support a particular pollutant or method, you must report your data using the data reporting tools we provide and include the additional file as an attachment to your ERT submittal. When you are ready to submit your data to the EPA, compile electronic copies of all ***nonconfidential**** requested files (including files that do not contain any Confidential Business Information (CBI) as well as files that have been redacted to remove CBI) and email the files to the address shown in your section 114 cover letter.

*** Please Note:** The EPA's procedures for handling CBI are described in Enclosure 4 of the letter accompanying the section 114 request. If you claim that some of the information being submitted is CBI,¹ **DO NOT** use the method described above to submit your CBI. You must create a separate submission containing all files associated with this request (*i.e.*, all information claimed to be CBI and non-CBI portions combined). Clearly mark the materials submitted with the words "Confidential Business Information." Send these files under separate cover **only** to Ms. Tiffany Purifoy at one of the CBI addresses shown in your section 114 cover letter.

For the security of your data, the EPA recommends sending your confidential files to the EPA's CBI Office as described in Section 6 of Enclosure 4 of your section 114 cover letter. If you compile the materials onto a CD, DVD, or USB flash drive to mail to the CBI office, the EPA recommends sending it via **registered U.S. Mail** using **return receipt requested**, Federal Express, or other method for which someone must provide a signature upon receipt.

4.0 Contact Information for Questions on Test Plan and Reporting

For questions on how to report data using the ERT, contact:

Theresa Lowe
U.S. EPA
(919) 541-4786
lowe.theresa@epa.gov

For questions on the test methods, contact:

David Nash
U.S. EPA
(919) 541-9425
nash.david@epa.gov

OR

Ned Shapley
U.S. EPA
(919) 541-7903
shapley.ned@epa.gov

OR

Kevin McGinn
U.S. EPA
(919) 541-3796
mcginn.kevin@epa.gov

¹ Under CAA section 114(c), emissions data is not entitled to confidential treatment.

For other questions on the required testing in your section 114 cover letter or this document, including emissions sources selected for testing, contact:

Melanie King
U.S. EPA
(919) 541-2469
King.Melanie@epa.gov

Appendix A

Guidance for Calculating and Reporting Measurements Less Than In-Stack Method Detection Levels for Emissions Data Submitted in Response to Section 114 Requests

Please identify the status of measured values relative to detection levels in the Stationary Combustion Turbines Testing Supplement or in the ERT using the descriptions below. For each reported emissions value, insert the appropriate flag (BDL, DLL, or ADL) in the *Flag* line of the ERT or in the *Flag* column of the Stationary Combustion Turbines Testing Supplement for the row that corresponds to that run.

- **BDL** (below detection level) – all analytical values used to calculate and report an in-stack emissions value are less than the laboratory’s reported detection level(s);
- **DLL** (detection level limited) – at least one but not all values used to calculate and report an in-stack emissions value are less than the laboratory’s reported detection level(s); or
- **ADL** (above detection level) – all analytical values used to calculate and report an in-stack emissions value are greater than the laboratory’s reported detection level(s).

When reporting and calculating individual test run data:

- You must use the approach specified in the test method for calculation and determination of the analytical method detection level (MDL). If the method does not specify the approach and calculation of the MDL, you must determine the MDL in accordance with the procedures specified in Section 15 of Method 301 (located in Appendix A of 40 CFR part 63).
- For analytical data reported from the laboratory as above the MDL, include the ADL flag in the *Outlet Detect Flag* column of the Stationary Combustion Turbines Testing Supplement as appropriate or in the *Comments* line in the ERT.
- For analytical data reported from the lab as BDL, “non-detect” or “below detection level”:
 - Include a brief description of the procedures used to determine the analytical detection and in-stack detection level:
 - In the *Analytical Comments* column of the Stationary Combustion Turbines Testing Supplement; or
 - In the *Comments* line of Lab Data tab in the Run Data Details in the ERT.
 - Describe these procedures completely in the complete test report, including the measurements made, the standards used, and the statistical procedures applied.
 - Calculate the in-stack emissions rate for any analytical result reported as BDL using the relevant MDL, sampling volumes, and other relevant run-specific parameters (such as O₂ or flow rate). The reported value must assume that the analyte is present at the full MDL value.
 - Report the calculated emissions concentration or rate result:

- As a numerical value (*i.e.*, no brackets or < symbol) in the Stationary Combustion Turbines Testing Supplement, columns ***Outlet Mass*** and/or ***Outlet Concentration*** as appropriate; select the appropriate flag in the ***Outlet Detect Flag*** column as appropriate; or
 - As a numerical value in the ERT with the appropriate flag in the ***Comments*** line.
- Report as numerical values (*i.e.*, no brackets or < symbol) any analytical data measured above the MDL, including any data between the MDL and a laboratory-specific reporting or quantification level (*i.e.*, flag as ADL).
- For pollutant measurements composed of multiple components or fractions (*e.g.*, mercury and other metals sampling trains), when the result for the value for any component is measured below the MDL:
 - Calculate in-stack emissions rate or concentrations as outlined above for each component or fraction;
 - Sum the measured values and/or calculated values (using the MDL as outlined above) for all of the components or fractions; and
 - Report the sum of all components or fractions:
 - As a numerical value (*i.e.*, no brackets or < symbol) in the Stationary Combustion Turbines Testing Supplement; columns ***Outlet Mass*** and/or ***Outlet Concentration*** as appropriate and select the appropriate flag in the ***Outlet Detect Flag*** column as appropriate; or
 - As a numerical value in the ERT with the appropriate flag in the ***Comments*** line.
 - If all components or fractions are BDL, the appropriate flag is BDL. If the components or fractions are a mix of BDL, DLL, and ADL, then the appropriate flag is DLL. [Note: If all components or fractions are above the MDL, the appropriate flag is ADL.]
 - In addition to reporting the sum of the components or fractions, report the individual component or fraction values for each run if the Stationary Combustion Turbines Testing Supplement or ERT format allows. If the Stationary Combustion Turbines Testing Supplement or ERT format does not allow reporting of the individual components or fractions (*i.e.*, the format allows reporting only a single sum value):
 - For the Stationary Combustion Turbines Testing Supplement, for each applicable run, report the appropriate flag in the ***Outlet Detect Flag*** column and report the values for the measured or MDL value for each component or fraction as used in the calculations (*e.g.*, 0.036, [<0.069], 1.239, [<0.945] for a four-fraction sample) in the ***Analytical Comments*** column; or
 - For the ERT, next to the sum reported as above, report on the ***Comments*** line the appropriate flag and the measured or MDL value for each component or fraction as used in the calculations (*e.g.*, 0.036, [<0.069], 1.239, [<0.945] for a four-fraction sample).

- For measurements conducted using the instrumental test methods (e.g., Methods 3A):
 - Record gaseous concentration values as measured including negative values and flag as ADL; do not report as BDL.
 - Calculate and report in-stack emissions rates using these measured values.
 - Include relevant information relative to calibration gas values or other technical qualifiers for measured values in the **Comments** line in the **ERT** or **Method Comments** line column of the Stationary Combustion Turbines Testing Supplement.

Enclosure 1

Table 1. Known Facilities with Stationary Combustion Turbines Subject to 40 CFR part 63, subpart YYYY

Facility Name ¹	Street Address	City	State
Sunshine Gas Producers	14747 San Fernando Rd	Sylmar	CA

1. Information should be provided for the listed facilities as well as any additional facilities wholly owned by Sunshine Gas Producers that are not included on this list and have units subject to 40 CFR part 63, subpart YYYY. If there is a facility on this list not wholly owned by Sunshine Gas Producers, please indicate that in the response letter. A completed survey is not required for that facility.

Table 2. Stationary Combustion Turbines Selected for Emissions Testing

Test Group	No. of Tests to Be Performed ¹	Fuel(s) To Be Used During Testing	General Unit Description	Facility Name	Select from These Unit IDs ²
A	2	Landfill Gas	Landfill gas-fired stationary combustion turbines	Sunshine Gas Producers	Turbine Engine #1 Turbine Engine #2 Turbine Engine #3 Turbine Engine #4 Turbine Engine #5

1. Tests run on units that fire only a single fuel are required to be performed on different units within the same test group. If you are required to test using two different fuels, you may elect to conduct each test on a different unit from the unit IDs provided or you may elect to conduct tests on the same unit(s) using multiple fuels.
2. If this table is missing any stationary combustion turbines subject to 40 CFR part 63, subpart YYYY, or if any of the stationary combustion turbines included in this table are misclassified (e.g., units are not in the appropriate test group or are not subject to subpart YYYY), please contact Melanie King (see section 114 cover letter).

THIS IS THE LAST PAGE OF THIS DOCUMENT

If you have any questions, please contact one of the following individuals by email or phone.

Name: Mr. Pete San Juan
Title: Field Project Manager
Region: West
Email: PSanjuan@montrose-env.com
Phone: (714) 279-6777

Name: Mr. Matt McCune
Title: Regional Vice President
Region: West
Email: MMccune@montrose-env.com
Phone: (714) 279-6777