

Kodiak FITC Boiler Conversion Evaluation


Kodiak, Alaska

Schematic Design Report

Prepared by:

**Bell Design Group
P.O. Box 81795
Fairbanks, Alaska 99708**

October 12, 2010



1.0 Executive Summary

With annual fuel costs of \$130,000 for 25,800 square feet of floor space the Fisheries Industry Technology Center is a very expensive building to operate. This report investigated both the hydronic heating system, the process steam system and the laboratory ventilation systems to identify ways to modify them and reduce operating costs. Six operating cost reduction options were identified and analyzed. The two with estimated simple paybacks of less than 10 years are:

- **Option S3:** Replace the existing steam boiler with a new electric boiler with a design capacity of 20 BHP at 60 PSI. Provide with 10:1 turndown ration and locate it in the Pilot Plant adjacent to the steam Done A vacuum condensate return system will be provided to allow the steam system to be on only when needed. The estimated cost is \$263,800 with an estimated payback time of 7.9 years.
- **Option H3:** Convert the constant volume laboratory ventilation system to a variable volume ventilation system capable of a 2.5:1 turndown ratio on the outside air quantity. Remove two existing perchloric acid fume hoods and replace them with two standard laboratory fume hoods. Replace three existing constant volume fume hoods with variable volume fume hoods, and replace AHU-2 fan motor and install VFD. Remove EF-4 and EF-5 (perchloric acid fume hood exhaust fans).place EF-3 on each. Add modulating dampers to laboratory exhaust air ducts. Modify laboratory supply air system VAV box controls. Add differential controls to the 5 laboratory rooms. Balance entire system. The estimated cost is \$223,700 with an estimated payback time of 9.4 years.

recommended
next steps

Option	Simple Payback (Years)	Estimated Cost
S3 – Steam Boiler, Electric Point of Use	7.9	\$263,800
H3 – Lab Ventilation Conversion	9.4	\$223,700
S1 – Steam Boiler, Oil Fired	12.3	\$216,500
S2 – Steam Boiler, Electric in Boiler Room	16.8	\$252,800
H2 – Two Heating Boilers	21.3	\$253,800
H1 – Three Heating Boilers	24.2	\$288,250

2.0 Background

The University of Alaska Fisheries Industry Technology Center (FITC) in Kodiak, Alaska is a 25,800 square foot building of offices, classrooms and laboratories. The building was constructed from 1989 to 1991 and has operated continuously since that time.

There are two boiler systems in the facility. The hydronic heating system has a 2,000 MBH capacity. Its one boiler heats the building and domestic hot water. The process steam system has a 1380 PPH capacity at 100 PSI steam pressure. Its one boiler provides process steam to the Pilot Plant equipment. Originally, it also provided steam for the laboratory equipment and to humidify the building but those systems are disconnected. Both system boilers are oil-fired. Schematic drawings of the two systems are in Appendix A.

Evaluation of the fuel oil use at the facility raised concerns that the boilers were consuming much more fuel than is required to meet the current building heating, service water heating, and process

steam loads. In FYE 2009 and 2010 fuel costs were about \$130,000; very high for a building in Kodiak. See Appendix B – Historical Fuel Use Data.

This report is a detailed examination of the current building heating and process steam loads with the intent of identifying ways to reduce fuel consumption primarily through modifications to the existing boilers.

3.0 Fuel Options

The existing boilers use No.2 fuel oil. Other boiler fuel options in Kodiak include propane and electricity. No.2 fuel oil costs \$3.78 per gallon. Based on 138,500 Btu/gallon for No.2 fuel oil and 91,370 Btu per gallon for propane, the \$4.86 per gallon cost of propane is equivalent to No.2 fuel oil priced at \$7.35 per gallon. On a per Btu basis propane is almost twice the cost of No.2 fuel oil. Even with increased operating efficiencies of 5% to 10%, switching to propane will not reduce annual fuel costs. Accordingly, the use of propane-fired equipment is not considered in this report.

The FITC pays an equivalent of \$0.14 to \$0.16 per KWH used, depending on the demand charge. For this report, \$0.17 per KWH is used for cost comparisons. Demand charges are based on Kodiak Electric Association's charge of \$5.67 per KW over 50 KVA. Based on the higher efficiencies of electric boilers operating at low loads, the use of electric boilers is evaluated as part of this report.

4.0 Process Steam System Evaluation

The existing steam system was designed to provide a diversified load of 800 PPH of steam at 85 PSI and 2,000 PPH of steam at 15 PSI. The existing boiler is sized at 1,380 PPH at 100 PSIG. Humidification steam and laboratory steam is no longer connected. Currently the steam system serves only the Pilot Plant with an installed equipment start-up load of 840 PPH (25 BHP) at 60 PSI. The operational load is 20 BHP and the new boiler will be sized for this steam demand.

The actual use of the steam system is limited to only a few weeks each year. The retort is used about 80 hours a year and the steam kettle about 100 hours a year. Because steam systems degrade quickly if not kept hot, the existing system burns 1.5 gallons of fuel oil per hour, 365 days a year, to stay warm. This is equivalent to 13,140 gallons per year at a current cost of about \$40,000.

With the reduction in operating pressure from 85 PSIG to 50 PSIG, and the reduced size of the system replacement of the existing, non-operating deaerator is not required. This eliminates another constant steam load on the system, and reduces maintenance costs.

Options

- **Option S1:** Replace the existing steam boiler with a new oil-fired boiler with a design capacity of 20 BHP at 60 PSI. Provide with a 3:1 turndown ratio, modulating burner and adjustable pressure set point controller allowing the boiler to idle at 15 PSI. The

pressure control will be manually adjusted to higher operating pressures when needed in the Pilot Plant.

- **Option S2:** Replace the existing steam boiler with a new electric boiler with a design capacity of 20 BHP at 60 PSI. Provide with 10:1 turndown ratio and an adjustable pressure set point controller allowing the boiler to idle at 15 PSI. The pressure control will be manually adjusted to higher operating pressures when needed in the Pilot Plant.
- **Option S3:** Replace the existing steam boiler with a new electric boiler with a design capacity of 20 BHP at 60 PSI. Provide with 10:1 turndown ration and locate it in the Pilot Plant adjacent to the steam consuming appliances. A new condensate return system will be provided to allow the steam system to be on only when needed.
- **Option S4:** Keep the existing steam boiler and replace the burner. Because the existing boiler is a 40 BHP model, with a 3:1 turndown ratio it will have a 440 MBH firing rate and inefficient short cycling will continue. Not recommended and payback not analyzed.

5.0 Hydronic Heating System Evaluation

The existing hydronic heating boiler system includes one, 2,000 MBH oil-fired hydronic boiler. Based on the design heating calculation included in Appendix C – Heat Loss Calculations, the existing winter design heating load is 2,000 MBH. The existing boiler is sufficient to meet the building heating load, but is oversized for average loads.

The heating load varies widely through the course of the year due to both seasonal climate variations and the intermittent use of large ventilation systems requiring the heating of the 100% makeup air. The building conduction and occupant ventilation air tempering winter design load is 667 MBH. The laboratory exhaust hood makeup air design heating load is 543 MBH and the Pilot Plant exhaust hood makeup air load is 790 MBH for a calculated total design load of 2,002 MBH. The service water heating load is small and not included in the analysis. The existing heating system seems adequately sized to meet the various heating demands and there have not been reports of underperformance.

The existing hydronic heating boiler burner is a low-high-low fire design. Assuming a 3:1 turn down, low fire output would be 670 MBH and for much of the year the boiler would short-cycle-fire to meet the average demand of 250 MBH to 400 MBH. This results in very inefficient operation due to the extensive pre- and post-purge of the burner during each firing cycle.

Options:

- **Option H1:** Replace the existing boiler with three 700 MBH (20 BHP) boilers with fully-modulating, 3:1 turndown ratio, fuel oil-fired burners.
- **Option H2:** Replace the existing boiler with two 1000 MBH (30 BHP) boilers with fully-modulating, 3:1 turndown ratio, fuel oil-fired burners.
- **Option H3:** Convert the constant volume laboratory ventilation system to a variable volume ventilation system capable of a 2.5:1 turndown ratio on the outside air quantity.

Remove two existing perchloric acid fume hoods and replace them with two standard laboratory fume hoods. Replace three existing constant volume fume hoods with variable volume fume hoods, and replace AHU-2 fan motor and install VFD. Remove EF-4 and EF-5 (perchloric acid fume hood exhaust fans), place EF-3 on each. Add modulating dampers to laboratory exhaust air ducts. Modify laboratory supply air system VAV box controls. Add differential controls to the 5 laboratory rooms. Balance entire system.

- **Option H4:** Replace the existing boiler burner with a fully modulating oil-fired burner. Since the existing boiler would still be rated at 60 HP (2,000 MBH output), and the turndown available on No.2 fuel oil is a maximum of 4:1, short-cycling will still occur due to the boiler's lowest output of 500 MBH being well above the average heating demand of 300 MBH. Not recommended and payback not analyzed.

7.0 Construction Cost Estimates and Payback Analyses

The costs of the Options and their simple paybacks are included in Appendix D. Costs are in 2010 dollars and include owner overhead and design fees. Simple paybacks are calculated by dividing the cost for each option by the anticipated annual energy cost savings.

Option	Simple Payback (Years)	Estimated Cost
S3 – Steam Boiler, Electric Point of Use	7.9	\$263,800
H3 – Lab Ventilation Conversion	9.4	\$223,700
S1 – Steam Boiler, Oil Fired	12.3	\$216,500
S2 – Steam Boiler, Electric in Boiler Room	16.8	\$252,800
H2 – Two Heating Boilers	21.3	\$253,800
H1 – Three Heating Boilers	24.2	\$288,250

Product data sheets for the various options are included in Appendix E.

8.0 Recommendations

Based on the evaluated steam boiler system options, Option S3, installing an electric boiler in the Pilot Plant adjacent to the steam appliances, has the quickest payback at 7.9 years. Its estimated cost is \$263,800.

For the hydronic heating system, Option H3, converting the laboratory ventilation systems to variable volume operation has the fastest payback at 9.4 years and an estimated cost of \$223,700. Option H2 is the heating system boiler conversion with the fastest payback at 21.3 years and an estimated cost of \$253,800.


Options S3 and H3 have paybacks of less than 10 years and are recommended.

End of Report

Kodiak FITC Boiler Conversion Analysis

Kodiak, Alaska


Appendix A – Schematic Drawings



NOTES
① REMOVE EXISTING BOILER AND PUMP. REPLACE WITH NEW.

1 SCHEMATIC-HYDRONIC HEATING SYSTEM

NOT TO SCALE



- NOTES**
- 1 REMOVE EXISTING BOILER AND PUMPS. REPLACE WITH NEW.
 - 2 REMOVE EXISTING CONDENSATOR SYSTEM.

1 SCHEMATIC- PROCESS STEAM SYSTEM

NOT TO SCALE



PROJECT NO. 10000
 JOB NO. 10000
 DATE: 10-1-81


REVISIONS
 1. GENERAL: GHT 10000, 10-1-81

FISHERY INDUSTRIAL TECHNOLOGY
 CENTER
 University of Alaska




LABORATORY
 HVAC PLAN
 PROJECT NO. 10000

SHEET
 M-11




NOTE: 1. ALL UNITS TO VERIFY EACH UNIT ARE IN PROPER LOCATION, PROPER PRESSURE TO SUPPLY OR EXHAUST, PROPER ADJUSTMENT TO SUPPLY OR EXHAUST.

LABORATORY HVAC PLAN
 1/4" = 1'-0"



2. SINK DETAIL (S-5)
 1/4" = 1'-0"



1. COLD LAB SINK (S-5)
 1/4" = 1'-0"

FAN SCHEDULE

DESIG	SERVICE	TYPE	CFM	SP	BFP	MAP	EFF. #	BASE OF DESIGN
AHU-1	BLDG VENTILATION	VAV CABINET	13,055	4"	12.1	5	XH	PAGE A-21AF IN A-27 CABINET
AHU-2	LAB VENTILATION	CV CABINET	10523	4"	9.41	10	XH	PAGE A-22AF IN A-24 CABINET
AHU-3	BOILER RM-VENT	CABINET	3000	1"	1.15	1 1/2	HE	PAGE A-14-FC
AHU-4	PLOT PLANT MAKE-UP	CABINET	10,000	1"	3.35	5	HE	PAGE A-24-FC
EF-1	1ST FLR TOILET EXHAUST	SMALL CABINET	800	1/2	12	1/4	SE	PAGE SCF-87-A
EF-2	2ND FLR TOILET EXHAUST	SMALL CABINET	480	1/2	12	1/6	SE	PAGE SCF-75-A
EF-3	LAB EXHAUST	UTILITY	3560	2	1.6	2	XH	PAGE U-2CB IN SOUND ENCLOSURE
EF-4	PERCHLORIC HOOD	ACID RESISTENT	1400	1 1/2	-	1	SE	HOOD MANUFACTURER
EF-5	PERCHLORIC HOOD	ACID RESISTENT	1400	1 1/2	-	1	SE	HOOD MANUFACTURER
EF-6	KITCHEN HOOD (GRILLE)	ROOF MTD	1,750	1 3/4	1.11	1 1/2	HE	ACME
EF-7	PLOT PLANT HOOD	UTILITY	10,000	1	2.9	5	HE	PAGE U-30-f
EF-8	UTILITY TUNNEL VENT.	SMALL CABINET	670	1	0.26	1/3	XH	PAGE SCF-73A
EF-9	UTILITY TUNNEL VENT.	SMALL CABINET	670	1	0.26	1/3	XH	PAGE SCF-73A
EF-10	ELEC. RM EXHAUST	PANEL FAN	2000	1/4	0.15	1/4	HE	PAGE 18" TYPE FM
EF-11	STORE RM. EXHAUST	SMALL CABINET	900	1/2	0.2	1/4	SE	PAGE SCF-85A
EF-1	BLDG RELIEF	VAV CABINET	10,135	1"	2.6	3	XH	PAGE A-24B1
EF-1 1/2	BOILER ROOM SUP.	PANEL FAN	3488	1/4	0.28	1/3	SE	PAGE 21" TYPE FM

* MOTOR EFFICIENCY (SE) = STANDARD EFFICIENCY;
(HE) = HIGH EFFICIENCY; (XH) = EXTRA HIGH EFFICIENCY.
SEE SPEC SECTION 15038

† CAPACITY FOR BASE BID. ALT #1 & #2, SEE BASE BID SCHEDULE.

COIL SCHEDULE

DESIG	SERVICE	CFM	MAX FACE VELOCITY		DRY BLUB		WET BULB		FLUID TYPE	GPM	ENT	LEA	AIR PD		H ₂ O PD
			ENT	LEA	ENT	LEA	ENT	LEA					ENT	LEA	
HC-2	AHU-1 HEAT	1055	900	55	95	-	-	-	40/60 GLYCOL	62	180	160	0.3"	5'	
CC-1	AHU-1 COOLING	1055	550	69	55	58	53.6	-	30/70 GLYCOL	49	42	49	0.4"	20'	
HC-3	AHU-2 PRE-HEAT	10520	900	13	60	-	-	-	40/60 GLYCOL	58	180	180	0.3"	5'	
HC-4	AHU-2 HEAT	1080	900	66	95	-	-	-	40/60 GLYCOL	47	180	180	0.3"	5'	
CC-2	AHU-2 COOLING	10520	550	66	55	58	53.6	-	30/70 GLYCOL	39	42	49	0.4"	20'	
HC-5	AHU-3 HEAT	3888	900	13	60	-	-	-	30/70 GLYCOL	7	180	180	0.3"	5'	
HC-6	AHU-4 PRE-HEAT	10000	900	13	50	-	-	-	40/60 GLYCOL	45	180	180	0.3"	5'	
HC-7	AHU-4 HEAT	10000	900	45	95	-	-	-	40/60 GLYCOL	59	180	180	0.3"	5'	

Deleted

Deleted

ALT #2

ALT#2

BOILER SCHEDULE

DESIG	SERVES	FLUID	PRESSURE	ENT	LEA	OUTPUT	INPUT *	FUEL	BASIS OF DESIGN
B-1	BLDG HEAT	40/60 GLYCOL	30	100	100	2024 MBH	15 GPM	OL	CLEAVER BROOKS CB-80
B-2	BLDG HEAT	40/60 GLYCOL	30	100	100	2024 MBH	15 GPM	OL	CLEAVER BROOKS CB-80 (FUTURE)
B-3	PROCESS STEAM	STEAM	100	-	-	1360 lbs/hr	12 GPM	OL	CLEAVER BROOKS CBH-40
									Δ

* AT 140 MBH/GAL

$\eta = 75\%$

18 GPM?


UNIT COOLER SCHEDULE - ALTERNATE #2

DESIG	BTU/HR	ΔT	FAN HP	DEFROST KW	MAX FMS/NCH	REFRIGERANT	BASIS OF DESIGN
UC-1	7,775	6.6	1/4	3.4	4	R-12	
UC-2	7,775	6.6	1/4	3.4	4	R-12	
UC-3	50,500	14	2 @ 1/4	6.9	5	R-502	COLUMAC "HIGH PROFILE"
UC-4	50,500	14	2 @ 1/4	6.9	5	R-502	COLUMAC "HIGH PROFILE"
UC-5	25,800	10	2 @ 1/4	6.9	4	R-502	COLUMAC "HIGH PROFILE"
UC-6	25,800	10	2 @ 1/4	6.9	4	R-502	COLUMAC "HIGH PROFILE"

Kodiak FITC Boiler Conversion Analysis

Kodiak, Alaska

Appendix B – Historical Fuel Use Data



Kodiak FITC Fuel Oil Usage

date	cumulative days	gallons	gal/day	unit cost	delivery cost	total inv		
7/1/2006		2330		\$ 2.24		\$ 5,224.79		
7/26/2006	25	2100	84	\$ 2.51		\$ 5,269.95		
8/24/2006	29	1748	60	\$ 2.82		\$ 4,934.60		
9/19/2006	26	2450	94	\$ 2.32		\$ 5,234.18		
10/16/2006	27	2660	99	\$ 1.89		\$ 5,029.53		
10/20/2006	4		0			\$ 1.40		
10/25/2006	5		0			\$ 1.56		
12/11/2006	47		0			\$ 6,632.08		
12/20/2006	9	2200	244	\$ 2.27		\$ 4,990.48		
1/11/2007	22		0			\$ 3,533.85		
1/11/2007	0	2905	#DIV/0!	\$ 2.21		\$ 6,420.05		
1/29/2007	18	2700	150	\$ 1.88	\$ 5,067.09	\$ 5,069.79		
2/14/2007	16	1860	116	\$ 1.97	\$ 3,669.41	\$ 3,671.27		
2/27/2007	13	2050	158	\$ 2.03	\$ 4,166.42	\$ 4,168.47		
3/12/2007	13	3000	231	\$ 2.18	\$ 6,525.90	\$ 6,528.90		
3/26/2007	14	3353	240	\$ 2.09	\$ 7,005.42	\$ 7,008.78		
4/9/2007	14	2680	191	\$ 2.30	\$ 6,176.06	\$ 6,178.74		
5/2/2007	23	3570	155	\$ 2.37	\$ 8,453.05	\$ 8,456.62		
5/17/2007	15	2400	160	\$ 2.26	\$ 5,435.76	\$ 5,438.16		
5/30/2007	13	1280	98	\$ 2.32	\$ 2,973.44	\$ 2,974.72		
6/14/2007	15	915	61	\$ 2.33	\$ 2,135.98	\$ 2,136.89	\$ 100,257.87	Total FYE07 expense
							40,801	Total FYE07 gallons
date	cumulative days	gallons	gal/day	unit cost	delivery cost	total inv		
7/11/2007	27	1200	44	\$ 2.25	\$ 2,704.92	\$ 2,706.12		
8/8/2007	28	1989	71	\$ 2.53	\$ 5,022.23	\$ 5,024.21		
8/23/2007	15	2097	140	\$ 2.38	\$ 4,993.17	\$ 4,995.26		
9/13/2007	21	1643	78	\$ 2.38	\$ 3,903.77	\$ 3,905.41		
10/10/2007	27	2599	96	\$ 2.89	\$ 7,511.11	\$ 7,513.71		
11/7/2007	28	3063	109	\$ 3.06	\$ 9,362.37	\$ 9,365.43		
11/19/2007	12	1500	125	\$ 3.01	\$ 4,510.80	\$ 4,512.30		
12/4/2007	15	1891	126	\$ 2.76	\$ 5,223.13	\$ 5,225.02		
12/19/2007	30	2310	77	\$ 2.79	\$ 6,436.82	\$ 6,439.13		
1/16/2008	28	3809	136	\$ 2.65	\$ 10,106.80	\$ 10,110.61		
1/31/2008	15	1940	129	\$ 2.45	\$ 4,756.30	\$ 4,758.24		
2/13/2008	13	2271	175	\$ 2.72	\$ 6,168.94	\$ 6,171.22		
2/26/2008	13	1900	146	\$ 3.07	\$ 5,827.87	\$ 5,829.77		
3/13/2008	16	2359	147	\$ 3.28	\$ 7,734.93	\$ 7,737.28		
3/27/2008	14	1992	142	\$ 3.40	\$ 6,772.60	\$ 6,774.59		
4/15/2008	19	2600	137	\$ 3.71	\$ 9,639.76	\$ 9,642.36		
4/29/2008	14	1601	114	\$ 3.75	\$ 6,010.15	\$ 6,011.76		
5/19/2008	20	2070	104	\$ 4.00	\$ 8,276.90	\$ 8,278.97		
6/17/2008	29	2150	74	\$ 4.07	\$ 8,753.30	\$ 8,755.45	\$ 126,116.73	Total FYE08 expense
							44,197	Total FYE08 gallons

date	cumulative days	gallons	gal/day	unit cost	delivery cost	total inv		
7/30/2008	43	2860	67	\$ 3.89	\$ 11,135.98	\$ 11,138.84		
8/27/2008	28	1854	66	\$ 3.59	\$ 6,652.71	\$ 6,654.56		
10/7/2008					\$ 6,815.25			
11/3/2008					\$ 5,777.37			
11/17/2008					\$ 7,760.57			
11/24/2008					\$ 6,956.57			
12/24/2008					\$ 6,555.01			
12/24/2008					\$ 10,156.58			
1/20/2009					\$ 10,419.45			
2/3/2009					\$ 5,316.97			
2/16/2009					\$ 6,182.34			
3/3/2009					\$ 5,869.22			
3/23/2009					\$ 8,913.76			
4/27/2009					\$ 4,996.50			
4/24/2009					\$ 9,196.76			
5/12/2009					\$ 6,685.77			
6/1/2009					\$ 4,957.33			
6/9/2009					\$ 4,621.50			
6/30/2009					\$ 4,621.50		\$ 125,257.65	Total FYE09 expense
							Unknown	Total FYE09 gallons
date	cumulative days	gallons	gal/day	unit cost	delivery cost	total inv		
7/1/2009		3067		\$ 3.18	\$ 9,753.06			
7/22/2009		1876		\$ 3.18	\$ 5,965.68			
8/12/2009		1722		\$ 3.18	\$ 5,475.96			
9/15/2009		2050		\$ 3.43	\$ 7,031.50			
10/7/2009		2990		\$ 3.43	\$ 10,255.70			
10/29/2009		3520		\$ 3.43	\$ 12,073.60			
11/20/2009		2683		\$ 3.43	\$ 9,202.69			
12/2/2009		1382		\$ 3.43	\$ 4,740.26			
1/6/2010		2112		\$ 3.43	\$ 7,244.16			
1/20/2010		1524		\$ 3.43	\$ 5,227.32			
2/3/2010		1514		\$ 3.43	\$ 5,193.02			
2/23/2010		2213		\$ 3.43	\$ 7,590.59			
3/17/2010		2560		\$ 3.46	\$ 8,857.60			
4/7/2010		2914		\$ 3.46	\$ 10,082.44			
4/28/2010		2634		\$ 3.78	\$ 9,956.52			
5/18/2010		2429		\$ 3.78	\$ 9,181.62			
6/9/2010		2018		\$ 3.78	\$ 7,628.04		\$ 135,459.76	Total FYE10 expense
							39,208	Total FYE10 gallons
date	cumulative days	gallons	gal/day	unit cost	delivery cost	total inv		
6/30/2010		1639		\$ 3.78	\$ 6,195.42			
7/26/2010		2696		\$ 3.78	\$ 10,190.88			
8/5/2010		341		\$ 3.81	\$ 1,299.21			
8/17/2010		1042		\$ 3.78	\$ 3,938.76			
8/31/2010		1248		\$ 3.78	\$ 4,717.44			

Kodiak FITC Boiler Conversion Analysis

Kodiak, Alaska

Appendix C – Heat Loss Calculations

**UAF Kodiak Fisheries Boiler
HVAC Load Analysis**

for

UAF

**COMMERCIAL
HVAC LOADS**

Prepared By:

Thursday, September 30, 2010



Building Envelope Report

Envelope Report Using Summer U-Factors

Material Types		Gross Area	Glass Area	Net Area	-U-Factor	Area x U-Factor	Average U-Factor
Roof	1	11,298.0	0.0	11,298.0	0.039	438.362	0.039
Tot.Roof		11,298.0	0.0	11,298.0	N/A	438.362	0.039
Wall	1	10,864.0	1,417.0	9,447.0	0.053	497.857	0.053
Wall	2	3,142.0	0.0	3,142.0	0.044	137.305	0.044
Wall	3	5,003.2	0.0	5,003.2	0.057	285.182	0.057
Wall	4	317.0	0.0	317.0	0.330	104.610	0.330
Wall	5	210.0	0.0	210.0	1.000	210.000	1.000
Tot.Wall		19,536.2	1,417.0	18,119.2	N/A	1,234.955	0.068
Glass	1	1,417.0	N/A	1,417.0	0.560	793.520	0.560
Tot.Glass		1,417.0	N/A	1,417.0	N/A	793.520	0.560
Totals				30,834.2		2,466.837	0.080

Wall Direction	Wall Area	Glass Area	Wall Net Area	Wall Avg U-Factor	Glass Avg U-Factor	Glass Avg Shd.Coef
N	3,925.2	210.0	3,715.2	0.055	0.560	0.950
NE	2,360.4	120.0	2,240.4	0.053	0.560	0.950
E	2,128.0	105.0	2,023.0	0.056	0.560	0.950
SE	773.0	0.0	773.0	0.061	0.000	0.000
S	4,392.2	885.0	3,507.2	0.054	0.560	0.950
SW	2,771.8	85.0	2,686.8	0.053	0.560	0.950
W	272.0	0.0	272.0	0.048	0.000	0.000
NW	2,913.6	12.0	2,901.6	0.140	0.560	0.950
Totals	19,536.2	1,417.0	18,119.2	0.068	0.560	0.950



Building Summary Loads

Bldg Load Descriptions	Area Quan	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Roof	11,298	36,165	18.51	0	0	0	0.00
Wall	18,119	101,884	52.16	0	0	0	0.00
Glass	1,417	57,282	29.33	0	0	0	0.00
Floor Slab	0	0	0.00	0	0	0	0.00
Skin Loads		195,331	100.00	0	0	0	0.00
Lighting	38,748	0	0.00	0	0	0	0.00
Equipment	25,832	0	0.00	0	0	0	0.00
People	0	0	0.00	0	0	0	0.00
Partition	0	0	0.00	0	0	0	0.00
Cool. Pret.	0	0	0.00	0	0	0	0.00
Heat. Pret.	0	0	0.00	0	0	0	0.00
Cool. Vent.	0	0	0.00	0	0	0	0.00
Heat. Vent.	0	0	0.00	0	0	0	0.00
Cool. Infil.	0	0	0.00	0	0	0	0.00
Heat. Infil.	0	0	0.00	0	0	0	0.00
Draw-Thru Fan	0	0	0.00	0	0	0	0.00
Blow-Thru Fan	0	0	0.00	0	0	0	0.00
Reserve Cap.	0	0	0.00	0	0	0	0.00
Reheat Cap.	0	0	0.00	0	0	0	0.00
Supply Duct	0	0	0.00	0	0	0	0.00
Return Duct	0	0	0.00	0	0	0	0.00
Misc. Supply	0	0	0.00	0	0	0	0.00
Misc. Return	0	0	0.00	0	0	0	0.00
Building Totals		195,331	100.00	0	0	0	0.00

Building Summary	Sen Loss	%Tot Loss	Lat Gain	Sen Gain	Net Gain	%Net Gain
Ventilation	0	0.00	0	0	0	0.00
Infiltration	0	0.00	0	0	0	0.00
Pretreated Air	0	0.00	0	0	0	0.00
Zone Loads	195,331	100.00	0	0	0	0.00
Plenum Loads	0	0.00	0	0	0	0.00
Fan & Duct Loads	0	0.00	0	0	0	0.00
Building Totals	195,331	100.00	0	0	0	0.00

Check Figures

Total Building Supply Air (based on a 20° TD):	9,067	CFM
Total Building Vent. Air (0.00% of Supply):	0	CFM
Total Conditioned Air Space:	25,832	Sq.ft
Supply Air Per Unit Area:	0.3510	CFM/Sq.ft
Area Per Cooling Capacity:	0.0	Sq.ft/Ton
Cooling Capacity Per Area:	0.0000	Tons/Sq.ft
Heating Capacity Per Area:	7.56	Btuh/Sq.ft
Total Heating Required With Outside Air:	195,331	Btuh
Total Cooling Required With Outside Air:	0.00	Tons



Air Handler #1 - AHU 1 - Summary Loads

Zn No	Description Zone Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
1	FF East	256	5,882	0	0	None	None
	-	0	273	0	0	0	0
		2,304	1.07	0.00	0	0	0
2	FF Middle	6,250	16,805	0	0	None	None
	-	0	780	0	0	0	0
		56,250	0.12	0.00	0	0	0
3	FF South	900	19,076	0	0	None	None
	-	0	886	0	0	0	0
		8,100	0.98	0.00	0	0	0
4	FF West	5,848	14,658	0	0	None	None
	-	0	680	0	0	0	0
		52,632	0.12	0.00	0	0	0
5	FF Southwest	480	7,038	0	0	None	None
	-	0	327	0	0	0	0
		4,320	0.68	0.00	0	0	0
6	SF East	6,250	73,759	0	0	None	None
	-	0	3,424	0	0	0	0
		56,250	0.55	0.00	0	0	0
7	SF West	5,848	58,113	0	0	None	None
	-	0	2,698	0	0	0	0
		70,176	0.46	0.00	0	0	0
	Zone Peak Totals:	25,832	195,331	0	0		
	Total Zones: 7	0	9,067	0	0	0	0
	Unique Zones: 7	250,032	0.35	0.00	0	0	0



Air Handler #1 - AHU 1 - Total Load Summary

Air Handler Description: AHU 1 Constant Volume - Proportion
Supply Air Fan: Draw-Thru with program estimated horsepower of 0.00 HP
Fan Input: 0% motor and fan efficiency with 0 in. water across the fan
Outdoor Conditions: 0° DB (System is Heating Only)
Indoor Conditions: 75° DB

Winter: Exhaust controls outside air.

Zone Space sensible loss:	195,331 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		195,331 Btuh

Heating Supply Air: $195,331 / (.997 \times 1.08 \times 20) =$ 9,067 CFM
Winter Vent Outside Air (0.0% of supply) = 0 CFM

Zone space sensible gain:	0 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	0 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		0 Btuh

Cooling Supply Air: $0 / (.997 \times 1.1 \times 0) =$ 0 CFM
Summer Vent Outside Air (0.0% of supply) = 0 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	0 Btuh	0 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		0 Btuh
Total sensible gain on air handling system:		0 Btuh

Zone space latent gain:	0 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	0 Btuh	
Total latent gain on air handling system:		0 Btuh
Total system sensible and latent gain:		0 Btuh

Check Figures

Total Air Handler Supply Air (based on a 20° TD):	9,067 CFM
Total Air Handler Vent. Air (0.00% of Supply):	0 CFM
Total Conditioned Air Space:	25,832 Sq.ft
Supply Air Per Unit Area:	0.3510 CFM/Sq.ft
Area Per Cooling Capacity:	0.0 Sq.ft/Ton
Cooling Capacity Per Area:	0.0000 Tons/Sq.ft
Heating Capacity Per Area:	7.56 Btuh/Sq.ft
Total Heating Required With Outside Air:	195,331 Btuh
Total Cooling Required With Outside Air:	0.00 Tons



Zone Detailed Loads (At Zone Peak Times)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Zone 1-FF East, Air Handler 1 (AHU 1), Group 0, 32.0 x 8.0, Construction Type: 1 (Light)								
Roof-1-1-Susp.C-L	128	0.50	-31.3	0.039	0		2.910	372
Roof-2-1-Susp.C-L	128	0.50	-31.3	0.039	0		2.910	372
Wall-1-0-G-M	48	0.83	-29.4	0.053	0		3.953	190
Wall-2-90-G-M	288	0.83	-32.7	0.053	0		3.953	1,138
Wall-3-0-C-M	24	0.83	-35.2	0.044	0		3.278	79
Wall-4-180-G-M	72	0.83	-17.4	0.053	0		3.953	285
Wall-5-180-C-M	64	0.83	-13.2	0.044	0		3.278	210
Wall-6-90-C-M	256	0.83	-23.6	0.044	0		3.278	839
Wall-7-0-G-M	50	0.83	-29.4	0.057	0		4.275	215
Wall-8-90-G-M	335	0.83	-32.7	0.057	0		4.275	1,431
Wall-9-180-G-M	50	0.83	-17.4	0.057	0		4.275	215
Sub-total					0	0		5,347
Safety factors:					+0%	+0%		+10%
Total w/ safety factors:					0	0		5,882

Zone 2-FF Middle, Air Handler 1 (AHU 1), Group 0, 125.0 x 50.0, Construction Type: 1 (Light)

Wall-1-0-G-M	1,044	0.83	-29.4	0.053	0		3.953	4,126
Wall-2-0-C-M	928	0.83	-35.2	0.044	0		3.278	3,042
Wall-3-180-G-M	381	0.83	-17.4	0.053	0		3.953	1,506
Wall-4-180-C-M	392	0.83	-13.2	0.044	0		3.278	1,285
Wall-5-90-G-M	129	0.83	-32.7	0.053	0		3.953	510
Wall-6-90-C-M	128	0.83	-23.6	0.044	0		3.278	420
Wall-7-270-G-M	36	0.83	-8.6	0.053	0		3.953	142
Wall-8-270-C-M	32	0.83	-24.4	0.044	0		3.278	105
Wall-9-90-G-M	21	0.83	-32.7	0.330	0		24.750	520
Wall-10-180-G-M	35	0.83	-17.4	0.330	0		24.750	866
Gls-90°-1-90-Tran	15.0	1.000	-34	0.560	0		36.750	551
0%S-0-NS-Solar	15.0	0.950	173	0.150	0			
Gls-180°-1-90-Tran	60.0	1.000	-34	0.560	0		36.750	2,205
0%S-0-NS-Solar	60.0	0.950	242	0.280	0			
Sub-total					0	0		15,277
Safety factors:					+0%	+0%		+10%
Total w/ safety factors:					0	0		16,805

Zone 3-FF South, Air Handler 1 (AHU 1), Group 0, 75.0 x 12.0, Construction Type: 1 (Light)

Roof-1-1-Susp.C-L	900	0.50	-31.3	0.039	0		2.910	2,619
Wall-1-180-G-M	390	0.83	-17.4	0.053	0		3.953	1,541
Wall-2-180-C-M	600	0.83	-13.2	0.044	0		3.278	1,967
Wall-3-270-G-M	108	0.83	-8.6	0.053	0		3.953	427
Wall-4-270-C-M	96	0.83	-24.4	0.044	0		3.278	315
Gls-180°-1-90-Tran	285.0	1.000	-34	0.560	0		36.750	10,474
0%S-0-NS-Solar	285.0	0.950	242	0.280	0			
Sub-total					0	0		17,342
Safety factors:					+0%	+0%		+10%
Total w/ safety factors:					0	0		19,076



Zone Detailed Loads (At Zone Peak Times) (cont'd)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Zone 4-FF West, Air Handler 1 (AHU 1), Group 0, 86.0 x 68.0, Construction Type: 1 (Light)								
Wall-1-NE-G-M	540	0.83	-35.2	0.053	0		3.953	2,134
Wall-2-NE-C-M	234	0.83	-31.1	0.044	0		3.278	767
Wall-3-NW-G-M	600	0.83	-16.1	0.053	0		3.953	2,372
Wall-4-NW-C-M	136	0.83	-31.9	0.044	0		3.278	446
Wall-5-SW-G-M	414	0.83	-10.3	0.053	0		3.953	1,636
Wall-6-SW-C-M	92	0.83	-16.9	0.044	0		3.278	302
Wall-7-SE-G-M	144	0.83	-25.2	0.053	0		3.953	569
Wall-8-SE-C-M	32	0.83	-16.9	0.044	0		3.278	105
Wall-9-NW-G-M	63	0.83	-16.1	0.330	0		24.750	1,559
Wall-10-NW-G-M	121	0.83	-16.1	0.330	0		24.750	2,995
Gls-NW-1-90-Tran	12.0	1.000	-34	0.560	0		36.750	441
0%S-0-NS-Solar	12.0	0.950	56	0.420	0			
Sub-total					0	0		13,325
Safety factors:					+0%	+0%		+10%
Total w/ safety factors:					0	0		14,658

Zone 5-FF Southwest, Air Handler 1 (AHU 1), Group 0, 40.0 x 12.0, Construction Type: 1 (Light)

Roof-1-1-Susp.C-L	480	0.50	-31.3	0.039	0		2.910	1,397
Wall-1-SE-G-M	108	0.83	-25.2	0.053	0		3.953	427
Wall-2-SE-C-M	24	0.83	-16.9	0.044	0		3.278	79
Wall-3-SE-G-M	90	0.83	-25.2	0.057	0		4.275	385
Wall-4-SE-G-M	21	0.83	-25.2	0.330	0		24.750	520
Wall-5-SW-G-M	360	0.83	-10.3	0.053	0		3.953	1,423
Wall-6-SW-C-M	80	0.83	-16.9	0.044	0		3.278	262
Wall-7-SW-G-M	252	0.83	-10.3	0.057	0		4.275	1,077
Wall-8-NW-G-M	108	0.83	-16.1	0.053	0		3.953	427
Wall-9-NW-C-M	24	0.83	-31.9	0.044	0		3.278	79
Wall-10-NW-G-M	76	0.83	-16.1	0.057	0		4.275	323
Sub-total					0	0		6,398
Safety factors:					+0%	+0%		+10%
Total w/ safety factors:					0	0		7.038

Zone 6-SF East, Air Handler 1 (AHU 1), Group 0, 125.0 x 50.0, Construction Type: 1 (Light)

Roof-1-1-Susp.C-L	3,050	0.50	-31.3	0.039	0		2.910	8,876
Roof-2-1-Susp.C-L	3,300	0.50	-31.3	0.039	0		2.910	9,603
Wall-1-N-G-M	834	0.83	-29.4	0.053	0		3.953	3,296
Wall-2-N-G-M	731	0.83	-29.4	0.057	0		4.275	3,124
Wall-3-E-G-M	310	0.83	-32.7	0.053	0		3.953	1,225
Wall-4-E-G-M	556	0.83	-32.7	0.057	0		4.275	2,378
Wall-5-S-G-M	666	0.83	-17.4	0.053	0		3.953	2,632
Wall-6-S-G-M	857	0.83	-17.4	0.057	0		4.275	3,663
Wall-7-N-G-M	56	0.83	-29.4	0.330	0		24.750	1,386
Gls-N-1-90-Tran	210.0	1.000	-34	0.560	0		36.750	7,718
0%S-0-NS-Solar	210.0	0.950	20	0.610	0			
Gls-E-1-90-Tran	90.0	1.000	-34	0.560	0		36.750	3,308
0%S-0-NS-Solar	90.0	0.950	173	0.150	0			
Gls-S-1-90-Tran	420.0	1.000	-34	0.560	0		36.750	15,435
0%S-0-NS-Solar	420.0	0.950	242	0.280	0			



Zone Detailed Loads (At Zone Peak Times) (cont'd)

Load Description	Unit Quan	-SC- CFAC	CLTD SHGF	U.Fac -CLF-	Sen. Gain	Lat. Gain	Htg. Mult.	Htg. Loss
Gls-S-1-90-Tran	120.0	1.000	-34	0.560	0		36.750	4,410
0%S-0-NS-Solar	120.0	0.950	242	0.280	0			
Sub-total					0	0		67,053
Safety factors:					+0%	+0%		+10%
Total w/ safety factors:					0	0		73,759

Zone 7-SF West, Air Handler 1 (AHU 1), Group 0, 86.0 x 68.0, Construction Type: 1 (Light)

Roof-1-1-Susp.C-L	1,620	0.50	-31.3	0.039	0		2.910	4,714
Roof-2-1-Susp.C-L	1,692	0.50	-31.3	0.039	0		2.910	4,924
Wall-1-NE-G-M	912	0.83	-35.2	0.053	0		3.953	3,605
Wall-2-NE-G-M	554	0.83	-35.2	0.057	0		4.275	2,370
Wall-3-SE-G-M	192	0.83	-25.2	0.053	0		3.953	759
Wall-4-SE-G-M	162	0.83	-25.2	0.057	0		4.275	693
Wall-5-SW-G-M	947	0.83	-10.3	0.053	0		3.953	3,743
Wall-6-SW-G-M	542	0.83	-10.3	0.057	0		4.275	2,316
Wall-7-NW-G-M	816	0.83	-16.1	0.053	0		3.953	3,225
Wall-8-NW-G-M	748	0.83	-16.1	0.057	0		4.275	3,198
Wall-9-NW-G-L	210	0.65	-22.1	1.000	0		75.000	15,750
Gls-NE-1-90-Tran	120.0	1.000	-34	0.560	0		36.750	4,410
0%S-0-NS-Solar	120.0	0.950	56	0.150	0			
Gls-SW-1-90-Tran	45.0	1.000	-34	0.560	0		36.750	1,654
0%S-0-NS-Solar	45.0	0.950	234	0.430	0			
Gls-SW-1-90-Tran	40.0	1.000	-34	0.560	0		36.750	1,470
0%S-0-NS-Solar	40.0	0.950	234	0.430	0			
Sub-total					0	0		52,830
Safety factors:					+0%	+0%		+10%
Total w/ safety factors:					0	0		58,113

Bell Design Group, LLC
P.O. Box 81795
Fairbanks, Alaska 99708
907-388-2603

JOB 17101: KODIAK BOILER

SHEET NO. 1 OF


CALCULATED BY SUB DATE 9/20/10

CHECKED BY DATE

SCALE

HEAT LOSS CALCS

1. WALL R-VALUES (TRANSVERSE)



.85 TORQUE FOR CONDUCTANCE
THRU MTL STUDS


	R
1/2" AIR FILM	0.17
Sheetrock siding	0.01
Block paver	0.62
1/2" CDX PLY	0.08
6" MTL STUDS + 6" P.F.C.	$(R \cdot D) \cdot (.85) = 16.1$
VAPOR BARRIER	0.05
5/8" GWB	0.56
1/2" AIR FILM	0.68

18.99

10

U = 0.0527

2. WALL R-VALUES (LONGITUDINAL)



	R
SOIL	6.45
CC WALL (8") (R/ft) =	.67
1/2" AIR SPACE	2.25
2" FOAM	10.0
3 1/2" AIR SPACE	2.25
5/8" GWB	0.56
1/2" AIR FILM	0.68

22.86

U = 0.0437

SOIL:
3' BROWN GRASS (AKA) = 6.45

Bell Design Group, LLC
P.O. Box 81795
Fairbanks, Alaska 99708
907-388-2603

JOB 17101 - Kodiak Boiler

SHEET NO. 2

OF

CALCULATED BY SUB


DATE 9/20/10

CHECKED BY

DATE

SCALE


3. WALL #3 IS THE ROOF FASCIA SYSTEM



R	
0.17	
0.62	
16.1	
ϕ	
0.68	
<u>R = 17.57</u>	
U = 0.057	

⑥ PER EACH LINEAR FOOT OF WALL THERE IS 2.5' + 3.3' + 1.5' = 6.3' SF OF WALL

4. ROOF SYSTEM



STANDING SEAM
MET ROOF
5" FOAM (R-15/in)
MET DECK
O/S AIR FILM
I/S AIR FILM

R	
ϕ	
25	
ϕ	
0.17	
0.62	
<u>25.79</u>	
U = 0.0388	

Bell Design Group, LLC
P.O. Box 81795
Fairbanks, Alaska 99708
907-388-2603

JOB 17101 KODIAK BOILER

SHEET NO. 3

OF

CALCULATED BY SVP

DATE 9/20/10

CHECKED BY

DATE

SCALE

5. DOUBLE-GLAZING (1991)

- ASSUME WOOD FRAMING $\left(\frac{U}{0.45}\right)$ FINISH WINDOWS, $\frac{1}{2}"$ AIR SPACE
FROM ASHRAE 2005 FUNDAMENTALS CHAPTER 31, TABLE 4: $U = 0.50$

6. DOOR: (WALL*4): $R = 3.0$, $U = 0.33$

7. LOUVER: (WALL*5) $R = 1.0$, $U = 1.0$


WALLS

① 8' x 32', NO WINDOWS.

SEE A4s PER ELEVATIONS


$$A_1 = \frac{1}{2}(6 \times 36) = 108 \text{ sq ft}$$

$$H_{AVE} = \frac{108}{36} = 3.0$$



$$A = (6 \times 3 + 3 \times 3) \times 36 = 108$$

$$A_{WALL} = \frac{116 + 134}{2} = 125'$$



• NO ROOF

③ 12' x 75'

- WITH SLOPES ROOF

- 19 S. WINDOWS 8' x 5' (H)

Bell Design Group, LLC
P.O. Box 81795
Fairbanks, Alaska 99708
907-388-2603





JOB 17101 KODIAK BUL

SHEET NO. 4 OF

CALCULATED BY SVB DATE 9.20.10

CHECKED BY DATE

SCALE




$$A_1 = \frac{1}{2} (3') (54') = 216 \text{ SF}$$

$$H_1 = \frac{216'}{54'} = 4'$$

$$H_{\text{AW}} = 6'3" + 4' = 10'3"$$

BASES AND DEPT



Bell Design Group, LLC
P.O. Box 81795
Fairbanks, Alaska 99708
907-388-2603

JOB 171.01 KOTIAK BOILER

SHEET NO. 5 OF

CALCULATED BY SWP DATE 9/20/10

CHECKED BY DATE

SCALE

REVIEW NEW PLANS FOR VENTILATION

171.01
U29 → YES
U30 NO (SCHEDULED)
U31 NOT SCHEDULED

AHU-1 BLOCK VENT CFM
13,055

AHU-2 LABS VENT 10,520

AHU-3 (DELETED)

AHU-4 FLOT PLANT MUA 10,000

EF. 7 FLOT PLANT E/A 10,000

100% O/A [ALT #2]

BLOCK E/A

EF-1

EF-2

EF-6 KITCHEN GRILL

BLOCK RS

CFM

800

480

1750

10,135

13,165

AHU-1 : CFM
13,055
BLOCK E/A : -13,165
-110 CFM

Δ X Φ (< 1%)

ASSUME O/A = EF1, 2, 6
= 3,030 CFM

LABS E/A

EF. 3

EF. 5

EF. 6

EF. 8

EF. 9

EF. 10

EF. 11

PC AND

" "

UTILITY ROOM

"

ELECT. RM

STORAGE ROOM

CFM

3,500

1400

1400

670

670

2000

900

10,600

AHU-2 : CFM
10,520
LABS E/A : -10,600
-80

Δ X Φ

ASSUME O/A = 100%

Bell Design Group, LLC
P.O. Box 81795
Fairbanks, Alaska 99708
907-388-2603

JOB 171-01 KODIAK BOILER

SHEET NO. 6

OF

CALCULATED BY SDB

DATE 9/20/10

CHECKED BY

DATE

SCALE

BLOG AMU SYSTEM: AMU-1, EF-1, 2, 6, RE-1.

$$\frac{3,030 \text{ CPM O/A}}{13,055 \text{ CPM TOTAL}} = 23.2\%$$

$$\text{HC. 1: } 13,055 \text{ CPM @ } 55^\circ \text{ to } 90^\circ \rightarrow Q = 1.1 (13,055) (35^\circ) = 502,618 \text{ BTUH}$$

LAB VENT

$$\text{HC. 3 (O/A PHC): } Q = 1.1 (10,520 \text{ CPM}) (60^\circ - 12^\circ) = 543,434 \text{ BTUH}$$

$$\text{Palace + LAB ONLY} \rightarrow 1,118,304 \text{ BTUH}$$

ART #2 PILOT PLT

$$\text{HC. 6 (PHC): } Q = 1.1 (10,000) (50^\circ - 13^\circ) = 402,000 \text{ BTUH}$$

$$\text{HC. 7 (HTG): } Q = 1.1 (10,000) \left(\frac{95^\circ - 45^\circ}{35^\circ - 50^\circ} \right) = \frac{385,000 \text{ BTUH}}{792,000 \text{ BTUH}}$$

$$\text{TOTAL DESIGN O/A VENT RATE (WITH PILOT PLANT)} \rightarrow 2,020,304 \text{ BTUH}$$

FROM ELITE HEATING LOADS.

$$\text{COND. LOSS} = \frac{195,331 \text{ BTUH}}{25,832 \text{ SF}} = \frac{7.6 \text{ BTUH}}{\text{SF}} \quad \text{With 15\% S.F. WBS 166 MBH FOR DESIGN CASE}$$

$$\text{COND + Palace VENT} = 165 \text{ MBH} + 502 \text{ MBH} = 667 \text{ MBH} / 25,832 \text{ SF} = 26 \text{ BTUH/SF}$$

$$\text{COND + Palace VENT + LAB VENT} = 667 \text{ MBH} + 543 \text{ MBH} = 1,210,000 \text{ BTUH} = \frac{47 \text{ BTUH}}{\text{SF}}$$

$$\text{COND + Palace VENT + LAB VENT + PILOT VENT} = 1,210,000 \text{ BTUH} + 792 \text{ MBH} = \frac{2,002 \text{ MBH}}{25,832 \text{ SF}} = \frac{76 \text{ BTUH}}{\text{SF}}$$

Bell Design Group, LLC
P.O. Box 81795
Fairbanks, Alaska 99708
907-388-2603

JOB 171.01 KODIAK FITC

SHEET NO. _____ OF _____

CALCULATED BY. SVB DATE 10/4/10

CHECKED BY. _____ DATE _____

SCALE _____

LAB VENT - CONVERSION TO VAV.

- REMOVE 2 P.C. ACID ADDS @ 1400 CFM EACH.
- REMAINING LAB EA = 2,800 CFM FROM LABS. (PWT 1901 DWG SCHED = 3,560 CFM)
 $40\% \text{ OF } 2,800 \text{ CFM} = 1,120 \text{ CFM MIN. VENT.}$
- CURRENT LAB MUA AHU-2 IS 10,520 CFM. (LT MUA PROVIDING MUA TO MORE THAN THE LABS.) WITH PCA ADDS REMOVED, AHU-2 CHANGES TO $10,520 - 2,800 \text{ CFM} = 7,720 \text{ CFM}$
 $40\% \text{ OF } 10,520 \text{ CFM} = 4,208 \text{ CFM}$
 $40\% \text{ OF } 7,720 \text{ CFM} = 3,088 \text{ CFM}$
- REBALANCE AHU-2 TO 7,720 CFM.
REPLACE AHU-2 10 HP MOTOR WITH NEW 7.5 HP
ADD VFD TO NEW 7.5 HP MOTOR.
- REPLACE EF-3 (LABS) MOTOR (2 HP) WITH NEW 7.5 HP.
ADD VFD TO NEW 2 HP MOTOR.
KEEP EA @ 3,560 CFM AT THIS TIME. NEED SERVICE TO CONFIRM IF EA IS 3,560 OR 2,800 CFM (EXISTING).



FIRST FLOOR

Kodiak FITC Boiler Conversion Analysis

Kodiak, Alaska

Appendix D – Construction Costs and Payback Calculations

Kodiak Boiler Analysis									
Building Area (SF)	25,832								
Design Heat Load Conditions	Heat Loss (BtuH)	Density (BtuH/SF)	Running Tally (BtuH)	Density (BtuH/SF)	Heat Load as Percent of Boiler Output	UA factor	Remarks		
Conduction Heat Load (BtuH)	165,000	6.4	165,000	6.4	8.2%		Calculated using Elite CHVAC program (Zero F Winter Design)		
Non-Lab Building Ventilation Heat Load (BtuH)	502,000	19.4	667,000	25.8	33.2%		Hand calculated from 1991 heating coil schedule information		
Laboratory Ventilation Heat Load (BtuH)	543,000	21.0	1,210,000	46.8	60.2%		Hand calculated from 1991 heating coil schedule information		
Pilot Plant Ventilation Heat Load (BtuH)	792,000	30.7	2,002,000	77.5	99.7%		Hand calculated from 1991 heating coil schedule information		
	2,002,000	77.5							
The original Cleaver-Brook Boiler is still in use and it has a design output of 2,009 MBH.									

Construction Cost Estimate									
Kodiak FITC Boiler Conversion Analysis									
Option S1, Replace Steam Boiler with New, Smaller Boiler - Oil Fired: The current steam design load is 20 BHP at 60 PSI. This option removes the existing boiler and replaces with a fully-modulating fuel oil-fired boiler with a 3:1 turndown, manually controlled pressure set point (10 PSI to 60 PSI), and new, low-pressure deaerator.									
Item	Description	Quantity	Units	Unit Cost	Materials Total Cost	\$/HR	Labor Hour	Cost	Total Cost
1	Demo existing steam boiler	1	EA	\$ 1,500	\$ 1,500	\$65	40	\$2,600	\$ 4,100
2	Demo existing steam piping	1	EA	\$ 500	\$ 500	\$65	40	\$2,600	\$ 3,100
3	Demo existing deaerator	1	EA	\$ 1,500	\$ 1,500	\$65	40	\$2,600	\$ 4,100
4	New 20 BHP steam boiler	1	EA	\$ 30,000	\$ 30,000	\$65	160	\$10,400	\$ 40,400
5	Controls	1	EA	\$ 10,000	\$ 10,000	\$65	40	\$2,600	\$ 12,600
6	New piping	150	LF	\$ 10.00	\$ 1,500	\$65	1	\$9,750	\$ 11,250
7	New chimney connection	1	EA	\$ 2,500	\$ 2,500	\$65	40	\$2,600	\$ 5,100
8	Electrical reconections	1	LUMP	\$ 10,000	\$ 10,000	\$65	80	\$5,200	\$ 15,200
9	Pipe Insulation	150	LF	\$ 5.00	\$ 750	\$65	0.25	\$2,438	\$ 3,188
10	Mob/Demob/Overhead	1	EA	\$ 20,000	\$ 20,000	\$65	200	\$13,000	\$ 33,000
11	Startup	1	EA	\$ 5,000	\$ 5,000	\$65	120	\$7,800	\$ 12,800
	Subtotal				\$ 83,250		761.25	\$ 61,588	\$ 144,838
	Administration	15%							\$ 21,726
	Engineering	15%							\$ 21,726
	Subtotal								\$ 188,289
	Estimating Contingency	15%							\$ 28,243
	Total Construction Cost Estimate								\$ 216,532
Simple Payback Analysis									
	Construction Cost	\$ 216,532							
	Annual Energy Cost Savings	\$ 17,671							
	Simple Payback (years)	12.25							

Construction Cost Estimate									
Kodiak FITC Boiler Conversion Analysis									
Option S2, Replace Steam Boiler with New, Smaller Boiler - Electric Fired: The current steam design load is 20 BHP at 60 PSI. This option removes the existing boiler and replaces with a multi-stage, electric boiler with a 10:1 turndown, and new condensate return system, both located in the boiler room.									
Item	Description	Quantity	Units	Materials		Labor		Total	
				Unit Cost	Total Cost	\$/HR	Hour	Cost	Cost
1	Demo existing steam boiler	1	EA	\$ 8,000	\$ 8,000	\$65	100	\$6,500	\$ 14,500
2	Demo existing steam piping	1	EA	\$ 2,500	\$ 2,500	\$65	60	\$3,900	\$ 6,400
3	Demo existing deaerator	1	EA	\$ 3,500	\$ 3,500	\$65	80	\$5,200	\$ 8,700
4	New 20 BHP steam boiler - elect	1	EA	\$ 33,000	\$ 33,000	\$65	68	\$4,420	\$ 37,420
5	Controls	1	EA	\$ 10,000	\$ 10,000	\$65	24	\$1,560	\$ 11,560
6	New piping	80	LF	\$ 10.00	\$ 800	\$65	1	\$5,200	\$ 6,000
7	Blank off chimney connection	1	EA	\$ 1,500	\$ 1,500	\$65	24	\$1,560	\$ 3,060
8	New Condensate Return System	1	EA	\$ 12,000	\$ 12,000	\$65	40	\$2,600	\$ 14,600
9	Electrical reconections	1	LUMP	\$ 20,000	\$ 20,000	\$65	140	\$9,100	\$ 29,100
10	Pipe Insulation	150	LF	\$ 5.00	\$ 750	\$65	0.25	\$2,438	\$ 3,188
11	Mob/Demob/Overhead	1	EA	\$ 20,000	\$ 20,000	\$65	200	\$13,000	\$ 33,000
12	Startup	1	EA	\$ 500	\$ 500	\$65	16	\$1,040	\$ 1,540
	Subtotal				\$112,550		753.25	\$ 56,518	\$ 169,068
	Administration		15%						\$ 25,360
	Engineering		15%						\$ 25,360
	Subtotal								\$ 219,788
	Estimating Contingency		15%						\$ 32,968
Total Construction Cost Estimate									\$ 252,756
Simple Payback Analysis									
	Construction Cost	\$ 252,756							
	Annual Energy Cost Savings	\$ 15,076							
	Simple Payback (years)	16.77							

Construction Cost Estimate									
Kodiak FITC Boiler Conversion Analysis									
Option S3, Replace Steam Boiler with New, Smaller Boiler - Electric Fired in Pilot Plant: The current steam design load is 20 BHP at 60 PSI. This option removes the existing boiler and replaces with a multi-stage electric boiler with a 10:1 turndown, and new condensate return system, both located in the Pilot Plant									
Item	Description	Quantity	Units	Unit Cost	Materials Total Cost	\$/HR	Labor Hour	Cost	Total Cost
1	Demo existing steam boiler	1	EA	\$ 8,000	\$ 8,000	\$65	100	\$6,500	\$ 14,500
2	Demo existing steam piping	1	EA	\$ 6,000	\$ 6,000	\$65	120	\$7,800	\$ 13,800
3	Demo existing deaerator	1	EA	\$ 3,500	\$ 3,500	\$65	80	\$5,200	\$ 8,700
4	New 20 BHP steam boiler - elect	1	EA	\$ 33,000	\$ 33,000	\$65	68	\$4,420	\$ 37,420
5	Controls	1	EA	\$ 10,000	\$ 10,000	\$65	24	\$1,560	\$ 11,560
6	New piping	80	LF	\$ 10.00	\$ 800	\$65	1	\$5,200	\$ 6,000
7	Blank off chimney connection	1	EA	\$ 1,500	\$ 1,500	\$65	24	\$1,560	\$ 3,060
8	New Condensate Return System	1	EA	\$ 12,000	\$ 12,000	\$65	40	\$2,600	\$ 14,600
9	Electrical reconnections	1	LUMP	\$ 20,000	\$ 20,000	\$65	140	\$9,100	\$ 29,100
10	Pipe Insulation	150	LF	\$ 5.00	\$ 750	\$65	0.25	\$2,438	\$ 3,188
11	Mob/Demob/Overhead	1	EA	\$ 20,000	\$ 20,000	\$65	200	\$13,000	\$ 33,000
12	Startup	1	EA	\$ 500	\$ 500	\$65	16	\$1,040	\$ 1,540
	Subtotal				\$116,050		813.25	\$ 60,418	\$ 176,468
	Administration		15%						\$ 26,470
	Engineering		15%						\$ 26,470
	Subtotal								\$ 229,408
	Estimating Contingency		15%						\$ 34,411
	Total Construction Cost Estimate								\$ 263,819
Simple Payback Analysis									
	Construction Cost	\$ 263,819							
	Annual Energy Cost Savings	\$ 33,623							
	Simple Payback (years)	7.85							

Construction Cost Estimate											
Kodiak FITC Boiler Conversion Analysis											
Option H1. Replace Hydronic Boiler with Three Smaller Boilers - Oil-Fired: The current steam design load is 60 BHP (2,000 MBH) at 30 PSI. This option removes the existing boiler and replaces it with three, 20 BHP, oil-fired boilers, each with a 3:1 turndown burner.											
Item	Description	Quantity	Units	Unit Cost	Materials Total Cost	\$/HR	Labor Hour	Cost	Total Cost		
1	Demo existing hydronic boiler	1	EA	\$ 1,500	\$ 1,500	\$65	40	\$2,600	\$ 4,100		
2	Demo existing hydronic piping	1	EA	\$ 500	\$ 500	\$65	40	\$2,600	\$ 3,100		
3	Demo existing blr circ pump	1	EA	\$ 1,500	\$ 1,500	\$65	40	\$2,600	\$ 4,100		
4	New 20 BHP hydronic boiler	3	EA	\$ 20,000	\$ 60,000	\$65	80	\$15,600	\$ 75,600	ESTIMATED	
5	Controls	1	EA	\$ 3,000	\$ 3,000	\$65	24	\$1,560	\$ 4,560		
6	New piping	200	LF	\$ 10.00	\$ 2,000	\$65	1	\$13,000	\$ 15,000		
7	New chimney manifold	1	EA	\$ 4,500	\$ 4,500	\$65	60	\$3,900	\$ 8,400		
8	New boiler circ pump	3	EA	\$ 2,500	\$ 7,500	\$65	40	\$7,800	\$ 15,300	ESTIMATED	
9	Electrical connections	1	LUMP	\$ 10,000	\$ 10,000	\$65	40	\$2,600	\$ 12,600		
10	Pipe Insulation	200	LF	\$ 5.00	\$ 1,000	\$65	0.25	\$3,250	\$ 4,250		
11	Mob/Demob/Overhead	1	EA	\$ 20,000	\$ 20,000	\$65	200	\$13,000	\$ 33,000		
12	Startup	1	EA	\$ 5,000	\$ 5,000	\$65	120	\$7,800	\$ 12,800		
	Subtotal				\$ 116,500		685.25	\$ 76,310	\$ 192,810		
	Administration	15%							\$ 28,922		
	Engineering	15%							\$ 28,922		
	Subtotal								\$ 250,653		
	Estimating Contingency	15%							\$ 37,598		
	Total Construction Cost Estimate								\$ 288,251		
Simple Payback Analysis											
	Construction Cost	\$ 288,251									
	Annual Energy Cost Savings	\$ 11,911									
	Simple Payback (years)	24.20									

Construction Cost Estimate									
Kodiak FITC Boiler Conversion Analysis									
Option H2, Replace Hydronic Boiler with Two Smaller Boilers - Oil-Fired: The current steam design load is 60 BHP (2,000 MBH) at 30 PSI. This option removes the existing boiler and replaces it with two oil-fired boilers. One will be 20 BHP and one will be 40 BHP; each with a 3:1 turndown burner.									
Item	Description	Quantity	Units	Unit Cost	Materials Total Cost	\$/HR	Labor Hour	Cost	Total Cost
1	Demo existing hydronic boiler	1	EA	\$ 1,500	\$ 1,500	\$65	40	\$2,600	\$ 4,100
2	Demo existing hydronic piping	1	EA	\$ 500	\$ 500	\$65	40	\$2,600	\$ 3,100
3	Demo existing blr circ pump	1	EA	\$ 1,500	\$ 1,500	\$65	40	\$2,600	\$ 4,100
4	New 30 BHP hydronic boiler	2	EA	\$ 26,000	\$ 52,000	\$65	90	\$11,700	\$ 63,700
5	Controls	1	EA	\$ 3,000	\$ 3,000	\$65	24	\$1,560	\$ 4,560
6	New piping	200	LF	\$ 10.00	\$ 2,000	\$65	1	\$13,000	\$ 15,000
7	New chimney manifold	1	EA	\$ 3,500	\$ 3,500	\$65	48	\$3,120	\$ 6,620
8	New boiler circ pump	2	EA	\$ 3,500	\$ 7,000	\$65	32	\$4,160	\$ 11,160
9	Electrical connections	1	LUMP	\$ 10,000	\$ 10,000	\$65	40	\$2,600	\$ 12,600
10	Pipe Insulation	200	LF	\$ 5.00	\$ 1,000	\$65	0.25	\$3,250	\$ 4,250
11	Mob/Demob/Overhead	1	EA	\$ 20,000	\$ 20,000	\$65	200	\$13,000	\$ 33,000
12	Startup	1	EA	\$ 5,000	\$ 5,000	\$65	40	\$2,600	\$ 7,600
	Subtotal	15%			\$ 107,000		595.25	\$ 62,790	\$ 169,790
	Administration	15%							\$ 25,469
	Engineering	15%							\$ 25,469
	Subtotal								\$ 220,727
	Estimating Contingency	15%							\$ 33,109
	Total Construction Cost Estimate								\$ 253,836
Simple Payback Analysis									
	Construction Cost	\$ 253,836							
	Annual Energy Cost Savings	\$ 11,911							
	Simple Payback (years)	21.31							

Construction Cost Estimate											
Kodiak FITC Boiler Conversion Analysis											
Option H3. Convert existing laboratory ventilation system from constant volume to variable air volume (VAV) system. Current design airflow rate is 10,520 CFM. Two perchloric acid hoods will also be removed. New SA airflow rate to be 7,720 CFM. EF-3 stays at 3,560 CFM.											
Item	Description	Quantity	Units	Materials		Labor		Total			
				Unit Cost	Total Cost	\$/HR	Hour	Cost		Cost	
1	Remove fume hoods	5	EA	\$ 500	\$ 2,500	\$65	8	\$2,600		\$ 5,100	
2	Remove PAH ducts and fans	2	EA	\$ 500	\$ 1,000	\$65	16	\$2,080		\$ 3,080	
3	Provide new VAV fume hoods	5	EA	\$ 2,000	\$ 10,000	\$65	16	\$5,200		\$ 15,200	
4	AHU-2: Install new 7.5 HP motor.	1	EA	\$ 4,000	\$ 4,000	\$65	24	\$1,560		\$ 5,560	
5	AHU-2: Install new 7.5 HP VFD.	1	EA	\$ 2,500	\$ 2,500	\$65	24	\$1,560		\$ 4,060	
6	Replace EF-3 with 3 HP + VFD	1	EA	\$ 2,000	\$ 2,000	\$65	18	\$1,170		\$ 3,170	
7	Modify EA ductwork	60	LF	\$ 10	\$ 600	\$65	4	\$15,600		\$ 16,200	
8	Balance system	1	LUMP	\$ 500	\$ 500	\$65	120	\$7,800		\$ 8,300	
9	Lab SA duct damper	7	EA	\$ 1,000	\$ 7,000	\$65	8	\$3,640		\$ 10,640	
10	Lab EA duct damper	7	EA	\$ 2,500	\$ 17,500	\$65	16	\$7,280		\$ 24,780	
11	Lab Ventilation Controls	12	EA	\$ 2,000	\$ 24,000	\$65	8	\$6,240		\$ 30,240	
12	Electrical connections	1	LUMP	\$ 8,500	\$ 8,500	\$65	80	\$5,200		\$ 13,700	
13	Mob/Demob/Overhead	1	EA	\$ 10,000	\$ 10,000	\$65	120	\$7,800		\$ 17,800	
14			EA		\$ -	\$65		\$0		\$ -	
	Subtotal	15%			\$ 86,600		438	\$ 63,050		\$ 149,650	
	Administration	15%								\$ 22,448	
	Engineering	15%								\$ 22,448	
	Subtotal									\$ 194,545	
	Estimating Contingency	15%								\$ 29,182	
Total Construction Cost Estimate										\$ 223,727	
Simple Payback Analysis											
	Construction Cost	\$ 223,727									
	Annual Energy Cost Savings	\$ 23,930									
	Simple Payback (years)	9.35									

Kodiak FITC Boiler Conversion Analysis

Kodiak, Alaska

Appendix E – Product Data Sheets

FULTON ELECTRIC BOILER

Specifications

Model FB-L	012	015	018	024	030	036	050	075	100	150	200	300	500	750	1000
Number of Elements	1	1	1	2	2	2	2	3	4	6	4	4	7	10	14
Output 1000 BTU/HR	41	51	61	82	102	123	171	256	341	512	683	1025	1708	2561	3416
1000 KCAL/HR	10	13	15	21	26	31	43	64	86	129	172	258	430	645	860
Steam Output** LB/HR	40	50	60	81	101	121	169	252	336	505	674	1011	1684	2526	3368
KG/HR	18	23	27	37	46	55	77	115	153	230	306	460	765	1148	1530
Approx. Shipping Weight LB	420	420	420	440	450	450	580	850	970	1225	1380	1440	1850	2150	2300
KG	191	191	191	200	204	204	263	386	440	556	623	655	839	977	1043
Water Capacity GALLONS	7	7	7	7	7	7	13	39	39	50	79	115	195	270	360
LITERS	26	26	26	26	26	26	49	148	148	189	299	435	738	1022	1362

Boiler Connection Sizes

Steam Outlet 15 PSI	IN	.75	.75	.75	.75	.75	.75	1	1.5	1.5	2	3	3	4	4	6
	MM	19	19	19	19	19	19	25	38	38	51	76	76	100	100	150
Steam Outlet 16-300 PSI	IN	.75	.75	.75	.75	.75	.75	.75	1	1	1.25	1.5	2	3	3	3
	MM	19	19	19	19	19	19	19	25	25	32	38	51	76	76	76
Feedwater Inlet	IN	.75	.75	.75	.75	.75	.75	.75	1	1	1	1	1	1	1	1.25
	MM	19	19	19	19	19	19	19	25	25	25	25	25	25	25	32
Blowdown Outlet	IN	1	1	1	1	1	1	1	1	1	1.25	1.25	1.5	1.5	1.5	2
	MM	25	25	25	25	25	25	25	25	25	32	32	38	38	38	51
Water Col. Blowdown Outlet	IN	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	.75	.75	.75	.75
	MM	-	-	-	-	-	-	-	-	-	-	-	19	19	19	19
Sight Glass Blowdown Outlet	IN	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25
	MM	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
Safety Valve 15 PSI	IN	.75	.75	.75	.75	.75	.75	1	1	1	1.25	1.50	1.5	1.5	2	2.5
	MM	19	19	19	19	19	19	25	25	25	32	38	38	38	51	64
Safety Valve 16-300 PSI	IN	.50	.50	.50	.50	.50	.50	.75	.75	.75	.75	1	1	1.25	1.5	2
	MM	13	13	13	13	13	13	19	19	19	19	25	25	32	38	51

Electrical Power Requirements (In Amps)

208V 3 Phase	34	42	50	67	84	100	139	208	278	416	556	832	*	*	*
230V 1 Phase	52	65	78	-	-	-	-	-	-	-	-	-	-	-	-
230V 3 Phase	30	35	46	60	76	92	126	188	252	378	512	756	*	*	*
460V 3Phase	15	19	23	30	38	46	63	94	126	189	256	378	630	941	1260
575V 3 Phase	13	16	18	24	30	36	50	76	101	150	201	301	502	756	1004

Dimensions are approximate. We reserve the right to change specifications.
Voltage applied higher than above ratings will result in higher amp draws.

Probe liquid level control is standard on all units.

Optional Water Level Controls

Watts 142-5

McDonnell Miller 53-2

McDonnell Miller 157 - 157M

Notes:


-Indicates not available.

* Indicates voltages available at special request.

**Steam output ratings, at 180°F (82°C) feedwater temperature, (0 PSIG).

Standard Electrical Control Panel Components

- Low Water Relay
 - Water Level Relay
 - High Limit Pressure Control Switch w/manual reset
 - Operating Pressure Control Element Contactor(s) Switch
 - Pump Starter (1 phase)
 - Power Switch
 - Power Lamp
 - Element Energized Lamp
 - CSD-1 Low Water Relay With Manual Reset (75 kW-1000kW)
- Models FB-L 100 to FB-L 1000 include a step sequencer.



Dimensions

Model FB-L		012	015	018	024	030	036	050	075	100	150	200	300	500	750	1000
Unit Size:	kW	12	15	18	24	30	36	50	75	100	150	200	300	500	750	1000
	HP	1.2	1.5	1.8	2.4	3.0	3.5	5.0	7.5	10	15	20	30	50	75	100
Height																
(A) Boiler Overall	IN	24	24	24	24	24	24	55	55	55	55	55	75	75	75	75
	MM	610	610	610	610	610	610	1397	1397	1397	1397	1397	1905	1905	1905	1905
(B) Boiler w/Piping	IN	30	30	30	30	30	30	65	65	65	65	71	80	80	80	80
	MM	762	762	762	762	762	762	1651	1651	1651	1651	1803	2032	2032	2032	2032
(C) Feedwater Inlet	IN	8	8	8	8	8	8	16	16	16	16	16	24	24	24	24
	MM	203	203	203	203	203	203	406	406	406	406	406	610	610	610	610
(D) Blowdown Outlet	IN	4	4	4	4	4	4	6	6	6	6	6	6.5	6.5	6.5	6.5
	MM	102	102	102	102	102	102	152	152	152	152	152	165	165	165	165
(E) Electric Control Box	IN	20.5	20.5	20.5	20.5	20.5	20.5	50	50	50	50	48	64	64	64	64
	MM	521	521	521	521	521	521	1270	1270	1270	1270	1219	1626	1626	1626	1626
(F) Hand Hole	IN	11	11	11	11	11	11	38	38	38	38	38	55	55	55	55
	MM	279	279	279	279	279	279	965	965	965	965	965	1397	1397	1397	1397
Width & Depth																
(G) Boiler Only	IN	20	20	20	20	20	20	17	24	24	28	32	36	44	50	63
	MM	508	508	508	508	508	508	432	610	610	711	813	914	1118	1270	1600
(H) Overall Depth Electric	IN	30	30	30	30	30	30	35	35	35	39	46	46	56	62	83
Panel to Blowdown	MM	762	762	762	762	762	762	899	899	899	991	1168	1168	1442	1575	2108
(I) Electric Panel Width	IN	14	14	14	14	14	14	17	17	32	32	40	52	64	64	64
	MM	356	356	356	356	356	356	432	432	813	813	1016	1321	1626	1626	1626
(J) Boiler Width Overall	IN	33	33	33	33	33	33	35	42	42	46	52	56	64	72	91
	MM	838	838	838	838	838	838	889	1067	1067	1168	1321	1422	1625	1829	2311
Minimum Clearances																
(K) Horizontal to remove elements	IN	14	14	14	14	14	14	-	-	-	-	-	-	-	-	-
	MM	356	356	356	356	356	356	-	-	-	-	-	-	-	-	-
(L) Floor to Ceiling to remove elements	IN	-	-	-	-	-	-	95	95	95	95	95	139	139	139	139
	MM	-	-	-	-	-	-	2413	2413	2413	2413	2413	3531	3531	3531	3531
(M) Front of Boiler	IN	24	24	24	24	24	24	24	32	32	32	34	34	36	36	36
	MM	610	610	610	610	610	610	610	813	813	813	864	864	914	914	914
(N) Sides & Rear of Boiler	IN	12	12	12	12	12	12	12	12	12	12	24	24	24	24	24
	MM	305	305	305	305	305	305	305	305	305	305	610	610	610	610	610



Dimensions are approximate. We reserve the right to change specifications.

-Indicates not available.

Panel Box size may change depending on voltage.

Models FB-L 012-036 12 to 36 kW (1.2 to 3.6 BHP)

Models FB-L 050-1000 50 kW to 1000 kW (5-100 BHP)



FULTON ELECTRIC BOILER

Specifications

Model FB-L	012	015	018	024	030	036	050	075	100	150	200	300	500	750	1000
Number of Elements	1	1	1	2	2	2	2	3	4	6	4	4	7	10	14
Output 1000 BTU/HR	41	51	61	82	102	123	171	256	341	512	683	1025	1708	2561	3416
Output 1000 KCAL/HR	10	13	15	21	26	31	43	64	86	129	172	258	430	645	860
Steam Output** LB/HR	40	50	60	81	101	121	169	252	336	505	674	1011	1684	2526	3368
KG/HR	18	23	27	37	46	55	77	115	153	230	306	460	765	1148	1530
Approx. Shipping Weight LB	420	420	420	440	450	450	580	850	970	1225	1380	1440	1850	2150	2300
KG	191	191	191	200	204	204	263	386	440	556	623	655	839	977	1043
Water Capacity GALLONS	7	7	7	7	7	7	13	39	39	50	79	115	195	270	360
LITERS	26	26	26	26	26	26	49	148	148	189	299	435	738	1022	1362

Boiler Connection Sizes

Steam Outlet 15 PSI	IN	.75	.75	.75	.75	.75	.75	1	1.5	1.5	2	3	3	4	4	6
MM	19	19	19	19	19	19	19	25	38	38	51	76	76	100	100	150
Steam Outlet 16-300 PSI	IN	.75	.75	.75	.75	.75	.75	.75	1	1	1.25	1.5	2	3	3	3
MM	19	19	19	19	19	19	19	19	25	25	32	38	51	76	76	76
Feedwater Inlet	IN	.75	.75	.75	.75	.75	.75	.75	1	1	1	1	1	1	1	1.25
MM	19	19	19	19	19	19	19	19	25	25	25	25	25	25	25	32
Blowdown Outlet	IN	1	1	1	1	1	1	1	1	1	1.25	1.25	1.5	1.5	1.5	2
MM	25	25	25	25	25	25	25	25	25	25	32	32	38	38	38	51
Water Col. Blowdown Outlet	IN	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	.75	.75	.75	.75
MM	-	-	-	-	-	-	-	-	-	-	-	-	19	19	19	19
Sight Glass Blowdown Outlet	IN	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25	.25
MM	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
Safety Valve 15 PSI	IN	.75	.75	.75	.75	.75	.75	1	1	1	1.25	1.50	1.5	1.5	2	2.5
MM	19	19	19	19	19	19	19	25	25	25	32	38	38	38	51	64
Safety Valve 16-300 PSI	IN	.50	.50	.50	.50	.50	.50	.75	.75	.75	.75	1	1	1.25	1.5	2
MM	13	13	13	13	13	13	13	19	19	19	19	25	25	32	38	51

Electrical Power Requirements (in Amps)

208V 3 Phase	34	42	50	67	84	100	139	208	278	416	556	832	*	*	*
230V 1 Phase	52	65	78	-	-	-	-	-	-	-	-	-	-	-	-
230V 3 Phase	30	35	46	60	76	92	126	188	252	378	512	756	*	*	*
460V 3Phase	15	19	23	30	38	46	63	94	126	189	256	378	630	941	1260
575V 3 Phase	13	16	18	24	30	36	50	76	101	150	201	301	502	756	1004

Dimensions are approximate. We reserve the right to change specifications.
Voltage applied higher than above ratings will result in higher amp draws.

Probe liquid level control is standard on all units.

Optional Water Level Controls

Watts 142-5

McDonnell Miller 53-2

McDonnell Miller 157 - 157M

Notes:

-Indicates not available.


* Indicates voltages available at special request.

**Steam output ratings, at 180°F (82°C) feedwater temperature, (0 PSIG).

Standard Electrical Control Panel Components

- Low Water Relay
- Water Level Relay
- High Limit Pressure Control Switch w/manual reset
- Operating Pressure Control Element Contactor(s) Switch
- Pump Starter (1 phase)
- Power Switch
- Power Lamp
- Element Energized Lamp
- CSD-1 Low Water Relay With Manual Reset (75 kW-1000kW)

Models FB-L 100 to FB-L 1000 include a step sequencer.



Dimensions

Model FB-L		012	015	018	024	030	036	050	075	100	150	200	300	500	750	1000
Unit Size:	kW	12	15	18	24	30	36	50	75	100	150	200	300	500	750	1000
	HP	1.2	1.5	1.8	2.4	3.0	3.5	5.0	7.5	10	15	20	30	50	75	100
Height																
(A) Boiler Overall	IN	24	24	24	24	24	24	55	55	55	55	55	75	75	75	75
	MM	610	610	610	610	610	610	1397	1397	1397	1397	1397	1905	1905	1905	1905
(B) Boiler w/Piping	IN	30	30	30	30	30	30	65	65	65	65	71	80	80	80	80
	MM	762	762	762	762	762	762	1651	1651	1651	1651	1803	2032	2032	2032	2032
(C) Feedwater Inlet	IN	8	8	8	8	8	8	16	16	16	16	16	24	24	24	24
	MM	203	203	203	203	203	203	406	406	406	406	406	610	610	610	610
(D) Blowdown Outlet	IN	4	4	4	4	4	4	6	6	6	6	6	6.5	6.5	6.5	6.5
	MM	102	102	102	102	102	102	152	152	152	152	152	165	165	165	165
(E) Electric Control Box	IN	20.5	20.5	20.5	20.5	20.5	20.5	50	50	50	50	48	64	64	64	64
	MM	521	521	521	521	521	521	1270	1270	1270	1270	1219	1626	1626	1626	1626
(F) Hand Hole	IN	11	11	11	11	11	11	38	38	38	38	38	55	55	55	55
	MM	279	279	279	279	279	279	965	965	965	965	965	1397	1397	1397	1397
Width & Depth																
(G) Boiler Only	IN	20	20	20	20	20	20	17	24	24	28	32	36	44	50	63
	MM	508	508	508	508	508	508	432	610	610	711	813	914	1118	1270	1600
(H) Overall Depth Electric Panel to Blowdown	IN	30	30	30	30	30	30	35	35	35	39	46	46	56	62	83
	MM	762	762	762	762	762	762	899	899	899	991	1168	1168	1442	1575	2108
(I) Electric Panel Width	IN	14	14	14	14	14	14	17	17	32	32	40	52	64	64	64
	MM	356	356	356	356	356	356	432	432	813	813	1014	1321	1626	1626	1626
(J) Boiler Width Overall	IN	33	33	33	33	33	33	35	42	42	46	52	56	64	72	91
	MM	838	838	838	838	838	838	889	1067	1067	1168	1321	1422	1626	1829	2311
Minimum Clearances																
(K) Horizontal to remove elements	IN	14	14	14	14	14	14	-	-	-	-	-	-	-	-	-
	MM	356	356	356	356	356	356	-	-	-	-	-	-	-	-	-
(L) Floor to Ceiling to remove elements	IN	-	-	-	-	-	-	95	95	95	95	95	139	139	139	139
	MM	-	-	-	-	-	-	2413	2413	2413	2413	2413	3531	3531	3531	3531
(M) Front of Boiler	IN	24	24	24	24	24	24	24	32	32	32	34	34	36	36	36
	MM	610	610	610	610	610	610	610	813	813	813	864	864	914	914	914
(N) Sides & Rear of Boiler	IN	12	12	12	12	12	12	12	12	12	12	24	24	24	24	24
	MM	305	305	305	305	305	305	305	305	305	305	610	610	610	610	610

Dimensions are approximate. We reserve the right to change specifications.

-Indicates not available.



Panel Box size may change depending on voltage.

Models FB-L 012-036

12 to 36 kW (1.2 to 3.6 BHP)

Models FB-L 050-1000

50 kW to 1000 kW (5-100 BHP)



OIL-FIRED BOILERS

Fulton Thermal Corporation



Product Data Submittal

Fulton Models ICS4 - ICS60 and
Models ICX4 - ICX30

Fulton Gas & Oil Fired Vertical Tubeless Steam Boilers

(Standard Burner)

Dimensions

Standard Models ICS		4	6	9.5	10	15	20	25	30	50	60
Models ICX		4	6	9.5	10	15	20	25	30		
Unit Size:	BHP	4	6	9.5	10	15	20	25	30	50	60
A. Boiler Height	IN	47.5	57.5	67.5	63.5	69.5	72.5	75	82.5	87.5	93.5
	MM	1207	1461	1715	1613	1765	1842	1905	2069	2223	2375
B. Boiler Height With Trim* & Fuel Train Assembly	IN	65	75	85	80.5	86.5	92.5	95	102	106.5	120
	MM	1651	1905	2159	2045	2197	2350	2413	2591	2705	3048
C. Overall Depth Stack to Burner Fan Housing	IN	44	44	44	46	47	58	59	67	78	78
	MM	1118	1118	1118	1168	1194	1474	1499	1702	1981	1981
D. Boiler Diameter	IN	26	26	26	28	30	39	39	46	55	55
	MM	660	660	660	710	760	990	990	1170	1400	1400
E. Overall Width with Water Column	IN	33	33	33	33.5	35.5	43	43	49	57	57
	MM	838	838	838	851	902	1091	1091	1244	1448	1448
F. Flue Outlet Diameter	IN	6	6	6	6	8	10	10	12	12	12
	MM	152	152	152	152	203	254	245	305	305	305
G. To Center of Flue Outlet	IN	42	52	62	58	63	66	68	73.5	79	85
	MM	1070	1320	1575	1473	1600	1675	1728	1867	2007	2159
H. Feedwater Inlet	IN	27	33	33.5	33	33.5	34	34	34	35	35
	MM	685	840	851	840	851	865	865	865	890	890
I. Handholes	IN	19	19	19	19	19	19	19	19	20	20
	MM	485	485	485	485	485	485	485	485	510	510
J. Blowdown Outlet	IN	15	15	15.5	15.5	15.5	16.5	16.5	16.5	17.5	17.5
	MM	380	380	394	394	394	420	420	420	445	445
K. Water Column Extension	IN	14	14	14	14	14	14	14	14	14	14
	MM	355	355	355	355	355	355	355	355	355	355
L. Gas Train Extension (CSD-1)	IN	22.5	22.5	25	21.5	20.5	25	25	27	22.5	34
	MM	572	572	635	546	521	635	635	686	572	867
M. Clearance Required for Burner Removal *	IN	72	82	92	86	92	96	98	106	114	124
	MM	1828	2083	2337	2184	2337	2438	2490	2692	2896	3150
Weights											
Approx. Shipping Weight	LB	1400	1700	1900	2000	2280	3400	3500	4780	6526	7280
	KG	635	773	862	910	1036	1545	1591	2173	2966	330

*This dimension is 6" less for oil fired units 4-50 HP and 12" less for oil fired units 60 HP.

